



June 23, 2017

Mindy Parrott  
Environmental Analyst  
South Florida Water Management District  
3301 Gun Club Road  
West Palm Beach, FL 33406

**RE: Florida Power & Light Company – Conditions of Certification PA 03-45E for Turkey Point Units 3-5**

Dear Ms. Parrott:

Pursuant to Condition XIII.C.4 of the Turkey Point Units 3-5 Conditions of Certification PA 03-45E, Florida Power & Light Company (FPL) submits the below short narrative description of the Upper Floridan Aquifer (UFA) wells monthly water withdrawals, water accounting method, and means of calibration. Please note that this submittal only includes water withdrawal from the month of March 2017. FPL has implemented the ePermitting online reporting process with the South Florida Water Management District. In an effort to streamline the reporting process between FPL's Nuclear and Fossil Facilities, as well as align to a calendar quarter, FPL is submitting this March only report for the water withdrawal from the UFA wells. The subsequent report will contain a full calendar quarter including April, May and June 2017 water withdrawals.

The F1 well began operation on June 14, 2016, F3 well began operation on November 28, 2016, F4 well began operation on November 7, 2016, F5 well began operation on November 16, 2016, and F6 well began operation on November 4, 2016. Water accounting is determined by a weekly cumulative manual reading from each flow meter totalizer. The totalizer readings are used to calculate a total weekly flow. Unique totalizer serial numbers are detailed in the notes for each UFA well in the table below. Monthly flow totals are calculated using weekly totalizer readings. Each flow meter has a 5-year factory calibration.

Period of Record Total Flow (MG)	F1 (MG)	F3 (MG)	F4 (MG)	F5 (MG)	F6 (MG)	
Quarterly (March ONLY)	406,251,142.86	0	103,450,429	86,215,143	110,031,857	106,553,714
<b>Quarterly Total</b>	<b>406.25</b>	<b>0</b>	<b>103.45</b>	<b>86.22</b>	<b>110.03</b>	<b>106.55</b>

**Note:**

F1 not in use, (Serial No. 20161018, 20161019, and 20161020)  
F3 (Serial No.16-09403)  
F4 (Serial No.16-09404)  
F5 (Serial No.16-09402)  
F6 (Serial No.16-09405)

FPL appreciates your review of this submittal; should you have any questions or requests for additional information, please contact me at (786) 243-5388.

Sincerely,



Amy Blystone  
Senior Environmental Scientist, PTN Environmental Monitoring Program

Florida Power & Light Company

700 Universe Boulevard, Juno Beach, FL 33408

CC: Cindy Mulkey/SCO FDEP  
Paul Wierzbicki/SED FDEP  
Gary Andersen/FPL Fossil