

NRR-DMPSPeM Resource

From: Green, Kimberly
Sent: Tuesday, September 11, 2018 7:04 AM
To: Steinman, Rebecca L:(GenCo-Nuc); Mathews, Mitchel A:(GenCo-Nuc)
Subject: Quad Cities LAR to Adopt TSTF-542 (EPID L-2018-LLA-0049)

Rebecca and Mitch,

The NRC staff has completed its initial review of the Quad Cities license amendment request (LAR) to adopt TSTF-542 (ADAMS Accession No. ML18057B125) and has determined that a request for additional information is not needed at this time. However, during the review, the staff identified two typo/editorial errors that it believes should be corrected. The two errors are listed below:

1. Quad Cities Nuclear Power Station, Units 1 and 2 (QCNPS), Technical Specification (TS) Limiting Condition for Operation (LCO) 3.5.2, Action C, currently states: "Two required ECCS injection/spray subsystems inoperable." and has two required action statements, C.1 and C.2, with associated completion times. Attachment 2 to the LAR contains the redline/strikeout version of the proposed changes to the QCNPS TSs. However, for LCO 3.5.2, Action C, Exelon does not show the current Action C with a strikeout. Only a redline of the proposed new Action C is provided. The current Action C should be shown with a strikeout so that it's clear that it is being deleted and replaced with the proposed new Action C.
2. In Attachment 2 to the LAR, proposed Surveillance Requirement (SR) 3.5.2.4 states: "Verify for the required ECCS injection/spray subsystem each manual, power operated, and automatic valve in the flow path, that is not locked, sealed, or otherwise secured in position, is in the correct position." However, TSTF-542 proposes that the SR include commas after "Verify..." and between "subsystem" and "each" as follows:

"Verify, for the required ECCS injection/spray subsystem, each manual, power operated, and automatic valve in the flow path..."

Please consider the above corrections and supplement the LAR, as appropriate.

Please let me know if you have any questions.

Kimberly Green
(301) 415-1627
kimberly.green@nrc.gov

Hearing Identifier: NRR_DMPS
Email Number: 557

Mail Envelope Properties (Kimberly.Green@nrc.gov20180911070400)

Subject: Quad Cities LAR to Adopt TSTF-542 (EPID L-2018-LLA-0049)
Sent Date: 9/11/2018 7:04:10 AM
Received Date: 9/11/2018 7:04:00 AM
From: Green, Kimberly

Created By: Kimberly.Green@nrc.gov

Recipients:

"Steinman, Rebecca L:(GenCo-Nuc)" <Rebecca.Steinman@exeloncorp.com>

Tracking Status: None

"Mathews, Mitchel A:(GenCo-Nuc)" <Mitchel.Mathews@exeloncorp.com>

Tracking Status: None

Post Office:

Files	Size	Date & Time
MESSAGE	1894	9/11/2018 7:04:00 AM

Options

Priority: Standard

Return Notification: No

Reply Requested: No

Sensitivity: Normal

Expiration Date:

Recipients Received: