



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

September 26, 2018

OMB Control No. 3150-0231

Mr. Daniel G. Stoddard
Senior Vice President & Chief Nuclear Officer
Dominion Nuclear Connecticut, Inc.
Millstone Power Station
Innsbrook Technical Center
5000 Dominion Boulevard
Glen Allen, VA 23060-6711

SUBJECT: MILLSTONE POWER STATION, UNIT 1 – CLOSEOUT OF GENERIC LETTER 2016-01, “MONITORING OF NEUTRON-ABSORBING MATERIALS IN SPENT FUEL POOLS” (EPID L-2016-LRC-0001)

Dear Mr. Stoddard:

On April 7, 2016, the U.S. Nuclear Regulatory Commission (NRC) issued Generic Letter (GL) 2016-01, “Monitoring of Neutron-Absorbing Materials in Spent Fuel Pools” (Agencywide Documents Access and Management System (ADAMS) Accession No. ML16097A169), to address the degradation of neutron-absorbing materials (NAMs) in wet storage systems for reactor fuel at power and non-power reactors.

The generic letter requested that licensees provide information to allow the NRC staff to verify continued compliance through effective monitoring to identify and mitigate any degradation or deformation of NAMs credited for criticality control in spent fuel pools (SFPs).

By letter dated November 1, 2016 (ADAMS Accession No. ML16312A064), Dominion Nuclear Connecticut, Inc. (the licensee), responded to GL 2016-01 for Millstone Power Station, Unit 1 (MPS1). In the licensee’s response to GL 2016-01, the licensee stated that, for MPS1, the licensee credits Carborundum for criticality control and has an established NAM monitoring program. The NRC staff’s review determined that the provided response sufficiently addressed the five areas of information described in Appendix A of GL 2016-01 for Carborundum. In particular, the described monitoring program for the Carborundum includes the following key features:


- Neutron attenuation testing of in-situ material.
- Established processes to ensure that the licensee will take the appropriate corrective actions if any potentially non-conforming material is discovered.
- A testing frequency not to exceed 5 years.

- Acceptance criteria to ensure maintenance of the 5-percent subcriticality margin for the SFP.

The NRC staff found that the licensee intends to continue monitoring the condition of its NAMs as described in its response.

For MSP1, the NRC staff's review determined that the information provided sufficiently addressed the five areas of information described in Appendix A to GL 2016-01. Based on the review of the information provided, the NRC staff concludes no further information is requested regarding GL 2016-01.

Sincerely,

A handwritten signature in black ink, appearing to read "Bruce A. Watson". The signature is fluid and cursive, with a long horizontal stroke at the end.

Bruce A. Watson, CHP, Chief
Reactor Decommissioning Branch
Division of Decommissioning, Uranium
Recovery, and Waste Programs
Office of Nuclear Material Safety
and Safeguards

Docket No. 50-245

cc: ListServ

SUBJECT: MILLSTONE POWER STATION, UNIT 1 – CLOSEOUT OF GENERIC LETTER 2016-01, “MONITORING OF NEUTRON-ABSORBING MATERIALS IN SPENT FUEL POOLS” (EPID L-2016-LRC-0001) DATED SEPTEMBER 26, 2018

DISTRIBUTION:

PUBLIC
 PM File Copy
 RidsACRS_MailCTR Resource
 RidsNmssDuwpRdb Resource
 RidsNrrDirslrgb Resource
 RidsNrrDmlrMccb Resource
 RidsNrrDorlLspb Resource
 RidsNrrDssSnpb Resource
 RidsNrrLAJBurkhardt Resource
 RidsNrrPMMillstone Resource
 RidsRgn1MailCenter Resource
 TCarter, NMSS
 TSMith, NMSS
 BBenney, NRR
 SKrepel, NRR
 SWall, NRR

ADAMS Accession No.: ML18269A351

***via email**

OFFICE	NRR/DORL/LSPB/PM*	NRR/DORL/LSPB/LA	NRR/DMLR/MCCB/BC*
NAME	SWall	JBurkhardt	SBloom
DATE	09/17/18	09/17/18	09/25/18
OFFICE	NRR/DIRS/IRGB/BC*	NRR/DSS/SNPB/BC*	NMSS/DUWP/RDP/BC*
NAME	BPham	RLukes	BWatson
DATE	09/17/18	09/17/18	09/26/18

OFFICIAL RECORD COPY