



**UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001**

November 30, 2018

Mr. Kenneth Schrader, PWR Owners Group Chairman
PWR Owners Group, Program Management Office
Westinghouse Electric Company, LLC
1000 Westinghouse Drive, Suite 380
Cranberry Township, PA 16066

**SUBJECT: STAFF RE-EVALUATION OF CLOSURE PATH FOR GENERIC SAFETY
ISSUE 191 AND GENERIC LETTER 2004-02**

Dear Mr. Schrader:

The U.S. Nuclear Regulatory Commission (NRC) staff is re-evaluating the closure path for Generic Safety Issue 191, "Assessment of Debris Accumulation on PWR [Pressurized-Water Reactor] Sump Performance," and Generic Letter 2004-02, "Potential Impact of Debris Blockage on Emergency Recirculation During Design Basis Accidents at Pressurized-Water Reactors [PWRs]," dated September 13, 2004 (Agencywide Documents Access and Management System Accession No. ML042360586), particularly as related to downstream in-vessel concerns. This generic letter resulted in the evaluation of potential adverse effects of post-accident debris blockage and operation with debris-laden fluids that may impair the recirculation functions of the emergency core cooling system (ECCS) and containment spray system.

This reevaluation recognizes that over the last 14 years, PWR licensees have made significant improvements to address these issues. All licensees installed larger ECCS sump strainers and many replaced problematic insulation materials with types that less adversely affect strainer performance. All plants also implemented programmatic changes to reduce the amount of debris that may be generated and transported to the sumps. Moreover, industry and the NRC staff have performed and reviewed a substantial amount of experimental and analytical work to increase the understanding of the phenomena associated with debris and potential adverse effects on both sump performance and downstream in-vessel effects.

If you have further technical questions regarding this matter, please contact, Mr. Victor Cusumano at 301-415-4011.

Sincerely

/RA/

Ho K. Nieh, Director
Office of Nuclear Reactor Regulation

Docket No. 99902037

SUBJECT: STAFF RE-EVALUATION OF CLOSURE PATH FOR GENERIC SAFETY
 ISSUE 191 AND GENERIC LETTER 2004-02 DATED NOVEMBER 30, 2018

DISTRIBUTION:

PUBLIC
 RidsNRROd Resource
 RidsNrrMailcenter Resource
 RidsNrrDlp Resource
 RidsNrrDe Resource
 RidsNrrDorl Resource
 RidsNrrDirs Resource
 RidsNrrDra Resource
 RidsNrrDe Resource
 RidsNrrDmlr Resource
 RidsResOd Resource
 RidsOgcMailCenter Resource
 RidsACRS_MailCTR Resource
 RidsOpaMail Resource
 EBrown, NRR
 TReed, NRR
 VCusumano, NRR
 SSmith, NRR
 BPham, NRR
 CJFong, NRR
 JDrake, NRR
 LPerkins, NRR
 LBurkhart, OEDO

ADAMS Accession No.: ML18311A297 *Email Concurrence NRR-106

OFFICE	NRR/DLP/PLPB/PM	NRR/DLP/PLPB/LA*	NRR/DLP/PLPB/BC	NRR/TA*	NRR/DSS/STSB*
NAME	JDrake	DHarrison	DMorey	JJohnston	VCusumano
DATE	11/19/2018	11/20/18	11/23/2018	11/7/2018	11/7/2018
OFFICE	NRR/DORL*	NRR/DSS*	NRR/DMLR*	NRR	
NAME	CErlanger	MGavrilas	GWilson	HNieh	
DATE	11/28/2018	11/27/2018	11/27/2018	11/30/2018	

OFFICIAL RECORD COPY