

Westinghouse Non-Proprietary Class 3

WCAP 4455A

◆ ◆ ◆ ◆ ◆ ◆ ◆ ◆

TOPICAL REPORT ON REACTOR COOLANT PUMP FLYWHEEL INSPECTION ELIMINATION

Westinghouse Energy Systems



9701020232 961220
PDR ADDCK 05000334
PDR

9701020232 961220
PDR ADOCK 05000334
P PDR

WESTINGHOUSE NON-PROPRIETARY CLASS 3

WCAP-14535A

**TOPICAL REPORT ON
REACTOR COOLANT PUMP
FLYWHEEL INSPECTION
ELIMINATION**

P. L. Strauch
W. H. Bamford
B. A. Bishop
D. Kurek

November 1996

Verified by: D. Bhowmick
D. C. Bhowmick
Structural Mechanics Technology

Approved by: S. A. Swamy
S. A. Swamy, Manager
Structural Mechanics Technology

Westinghouse Electric Corporation
Energy Systems Business Unit
Systems and Major Projects Division
P. O. Box 355
Pittsburgh, PA 15230-0355

© 1996 Westinghouse Electric Corporation
All Rights Reserved

EXECUTIVE SUMMARY

This report provides the technical basis for the elimination of inspection requirements for reactor coolant pump (RCP) motor flywheels for all operating domestic Westinghouse plants and several Babcock and Wilcox plants, including Crystal River Unit 3, Oconee Units 1, 2 and 3, Davis Besse and Three Mile Island Unit 1. This report was submitted for review by the United States Nuclear Regulatory Commission (NRC) in January 1996, and after two requests for additional information, the NRC issued a Safety Evaluation Report (SER) in September 1996. This SER accepted the technical arguments presented herein, and provided partial relief from RCP motor flywheel inspection requirements.

At the request of the NRC (see the letter in Appendix G of this report), Westinghouse Report WCAP-14535 has been revised to include the responses to the NRC requests for additional information (Appendices E and F), and the NRC safety evaluation report (Appendix G). Additionally, the key provisions of the SER and followup clarifications are included in Appendix H. This final version of WCAP-14535 includes an "A" following the report number, which designates acceptance by the NRC. The content of this report is identical to WCAP-14535, with the exception of the additional appendices as noted.

TABLE OF CONTENTS

SECTION	TITLE	PAGE
1.0	Introduction	1-1
2.0	Design and Fabrication	2-1
3.0	Inspection	3-1
4.0	Stress and Fracture Evaluation	4-1
5.0	Risk Assessment: Effect of Inspections	5-1
6.0	Summary and Conclusions	6-1
7.0	References	7-1
Appendix A	Regulatory Position	A-1
Appendix B	Historical Inspection Information: Haddam Neck	B-1
Appendix C	Sample Flywheel Inspection Procedures	C-1
Appendix D	Sample Flywheel Material Test Certificates	D-1
Appendix E	Response to First NRC Request for Additional Information	E-1
Appendix F	Response to Second NRC Request for Additional Information	F-1
Appendix G	United States Nuclear Regulatory Commission Safety Evaluation Report	G-1
Appendix H	Key Provisions and Follow-up Clarifications	H-1

SECTION 1 INTRODUCTION

An integral part of the reactor coolant system (RCS) in pressurized water reactor plants is the reactor coolant pump (RCP), a vertical, single stage, single-suction, centrifugal, shaft seal pump. The RCP ensures an adequate cooling flow rate by circulating large volumes of the primary coolant water at high temperature and pressure through the reactor coolant system. Following an assumed loss of power to the RCP motor, the flywheel, in conjunction with the impeller and motor assembly, provide sufficient rotational inertia to assure adequate cooling flow during RCP coastdown, thus resulting in adequate core cooling.

During normal power operation, the RCP flywheel possesses sufficient kinetic energy to produce high energy missiles in the event of failure. Conditions which may result in overspeed of the RCP increase both the potential for failure and the kinetic energy of the flywheel. This led to the issuance of Regulatory Guide 1.14 in 1971 (Reference 1), which describes a range of actions to ensure flywheel integrity.

One of the recommendations of Regulatory Guide 1.14 (a portion of which is shown in Appendix A) is regular inservice volumetric inspection of flywheels. Operating power plants have been inspecting their flywheels for over twenty years now, and no flaws have been identified which affect flywheel integrity. Flywheel inspections are expensive, and involve irradiation exposure for personnel, so this study was commissioned to present the safety case for flywheels, and to quantify the effects of elimination of such inspections.

1.1 Previous Flywheel Integrity Evaluations

Westinghouse Plants

Fracture evaluations were performed in WCAP-8163 (Reference 2) for a postulated rupture of the RCP discharge piping. The RCP flywheel evaluated had an outer radius of 37.5", a bore radius of 4.7" and a keyway with a radial length of 0.9" and a width of 2.0", which are typical dimensions for RCP flywheels. The flywheel material was A533, Grade B, Class 1 steel plate, which is typically used in flywheel construction. The ultimate tensile stress (for ductile failure analysis) was 80,000 psi, and the fracture toughness at 120°F in the weak or transverse direction was 220,000 psi $\sqrt{\text{inch}}$. Detailed finite element analyses were performed to determine the stress intensity factors for cracks emanating radially from the flywheel keyway. These results were compared to closed form solutions for crack tip locations remote from the keyway, with good correlation. The conclusion of the Reference 2 evaluation was that the limiting speed for ductile failure of 3485 rpm (about 290 % of the normal operating speed) is governing for crack lengths less than 1.15 inches, and that the brittle fracture limit is

governing for larger crack lengths. Because the 1.15 inch crack is very large in comparison to that detectable under inspection and quality assurance procedures for the flywheel design, it was concluded that 3485 rpm was the limiting speed for design. The failure prediction methodology was verified by scale model testing, which is discussed in detail in Reference 2.

A series of flywheel overspeed studies were carried out for postulated circumferential and longitudinal split pipe breaks. Table 1-1 summarizes the studies performed in Reference 2. The maximum speed of 3321 rpm is less than the original design limiting speed of 3485 rpm.

Table 1-1: Summary of LOCA Speed Calculations for Westinghouse Plants

Case No.	Description	Peak Speed (rpm)
1	4 Loop plant, double ended break, RCP trip after 30 seconds.	1248
2	Case 1 with instantaneous power loss.	3321
3	Case 1 with instantaneous power loss and break area equal to 60% of double ended break area.	2609
4	Case 3 with break area equal to 3.0 ft ² .	1189
5	Case 3 with break area equal to 0.5 ft ² .	1189
6	Case 3 for a 3 loop plant	2330
7	Case 2 with moment of inertia increased by 10%	3200
8	Case 1 with moment of inertia increased by 10%	1248
9	Case 1 with loop out of service	2965
10	Case 1 with longitudinal split break areas of 0.5 ft ² , 3.0 ft ² and pipe cross sectional area.	1200
11	Case 10 with instantaneous power loss	1200

Babcock and Wilcox Plants

Babcock and Wilcox analyzed the RCP for a spectrum of postulated reactor coolant system breaks for a typical Babcock and Wilcox 2568 MWt, 17% fuel assembly, nuclear steam system (Reference 3). A stress analysis of the upper flywheel assembly top flywheel was conducted to determine areas of stress concentration, stress magnitude, and the most likely flawed configurations to consider in the fracture mechanics analysis. The upper assembly top flywheel was considered to be the most critical component, and was the only component

modeled for the stress analysis. This spoked flywheel had an outer radius of 36", and an inner radius of 15.2". The flywheel material was ASTM A-516-67 grade 65. The ultimate tensile stress was 76,500 psi, the yield stress was 48,500 psi, and the fracture toughness at 70°F and 120°F was 67,000 and 109,000 psi $\sqrt{\text{inch}}$, respectively. Stresses were calculated using a finite element model.

Three flawed configurations were considered in the linear elastic fracture mechanics analysis. These configurations were through-wall radial cracks perpendicular to the faces of the flywheel, and emanating from the following locations: the inner bore, a bolt hole, and a keyway. Since shrink fit forces would retard the growth of radial cracks in the keyway area, they were omitted from the analysis of the keyway crack. The initial crack length was assumed to be the largest crack that could be missed in nondestructive testing (0.24").

Linear elastic fracture mechanics calculations were performed for flywheel temperatures of 70°F and 120°F. The results of the analysis indicated that the flywheels of the RCPs will not fail under the expected normal operating conditions and that failure conditions are not reached until 220% of the normal operating speed is attained, for the assumed initial crack of 0.24". (The normal operating speed is 1190 rpm, rounded off to 1200 rpm for calculational purposes).

Fatigue crack growth calculations were performed to determine the size of the flaw over the life of the plant. Motor startup is the only plant transient significant to the flywheel. It was assumed that there are 500 starts over the 40 year life of the plant. The applied cycle stress was based on 125% of normal speed. Fatigue crack growth was calculated to be less than 0.0002". Therefore, it was concluded that the assumed initial crack would not grow to critical length during the design life of the flywheel.

LOCA evaluations performed in Reference 3 included eight different cold leg breaks, including the 8.55 ft² double ended break at the RCP discharge (with and without electrical braking effects), and smaller break sizes. A summary of the results from the eight analyses are provided in Table 1-2.

Table 1-2: Summary of LOCA Speed Calculations for Babcock and Wilcox Plants

Case No.	Description	Pump Trip Time (seconds)	Max Speed (rpm)
1	8.55 ft ² cold leg guillotine break (pump discharge).	0.1	3310
2	8.55 ft ² cold leg guillotine break (pump discharge).	30.0	1700
3	5.00 ft ² cold leg split break (pump discharge).	30.0	1210
4	3.0 ft ² cold leg split break (pump discharge).	30.0	1200
5	1.0 ft ² cold leg split break (pump discharge).	30.0	1190
6	8.55 ft ² cold leg guillotine break with 80% voltage (pump discharge).	30.0	2510
7	8.55 ft ² cold leg guillotine break with 90% pump and motor inertia (pump discharge).	30.0	1750
8	8.55 ft ² cold leg guillotine break (pump suction).	0.1	1190

Notes: Maximum speed is for the pump in the broken line.

Pump trip time is seconds after the break.

1.2 Leak Before Break (LBB) Considerations

Subsequent to the analyses of References 2 and 3, 10 CFR Part 50 Appendix A General Design Criterion 4 was revised to allow exclusion of dynamic effects associated with postulated pipe ruptures, including the effects of missiles, pipe whip, and discharging fluids from the design basis, when analyses reviewed and approved by the NRC demonstrate that the probability of fluid system rupture is extremely low under conditions consistent with the design basis for the piping. This is commonly referred to as leak-before-break (LBB) licensing. Since that time, all domestic Westinghouse and Babcock and Wilcox designed PWR plants have qualified for LBB exclusion of the primary loop double ended guillotine LOCA.

Given that a plant has LBB exclusion for the main loop LOCA, the largest break required to be postulated under the structural design basis becomes that of the largest branch line. The largest branch lines not covered by the LBB exclusion would be 14" schedule 140 or 160 piping (0.72 ft² break area, maximum), typically the accumulator line in the cold leg piping. Such a break may be treated as the equivalent of a 0.72 ft² longitudinal split break in the primary loop piping.

Westinghouse Plants

As shown in Table 1-1, the smallest breaks examined were 3.0 ft² and 0.5 ft² longitudinal split breaks (Cases 10 and 11). The 3.0 ft² split break would bound the largest branch line break not covered by the LBB exclusion (0.72 ft²) with respect to the effect on the RCP speed. From Reference 2, it is apparent that with or without RCP power, the RCP speed will not exceed 1200 rpm for 3.0 ft² or 0.5 ft² longitudinal split breaks for the model 93A 6000 hp RCP described in Reference 2.

Reference 2 concluded that the increase in RCP speed due to the 3.0 ft² area split break was less than 11 rpm over the normal operating speed of 1189 rpm, or less than 1%. Given that the Reference 2 analysis shows that the RCP speed increase is less than 1% for the 3.0 ft² longitudinal breaks area, and that the maximum credible break under LBB is less than 1/4 of that size, it is concluded that any RCP speed increase resulting from a branch line break will be well within the design RCP speed tolerance of 25%, i.e., 1.25 times the design speed of 1200 rpm, or 1500 rpm, with or without the dynamic braking effects from the RCP being energized. No known non-LOCA events which lead to RCP speedup would be more limiting than the above mentioned pipe break with respect to overspeed. (Further studies extended this conclusion to a range of RCP designs including 63A (4000 hp), 93 (6000 hp), 93A (6000 hp), 93A (7000 hp) and 100 (8000 hp). Note that RCP rotational inertia is a plant specific parameter. The above conclusion for RCP applicability is only valid for the range of pump rotational inertias from 45000 to 123000 lb_m-ft². As shown in the next section, all Westinghouse flywheels meet this criterion. Therefore, a peak LOCA speed of 1500 rpm is used in the evaluation of Westinghouse RCP flywheel integrity in this report.

Babcock and Wilcox Plants

As shown in Table 1-2, the smallest breaks examined were 5.0 ft², 3.0 ft², and 1.0 ft² split breaks (Cases 3, 4 and 5). The 1.0 ft² split break would bound the largest branch line break not covered by the LBB exclusion (0.72 ft²) with respect to the effect on the RCP speed. From Reference 3, the RCP speed will not exceed 1200 rpm for 1.0 ft² split breaks, with the effects of electrical braking. Although calculations were not specifically performed to determine the effect of excluding electrical braking effects, the Babcock and Wilcox pumps

are similar in design to Westinghouse pumps, where the effect of electrical braking was found to be very small on the small break sizes of interest. (As noted for typical Westinghouse pressurized water reactors, a loss of RCP drive power due to electrical faults in the 30 second time interval following a large area break LOCA is an event of extremely low probability, in the range of 3.0×10^{-7}). Therefore, a peak LOCA speed of 1500 rpm is used in the evaluation of Babcock and Wilcox RCP flywheel integrity in this calculation.

1.3 Report Purpose

The purpose of this report is to provide an engineering basis for the elimination of RCP flywheel inservice inspection requirements for all operating domestic Westinghouse plants and the following Babcock and Wilcox plants:

- Crystal River Unit 3
- Oconee Units 1, 2 and 3
- Davis Besse
- Three Mile Island Unit 1

Three complimentary approaches will be used to demonstrate that flywheel inspection may be safely eliminated. A study of the inspection techniques and a summary of inspection results to date shows no indications have been found which affect flywheel integrity (see Section 3.) A stress and fracture evaluation has shown that very large flaws are needed to cause a failure under maximum overspeed conditions (Section 4). Finally, a risk assessment has been completed to directly compare the flywheel failure probabilities with and without further inspections (Section 5).

SECTION 2

DESIGN AND FABRICATION

Reactor coolant pump flywheels consist of one or more large steel discs which are shrunk fit either directly to the RCP motor shaft or to spokes extending from the motor shaft. In the case of two or more flywheel discs, the individual flywheels are bolted together to form an integral flywheel assembly. Each flywheel is keyed to the motor shaft with one or more vertical keyways.

2.1 Flywheel Geometry

The flywheels which are attached directly to the motor shaft typically consist of two flywheel discs which are bolted together and are located above the RCP rotor core. The top and bottom discs typically have the same outer diameter and bore dimensions but different thicknesses. The bottom disc usually has a circumferential notch along the outside diameter bottom surface for placement of antirotation pawls. Typically, each flywheel is keyed to the motor shaft by means of three vertical keyways, positioned at 120° intervals. An example of this type of flywheel is shown in Figure 2-1.

The spoked flywheels consist of an upper and a lower flywheel assembly, above and below the RCP rotor core. The upper flywheel assembly consists of three discs bolted together, with the top disc having a larger outside diameter than the middle and bottom disc. The lower flywheel consists of a single disc, of the same dimensions as the middle and bottom disc of the upper flywheel assembly. There are eight spokes, 2.5 inches thick, extending from and welded to the motor shaft. Each flywheel assembly is keyed to the spokes by means of one keyway. An example of this type of flywheel is shown in Figure 2-2.

For the purpose of the evaluations performed for this report, the larger flywheel outside diameter for a particular flywheel assembly is used, since this is judged to be conservative with respect to stress and fracture. For the flywheels investigated in this report, outer diameters range from 65 to 76.5 inches, bore diameters range from 8.375 to 30.5 inches (the latter being the spoked flywheel), and keyway radial lengths range from 0.39 to 1.06 inches.

Most of the flywheels covered by this report are made from A533 Grade B Class 1 or A508 Class 3 steel. Flywheels for the pumps at three plants are made from A516 Grade 70 steel, and those at one plant are made from boiler plate.

A summary of pertinent flywheel parameters is provided in Table 2-1. Plant alpha designations used in Table 2-1 are identified in Table 2-2.

2.2 Material Information

The pump motors for all the Westinghouse plants and many of the Babcock and Wilcox plants were manufactured by Westinghouse. All of the Westinghouse flywheels except Haddam Neck are made of A533 Grade B Class 1 steel. The Haddam Neck flywheels were made of boiler plate steel.

It has not been possible to locate each of the certified material test reports for all of the flywheels, but a sample is contained in Appendix D. It will be helpful to examine the ordering specifications for the Westinghouse flywheel materials. The first specification is dated December 1969, and requires that the nil-ductility transition temperature from both longitudinal and transverse Charpy specimens be less than 10°F. This does not guarantee RT_{NDT} is less than 10°F, but it is highly likely that this is the case.

The Westinghouse equipment specification was changed in January of 1973 to require both Charpy and drop weight tests to ensure that RT_{NDT} is no greater than 10°F.

Even though it is likely that most, if not all, of the flywheels in operation have an RT_{NDT} of 10°F or less, a range of RT_{NDT} values from 10°F to 60°F has been assumed in the integrity evaluations to be discussed later.

**Table 2-1: Summary of Westinghouse and Babcock & Wilcox
Domestic Flywheel Information**

Group	Outer Diam. (Inches)	Bore (Inches)	Keyway Radial Length (Inches)	Pump & Motor Inertia (Lb _m -ft ²)	Material Type	Applicable Plants (Plant Alpha Designation)
1	76.50	9.375	0.937	110,000	SA533B	TGX/THX/Spare
2	75.75	8.375	0.906	82,000	SA533B	PSE ¹ /PNJ/Spare
3	75.00	9.375	0.937	95,000	SA533B	CQL; CAE/CBE/CCE/CDE ¹ ; DAP/DBP/DCP/DDP; GAE/GBE ¹ ; SAP/Spare; NEU; NAH; CGE/Spare; WAT/Spare; TBX/TCX/Spare; SCP; VRA/VGB/Spare
4	75.00	9.375	0.937	83,000	SA533B	TVA/TEN/Spare
5	75.00	9.375	0.937	82,000	SA533B	ALA/APR/Spare; AEP/AMP/Spare; CWE/COM; DLW/DMW
6	75.00	9.375	0.937	80,000	SA533B	NSP/NRP ¹ ; WPS ³
7	75.00	8.375	0.911	82,000	SA533B	INT Spare
8	75.00	8.375	0.906	82,000	SA533B	IPP/INT; PGE/PEG
9	75.00	8.375	0.906	80,000	SA533B	WEP ⁶ /WIS
10	72.00	16.125	0.906	72,000	SA533B	BOCO/Spare
11	72.00	9.375	0.937	72,700	SA533B	BDAVI ⁵
12	72.00	8.375	0.906	80,000	SA533B	RGE ⁴
13	72.00	8.375	0.906	70,000	SA533B	CPL/Spare; FPL/FLA/Spare; VPA/VIR ⁴
14	65.00	8.375	0.656	45,000	Boiler Plate	CYW ²
15	72.00	30.50	0.390	70,540	A516	B3MI1 ⁷
16	65.00	13.800	1.060	70,000	A516	BCRY3

Notes:

- 1) Spare has a keyway radial length of 0.885".
- 2) Haddam Neck spare has a keyway radial length of 0.618", and material is SA533B.
- 3) Spare has a keyway radial length of 0.883".
- 4) Spare has a keyway radial length of 0.911".
- 5) Spares have a keyway radial length of 0.942", one spare is of SA508 material.
- 6) Spare has a keyway radial length of 0.937".
- 7) Spoked flywheels.

Table 2-2: Plant Alpha Designation Listing

Plant Alpha Designation	Plant
AEP/AMP	D.C. Cook Units 1 and 2
ALA/APR	J.M. Farley Units 1 and 2
CAE/CBE	Byron Units 1 and 2
CCE/CDE	Braidwood Units 1 and 2
CGE	V.C. Summer
CWE/COM	Zion Units 1 and 2
CPL	H.B. Robinson Unit 2
CQL	Shearon Harris
CYW	Haddam Neck
DAP/DBP	McGuire Units 1 and 2
DCP/DDP	Catawba Units 1 and 2
DLW/DMW	Beaver Valley Units 1 and 2
FPL/FLA	Turkey Point Units 3 and 4
GAE/GBE	Vogtle Units 1 and 2
IPP/INT	Indian Point Units 2 and 3
NAH	Seabrook
NEU	Millstone Unit 3
NSP/NRP	Prairie Island Units 1 and 2
PGE/PEG	Diablo Canyon Units 1 and 2
PSE/PNJ	Salem Units 1 and 2
RGE	Ginna
SAP	Wolf Creek
SCP	Callaway
TBX/TCX	Comanche Peak Units 1 and 2
TVA/TEN	Sequoyah Units 1 and 2
TGX/THX	South Texas Units 1 and 2
VGB/VRA	North Anna Units 1 and 2
VPA/VIR	Surry Units 1 and 2
WAT	Watts Bar Unit 1
WEP/WIS	Point Beach Units 1 and 2
WPS	Kewaunee
BCRY3	Crystal River Unit 3
BDAV1	Davis Besse
BOCO1/BOCO2/BOCO3	Oconee Units 1, 2 and 3
B3MI1	Three Mile Island Unit 1




Figure 2-1: Example of a Flywheel which is Attached Directly to the Motor Shaft




Figure 2-2: Example of a Spoked Flywheel

SECTION 3 INSPECTION

Flywheels are inspected at the plant or during motor refurbishment. Inspections are conducted under Section XI (Reference 4) standard practice for control of instrumentation and personnel qualification. The inspections are conducted by UT level II and level III examiners.

3.1 Examination Volumes

Reactor Coolant pump flywheel examinations are conducted under the control of Utility ISI programs according to surveillance schedules governed by individual Plant Technical Specifications. The volumetric examinations recommended in Regulatory Guide 1.14 have been uniformly applied to the accessible surfaces of the pump flywheel after removal of the shroud cover and gauge hole plugs. The volume of flywheel is inspected generally with straight beam techniques applied laterally, checking the plate material for planar defects emanating from the bore, keyways, and around the gauge holes and ream bolt holes.

3.2 Examination Approaches

Generally, three examinations are performed. The keyway corner exam is conducted by inserting specially designed ultrasonic probes into the gauge holes and directing the sound laterally through the plate material so that reflections are obtained from the center bore radius. Normal reflections will then be seen from the corners of the keyways. These reflections are predictable in distance and rate of occurrence, with abnormalities such as cracking branching out from the keyway being detectable as an abnormal response. A second examination is performed when the sound is projected laterally towards the other remaining gauge holes, for evidence of cracking emanating from the bores of the holes and plate material between the holes. The third examination is commonly referred to as the "Periphery" examination. In this test, standard contact transducers are placed on the outer edges of both upper and lower flywheel plates. The sound is directed laterally into the plate material for examination of the material between the peripheral holes and the plate outer edge.

3.3 Access and Exposure

Access to the exam surfaces is made possible by permanent walkways or by erecting scaffolding. Radiation exposure depends greatly on the amount of pump motor work being conducted nearby and can range from 20-100 millirem/hour.

3.4 Inspection History

A survey was conducted of historical plant inservice inspection results, and all member utilities contributed. The flywheel population surveyed was a total of 217. A total of 729 examination results were reported, and no indications which would affect the integrity of the flywheels were found. These results are summarized on a plant by plant basis in Table 3-1. A summary of recordable indications is provided in Table 3-2. It is interesting to note from Table 3-2 that a number of indications in the form of nicks, gashes, etc. were found at the keyway area, having been created by the act of removing or reassembling the flywheel. These were all dispositioned as not affecting flywheel integrity, but are clear evidence that disassembly for inspection and reassembly actually can produce damage.

Indications were found at the Haddam Neck plant, in the weld used to join the two flywheel plates together. The indications identified were associated with this seal weld and resulted in no radially oriented cracking, and no impact on the integrity of the flywheels. A detailed summary of this finding is given in Appendix B. Sample flywheel inspection procedures are provided in Appendix C.

Table 3-1: Flywheel Inspection Results

Plant Alpha Designation	Plant	Number of Flywheels	Total Number of Flywheel Inspections	Total Number of Inspections with No Indications or Nonrecordable Indications	Total Number of Inspections with Recordable Indications	Number of Indications Affecting Flywheel Integrity
AEP	Cook 1	4	14	13	1	0
AMP	Cook 2	4	12	12	0	0
ALA	Farley 1	3	17	17	0	0
APR	Farley 2	3	19	19	0	0
CAE/CBE	Byron 1 & 2	8	20	19	1	0
CCE	Braidwood 1	4	13	11	2	0
CDE	Braidwood 2	4	9	8	1	0
CGE	Summer	4	10	10	0	0
CWE	Zion 1	4	10	9	1	0
COM	Zion 2	4	16	16	0	0
CPL	Robinson 2	4	22	20	2	0
CQL	Harris	3	17	17	0	0
CYW	Haddam Neck	4	32	28	4	0
DAP	McGuire 1	4	13	13	0	0
DBP	McGuire 2	4	8	8	0	0
DCP	Catawba 1	4	6	6	0	0
DDP	Catawba 2	4	6	6	0	0
DLW	Beaver Valley 1	3	15	11	4	0
DMW	Beaver Valley 2	3	5	5	0	0
FPL/FLA	Turkey Point 3 and 4	7	36	34	2	0
GAE/GBE	Vogtle 1 and 2	9	19	19	0	0
IPP	Indian Point 2	5	21	21	0	0
INT	Indian Point 3	5	17	17	0	0
NAH	Seabrook	4	8	8	0	0
NEU	Millstone 3	5	12	12	0	0
NSP	Prairie Island 1	2	13	12	1	0
NRP	Prairie Island 2	2	11	10	1	0

Table 3-1: Flywheel Inspection Results (continued)

Plant Alpha Designation	Plant	Number of Flywheels	Total Number of Flywheel Inspections	Total Number of Inspections with No Indications or Nonrecordable Indications	Total Number of Inspections with Recordable Indications	Number of Indications Affecting Flywheel Integrity
PGE	Diablo Canyon 1	4	12	11	1	0
PEG	Diablo Canyon 2	4	11	11	0	0
PSE/PNJ	Salem 1 and 2	9	24	13	11	0
RGE	Ginna	3	21	21	0	0
SAP	Wolf Creek	4	13	12	1	0
SCP	Callaway	4	11	11	0	0
TBX	Comanche Peak 1	4	8	8	0	0
TCX	Comanche Peak 2	4	4	4	0	0
TVA/TEN	Sequoyah 1 and 2	9	37	36	1	0
TGX	South Texas 1	4	12	12	0	0
THX	South Texas 2	4	12	12	0	0
VGB/VRA	North Anna 1 and 2	7	37	33	4	0
VPA/VIR	Surry 1 and 2	7	17	17	0	0
WAT	Watts Bar 1	4	4	2	2	0
WEP	Point Beach 1	2	12	12	0	0
WIS	Point Beach 2	2	13	13	0	0
WPS	Kewaunee	3	6	5	1	0
BCRY3	Crystal River 3	4	30	30	0	0
BDAV1	Davis Besse	5	24	22	2	0
BOCO1	Oconee 1	4	6	6	0	0
BOCO2	Oconee 2	4	2	2	0	0
BOCO3	Oconee 3	4	3	3	0	0
B3M11	Three Mile Island 1	4	9	9	0	0
TOTALS	57	217	729	686	43	0

Table 3-2: Summary of Recordable Indications

Plant Alpha Designation	Year	Description of Recordable Indications
AEP	1987	Surface examination on RCP flywheel no. 13 showed two 3/8" long recordable indications. Surface chatter removed by minor surface reconditioning.
CAE/CBE	1993	0.45" rounded indication in RCP flywheel 1B keyway area (surface exam) characterized as minor tool mark.
CCE	1991	PT indications on RCP "A" flywheel were acceptable.
	1994	Indications noted on RCP "B" flywheel with PT and VT-1 were resurfaced and found to be acceptable.
CDE	1994	Four 1/16" rounded indications noted in various areas located approximately 0.8" below top surface of RCP "C" flywheel. One linear indication noted (circ. oriented). Indications were acceptable.
CWE	1986	PT recordable indication in loop 1 RCP flywheel, bleed out from gouges and metal folds in keyways.
CPL	1984	PT recordable indication on RCP "C" flywheel bore was filed out and reexamined.
	1992	Gouge on spare flywheel blended out to 3 to 1 taper.
DLW	1980	PT indication, unsatisfactory mechanical damage from removal of RCP "B" flywheel. Grinding repaired condition.
	1987	PT recordable indication dispositioned as satisfactory for RCP "A" flywheel. Damage from handling.
	1993	UT recordable indication in RCP "B" flywheel due to geometry, dispositioned as satisfactory. PT recordable indication due to handling, dispositioned as satisfactory.
	1994	UT recordable indication in RCP "C" flywheel due to geometry, dispositioned as satisfactory.
FPL/FLA	1974	Laminations midwall (UT) in motor 1S-76P499 flywheel accepted as-is.
	1993	Torn metal in keyway (PT) on motor 2S-76P499 flywheel removed by buffing.
NSP	1994	MT of flywheel no. 11 periphery (0.4 inch) to be re-examined in January 1996 outage.
NRP	1995	MT indications in periphery of flywheel no. 21 (which were buffed in 1993) were found to be unchanged.
PGE	1995	Multiple MT linear indications (laminations) on lower periphery of RCP 1-4 flywheel, accept as-is, monitor.
PSE/PNJ	1983-1995	Eleven recorded indications from surface examinations on seven flywheels were identified as minor chatter marks in keyway from original rough machine cuts due to the arbor tool used during manufacture. Accept as is.

Table 3-2: Summary of Recordable Indications (Continued)

Plant Alpha Designation	Year	Description of Recordable Indications
SAP	1995	Wear marks on bottom surface of RCP 1 flywheel within seal ring (circular like spacer wear) - removed.
TVA/TEN	1993	Recorded indications (10 year MT) in flywheel 3S-81P352. Laminations in edge, dispositioned as acceptable.
VGB/VRA	1983	Tool marks noted in keyway of flywheel 2S-81P355.
	1986	Four PT indications in the keyway of flywheel 3S-81P355 caused by incorrect installation.
	1988	Six reportable indications from keyway scratches in flywheel 3S-81P777.
	1993	Three acceptable rounded indications in the keyway of flywheel 2S-81P777.
WAT	1986	PT recorded indication in keyway area of RCP 1 flywheel resulted from tool chatter which occurred during manufacture of the flywheel. The indications were formed by the tearing and smearing of the raised metal (introduced by the tool chatter) at disassembly and reassembly of the keys.
	1986	VT recorded indication in keyway area of RCP 4 flywheel.
WPS	1976	Visual recorded indication in RCP "A" flywheel. Machine chips in five small holes in center of shaft.
BDAV1	1975	Volumetric preservice indication in RCP 2 flywheel found to be acceptable. Surface tears in keyway removed by surface conditioning.
	1988	Surface gouges in bore of RCP 4 flywheel from flywheel removal found to be acceptable.
CYW	1971	See Appendix B.

SECTION 4

STRESS AND FRACTURE EVALUATION

All of the flywheels were subjected to a detailed stress and fracture evaluation, which is summarized in this section. To avoid repetition, the flywheels were grouped by geometry, and the logic for this grouping is explained in Section 4.1. There are two possible failure mechanisms, ductile and brittle, which must be considered in flywheel evaluation and these are discussed in detail in evaluations reported earlier (References 2 and 3). Figure 4-1 shows the results of a typical flywheel overspeed evaluation, where the flywheel failure speed was calculated for a range of postulated crack depths. Note that the brittle failure limit governs for large flaws. The limiting speed increases for small flaws. Using brittle fracture considerations alone, the limiting speed would approach infinity for vanishingly small flaws. For these situations, the ductile failure limit governs, a finding that has been proven by scale model tests whose results are reported in Reference 2.

Regulatory Guide 1.14, Revision 1, Section C, Subsection 2 (see Appendix A, or Reference 1), provides the following regulatory position for flywheel design:

- a. *The flywheel assembly, including any speed-limiting and antirotation devices, the shaft, and the bearings, should be designed to withstand normal conditions, anticipated transients, the design basis loss-of-coolant accident, and the Safe Shutdown Earthquake loads without loss of structural integrity.*
- b. *Design speed should be at least 125% of normal speed but not less than the speed that could be attained during a turbine overspeed transient. Normal speed is defined as synchronous speed of the a.c. drive motor at 60 hertz.*
- c. *An analysis should be conducted to predict the critical speed for ductile failure of the flywheel. The methods and limits of paragraph F-1323.1(b) in Section III of the ASME Code are acceptable. If another method is used, justification should be provided. The analysis should be submitted to the NRC staff for evaluation.*
- d. *An analysis should be conducted to predict the critical speed for nonductile failure of the flywheel. Justification should be given for the stress analysis method, the estimate of flaw size and location, which should take into account initial flaw size and flaw growth in service, and the values of fracture toughness assumed for the material. The analysis should be submitted to the NRC staff for evaluation.*

- e. *An analysis should be conducted to predict the critical speed for excessive deformation of the flywheel. The analysis should be submitted to the NRC staff for evaluation. (Excessive deformation means any deformation such as an enlargement of the bore that could cause separation directly or could cause an unbalance of the flywheel leading to structural failure or separation of the flywheel from the shaft. The calculation of deformation should employ elastic-plastic methods unless it can be shown that stresses remain within the elastic range).*
- f. *The normal speed should be less than one-half of the lowest of the critical speeds calculated in regulatory positions C.2.c, d, and e above.*
- g. *The predicted LOCA overspeed should be less than the lowest of the critical speeds calculated in regulatory positions C.2.c, d, and e above.*

These guidelines will be reviewed in this section, for all the flywheels covered by this report, and the results tabulated.

4.1 Selection of Flywheel Groups for Evaluation

From the flywheel dimensional information provided in Table 2-1 of this report, six flywheel groups were selected for evaluation, which encompass the range of domestic flywheel dimensions covered by this report. These groups are as follows:

Table 4-1: Flywheel Groups Evaluated

Flywheel Group	Outer Diameter (Inches)	Bore (Inches)	Keyway Radial Length (Inches)	Comments
1	76.50	9.375	0.937	Maximum flywheel OD.
2	75.75	8.375	0.906	Large flywheel OD, Minimum flywheel bore.
10	72.00	16.125	0.906	Large flywheel OD, Large flywheel bore.
14	65.00	8.375	0.656	Minimum flywheel OD, Minimum flywheel bore.
15	72.00	30.500	0.390	Maximum flywheel bore (spoked flywheel), Minimum keyway radial length.
16	65.00	13.800	1.060	Minimum flywheel OD, Maximum keyway radial length.

4.2 Ductile Failure Analysis

The capacity of a structure to resist ductile failure with sufficient margin of safety during faulted conditions can be demonstrated by meeting the faulted condition criteria of Section III of the ASME Boiler and Pressure Vessel Code. The faulted condition stress limits for elastic analysis, P_m and $P_m + P_b$, are taken as $0.7 S_u$ and $1.05 S_u$, where S_u is the minimum specified ultimate tensile stress of the material. As in Reference 2, 80 ksi was used for S_u , which is the minimum specified value for A-533 Grade B, Class 1 steel. The stresses in the RCP flywheel, neglecting local stress concentrations such as holes and keyways, can be calculated by the following equations (Reference 2):

$$\sigma_r = \frac{(3+\nu)}{8} \frac{\rho \omega^2}{386.4} \left(b^2 + a^2 - \frac{a^2 b^2}{r^2} - r^2 \right)$$

$$\sigma_\theta = \frac{(3+\nu)}{8} \frac{\rho \omega^2}{386.4} \left[b^2 + a^2 + \frac{a^2 b^2}{r^2} - \left(\frac{1+3\nu}{3+\nu} \right) r^2 \right]$$

where σ_r	=	radial stress, psi
σ_θ	=	circumferential, or hoop stress, psi
ν	=	Poisson's ratio, 0.3
ρ	=	flywheel material density, 0.283 lb _m /inch ³
ω	=	flywheel angular speed, radians/second
b	=	flywheel outer radius, inches
a	=	flywheel bore radius, inches
r	=	flywheel radial location of interest, inches

Since the stress in the thickness direction (σ_z) is assumed to be negligible, and the radial stress (σ_r) always falls between σ_z and σ_θ , the maximum stress intensity at any point in the flywheel is equal to the circumferential stress, σ_θ . It should be noted that the circumferential stress peaks at the flywheel bore and keyway locations and decreases approximately linearly thereafter in the radial direction. To apply the faulted stress limits to a nonlinear stress

distribution, the actual stress distribution must be resolved into its membrane and bending components:

$$P_m = \frac{1}{(b-a)} \int_a^b \sigma_\theta \, dr$$

$$P_b = \frac{6}{(b-a)^2} \int_a^b \sigma_\theta (r_m - r) \, dr$$

where r_m is the flywheel mean radius defined as $(a + b) / 2$. Substituting the circumferential stress term shown above and carrying out the integrations yields

$$P_m = \left(\frac{3+\nu}{8} \right) \frac{\rho \omega^2}{386.4 (b-a)} (b^3 - a^3) \left[1 - \frac{1}{3} \left(\frac{1+3\nu}{3+\nu} \right) \right]$$

$$P_b = \left(\frac{3+\nu}{8} \right) \frac{6 \rho \omega^2}{386.4 (b-a)^2} \left[\frac{b^4}{12} \left(\frac{1+3\nu}{3+\nu} \right) - \frac{b^3 a}{2} \left[1 - \frac{1}{3} \left(\frac{1+3\nu}{3+\nu} \right) \right] \right.$$

$$\left. - a^2 b^2 \ln\left(\frac{b}{a}\right) - \frac{b a^3}{2} \left[1 + \frac{1}{3} \left(\frac{1+3\nu}{3+\nu} \right) \right] - \frac{a^4}{12} \left(\frac{1+3\nu}{3+\nu} \right) \right]$$

As was performed in the Reference 2 evaluation, a ductile failure limiting speed was determined for each flywheel group selected for evaluation, assuming that cracks are not present and neglecting the local stress effects from holes and keyways. Limiting speeds were also calculated considering the reduced cross sectional area resulting from the keyway, and from assuming that cracks may be present. Cracks were assumed to emanate radially from the keyway, through the full thickness of the flywheel. The results of these calculations are provided in the following table.

Table 4-2: Ductile Failure Limiting Speed (rpm)

Flywheel Group	Assuming No Cracks		Crack Length (from Keyway)			
	Neglecting Keyway Radial Length	Considering Keyway Radial Length	1" Crack	2" Crack	5" Crack	10" Crack
1	3487	3430	3378	3333	3240	3012
2	3553	3493	3435	3386	3281	3060
10	3503	3471	3443	3398	3238	2990
14	4086	4032	3961	3903	3768	3448
15	3175	3155	3105	3056	2915	2698
16	3900	3850	3815	3760	3565	3264

Per Regulatory Guide 1.14, Revision 1, Section C, item 2f, the normal speed should be less than one-half of the lowest of the critical speeds as calculated for ductile failure, nonductile failure and excessive deformation. At the minimum calculated limiting speed of 3155 rpm (assuming cracks are not present), the normal speed must be less than 1577 rpm. Since the normal operating flywheel speed is 1200 rpm, item 2f of the Regulatory Guide is satisfied for ductile failure with no cracks present. Assuming that a rather large crack of 10" depth is present, item 2f is still satisfied for ductile failure since one-half of the lowest calculated critical speed (2698 rpm) is 1349 rpm, which is higher than the normal operating flywheel speed of 1200 rpm.

Per item 2g of Section C of the Regulatory Guide, the predicted LOCA overspeed should be less than the lowest of the critical speeds calculated for ductile failure, nonductile failure and excessive deformation. Since the predicted LOCA overspeed is in all cases less than 1500 rpm, and the minimum calculated limiting velocity for ductile failure is 3155 rpm, item 2g of the Regulatory Guide is satisfied for ductile failure, assuming no cracks are present. Assuming that a rather large crack of 10" length is present, item 2g is still satisfied for ductile failure since the lowest calculated critical speed (2698 rpm) is higher than the LOCA overspeed of 1500 rpm.

Therefore, the Regulatory Guide acceptance criteria for ductile failure of the flywheels are satisfied.

4.3 Nonductile Failure Analysis

As provided in Reference 2, an approximate solution for the stress intensity factor for a radial full depth crack emanating from the bore of a rotating disk may be calculated by the following equations (Reference 5):

$$K_I = \frac{\rho \omega^2}{386.4} b^{3/2} \phi \left[\frac{\pi \left(\frac{c}{b} - \frac{a}{b} \right)}{(1-v^2)} \right]^{1/2}$$

$$\phi = \frac{(3+v)}{32} \left[3 \left(1 + \frac{a^2}{b^2} \right) + 3 \left(\frac{a}{b} \right) \left(\frac{b}{c} \right) + \left(1 + \frac{a}{b} + \frac{a^2}{b^2} \right) \frac{\left(1 - \frac{a}{b} \right)}{\left(1 - \frac{c}{b} \right)} \right]$$

$$- \left(\frac{1 + 3v}{32} \right) \left[\frac{\left(\frac{c}{b} \right)^3 - \left(\frac{a}{b} \right)^3}{\left(\frac{c}{b} - \frac{a}{b} \right)} + \frac{1}{3} \frac{\left(1 - \frac{a}{b} \right)^3}{\left(1 - \frac{c}{b} \right)} \right]$$

where ρ = flywheel material density (lb_m per cubic inch)
 ω = flywheel angular speed (radians per second)
 b = flywheel outer radius (inches)
 a = flywheel inner radius (inches)
 c = radial location of crack tip (inches)
 v = Poisson's ratio (0.3)

In the Reference 2 analysis, the keyway radial length was initially assumed to be included as part of the total crack length for conservatism. Using the closed form solution, a nonzero value of stress intensity was obtained for a zero crack length (i.e., $c = a +$ keyway radial length), as would be expected, since the keyway itself was in essence considered to be a crack. To eliminate this undue conservatism for short crack lengths, finite element analysis was performed. It was shown that cracks emanating from the center of the keyway yielded higher stress intensity factors than cracks emanating from the keyway corner, and that a zero length crack resulted in a zero stress intensity factor. The finite element analysis results were in close agreement with the closed form solution for crack lengths larger than about 1.0 inch. It was also shown in the Reference 2 analysis that the ductile failure mode controls for smaller crack lengths (less than 1.15 inches for the particular flywheel evaluated), and that

nonductile failure controls for larger crack lengths. Therefore, the closed form solution was used for calculation of the stress intensity factors in this report, keeping in mind that it is overly conservative for small cracks. (However, small cracks are controlled by the ductile failure mode).

To envelope the range of RT_{NDT} values for the flywheel materials, an upper and lower bound value of 0°F and 60°F were used in this report. The lower bound fracture toughness for ferritic steels was calculated by the following equation (Reference 4):

$$K_{IC} = 33.2 + 20.734 \exp[0.02 (T - RT_{NDT})]$$

This resulted in fracture toughness values of 117 ksi $\sqrt{\text{inch}}$ and 58.5 ksi $\sqrt{\text{inch}}$ for RT_{NDT} values of 0°F and 60°F, respectively, at an ambient temperature of 70°F. The ambient temperature used for the fracture evaluation represents a much lower temperature than would be expected in the containment building during normal plant operating conditions (typically 100°F to 120°F), and is therefore conservative with respect to nonductile failure analysis.

At the maximum flywheel overspeed condition of 1500 rpm, the following critical crack lengths were calculated for cracks emanating radially from the keyway. Note that an intermediate RT_{NDT} value of 30°F ($K_{IC} = 79.3$ ksi $\sqrt{\text{inch}}$) is included in the table.

Table 4-3: Critical Crack Lengths for Flywheel Overspeed of 1500 rpm

Flywheel Group	Critical Crack Length in Inches and % through Flywheel		
	$RT_{NDT} = 0^{\circ}\text{F}$	$RT_{NDT} = 30^{\circ}\text{F}$	$RT_{NDT} = 60^{\circ}\text{F}$
1	16.6" (50%)	7.7" (24%)	3.1" (9%)
2	17.5" (53%)	8.5" (26%)	3.6" (11%)
10	15.1" (56%)	7.5" (27%)	3.3" (12%)
14	20.3" (73%)	14.4" (52%)	8.3" (30%)
15	10.4" (51%)	5.3" (26%)	2.6" (12%)
16	17.2" (70%)	11.4" (46%)	6.0" (24%)

Note: Crack length is measured radially from the keyway, and percentage through flywheel is calculated as the crack length divided by the radial length from the keyway to the flywheel outer radius.

As shown in the above table, the critical crack lengths are quite large, even when considering higher values of RT_{NDT} and a lower than expected operating temperature.

4.3.1 Fatigue Crack Growth

To estimate the magnitude of fatigue crack growth during plant life, an initial radial crack length of 10% of the way through the flywheel (from the keyway to the flywheel outer radius) was conservatively assumed. The fatigue crack growth rate may be characterized in terms of the range of applied stress intensity factor, and is generally of the form (Reference 4):

$$\frac{da}{dN} = C_0 (\Delta K_I)^n$$

where da/dN = crack growth rate (inches/cycle)
 n = slope of the log (da/dN) versus log (ΔK_I)
 C_0 = scaling constant

The fatigue crack growth behavior is affected by the R ratio (K_{min}/K_{max}) and the environment. Reference fatigue crack growth behavior of carbon and low alloy ferritic steels exposed to an air environment is provided by the above equation with $n = 3.07$ and $C_0 = 1.99 \times 10^{-10} S$. (S is a scaling parameter to account for the R ratio and is given by $S = 25.72 (2.88 - R)^{-3.07}$ where $0 \leq R < 1$. Since the maximum stress intensity range occurs between RCP shutdown (zero rpm) and the normal operating speed of approximately 1200 rpm, the R ratio is zero, and $S = 1$). The fatigue crack growth rate for the flywheels may therefore be estimated by

$$\frac{da}{dN} = 1.99 \times 10^{-10} (\Delta K_I)^{3.07}$$

Assuming 6000 cycles of RCP starts and stops for a 60 year plant life (typical for RCP design including the potential for extended plant life, and conservative for actual operation), the estimated radial crack growth is as shown below:

Table 4-4: Fatigue Crack Growth Assuming 6000 RCP Starts and Stops

FLY-WHEEL GROUP	FLY-WHEEL OD (INCHES)	FLY-WHEEL BORE (INCHES)	KEY-WAY RADIAL LENGTH (INCH)	LENGTH FROM KEYWAY TO OD (INCHES)	ASSUMED INITIAL CRACK LENGTH (INCHES)	ΔK_I (KSI $\sqrt{\text{INCH}}$)	CRACK GROWTH AFTER 6000 CYCLES (INCH)
1	76.50	9.375	0.937	32.63	3.26	38	0.08
2	75.75	8.375	0.906	32.78	3.28	37	0.08
10	72.00	16.125	0.906	27.03	2.70	35	0.07
14	65.00	8.375	0.656	27.66	2.77	25	0.02
15	72.00	30.500	0.390	20.36	2.04	33	0.05
16	65.00	13.800	1.060	24.54	2.45	28	0.03

As shown in the above table, crack growth is negligible over a 60 year life of the flywheel, even when assuming a large initial crack length.

4.4 Excessive Deformation Analysis

The change in the bore radius (a) and the outer radius (b) of the flywheel at the overspeed condition may be estimated by the following equations (Reference 6):

$$\Delta a = \frac{1}{4} \frac{\rho \omega^2}{386.4} \frac{a}{E} [(3 + \nu) b^2 + (1 - \nu) a^2]$$

$$\Delta b = \frac{1}{4} \frac{\rho \omega^2}{386.4} \frac{b}{E} [(1 - \nu) b^2 + (3 + \nu) a^2]$$

where a = bore radius (inches)
b = outer radius (inches)
 ρ = flywheel material density (0.283 lb_m/cubic inch)
 ω = flywheel angular speed (radians per second)
E = Young's modulus (30 x 10⁶ psi)
 ν = Poisson's ratio (0.3)

At the flywheel overspeed condition of 1500 rpm (157.08 radians/second), the change in the bore radius and the outer radius is calculated as shown below:

Table 4-5: Flywheel Deformation at 1500 rpm

FLYWHEEL GROUP	CHANGE IN BORE RADIUS (INCH)	CHANGE IN OUTER RADIUS (INCH)
1	0.003	0.006
2	0.003	0.006
10	0.005	0.006
14	0.002	0.004
15	0.010	0.009
16	0.004	0.004

As shown in the table above, a maximum flywheel deformation of only 0.010 inches is anticipated for the flywheel overspeed condition. As deformation is proportional to ω^2 , this represents an increase of 56% over the normal operating deformation. This increase would not result in any adverse conditions, such as excessive vibrational stresses leading to crack propagation, since the flywheel assemblies are typically shrunk fit to the flywheel shaft, and the deformations are negligible.

4.5 Summary of Stress and Fracture Results

The integrity evaluations presented in this section have shown that the reactor coolant pump flywheels have a very high tolerance for the presence of flaws. The results obtained here are even better than those obtained in earlier evaluations, because the application of leak before break has demonstrated that flywheel overspeed events are limited to less than 1500 rpm.

There are no significant mechanisms for inservice degradation of the flywheels, since they are isolated from the primary coolant environment. Analyses presented in this section have shown there is no significant deformation of the flywheels even at maximum overspeed conditions. Fatigue crack growth calculations have shown that for 60 years of operation, crack growth from large postulated flaws in each of the flywheel groups is only a few mils. Therefore the flywheel inspections completed prior to service are sufficient to ensure their integrity during service. In fact, the most likely source of inservice degradation is damage to the keyway region which could occur during disassembly or reassembly for inspection.




Figure 4-1: Results of a Typical Reactor Coolant Pump Flywheel Overspeed Evaluation

SECTION 5

RISK ASSESSMENT: EFFECT OF INSPECTIONS

To investigate the effect of flywheel inspections on the risk of failure, a structural reliability and risk assessment was performed for each of the flywheel groups selected for evaluation in Section 4. A 40 year plant life including the potential for an extended plant life of 60 years, and 12 month operating cycles were assumed for the evaluation. The following subsections describe the methodology used and the results of this assessment.

5.1 Method of Calculating Failure Probabilities

The probability of failure of the RCP flywheel as a function of operating time t , $\Pr(t \leq t_f)$, is calculated directly for each set of input values using Monte-Carlo simulation with importance sampling. The Monte-Carlo simulation does not force the calculated distribution of time to failure to be of a fixed type (e.g. Weibull, Log-normal or Extreme Value). The actual failure distribution is estimated based upon the distributions of the uncertainties in the key structural reliability model parameters and plant specific input parameters. Importance sampling, as described by Witt (Reference 7), is a variance reduction technique to greatly reduce the number of trials required for calculating small failure probabilities. In this very effective technique, random values are selected from the more severe high or low regions of their distributions so as to promote failure. However, when failure is calculated, the count is corrected to account for the lower probability of simultaneously obtaining all of the more severe random values.

To apply this simulation method to reactor pump flywheel (RPFW) failure, the existing Westinghouse PROF (probability of failure) Software System (object library) is combined with the problem-specific structural analysis models described in Section 4.3. The PROF library provides standard input and output, including plotting, and probabilistic analysis capabilities (e.g. random number generation, importance sampling). The result is the executable program RPFWPROF.EXE for calculation of pump flywheel failure probability with time. The failure mode being simulated by the program is an initial flaw, undetected during pre-service inspection, growing by fatigue crack growth due to pump startup and shutdown until a critical length is obtained. The critical length is that which causes the flaw stress intensity factor due to pump overspeed during the design limiting event to exceed the fracture toughness of the flywheel material.

The Westinghouse PROF Software Library, which was used to generate the RPFWPROF program, has been verified and benchmarked in a number of ways. Table 5-1 provides a comparison of probabilities from hand calculation for simple models where the only random variables are the initial and limiting crack depths. The crack growth due to two independent mechanisms is deterministic (variables are constant). As can be seen, the W-PROF calculated values agree very well (less than 4% error) for a number of different distributions and with the effects of importance sampling.

Table 5-1: Simple Verification of Results for Westinghouse PROF Methods

Type of Distribution on Crack Depths (1)	Import. Sampling Shift (2)	Hand Calculated Prob. (3)	W-PROF Calculated Probability	Percent Error
Normal	0.0	0.1003	0.10004	-0.26
Normal	± 1.0	0.1003	0.09889	-1.41
Log-Normal	0.0	0.1003	0.09880	-1.50
Log-Normal	± 1.0	0.1003	0.09652	-3.77
Uniform	0.0	0.1003	0.10393	+3.62
Log-Uniform	0.0	0.1003	0.10018	-0.12
Weibull	0.0	0.0950	0.0934	-1.68
(1) Same type of distribution on the random values of initial crack depth and limiting crack depth. (2) Median value of initial depth shifted +1 standard deviation and median value of limiting depth shifted -1 standard deviation when importance sampling (Reference 7) is used with less than half the number of trials. (3) Calculated using stress-strength overlap techniques on crack depth.				

The calculation of failure probability using the W-PROF methods and importance sampling was also compared to that calculated by an alternative method for more complex models. The more complex model also included the uncertainties in growth rate, which were also a function of the crack depth. The alternative method was the @RISK add-in for Lotus 1-2-3 spreadsheets (Reference 8). As seen in Figure 5-1, the comparison of calculated probabilities is excellent at the low probability values, where importance sampling is normally used.

In the verification of the simplified piping fracture mechanics (SPFM) structural reliability programs for risk based inspection (Reference 9), the calculated probabilities for thermal transient induced fatigue crack growth were compared with results from the pc-PRAISE program (Reference 10). PRAISE, which was developed by Lawrence Livermore National Laboratory for the NRC, is the nuclear industry's standard for calculating the structural reliability of piping. As shown in Figure 5-2, the comparison of calculated leak probabilities with the number of operating cycles, without the effects of inspection, is excellent for both the SPFM-PROF and SPFMSRRA programs. The SPFMSRRA program uses Westinghouse developed approximations to estimate the changes in probability with time due to changes in the input variables relative to a reference case. The reference case is initially calculated using the SPFM-PROF Program, which is the same type of program as RPFV-PROF.

When the same inservice inspection frequency and accuracy are used, Figure 5-3 shows that essentially the same failure probabilities are calculated by pc-PRAISE, SPFM-PROF and SPFMSRRA. Therefore, it is concluded that the Westinghouse methods employed in calculating probabilities with

the RPFWPROF.EXE program have been sufficiently verified and benchmarked for the assessment of pump flywheel failure risk and the effects of inspection.

The input parameters to the RPFWPROF program are described in Table 5-2. Variables 1 to 4 and 9 to 17 are the key input parameters needed for failure probability calculation, as identified in Section 4.3. Their usage in the program is specified as shown in the last column of Table 5-2 and schematically in the flow chart of Figure 5-4. "Initial" conditions do not change with time, "Steady-State" is not needed for RPFWPROF, "Transient" calculates fatigue crack growth and "Failure" checks to see if the accumulated crack length exceeds the critical length.

Table 5-2: Variables for Structural Reliability Model of RCP Flywheel Failure

No.	Name	Description of Input Variable	Usage Type
1	ORADIUS	Outer Flywheel Radius (Inch)	Initial
2	IRADIUS	Inner Flywheel Radius (Inch)	Initial
3	PFE-PSI	Probability of Flaw Existing After Preservice Inspection	Initial
4	ILENGTH	Initial Radial Flaw Length (Inch)	Initial
5	CY1-ISI	Operating Cycle for First Inservice Inspection	Inspection
6	DCY-ISI	Operating Cycles Between Inservice Inspections	Inspection
7	POD-ISI	Flaw Detection Probability per Inservice Inspection	Inspection
8	DFP-ISI	Fraction PFE Increases per Inservice Inspection	Inspection
9	NOTR/CY	Number of Transients per Operating Cycle	Transient
10	DRPM-TR	Speed Change per Transient (RPM)	Transient
11	RATE-FCG	Fatigue Crack Growth Rate (Inch/Transient)	Transient
12	KEXP-FCG	Fatigue Crack Growth Rate SIF Exponent	Transient
13	RPM-DLE	Speed for Design Limiting Event (RPM)	Failure
14	TEMP-F	Temperature for Design Limiting Event (F)	Failure
15	RT-NDT	Reference Nil Ductility Transition Temperature (F)	Failure
16	F-KIC	Crack Initiation Toughness Factor	Failure
17	DLENGTH	Flywheel Keyway Radial Length (Inch)	Failure

Variables 5 to 8 are available to calculate the effects of an inservice inspection (ISI) in the RPFWPROF program. In a Monte-Carlo type simulation, the failure probability at a given time is approximated as the ratio of the number of failures at that time to the total number of trials. For inservice inspections, this ratio is modified to reflect the fact that only those cracks that are not

detected will remain to possibly cause failure. That is, a component with a detected crack is assumed to be repaired or replaced, returning it to a good-as-new condition. This modified ratio for ISI is expressed by the following equation:

$$Pr_f = \text{Summation } [Pr_{ND}(n) F(n)] / N$$

$$n = 1 \text{ to } N$$

Where:

Pr_f = the approximate probability of failure,

$Pr_{ND}(n)$ = the ISI non-detection probability for the nth trial,

$F(n)$ = the failure weight for the nth trial
(e.g. 1 if failure occurs and 0 otherwise for no importance sampling), and

N = the total number of trials (simulations).

The non-detection probability normally varies as a function of time since it depends upon the size of the crack at the time the ISI is performed. That is, the larger the crack size, the lower the probability of not detecting it. This is also expressed in equation form for the lth inservice inspection as:

$$Pr_{ND}(n) = \text{Product } [Pr_{ND}(n, t_i)]$$

$$i = 1 \text{ to } l$$

Where:

$Pr_{ND}(n, t_i)$ = the probability of non-detection for the inservice inspection of weld n at time t_i .

These equations, which are used in the simplified model for the effect of ISI, are consistent with those described in the pc-PRAISE Code User's Manual (Reference 10). They are somewhat optimistic since there is no correlation between successive inspections of the same material, which may systematically occur in actual practice. The parameters needed to describe the selected ISI program are the time of the first inspection, the frequency of subsequent inspections (expressed as the number of fuel or operating cycles between inspections) and the probability of non-detection as a function of crack length. For the reactor pump flywheel, the non-detection probability, which is independent of crack length, is simply one minus a constant value of detection probability, variable 7 in Table 5-2. An increase in failure probability due to pump inspection (chance of incorrect disassembly and reassembly) was included in the ISI model but not used (variable 8 set to zero).

The median input values and their uncertainties for each of the parameters of Table 5-2 are shown in Table 5-3. The median is the value at 50% probability (half above and half below this value); it is also the mean (average) value for symmetric distributions, like the normal (bell-shaped curve) distribution. Uncertainties are based upon expert engineering judgement and previous structural

reliability modeling experience. For example, the fracture toughness for initiation as a function of the reference nil-ductility transition temperature and the uncertainties on these parameters are based upon prior probabilistic fracture mechanics analyses of the pressure vessel (Reference 11). Also note that the stress intensity factor calculation for crack growth and failure used the flywheel keyway radial length (variable 17) in addition to the calculated flaw length. This allowed the probabilistic models to be checked using the results of the conservative deterministic evaluations of Tables 4-3 and 4-4.

Table 5-3: Input Values for Structural Reliability Model of RCP Flywheel Failure

No.	Name	Median	Distribution	Uncertainty*
1	ORADIUS	Per Flywheel Group	Constant	
2	IRADIUS	Per Flywheel Group	Constant	
3	PFE-PSI	1.000E-01	Constant	
4	ILENGTH	1.000E-01	Log-Normal	2.153E+00
5	CY1-ISI	3.000E+00	Constant	
6	DCY-ISI	4.000E+00	Constant	
7	POD-ISI	5.000E-01	Constant	
8	DFP-ISI	0.000E+00	Constant	
9	NOTR/CY	1.000E+02	Normal	1.000E+01
10	DRPM-TR	1.200E+03	Normal	1.200E+02
11	RATE-FCG	9.950E-11	Log-Normal	1.414E+00
12	KEXP-FCG	3.070E+00	Constant	
13	RPM-DLE	1.500E+03	Normal	1.500E+02
14	TEMP-F	9.500E+01	Normal	1.250E+01
15	RT-NDT	3.000E+01	Normal	1.700E+01
16	F-KIC	1.000E+00	Normal	1.000E-01
17	DLENGTH	Per Flywheel Group	Constant	

* Note: Uncertainty is either the normal standard deviation, the range (median to maximum) for uniform distributions or the corresponding factor for logarithmic distributions.

Table 5-4 provides sample output from the RPFWPROF Program for the values of the input variables in Table 5-3. The first page of the output describes the input that is used for the calculations. The "SHIFT MV/SD" column indicates how many standard deviations (SD) the median value (MV) is shifted for importance sampling (Reference 7). The second page of the output provides the change in failure probability per fuel (operating) cycle and the cumulative probability. The deviation on the

cumulative total that is output is the deviation due to the Monte-Carlo simulation only. Figure 5-5 shows the computer generated plot comparing the calculated reactor pump failure probabilities with and without the effects of inservice inspection. As can be seen, the effect of ISI, even with a 50% probability of detection, is very small. This is because the failure probability is not changing much with time; therefore, the rate of increase cannot be significantly reduced even for a perfect inspection with 100% probability detection.

Table 5-4: Example Output from the RPFWPROF Program

WESTINGHOUSE

STRUCTURAL RELIABILITY AND RISK ASSESSMENT (SRRA)

PROBABILITY OF FAILURE PROGRAM RPFWPROF

ESEU-NTD

INPUT VARIABLES FOR CASE 1: REACTOR COOLANT PUMP FLYWHEEL FAILURE

NCYCLE = 60

NOVARS = 17

NUMESC = 0

NFAILS = 1000

NUMSET = 4

NUMTRC = 4

NTRIAL = 9999

NUMISI = 4

NUMFMD = 5

VARIABLE NO.

NAME

DISTRIBUTION TYPE

LOG

MEDIAN VALUE

DEVIATION OR FACTOR

SHIFT MV/SD

USAGE NO.

SUB

1

ORADIUS

-

CONSTANT

-

3.6000D+01

1

SET

2

IRADIUS

-

CONSTANT

-

8.0625D+00

2

SET

3

PFE-PSI

-

CONSTANT

-

1.0000D-01

3

SET

4

ILENGTH

NORMAL

YES

1.0000D-01

2.1528D+00

1.00

4

SET

5

CYI-ISI

-

CONSTANT

-

3.0000D+00

1

ISI

6

DCY-ISI

-

CONSTANT

-

4.0000D+00

2

ISI

7

POD-ISI

-

CONSTANT

-

5.0000D-01

3

ISI

8

DFP-ISI

-

CONSTANT

-

0.0000D+00

4

ISI

9

NOTR/CY

NORMAL

NO

1.0000D+02

1.0000D+01

.00

1

TRC

10

DRPM-TR

NORMAL

NO

1.2000D+03

1.2000D+02

1.00

2

TRC

11

RATE-FCG

NORMAL

YES

9.9499D-11

1.4142D+00

1.00

3

TRC

12

KEXP-FCG

-

CONSTANT

-

3.0700D+00

4

TRC

13

RPM-DLE

NORMAL

NO

1.5000D+03

1.5000D+02

1.00

1

FMD

14

TEMP-F

NORMAL

NO

9.5000D+01

1.2500D+01

-2.00

2

FMD

15

RT-NDT

NORMAL

NO

3.0000D+01

1.7000D+01

2.00

3

FMD

16

F-KIC

NORMAL

NO

1.0000D+00

1.0000D-01

-1.00

4

FMD

17

DLENGTH

-

CONSTANT

-

9.0600D-01

5

FMD

Table 5-4: Example Output from the RPFWPROF Program (Cont'd.)

PROBABILITIES OF FAILURE MODE: FATIGUE CRACK GROWTH SIF > TOUGHNESS

NUMBER FAILED = 470

NUMBER OF TRIALS = 9999

END OF CYCLE	FAILURE PROBABILITY WITHOUT FOR PERIOD	AND CUM. TOTAL	WITH IN-SERVICE FOR PERIOD	INSPECTION CUM. TOTAL
1.0	9.00777D-08	9.00777D-08	9.00777D-08	9.00777D-08
2.0	1.00713D-08	1.00149D-07	1.00713D-08	1.00149D-07
3.0	8.70982D-11	1.00236D-07	8.70982D-11	1.00236D-07
11.0	3.56616D-11	1.00272D-07	8.91540D-12	1.00245D-07
12.0	9.40206D-13	1.00273D-07	1.17526D-13	1.00245D-07
13.0	2.17369D-11	1.00294D-07	2.71711D-12	1.00248D-07
14.0	4.71179D-10	1.00766D-07	5.88974D-11	1.00307D-07
18.0	2.91939D-10	1.01058D-07	1.82462D-11	1.00325D-07
19.0	1.59524D-09	1.02653D-07	9.97024D-11	1.00425D-07
24.0	6.00973D-12	1.02659D-07	9.39020D-14	1.00425D-07
26.0	2.07667D-11	1.02680D-07	3.24480D-13	1.00425D-07
31.0	1.30332D-09	1.03983D-07	1.01822D-11	1.00435D-07
32.0	2.87692D-11	1.04012D-07	1.12380D-13	1.00435D-07
34.0	1.81125D-11	1.04030D-07	7.07521D-14	1.00435D-07
35.0	1.30472D-10	1.04160D-07	5.09655D-13	1.00436D-07
38.0	1.12340D-10	1.04273D-07	2.19414D-13	1.00436D-07
40.0	2.93218D-11	1.04302D-07	2.86346D-14	1.00436D-07
46.0	8.71264D-11	1.04389D-07	4.25422D-14	1.00436D-07
47.0	1.12251D-10	1.04501D-07	5.48099D-14	1.00436D-07
50.0	7.94921D-11	1.04581D-07	1.94072D-14	1.00436D-07
51.0	5.07795D-12	1.04586D-07	1.23973D-15	1.00436D-07
52.0	2.88193D-12	1.04589D-07	3.51798D-16	1.00436D-07
54.0	4.48702D-10	1.05037D-07	5.47732D-14	1.00436D-07
55.0	1.17426D-11	1.05049D-07	1.43343D-15	1.00436D-07
58.0	9.35600D-11	1.05143D-07	5.71045D-15	1.00436D-07
59.0	2.43375D-11	1.05167D-07	1.48544D-15	1.00436D-07
60.0	0.00000D+00	1.05167D-07	0.00000D+00	1.00436D-07
DEVIATION ON CUMULATIVE TOTALS =			4.73585D-09	4.63324D-09

Note: Failure probabilities are provided in double precision format
(e.g. 4.28172D-08 is 4.28172×10^{-8})

5.2 Evaluation of Risk for RCP Flywheels

Evaluations were performed to determine the effect on the probability of flywheel failure for continuing the current inservice inspections over the life of the plant and for discontinuing the inspections. Since most plants have been in operation for at least ten years, the evaluation calculated the effects of the inspections being discontinued after ten years.

It is important to keep in mind that the probability of failure determined by these evaluations is only a calculated parameter. The reason for this is that the evaluation conservatively assumes that the probability of a flaw existing after pre-service inspection is 10%, and that the ISI flaw detection probability is only 50%. In reality, most preservice and ISI flaws would be detected, especially for the larger flaw depths which may lead to failure. Therefore, the calculated values are very conservative. (The effects of some important parameters on the calculated probability of failure are discussed later in Section 5.3). The most important result of the evaluation is the change in calculated probability of failure from continuing to discontinuing the inspections after ten years (cycles) of plant life.

As shown in Figures 5-6 through 5-11, the effect of inservice inspection on failure probability has little effect on minimizing the potential for failure of the flywheel. The results of this assessment are summarized as follows for a plant life of 40 and 60 years:

Table 5-5: Probability of Failure after 40 and 60 Years with and without Inservice Inspection

Flywheel Group	Probability of flywheel failure with ISI prior to and after 10 years	Probability of flywheel failure with ISI prior to 10 years and without ISI after 10 years		% Increase in failure probability for eliminating inspections	
		At 40 years	At 60 years	At 40 years	At 60 Years
1	2.45E-7	2.50E-7	2.57E-7	2	5
2	1.43E-7	1.45E-7	1.47E-7	1	3
10	1.00E-7	1.04E-7	1.05E-7	4	5
14	2.98E-10	2.98E-10	2.98E-10	0	0
15	1.15E-8	1.18E-8	1.22E-8	3	6
16	6.92E-9	7.02E-9	7.02E-9	1	1

It can be seen above that continuing inspection after 10 years has essentially no impact on the failure probabilities.

5.3 Sensitivity Study

A sensitivity study was performed to determine the effect of some important flywheel risk assessment parameters on the probability of failure. Flywheel group 10 was arbitrarily chosen for the study. The parameters evaluated included the probability of detection, the initial flaw length, and the initial flaw length uncertainty. The results of this study are summarized in the table below. Note that this study was performed for a flywheel design life of 40 years.

Table 5-6: Effect of Flywheel Risk Parameters on Failure Probability

Description of flywheel risk parameter varied	Probability of flywheel failure after 40 years with ISI prior to and after 10 years	Probability of flywheel failure after 40 years with ISI prior to 10 years and without ISI after 10 years
Base Case	1.00E-7	1.04E-7
Probability of Detection of 10%	1.03E-7	1.04E-7
Probability of Detection of 80%	1.00E-7	1.04E-7
Initial flaw length of 0.05 inches	4.57E-8	4.74E-8
Initial flaw length of 0.20 inches	2.97E-7	3.01E-7
Length 3 Sigma Bound Factor of 3	6.40E-8	6.46E-8
Length 3 Sigma Bound Factor of 20	1.94E-7	1.95E-7

The values for the base case, shown in Table 5-6 above are for a 10% probability of a flaw existing after preservice inspection, an initial flaw length of 0.10 inch (1.006 inch with keyway), an initial flaw length (Length) 3-sigma bound factor of 10, an initial inservice inspection at three years of plant life and subsequent inspections at four year intervals, and a probability of detection of 50% per inservice inspection (see Table 5-5, flywheel group 10).

The flaw detection probability was varied from 50% to 10% and 80%. Failure probability increased approximately 3% for a decrease in flaw detection probability from 50% to 10%. Failure probability did not change for an increase in flaw detection probability from 50% to 80%. Therefore, flaw detection probability, which is a measure of how well the inspections are performed, has essentially no effect on flywheel failure probability.

The initial flaw length was varied from 0.10 inch to 0.05 inch and 0.20 inches. Failure probability decreased by 54% for a decrease in initial flaw length from 0.10 inch to 0.05 inch. Failure probability tripled for an increase in initial flaw length from 0.10 inch to 0.20 inches. Therefore, initial flaw length does affect flywheel failure probability, but the failure probability is small, even for larger

initial flaw lengths. Moreover, the probability of the larger flaw being missed during preservice inspection would be even smaller than the assumed 10 percent.

The initial flaw length 3-sigma bound factor was varied from 10 to 3 and 20. Failure probability decreased about 38% for a decrease in the 3-sigma bound factor from 10 to 3. Failure probability increased about 90% for an increase in the factor from 10 to 20. Therefore, the uncertainty in the deviation factor does affect flywheel failure probability, but failure probability is still small, even for a higher 3-sigma bound factor of 20.

5.4 Risk Assessment Conclusions

An evaluation of flywheel structural reliability was performed for each of the flywheel groups selected for evaluation in Section 4, using methods which have been sufficiently verified and benchmarked.

Using conservative input values for preservice flaw existence, initial flaw length, inservice flaw detection capability and RCP start/stop transients, it was shown that flywheel inspections beyond ten years of plant life have no significant benefit on the risk of flywheel failure. The reasons for this are that most flaws which could lead to failure would be detected during preservice inspection or at worst early in the plant life, and crack growth is negligible over the plant life. It should be noted that the effect on potential flywheel failure from damage through disassembly and reassembly for inspection has not been evaluated. It is believed that this effect could demonstrate that the risk of failure by continuing flywheel inspections is the same as or greater than the risk by eliminating the inspections.

Sensitivity studies showed that improved flaw detection capability and more inspections result in a small relative change in calculated failure probability. Failure probability was most affected by the initial flaw length and its uncertainty. These parameters are determined by the accuracy of the preservice inspection. The uncertainty could be reduced using the results from the first inservice inspection but would probably not change much during subsequent inspections.




Figure 5-1: Importance Sampling Check of Westinghouse PROF Methods




Figure 5-2: Comparison of Leak Probabilities without Inspection





Figure 5-3: Comparison of Leak Probabilities with Inservice Inspection



Method for Component Probabilistic SRRA Analysis

Figure 5-4: Westinghouse PROF Program Flow Chart for Calculating Failure Probability

SRRA Plots

Hestonhouse
ESBU - NTD

Maximum
Probability
of $0.1052E-06$

Maximum Time
of 60 Cycles

Current Case 1 X 1.0

■ ■ ■ = No ISI
□ □ □ = With ISI

Case 1 Title: REACTOR COOLANT PUMP FLYWHEEL FAILURE




Figure 5-5: Computer SRRA Plot for RCP Flywheel Failure Probability




Figure 5-6: Probability of Failure for Flywheel Evaluation Group 1




Figure 5-7: Probability of Failure for Flywheel Evaluation Group 2




Figure 5-8: Probability of Failure for Flywheel Evaluation Group 10




Figure 5-9: Probability of Failure for Flywheel Evaluation Group 14




Figure 5-10: Probability of Failure for Flywheel Evaluation Group 15




Figure 5-11: Probability of Failure for Flywheel Evaluation Group 16

SECTION 6

SUMMARY AND CONCLUSIONS

Reactor coolant pump flywheel inspections were implemented as a result of United States Nuclear Regulatory Commission Regulatory Guide 1.14, which was published in 1971 and revised in 1975.

- Flywheels are carefully designed and manufactured from excellent quality steel, which has a high fracture toughness.
- Flywheel overspeed is the critical loading, but leak-before-break has limited the maximum speed to less than 1500 rpm.
- Flywheel inspections have been performed for 20 years, with no indications of service induced flaws.
- Flywheel integrity evaluations show a very high flaw tolerance for the flywheels.
- Crack extension over a 60 year service life is negligible.
- Structural reliability studies have shown that eliminating inspections after 10 years of plant life will not significantly change the probability of failure.
- Inspections result in man-rem exposure and the potential for flywheel damage during assembly and reassembly.

Based on the above conclusions, continued inspections of reactor coolant pump flywheels are not necessary. Furthermore, overall plant safety could be increased by eliminating these inspections, because man rem doses would be lowered, and the potential for flywheel damage during disassembly and reassembly for inspection would be eliminated.

SECTION 7

REFERENCES

- 1) United States Nuclear Regulatory Commission, Office of Standards Development, Regulatory Guide 1.14, "Reactor Coolant Pump Flywheel Integrity," 1971; Revision 1, August 1975.
- 2) Westinghouse report WCAP-8163, "Topical Report Reactor Coolant Pump Integrity in LOCA," September 1973, WNES Class 3.
- 3) Babcock and Wilcox Power Generation Group, Nuclear Power Generation Division Topical Report BAW-10040, December 1973, "Reactor Coolant Pump Assembly Overspeed Analysis."
- 4) ASME Boiler and Pressure Vessel Code, Section XI, 1995 Edition.
- 5) J. G. Williams and D. P. Isherwood, "Calculation of the Strain-Energy Release Rates of Cracked Plates by an Approximate Method," Journal of Strain Analysis, Vol. 3, No. 1, 17-22 (1968).
- 6) Formulas for Stress and Strain, Fifth Edition, R. J. Roark and W. C. Young, McGraw-Hill Book Company, 1975.
- 7) "Development and Applications of Probabilistic Fracture Mechanics for Critical Nuclear Reactor Components," pp 55-70, *Advances in Probabilistic Fracture Mechanics*, ASME PVP-Vol. 92, F. J. Witt, 1984
- 8) @RISK, *Risk Analysis and Simulation add-In for Lotus 1-2-3, Version 2.01 Users Guide*, Palisade Corporation, Newfield, NY, February 6, 1992
- 9) *Final Report Documenting the Development of Piping Simplified Probabilistic Fracture Mechanics (SPFM) Models for EG&G Idaho, Inc.*, B. A. Bishop, October 1993, transmitted by Westinghouse Letter FDRT/SRPLO-027(94), February 17, 1994
- 10) NUREG/CR-5864, *Theoretical and User's Manual for pc-PRAISE, A Probabilistic Fracture Mechanics Computer Code for Piping Reliability Analysis*, Harris and Dedhia, July 1992
- 11) EPRI TR-105001, *Documentation of Probabilistic Fracture Mechanics Codes Used for Reactor Pressure Vessels Subjected to Pressurized Thermal Shock Loading*, K. R. Balkey and F. J. Witt (Part 1) and B. A. Bishop (Part 2), June 1995

APPENDIX A

REGULATORY POSITION

The United States Nuclear Regulatory Commission (NRC) issued Regulatory Guide 1.14, (Reference 1) to describe acceptable methods to ensure RCP flywheel integrity. Under Section C of the regulatory guide, the NRC Regulatory position is defined. This portion of the regulatory guide is provided below.

1. *Material and Fabrication*

- a. *The flywheel material should be of closely controlled quality. Plates should conform to ASTM A20 and should be produced by the vacuum-melting and degassing process or the electroslag remelting process. Plate material should be cross-rolled to a ratio of at least 1 to 3.*
- b. *Fracture toughness and tensile properties of each plate of a flywheel material should be checked by tests that yield results suitable to confirm the applicability to that flywheel of the properties used in the fracture analyses called for in regulatory positions C.2.c, d, and e.*
- c. *All flame-cut surfaces should be removed by machining to a depth of at least 12 mm (1/2 inch) below the flame cut surface.*
- d. *Welding, including tack welding and repair welding, should not be permitted in the finished flywheel unless the welds are inspectable and considered as potential sources of flaws in the fracture analysis.*

2. *Design*

- a. *The flywheel assembly, including any speed-limiting and antirotation devices, the shaft, and the bearings, should be designed to withstand normal conditions, anticipated transients, the design basis loss-of-coolant accident, and the Safe Shutdown Earthquake loads without loss of structural integrity.*
- b. *Design speed should be at least 125% of normal speed but not less than the speed that could be attained during a turbine overspeed transient. Normal speed is defined as synchronous speed of the a.c. drive motor at 60 hertz.*
- c. *An analysis should be conducted to predict the critical speed for ductile failure of the flywheel. The methods and limits of paragraph F-1323.1(b) in Section III of the ASME Code are acceptable. If another method is used, justification should be provided. The analysis should be submitted to the NRC staff for evaluation.*

- d. *An analysis should be conducted to predict the critical speed for nonductile failure of the flywheel. Justification should be given for the stress analysis method, the estimate of flaw size and location, which should take into account initial flaw size and flaw growth in service, and the values of fracture toughness assumed for the material. The analysis should be submitted to the NRC staff for evaluation.*
- e. *An analysis should be conducted to predict the critical speed for excessive deformation of the flywheel. The analysis should be submitted to the NRC staff for evaluation. (Excessive deformation means any deformation such as an enlargement of the bore that could cause separation directly or could cause an unbalance of the flywheel leading to structural failure or separation of the flywheel from the shaft. The calculation of deformation should employ elastic-plastic methods unless it can be shown that stresses remain within the elastic range).*
- f. *The normal speed should be less than one-half of the lowest of the critical speeds calculated in regulatory positions C.2.c, d, and e above.*
- g. *The predicted LOCA overspeed should be less than the lowest of the critical speeds calculated in regulatory positions C.2.c, d, and e above.*

3. *Testing*

Each flywheel assembly should be spin tested at the design speed of the flywheel.

4. *Inspection*

- a. *Following the spin test described in regulatory position C.3, each finished flywheel should receive a check of critical dimensions and a nondestructive examination as follows:*
 - (1) *Areas of higher stress concentrations, e.g. bores, keyways, splines, and drilled holes, and surfaces adjacent to these areas on the finished flywheel should be examined for surface defects in accordance with paragraph NB-2545 or NB-2546 of Section III of the ASME Code using the procedures of paragraph NB-2540. No linear indications more than 1.6 mm (1/16 inch) long, other than laminations, should be permitted.*
 - (2) *Each finished flywheel should be subjected to a 100% volumetric examination by ultrasonic methods using procedures and acceptance criteria specified in paragraph NB-2530 (for plates) or paragraph NB-2540 (for forgings) of Section III of the ASME Code.*

b. *Inservice inspection should be performed for each flywheel as follows:*

- (1) An in-place ultrasonic volumetric examination of the areas of higher stress concentration at the bore and keyway at approximately 3 year intervals during the refueling or maintenance shutdown coinciding with the inservice inspection schedule as required by Section XI of the ASME Code.*
- (2) A surface examination of all exposed surfaces and complete ultrasonic volumetric examination at approximately 10 year intervals, during the plant shutdown coinciding with the inservice inspection schedule as required by Section XI of the ASME Code.*
- (3) Examination procedures should be in accordance with the requirements of Subarticle IWA-2200 of Section XI of the ASME Code.*
- (4) Acceptance criteria should conform to the recommendations of regulatory position C.2.f.*
- (5) If the examination and evaluation indicate an increase in flaw size or growth rate greater than predicted for the service life of the flywheel, the results of the examination and evaluation should be submitted to the staff for evaluation.*

APPENDIX B

HISTORICAL INSPECTION INFORMATION: HADDAM NECK

The following chronological listing shows the results of reactor coolant pump flywheel inspections at the Haddam Neck Plant:

1970 - Prior to the April 1970 refueling outage, Westinghouse and the AEC, became concerned about the possibility of cracks being initiated at or propagating from the interior corners of the keyway areas in RCP flywheels. Ultrasonic examinations were performed during the refueling outage on all four RCP flywheels and revealed a <5% amplitude indication on RCP flywheel #4 in the bore keyway area and it was not recordable. The indication was recorded by Westinghouse personnel purely for future reference purposes.

RCP flywheel #1 was liquid penetrant inspected in the bore area after it had been removed from the shaft and no indications were observed.

Total radiation exposure for these first inspections was 1.038 Person REM and included examination technicians, and engineering and maintenance personnel. This amount of personnel radiation exposure has continued to be expended to complete these inspections when they were required during the last 25 years.

1971 - In April 1971, the Inservice Inspection Program Requirements of ASME Section XI, were put into the Plant Technical Specifications. Requirements were additionally added for RCP flywheels, outside of Section XI Requirements, based on AEC request.

Technical Specification Requirement - One different flywheel shall be examined visually and 100% volumetrically at every other refueling shutdown.

The AEC requested that all four flywheels be examined at the next refueling outage before this inspection sampling program could be put into effect.

During the May 1971 refueling outage, all four flywheels were inspected. The bore seal weld area of RCP flywheel #4 was found to be cracked. The cracks were identified in the bore seal weld and it's associated heat affected zone. Cracked areas were removed by grinding and weld repaired.

Review of the inspection data shows that these cracks may have been identified by the ultrasonic examination indication reported in 1970, but the data is not conclusive. One point that does stand out is that the material of the RCP flywheel #4 is Grade T-1 Boiler Plate and is different than the other three flywheels which were fabricated to a Westinghouse specification.

1973 - During the 1973 refueling outage, the inspection sampling program now required by Plant Technical Specifications began. RCP flywheels #1 and #4 were examined. Both flywheels were removed from their shafts. Cracks were discovered in the RCP flywheel #4 bore seal weld area emanating from the weld repairs and in the existing seal weld areas.

Westinghouse was contacted and recommended that the bore seal weld and associated heat affected zone be removed by grinding. Ultrasonic and liquid penetrant examinations were performed following the grinding repair and no indications were identified. Additionally, liquid penetrant examinations were performed in the bore pawl areas of both RCP flywheels. Liquid penetrant indications were identified in RCP flywheel #1 at two bore pawl areas. These indications were determined to be from mechanical surface marks and were dispositioned as acceptable.

1980 - During this time frame inspections continued under the sampling program provided in Plant Technical Specifications with continuing efforts by CYAPCO to meet a request by the NRC to comply with the inspection requirements specified in Regulatory Guide 1.14. No further flaws/cracks were identified in any of the flywheels. In 1980, one of the flywheels had liquid penetrant indications in the bore keyway areas, but were once again determined to be from mechanical surface marks and dispositioned as acceptable.

1986 - Plant Technical Specifications were changed under Amendment No. 87 to specifically include reference to Regulatory Guide 1.14 inspection requirements.

1987 - During this refueling outage all four of the RCP flywheels were completely removed from the motors and sent to Westinghouse for a 10-year refurbishment. RCP flywheel #1 and #2 were examined to the requirements of Regulatory Guide 1.14 and magnetic particle indications were found in the seal baffle surface fillet weld area of RCP flywheel #2. These indications/flaws/cracks were removed by grinding, weld repaired and reinspected until no indications were found. RCP flywheel #3 was not required to be inspected per Regulatory Guide 1.14 requirements. The RCP flywheel #4 bore seal weld area that had been ground out in 1973 was machined smooth, liquid penetrant inspected, and no indications were observed.

1988 - No cracks have been identified on any of the RCP flywheels in the critical areas of the bore and keyways since 1973.

to
Present

No cracks have exceeded the critical flaw size needed to cause a catastrophic failure of our flywheels in a normal operating overspeed condition.

All of the 1973 RCP flywheel #4 cracks were of a limited depth approximately 1/2" deep and the bore seal weld and heat affected zone is now totally removed.

Note: Additional details are available in Docket No. 50-213, B15320, dated August 10, 1995.

APPENDIX C

SAMPLE FLYWHEEL INSPECTION PROCEDURES

NORTHEAST UTILITIES

NUCLEAR QUALITY-RELATED
NONDESTRUCTIVE EXAMINATION PROCEDURES

NU-UT-24

Ultrasonic Examination
Reactor Coolant Pump Flywheel
Connecticut Yankee

Rev	Issue Date	NUSCO Level III Approval/Date	Director QSD Approval/Date	Auth. Insp. Agency Approval/Date
5	11/29/88	R. J. Fuller-10/12/88	B. Kaufman-10/18/88	R. L. Zoner-10/28/88
6	1-4-91	RJ Fuller 6/4/90	B. Kaufman 6/14/90	Ed Zoner 11/8/90
7	4-20-93	EA Zoner 4/5/93	B. Kaufman 4/12/93	EA Zoner 4.15.93

Always verify with the procedure Status Log before using this procedure.

ULTRASONIC EXAMINATION
REACTOR COOLANT PUMP FLYWHEEL
CONNECTICUT YANKEE

1. SCOPE

1.1 INTENT

This procedure shall be used in conjunction with Procedure NU-UT-1 unless otherwise specified. NU-UT-1 contains all the general requirements applicable to this examination procedure. This procedure contains all the specific application requirements for the examination of areas specified in paragraph 1.2.

1.2 AREAS OF EXAMINATION

This document covers the ultrasonic examination procedure for the bore and keyway areas and the remaining volume of the Connecticut Yankee reactor coolant pump (RCP) flywheels.

1.3 TYPE OF EXAMINATION

1. Volumetric examination shall be performed using ultrasonic pulse echo 0° and 3½° beam technique applied to the gage holes in the flywheel.
2. The examinations shall be performed manually using contact search units.

2. REFERENCES

1. NU-UT-1 Ultrasonic Examination General Requirements.
2. Calibration block CYW-47.
3. Nuclear Regulatory Commission Guide 1.14.
4. ASME Section XI Code - IWA 2240.

△
7

3. PROCEDURE CERTIFICATION

The examination procedure described in this document is in conjunction with Procedure NU-UT-1 and complies with Section XI of the ASME Boiler and Pressure Code, 1983 Edition, Summer of 1983 Addenda, except where examination coverage is limited by part geometry or access.

4. PERSONNEL CERTIFICATION

1. Each person performing ultrasonic examination governed by this procedure shall be certified in accordance with Procedure NU-UT-1.

5. EXAMINATION REQUIREMENTS

5.1 EXAMINATION FREQUENCY

The nominal examination frequency shall be 5 MHz. Other frequencies may be used if such variables as materials, attenuation, grain structure, etc., necessitates their use to achieve penetration or resolution.

5.2 EXAMINATION ANGLES AND COVERAGE

1. The bore and keyways and the remaining accessible volume of the RCP flywheel shall be examined using special design 0° and 34° azimuth probes. Coverage will be limited to those areas of the flywheel that can be scanned from the four gage hole probes in each flywheel.
2. Other angles and techniques may be used if required for aid in evaluating indications.

6. EQUIPMENT REQUIREMENTS

6.1 EXAMINATION EQUIPMENT

The following test equipment or its equivalent shall be provided for examinations specified in this procedure.

1. Special design azimuth probes
2. Couplant

7. EXAMINATION SYSTEM CALIBRATION

7.1 Calibration using the .920" diameter azimuth probe shall be performed as follows:

1. Fully insert the .920" diameter transducer and set the 0° on the azimuth to coincide with the axial centerline and facing the bore of the flywheel calibration block.
2. Inject couplant and establish acoustic contact.
3. Set the amplitude of the reflection from the bore to 100% full screen height.
4. Rotate transducer counterclockwise, CCW, through 90° and locate the 1/4" diameter through drilled hole. Adjust gain if necessary.
5. Using the sweep control, establish a 20" sweep on the display by placing the signal from the sidewall at 5.75" along the time-base. Return to the bore signal and place this at 10" on the timebase.

Through the use of the sweep control and delay control, repeat the above procedure until the display is as described above.

6. Sensitivity: Rotate the transducer to locate the signal from the number one $\frac{1}{4}$ " diameter thru hole, see Figure 1, and adjust signal amplitude from this reflector to 80% FSH. Rotate transducer to locate signal from the number two $\frac{1}{4}$ " diameter thru hole and record % FSH. Draw DAC curve between two points obtained from holes #1 and #2. Rotate transducer to notch in flywheel keyway and record % FSH. If the CRT is saturated, record the dB difference to bring notch signal to 80% FSH. 
7. Attenuation: Locate the signal from the bore of the CYW-47 and adjust the amplitude to 80% FSH and note the gain setting. Locate the signal from the bore of the flywheel and set the signal to 80% FSH and record the gain setting. The difference between the gain setting on the calibration block and flywheel must be added or subtracted to the instrument settings for calibration to account for any attenuation differences between the calibration block and the flywheel. 
8. Repeat the above calibration steps for the .721" diameter and 34° azimuth probe. 
9. Upon completion of the calibration, ensure that all data and instrument settings are recorded on the appropriate calibration data sheet (NU-UT-1, Figure 6).

7.2 CALIBRATION CHECKS

Calibration checks shall be performed in accordance with Procedure NU-UT-1.

8. EXAMINATION PROCEDURES

1. Insert .920" diameter azimuth probe into gage holes on the RCP flywheel and examine bore and keyway to maximum extent possible.
2. Insert .721" diameter azimuth probe into gage holes on the RCP flywheel and examine bore and keyway to the maximum extent possible.
3. Insert the 34° angle beam azimuth probe so that the transducer just clears the threaded portion of the gage hole. Examine the bore and keyway to maximum extent possible.


9. RECORDING CRITERIA

1. All indications with a signal amplitude >100% DAC at reference level shall be recorded and investigated to ensure proper evaluation.
2. The reference point for recording all indications shall be as follows: Looking down at the top surface of the flywheel, locate all indications clockwise, CW, from the gage hole in line with the largest keyway in the flywheel. All radial and angular measurements to recordable indications shall be taken from the exit point of the

probe. A sketch of all recordable indications shall be attached to the RCP flywheel data sheet.

FIGURE 1

CALIBRATION BLOCK
CYW-47



REVISION/CHANGE ATTACHMENT SHEET

<u>Revision</u>	<u>Section</u>	<u>Change</u>
5	All	Major Rewrite
6	All	Major Rewrite
7	Para. 2.2	Change Blocks to Read "Block"
	Para. 7.1.6	Correct Typo
	Para. 7.1.7	Reword 1st Sentence
	Para. 7.1.8	Change 7.6.1 to Read "7.2.1"

SOUTHERN NUCLEAR OPERATING COMPANY

INSPECTION AND TESTING SERVICES

MANUAL ULTRASONIC EXAMINATION OF
REACTOR COOLANT PUMP MOTOR FLYWHEELS

UT-V-417

REVISION 3

Terry Styers
PREPARED BY

William A. Mays
SUPERVISOR, NDE PROJECTS APPROVAL

John C. ...
NDE LEVEL III APPROVAL

James H. ...
MANAGER ITS APPROVAL

W. H. ...
PLANT VOGTLE APPROVAL

1/11/75
DATE

TABLE OF CONTENTS

<u>SECTION</u>	<u>TITLE</u>	<u>PAGE</u>
1.0	Purpose	1
2.0	Scope	1
3.0	Applicable Documents	1
4.0	Responsibilities	1
5.0	Qualification of Ultrasonic Examination Personnel	2
6.0	Ultrasonic Equipment	2
7.0	Surface Preparation	3
8.0	Equipment Calibration	3
9.0	Examination Procedure	5
10.0	Investigation of Indications	6
11.0	Recording of Indications	6
12.0	Reporting of Indications	7

.0 PURPOSE

This procedure provides the ultrasonic examination requirements for reactor coolant pump flywheel in accordance with the applicable American Society of Mechanical Engineers (ASME) Boiler and Pressure Vessel Code.

2.0 SCOPE

This procedure defines the method for ultrasonic examination reactor coolant pump flywheel to facilitate preservice and inservice inspection all high-stress regions (bore, keyways and bolt hole regions) with or without the removal of the flywheel from its shaft.

Note: Applications in this procedure are not covered in Section XI and are based on special techniques as allowed in IWA-2240.

3.0 APPLICABLE DOCUMENTS

This procedure is written to comply with the requirements of the following documents to the extent specified within this procedure.

- 3.1 ASME Boiler and Pressure Vessel Code, Section XI, 1983 Edition with Addenda through Summer 1983, "Rules for Inservice Inspection of Nuclear Power Plant Components."
- 3.2 ASME Boiler and Pressure Vessel Code, Section V, 1983 Edition with Addenda through Summer 1983, "Nondestructive Examination."
- 3.3 U. S. Nuclear Regulatory Commission Regulatory Guide 1.14 "Reactor Coolant Pump Flywheel Integrity" Revision 1 dated August 1975.

4.0 RESPONSIBILITIES

- 4.1 The Manager- Inspection and Testing Services shall be responsible for the approval and control of this procedure.
- 4.2 An ITS NDE Level III individual certified in ultrasonic examination is responsible for having ultrasonic procedures and techniques developed, approved, and for assuring that this procedure, when correctly followed, will detect discontinuities which do not meet the applicable acceptance standards.

5.0 QUALIFICATION OF ULTRASONIC EXAMINATION PERSONNEL

- 5.1 All personnel performing ultrasonic examinations in accordance with this procedure shall be qualified and certified to the requirements of a procedure (written practice) written and approved by ITS in accordance with the "American Society of Nondestructive Testing" (ASME) SNT-TC-1A.
- 5.2 The ultrasonic examination may be performed by a Level I Examiner under the direct supervision of a certified Level II or Level III individual in ultrasonic examination; however, all interpretation of the results shall be performed by a Level II or Level III examiner certified in ultrasonic examination.

6.0 ULTRASONIC EQUIPMENT

6.1 The Ultrasonic Instrument

- 6.1.1 A pulse-echo type ultrasonic instrument with an A-Scan presentation and operating frequencies of one to ten MHz shall be used to perform examination in accordance with this procedure.

6.2 The Ultrasonic Transducer Search Unit

- 6.2.1 Search units with a nominal frequency of 2.25 MHz shall be used for examination in accordance with this procedure.
- 6.2.2 Search unit size for the "periphery" scan shall be .750" to 1.00" diameter straight beam.
- 6.2.3 Search unit size and configuration for "radial gauge hole" and "keyway corner" examination will be a special design internal probe from the gauge hole.
- 6.2.4 Upon ITS NDE Level III concurrence, other frequencies and sizes of search units may be used if product grain structure precludes achieving the necessary penetration or sensitivity required.

6.3 Couplant

Any commercially available ultrasonic couplant may be used and shall be certified for total sulfur and halogen content in accordance with the American Society for Testing and Materials ASTM D-129 and D0808. The total residual amount of sulfur and halogen shall not exceed one percent by weight.

6.4 Reference Block

Reference blocks (e.g., IIW, ROMPAS, DSC) if used, shall be of the same material as the component to be examined.

6.5 Calibration Block

The flywheel to be examined shall be used for calibration.

6.6 CABLES

Coaxial type cables shall be used and may be of any convenient length not to exceed 50 feet (unless permitted by qualification). The type and length shall be recorded on the Reactor Coolant Pump Flywheel Report, (Figure 417-1), or equivalent form.

7.0 SURFACE PREPARATION

The finished contact surface shall be free from any roughness that would interfere with free movement of the search unit. This examination and calibration may be performed through tightly adhered paint.

8.0 EQUIPMENT CALIBRATION

8.1 A daily linearity, as a minimum, shall be performed to verify the instrument to linearity requirements of Procedure UT-V-455.

8.2 The reject control shall be placed and remain in the "0" (off or minimum) position during calibration and examination.

8.3 Temperature of the flywheel shall be recorded on the Data Report.

8.4 The equipment calibration shall be performed in accordance with the following and the results documented on the Reactor Coolant Pump Flywheel Report, (Figure 417-1), or equivalent form.

8.4.1 Keyway Corner Examination

8.4.1.1 Reflections from the bore of the flywheel shall be used for calibration.

8.4.1.2 From the gauge hole, obtain the maximum reflection from the bore of the flywheel using the special gauge hole probe.

- 8.4.1.3 Establish a horizontal screen range by setting the response from the flywheel bore at a maximum of 60 percent of the instruments screen range.
- 8.4.1.4 Bring the bore reflection to 80% FSH. This shall be the primary reference level.

8.4.2 Radial Gauge Hole Examinations

- 8.4.2.1 Reflections from any two holes shall be used for calibration. The hole selected for the longest metal path shall be a maximum of 25 inches.
- 8.4.2.2 From the hole, obtain the maximum response from the nearer of the two holes. Set this response at 80% FSH.
- 8.4.2.3 Without changing the gain setting, obtain the maximum response from the remaining hole.
- 8.4.2.4 Mark these amplitudes on the CRT. Connect the two points with a smooth line. Extend the DAC to cover the maximum calibrated screen width. This shall be the primary reference level.

8.4.3 Periphery Examination

- 8.4.3.1 From the edge of the flywheel, obtain the maximum response from any two holes with a minimum of 10 inches metal path separation.
- 8.4.3.2 Establish the horizontal screen range to coincide with the hole location from the edge of the plate. The response obtained from the hole with the greatest metal path shall be set between 50-80 percent of screen range.
- 8.4.3.3 Construct a DAC curve by setting the maximum response from the hole with the shortest metal path at 80% FSH.
- 8.4.3.4 Without changing the gain setting, obtain the maximum response from the hole with the greatest metal path. Mark these points on the CRT and connect them with a smooth line to cover the examination area. This shall be the primary reference level.

8.5 Calibration Checks

- 8.5.1 A calibration check shall be performed at the beginning and end of each examination or every 12 hours, whichever is less.
- 8.5.2 If, in the opinion of the examiner, the validity of the calibration is in doubt, a calibration check shall be performed.
- 8.5.3 If any point of the calibration check has moved on the sweep line by more than 10 percent of the sweep division reading, correct the sweep range calibration and note the correction on the applicable calibration sheet. If recordable indications are noted, the examination is voided, and a new calibration Section 8.0) shall be recorded and the voided examination shall be reexamined.
- 8.5.4 If any point of the calibration check has decreased 20 percent or 2 dB of its amplitude, all data and/or calibration sheets since the last calibration or calibration check shall be recorded and the voided examinations shall be reexamined.
- 8.5.5 If any points of the calibration check was increased more than 20 percent or 2 dB of its amplitude, all recorded indications since the last valid calibration or calibration check may be reexamined with the corrected calibration and their value shall be recorded on the applicable calibration and data sheet.

9.0 EXAMINATION PROCEDURE

9.1 Keyway Corner Examination

- 9.1.1 Scanning of the keyway corners shall be accomplished starting at the top of the gauge hole and rolling the sound beam from the bore over to examine the keyway and back. Insert the probe with a minimum of 25% overlap and repeat until the entire length of the keyway has been examined.
- 9.1.2 Each gauge hole shall be used to examine the keyway corners for indications propagating from the keyway.

9.2 Radial Gauge Hole Examination

- 9.2.1 Scanning shall be accomplished by inserting and retracting the probe the full length of the gauge hole and overlapping a minimum of 25% for each insertion.

- 9.2.2 Each gauge hole shall be used to scan the complete available portion of the flywheel cross-section.

9.3 Periphery Examination

- 9.3.1 Scanning from the edge shall include the area from the edge up to and including the gauge holes.

- 9.3.2 The transducer shall be moved across and along the flywheel edge so as to scan the entire edge overlapping each scan by a minimum of 25% of the transducer diameter.

- 9.4 Scanning speed shall not exceed six inches/second.

- 9.5 Scanning shall be performed at a minimum gain setting of two times the primary reference level sensitivity (6 dB).

NOTE:

If conditions such as material properties produce noise levels which preclude a meaningful examination, then scanning shall be performed at the highest possible sensitivity level above the primary reference level. The examiner shall note the dB and the reason on the applicable data sheet and notify the site NDE coordinator to proceed per the applicable ITS PM Procedure 2-1.

- 9.6 Upon completion of the ultrasonic examination, the couplant shall be removed from the area of examination to the extent practical.

10.0 INVESTIGATION OF INDICATIONS

- 10.1 All indications shall be investigated to the extent that the examiner can determine the size, identify and location of the reflectors.
- 10.2 Previous data, when applicable, shall be made available to the technicians to provide previous examination information.

11.0 RECORDING OF INDICATIONS

- 11.1 For the keyway corner examination, all indication which exceed 10% of the primary reference level shall be recorded.
- 11.2 For the radial gauge hole or periphery examinations, all indications which exceed 50% DAC shall be recorded.

NOTE:

Geometric reflectors in the flywheel shall be verified by physical measurements and need not be recorded.

12.0 REPORTING INDICATIONS

- 12.1 It shall be the responsibility of the Level II or level III individual certified in ultrasonic examination re review, evaluate the disposition all recordable indications to determine their reportability requirements. Previous data shall be made available to the reviewer/evaluator for appropriate indication disposition.
- 12.2 Reportable indications or other indications determined to be significant by the ITS Level II or level III individual shall be reported to the operating company in accordance with ITS PM Procedure 3-4.

VOGTLE ELECTRIC GENERATING PLANT Southern Nuclear Operating Company
Reactor Coolant Pump Flywheel Report UT-V-Form 015

Plant/Unit:	RCP Flywheel No:
-------------	------------------

Isometric Drawing No:	Procedure/Revision/Deviation:
-----------------------	-------------------------------

Couplant Batch No:	Sheet No:
--------------------	-----------

Transducer	Periphery Exam	Gauge Hole & Keyway Exam
Serial No: _____	_____	_____
Size: _____	_____	_____
Frequency: _____	_____	_____

Equipment		
Instrument: _____	Frequency: _____	Damping: _____
Serial No: _____	Rep. Rate: _____	Reject: _____
Cable Type: _____	Cable Length: _____	

Calibration/Examination			
Keyway Corner	Screen Range: _____	%	FSH
	dB: _____		
	Screen Div: _____	NI	NRI RI
Bolt Hole Region	Screen Range: _____		
	dB: _____		
	Screen Div: _____	NI	NRI RI
Periphery	Screen Range: _____		
	dB: _____		
	Screen Div: _____	NI	NRI RI


Remarks: _____ _____

Examiner/SNT Level:	Examiner/SNT Level:
---------------------	---------------------

Technical Review:	Non Technical Review:
-------------------	-----------------------

Figure 417-1

Vogtle Reactor Coolant
Pump Flywheel



- 3/4" x 3-3/4"
- 1-3/8" x 5"
- 1-1/2" x 3-3/4"
- 1" x 10"
- 2" x 1-7/8"
- 3" x 10"

Figure 417-2

Title

Revision No.

ULTRASONIC EXAMINATION OF REACTOR COOLANT PUMP FLYWHEELS

0

Applicability/Scope

Responsible Office

This procedure is applicable at any site

5361

This document is within QA Plan Scope ☒ Yes ☐ No

Effective Date


Safety Reviews Required ☒ Yes ☐ No

08-15-95

List of Effective Pages

Page	Revision	Page	Revision
1.0	0	E1-1	0
2.0	0	E2-1	0
3.0	0	E3-1	0
4.0	0	E4-1	0
5.0	0	E5-1	0
6.0	0	E6-1	0
7.0	0	E7-1	0
8.0	0		
9.0	0		
10.0	0		
11.0	0		
12.0	0		
13.0	0		

TMI-1



This procedure replaces 6100-QAP-7209.24.

	Signature	Concurring Organizational Element	Date
Originator	<i>Michael J. Lee</i>	NDE/ISI Specialist	7-25-95
Concurred By	<i>[Signature]</i>	Level III	7-28-95
Approved By	<i>[Signature]</i>	Chemistry/Materials Director	8/18/95

GPU NUCLEAR
ISI/NDE MANUAL

Number

5361-NDE-7209.24

Title

Revision No.

Ultrasonic Examination of Reactor Coolant Pump Flywheels

0

DOCUMENT HISTORYRevisionSummary of ChangeDate

0

Original Revision. This procedure replaces 6100-QAP-7209.24.

08-15-95

TABLE OF CONTENTS

Cover Page	1.0
Document History	2.0
Table of Contents	3.0
1.0 <u>PURPOSE</u>	4.0
2.0 <u>APPLICABILITY/SCOPE</u>	4.0
3.0 <u>DEFINITIONS</u>	4.0
4.0 <u>PROCEDURE</u>	4.0
4.1 Personnel Certification/Qualification	4.0
4.2 Material/Equipment	4.0
4.3 Prerequisites	6.0
4.4 Calibration	6.0
4.5 Examination	9.0
4.6 Reporting	11.0
4.7 QA Records	11.0
5.0 <u>RESPONSIBILITIES</u>	12.0
6.0 <u>REFERENCES</u>	12.0
7.0 <u>EXHIBITS</u>	13.0



**GPU NUCLEAR
ISI/NDE MANUAL**

Number

5361-NDE-7209.24

Title

Revision No.

Ultrasonic Examination of Reactor Coolant Pump Flywheels

0

1.0 PURPOSE

- 1.1 The purpose of this procedure is to describe the techniques for manual ultrasonic examination of TMI-1 Reactor Coolant pump motor assembly flywheels.

2.0 APPLICABILITY/SCOPE

- 2.1 This procedure is applicable to all certified GPUN and contractor personnel assigned by GPUN to perform manual ultrasonic examination of reactor coolant pump flywheels.
- 2.2 The requirements of this procedure delineate the manual ultrasonic techniques to detect, locate and dimension indications in the reactor coolant pump motor assembly flywheels in accordance with Reference 6.2

3.0 DEFINITIONS

- 3.1 None.

4.0 PROCEDURE

4.1 Personnel Qualification and Certification

- 4.1.1 GPUN personnel performing examinations to this procedure shall be certified in accordance with Reference 6.3.
- 4.1.2 Contractor personnel performing examinations to this procedure shall be qualified and certified in accordance with the Contractor's written practice which has been approved by GPUN or they may be certified in accordance with Reference 6.3.
- 4.1.3 At least one member of the examination crew shall be certified Level II UT inspector or higher.
- 4.1.4 The examination crew should demonstrate practical proficiency in applying the technical requirements of this standard to a GPUN UT Level III.

4.2 Material/Equipment

4.2.1 Flaw detector

- 4.2.1.1 A pulse echo ultrasonic flaw detection instrument capable of generating frequencies from 1.0 to 5.0 MHZ shall be utilized. The instrument shall contain a stepped gain control, calibrated in units of 2db or less, and shall be accurate over its useful range to $\pm 0\%$ of the nominal amplitude ratio which will allow comparison of indications beyond the viewable portion of the CRT.

4.2.2 Search units

- 4.2.2.1 Angle beam and straight beam search units shall be single element with a nominal frequency of 2.25 MHZ. Other frequencies may be

used to overcome variables caused by material properties and for purposes of evaluation of indications. Use of other frequencies shall be approved by a GPUN UT Level III and recorded on Exhibit 1.

- 4.2.2.2 Examinations shall be performed utilizing a 45° beam angle for flywheels #1 and #4 from the top and bottom surfaces respectively.

4.2.3 Angle beam exit point/angle verification

- 4.2.3.1 Prior to performance of examinations the exit point of the search unit wedge (angle beam) shall be verified utilizing a standard IIW block or mini-IIW block. This verification shall be performed daily prior to any examinations being performed.

- 4.2.3.2 Prior to performance of examinations, the actual beam angle shall be determined utilizing a carbon steel IIW block or mini-IIW block. This shall be done to verify that the beam angle is within the required range of $\pm 2^\circ$ of the nominal angle of the search unit wedge. This verification shall be performed daily prior to any examinations being performed. The actual angle and nominal angle of the search unit wedge shall be recorded on Exhibit 1.

4.2.4 Coaxial cables

- 4.2.4.1 Coaxial cable assembly shall be of any convenient length not to exceed 50 feet.

4.2.5 Couplant

- 4.2.5.1 Any GPUN approved couplant, such as Ultragel II, which provides intimate contact required for the transmission of high frequency ultrasound shall be acceptable for use. Use of couplant shall be as required by reference 6.8.

- 4.2.5.2 The minimum amount of couplant should be utilized to prevent damage to the motor windings.

- 4.2.5.3 Couplant shall be removed from the flywheels after completion of the examinations.

4.2.6 Calibration standard

- 4.2.6.1 The pump motor assembly flywheels have calibration holes as shown in Exhibits 3 and 4. These holes may be utilized for the initial calibration if directed by a GPUN UT Level III. Flywheel Calibration Standards TMI 370 (Flywheel #1) and TMI 371 (Flywheel #4) shall be used to establish the sweep range of the instrument and DAC curve. To establish the primary sensitivity level for examination, the transfer method, which is outlined in paragraph 4.4.3.6, shall be performed when using calibration standards.

4.3 Prerequisites

4.3.1 Surface preparation

- 4.3.1.1 Surfaces to be examined shall be clean and free of foreign material which could interfere with the performance of the examination or conduction of sound energy into the part.

NOTE

Precautions shall be taken to prevent loose parts from falling into motor flywheel assemblies whenever access is gained to the flywheels.

4.3.2 Examination records

- 4.3.2.1 Baseline and subsequent examination records should be available for review.

4.3.3 Maintenance and Operation Preparation

- 4.3.3.1 Operation of the flywheel motor lift pumps shall be coordinated with the control room. The motor lift pumps must be energized before the flywheels can be rotated.
- 4.3.3.2 The oil drip pan should be removed for access to the lower flywheel.

4.4 Calibration

4.4.1 Instrument calibration

- 4.4.1.1 Instrument calibration for screen height, horizontal and amplitude control linearity shall be in accordance with References 6.4.
- 4.4.1.2 For instruments and search units, maintenance, calibration and performance characteristics shall be as required by reference 6.9.

4.4.2 System calibration

- 4.4.2.1 Calibration shall include the complete ultrasonic examination system. Any change in search units, shoes, couplants, cables, ultrasonic instruments, recording devices or any part of the examination system shall be cause for a calibration check. The calibration shall be performed on flywheel calibration standards and the transfer method identified in paragraph 4.4.3.6 shall be performed.
- 4.4.2.2 The maximum reflector response, during calibration, shall be obtained with the sound beam oriented essentially perpendicular to the axis of the calibration reflector. The centerline of the search unit

shall be a minimum of 3/4" from the nearest edge of the calibration standard. Rotation of the sound beam into a corner formed by the reflector and the side of the block may produce a higher amplitude signal at a longer beam path; this beam path shall not be used for calibration.

4.4.2.3 The temperature difference between component to be examined and the basic calibration block shall not exceed 25°F.

4.4.2.4 The transfer method as described elsewhere in this procedure may be omitted by a GPUN Level III if there is reason to question the reliability of the results or if unobtainable.

4.4.3 45° angle beam calibration

4.4.3.1 Calibration shall be performed on Calibration Standard TMI-370 for flywheel #1 and TMI-371 for flywheel #4. Side drilled holes (SDH) are present in each flywheel as identified in Exhibits 3 and 4, however, only the 1/2T SDHs shall be utilized for the transfer method.

NOTE

Calibration may be performed directly on the flywheel but only as directed by a GPUN UT Level III.

4.4.3.2 To determine the 45° angle beam sweep calibration on flywheel #1, utilize Calibration Standard TMI-370 and place the bottom notch at the 4.2 screen position and the top notch at 8.4. The instrument sweep is now calibrated to represent 10" of metal path.

4.4.3.3 On Calibration Standard TMI-370 for Flywheel #1, establish a DAC curve by adjusting the gain to set the bottom notch signal at 80% $\pm$ % FSH at screen position 4.2. Without changing gain, peak the top notch signal at screen position 8.4 and mark the location on the screen. Plot a DAC curve by connecting the peak signal locations (marked on the CRT screen) with a straight line and extrapolate through the full examination range. Note the gain setting (db) on Exhibit 1.

4.4.3.4 On Calibration Standard TMI-370, locate the 1/2T SDH and establish a signal between 50% and 80% FSH and note the signal height and gain setting (db) on Exhibit 1.

4.4.3.5 On flywheel #1, locate the 1/2T SDH by scanning adjacent to the edge of the flywheel (i.e. 1 to 3 inches) as the flywheel is being slowly rotated or by visually locating the holes between the flywheel face and the motor housing or both.

- 4.4.3.6 The transfer method shall be used to note the difference in gain (db) between the response received from the 1/2T signal in the calibration standard and the 1/2T signal in the flywheel and add or subtract the difference to the reference level established by the bottom notch. This level shall be primary reference level and the difference shall be noted on Exhibit 1.

NOTE

Other transfer methods may be utilized such as the two search unit techniques with the sound opposing each other, but only as directed and approved by GPUN UT Level III.

- 4.4.3.7 To determine the 45° angle beam sweep calibration on Flywheel #4, utilize Calibration Standard TMI-371 and place the 1/2T signal at screen division 3, the 3/4T at 4.5 the bottom notch at 6 and the 1 1/4T at 7.5. The instrument sweep is now calibrated to represent 20" of metal path.
- 4.4.3.8 On Calibration Standard TMI-371 for flywheel #4, establish a DAC curve by adjusting the gain to set the 1/2T signal at 80% $\pm$ 5% FSH at screen position 3 and mark its position on the CRT. Maximize the response from the 3/4T and 1 1/4T SDHs and mark their positions on the CRT. Note the gain setting (db) on Exhibit 1, since this reference level will be utilized for the transfer method on the flywheel. Connect the marks with a straight line and extrapolate through the thickness being examined.
- 4.4.3.9 Locate the bottom notch signal on Calibration Standard TMI-371 at screen division 6. Increase or decrease the gain to set the peak of this signal to the DAC curve line. Note this gain setting (db) on Exhibit 1.
- 4.4.3.10 On flywheel #4, locate the 1/2T SDH as identified in paragraph 4.4.3.5 for flywheel #1. With the gain setting and signal height from the 1/2T SDH in paragraph 4.4.3.8, utilize the transfer method as outlined in paragraph 4.4.3.6 to determine the db difference between the 1/2T SDH in flywheel #4 and the 1/2T SDH response on Calibration Standard TMI-371.
- 4.4.3.11 Add or subtract the db difference established in paragraph 4.4.3.10 to the gain setting established in paragraph 4.4.3.9. This gain setting shall be primary reference level.

GPU Nuclear**GPU NUCLEAR
ISI/NDE MANUAL**

Number

5361-NDE-7209.24

Title

Revision No.

Ultrasonic Examination of Reactor Coolant Pump Flywheels

0

4.4.4 System calibration confirmation**4.4.4.1 The sweep range and primary DAC curve shall be checked and verified:**

- At the beginning of each day of examination.
- At least every four (4) hours during performance of examinations.
- If any component of the test system is changed (i.e., instrument, transducer, coaxial cable, etc.).
- After any change in personnel.
- At the completion of the examination to which the calibration applies.
- If the operator suspects any malfunction of the UT system.
- In the event of a power loss.

4.4.5 Calibration changes

- 4.4.5.1** If any point on the DAC curve has decreased 20% of its amplitude, all data sheets since the last calibration check shall be marked void. A new calibration shall be performed and recorded and the voided examination area(s) shall be re-examined.
- 4.4.5.2** If any point on the DAC curve has increased more than 20% of its amplitude, recordable indications taken since the last valid calibration or calibration check may be re-examined with the current calibration and their values changed on the data sheets.
- 4.4.5.3** If any point on the DAC curve has moved on the sweep line more than 10% of the sweep division reading, correct the sweep range calibration and note the correction on the appropriate data sheets. If recordable indications are noted on the data sheets, those data sheets shall be voided and a new calibration shall be recorded and the examination areas shall be re-examined.

4.5 Examination procedures**4.5.1 Examination of base material for laminar type reflectors.**

- 4.5.1.1** Base material adjacent to the inner bore region on flywheels #1 and #4 and the bolt holes on flywheel #1 shall be scanned with a longitudinal (0 degree) search unit to detect discontinuities which may interfere with the transmission of shear waves during angle beam examination. (See Exhibit 7)

NOTE

The requirements of paragraph 4.5.1.1 apply only when there is a reason to question sound penetration such as excessive loss of back reflection or existence of abnormal geometric reflectors which dampen.

4.5.2 General requirements

- 4.5.2.1 All angle beam examinations shall be performed at a scanning sensitivity level at 2x (+6 db) greater than the calibrated reference sensitivity level.
- 4.5.2.2 Scan speeds shall not exceed six (6) inches per second. Scan the exposed areas within each access port prior to moving the flywheel to the next adjacent area for each system calibration.
- 4.5.2.3 All angle beam examinations shall be performed in two directions (i.e. beam directed essentially clockwise and counter clockwise around the flywheel bore regions and bolt holes as depicted on Exhibits 5 and 6).
- 4.5.2.4 Beam angles other than 45° may be utilized as directed and approved by a GPUN UT Level III.

4.5.3 45° Angle Beam Examination

- 4.5.3.1 On flywheel #1, the top surface is accessible through access ports 1 through 3. The area of interest for the top flywheel is the inside bore region which includes the keyway and all accessible areas surrounding the four (4) bolt holes (Reference Exhibits 5 and 6).
- 4.5.3.2 On flywheel #4, the bottom surface is accessible through one access port. The area of interest for the bottom flywheel is the inside bore region which includes the keyway.
- 4.5.3.3 For both Flywheels #1 and #4, the examination requirements for the inside bore region and keyway are identified on Exhibit 5. Exhibit 6 delineates the requirements on flywheel #1 for examination of the areas surrounding each bolt hole.
- 4.5.3.4 For the inside bore region, Keyway and the areas surrounding the bolt holes, scanning shall be performed on a tangential line or on a line perpendicular to the flywheel and bolt hole radii. The scan width (w) shall be as identified in Exhibits 5 and 6. The minimum overlap of the search unit shall be 25% of the search unit width. The search unit shall be oscillated a minimum of 15° in each direction for each parallel path.

Title

Revision No.

Ultrasonic Examination of Reactor Coolant Pump Flywheels

0

NOTE

Due to access restrictions and surface area limitations, the scanning distances and patterns will be a best effort activity. Limitations and restrictions shall be documented on the UT Examination Data Sheet, Exhibit 2, or a Limited Examination Sheet.

- 4.5.3.5 45° angle beam examination of flywheels #2 and #3 is not possible unless the flywheels are disassembled.
- 4.5.4 Evaluation/Interpretation
- 4.5.4.1 Indications showing a signal amplitude response equal to or greater than 20% of the reference response shall be investigated to determine their origin (geometric or non-geometric). If an indication is determined geometric, it need not be recorded.
- 4.5.4.2 Evaluation of indications shall be made at the reference sensitivity level and in accordance with the requirements of the Reference 6.6.
- 4.5.4.3 Non-geometric indications showing a signal amplitude response equal to or greater than 50% of the reference sensitivity level shall be recorded on the data sheet.
- 4.5.4.4 Each recorded indication shall be identified on the data sheet as to depth, length, signal amplitude and location.
- 4.5.4.5 In order to determine depth and length of a flaw, flaw sizing techniques, as delineated in Reference 6.7, may be required.
- 4.5.4.6 Calibration and examination results shall be documented on the applicable data sheets Exhibits 1 and 2.
- 4.6 Reporting
- 4.6.1 The distribution of NDE/ISI data shall be performed in accordance with Reference 6.5.
- 4.7 QA Records
- 4.7.1 All calibration and examination results shall be recorded on Exhibits 1 and 2, as applicable, and are considered permanent QA Records.
- 4.7.2 All forms must be totally filled out as applicable, then signed and dated for the day the examination was performed. There shall be no blank spaces on any form after completion. If there is no information available for a particular space, the space shall be filled in with "N/A".

4.7.3 Errors on data forms shall not be covered or eradicated with white-out (liquid paper). Any error which may occur shall be crossed out with a line, initialed and dated by the person making the change. All forms shall be filled out with black ink.

4.7.4 Record retention and transmittal shall be in accordance with Reference 6.5.

5.0 RESPONSIBILITIES

5.1 Responsibilities are as defined earlier in this procedure.

6.0 REFERENCES

- 6.1 ASME Boiler and Pressure Vessel Code, Section V, Non-destructive Examination, Article 5, 1986 Edition, No addenda
- 6.2 TMI-1 Technical Specifications Section 4.2.4
- 6.3 GPUN Procedure 5361-ADM-7230.01, Qualification and Certification of NDE Examination Personnel
- 6.4 GPUN Procedure 5361-NDE-7209.17, Ultrasonic Instrument Linearity
- 6.5 GPUN Procedure 5361-ADM-3272.03, Control and Processing of NDE Data
- 6.6 GPUN Procedure 5361-SPC-7230.26, Evaluation of Recordable Indications
- 6.7 GPUN Procedure 5361-NDE-7209.10, Ultrasonic Sizing of Planar Flaws
- 6.8 TMI Administrative Procedure 1104-28Q, Mixed Low Level Radioactive Waste Control Program
- 6.9 GPUN Procedure 5361-NDE-7209.18, Calibration and Maintenance of Nondestructive Examination Equipment
- 6.10 TMI Administrative Procedure 1068 - Controlled Consumable Materials

GPU NUCLEAR
ISI/NDE MANUAL

Number

5361-NDE-7209.24

Title

Revision No.

Ultrasonic Examination of Reactor Coolant Pump Flywheels

0

7.0 EXHIBITS

- 7.1 Exhibit 1 - UT Calibration Data Sheet (Typical).
- 7.2 Exhibit 2 - UT Examination Data Sheet (Typical).
- 7.3 Exhibit 3 - Configuration of Flywheel #1.
- 7.4 Exhibit 4 - Configuration of Flywheel #4.
- 7.5 Exhibit 5 - Scanning Requirements for flywheel #1 and 4 inside bore region and keyway
- 7.6 Exhibit 6 - Scanning Requirements for flywheel #1 bolt hole region
- 7.7 Exhibit 7 - Straight beam scan requirements for laminar reflectors

EXHIBIT 1

UT CALIBRATION DATA SHEET -TYPICAL-

Components Examined:				Procedure:				Rev	
Examiner Signature		Print:		Initial:		SSN:		Level	
Examiner Signature		Print:		Initial:		SSN:		Level	
Instrument Make		Model		DAC Plot		Search Unit Cable			
Instrument ID Number						Type _____ Length _____			
Pulse		Gain				No. of Inter. Connectors _____			
Pulse Duration _____		Coarse _____				Compair			
Damping ☐ Off ☐ On		Fine _____				Make _____ Batch # _____			
☐ Pulse Echo ☐ Dual		Uncal _____ %				Thermometer			
Repetition Rate _____		Receiver				SN: _____ Cal Due _____			
Voltage _____		Frequency _____				Cal Standard		Cal Direction	
Setup Circuit		Reject ☐ Off ☐ On _____ %				ID# _____		☐ Axial ☐ Bore	
Coarse		Display				Size _____ Sch _____		☐ Circ. ☐ Normal	
Range		☐ Fullwave ☐ RF				Thickness _____		System Check	
Delay		☐ Half (+) ☐ Half (-)				S/S CS _____		☐ Exit Point	
Velocity		☐ Filter 1 2 3 4 5				Temp _____ °F		☐ Angle +/- 2	
Screen Depth _____ in.		☐ Other _____				Search Unit			
Other Instrument Settings		Date / Hours				I.D. # _____			
Setting		Value				Type _____ Size _____			
		Reflector				Freq _____ MHz			
		% FSH				Angle _____ Mode _____			
		Inches				ANN Review			
		% FSH							
		Inches							
		% FSH							
		Inches							
		Initials							
		Remarks:				Technical Review			
						Reviewed By _____			
						Level _____ Date _____			



GPU NUCLEAR IS/INDE MANUAL

Number

5361-NDE-7209.24

Title

Revision No.


Ultrasonic Examination of Reactor Coolant Pump Flywheels

0

EXHIBIT 2

UT EXAMINATION DATA SHEET
-TYPICAL-

[illegible]

EXHIBIT 5**SCANNING REQUIREMENTS FOR FLYWHEEL #1 AND #4
INSIDE BORE REGION AND KEYWAY**

<u>Inner bore and Keyway</u>	<u>Foreward/Backward Scan Distance</u>	<u>Scan Width(V)</u>	<u>Scan Direction</u>
(1) Flywheel #1	3.5" (1/2V) to 7" (full 'V')	1"	360° CW & CCW
(2) Flywheel #4	0" (Surface) to 8.4" (1/2V)	1"	360° CW & CCW

EXHIBIT 7**STRAIGHT BEAM SCAN REQUIREMENTS FOR LAMINAR REFLECTORS**

Straight Beam for Laminar Reflectors (all procedure requirements apply except when superseded by this exhibit).

1.0 CALIBRATION

- 1.1 Calibrate the screen range on the calibration standard or other similar metal standard.
- 1.2 Select a direct rear screen range which will produce a back reflection of greater than 40% but less than 100% full screen sweep from the maximum anticipated examination thickness.
- 1.3 Couple the search unit to the calibration standard and calibrate the screen range by use of the sweep and delay controls.
- 1.4 Couple the search unit to the part being examined and adjust the initial back reflection to 80% FSH. Adjustment of the gain control is permitted during examination in order to maintain the back reflection response.

2.0 RECORDING

- 2.1 Record all areas giving indications equal to or greater than the remaining back reflection.
- 2.2 Recording of straight beam laminar type reflectors requires recording the locations of all four sides of a rectangle which would contain the indication extremities at the required recording level.
- 2.3 Record all laminar indications which produce a response equal to or greater than the remaining back reflection. These dimensions and locations will be used to determine areas of interference with the angle beam examination.
- 2.4 Record all laminar indications where a continuous loss of back reflection exists along with a continuous indication in the same plane. These dimensions and locations will be used to determine acceptability of the component for continued service.

3.0 SCAN SENSITIVITY

- 3.1 Adjustment to the scan sensitivity may be necessary and shall be considered when recordable laminar reflectors are noted in order to maintain an acceptable back reflection.

APPENDIX D

SAMPLE FLYWHEEL MATERIAL TEST CERTIFICATES

NON-DESTRUCTIVE TEST REPORT
QUALITY CONTROL
 WESTINGHOUSE FORM 38196

FILE: SHOP ORDER 81 P352-#2
 TEST: ULTRASONIC ZYGLO DYE PENETRANT MAGNAFLUX HARDNESS

 C.C.: Miss Jackson 584 C.C.: ME 2 INSP.

 C.C.: Mr. Carlson 66 C.C.:

PURCHASE ORDER NO. 10 FV 46 409 10 PV 47470	SUPPLIER L. KENS	SECTION ME 2	DRAWING NO. 6550 DFT	HEAT NO. C9474 C9446	FORGING NO. 3 21
---	---------------------	-----------------	-------------------------	----------------------------	------------------------

MATERIAL

FLY WHEEL ASSY.

 RESULTS of dye check of 9.438 dia bore & 18" dia face shows
 no indications E.G. Patrick 2-23-72
 9.375 bore & 18" dia face shows no indications E.G.P. 2-28-72

DA NO.

REPORTED BY

E.G. Patrick

DATE

2-28-72

NON-DESTRUCTIVE TESTING REPORT

[illegible]

U.T. OK per. YPEC.

W. Paul

0356

PURCHASER:

Westinghouse Elec. Corp.
3 LRA Purch. Dept.
Mr. O. E. Stepp
E. Pittsburgh, Pa. 15112

LUKENS STEEL COMPANY

COALSVILLE, PA. 15120

TEST CERTIFICATE

DATE 12-31-71 FILE NO. 8587-07-14

CONTRACT NO.

J.O. U33C TVA

BILL ORDER NO.

CUSTOMER P.O.

57808-1

10-PV-66404

DP 122371 DD

Motor No. 81P352-2

SPECIFICATIONS:

A-533-67 Gr. B Class 1 Hbd. by Sales Order


BEND TEST

0.2% elongation in 2"

CHEMICAL ANALYSIS

Basic
Process

MELT NO.	C	Mn	P	S	Cu	Si	Ni	Cr	Mo	V	Ti	Al	R	
C9479	20	1.32	010	020		24	47		51					Elec. Z.G.P. V.I.P. Steel



PHYSICAL PROPERTIES

MELT NO.	SLAB NO.	YIELD STRENGTH	TENSILE STRENGTH	% ELONG IN 2"	% RA	BHN	IMPACTS	DESCRIPTION
							V-notch +10°F.	
C9479	3	TX 638	865	28		174	T 67 71 77	
		EX 673	880	27		179		
		FL 646	873	29		174		
		BL 667	881	28		179	L 81 74 79	

Ring and tests heated to 1650°F./1700°F., held 1 hr. per inch min. and water quenched to 500°F., then tempered 1280°F., held 1 hr. per inch min. and air cooled.

Ring and tests stress relieved by heating to 1150°F., held 1 hr. per inch min. and furnace cooled to 600°F.

79852.8

D

11-1-72
CAV

We hereby certify the above figures are correct as contained in the records of the company.

L. H. Dine

U336

NON-DESTRUCTIVE TESTING REPORT

[illegible]

0336

NON-DESTRUCTIVE TEST REPORT
QUALITY CONTROL
 WESTINGHOUSE FORM 36310

FILE: SHOP ORDER **BIP352**

TEST: ULTRASONIC ZYGLO **DYE PENETRANT** MAGNAFLUX HANDNESS

c.c. **Miss Jackson** c.c. **ME-2 Insp.**

c.c. **Mr. Carlson** c.c. _____

PURCHASE ORDER NO. NPV47470 NPV47471	SUPPLIER LUKENS	SECTION ME-2	DRAWING NO. 6550 DB5	HEAT NO. CF446 69362	FORGING NO. 2B 1A
--	---------------------------	------------------------	--------------------------------	--	---------------------------------------

MATERIAL **Flywheel Assy.**

any of dye check of 9.4375 dia bore and 18" dia face
shows **OR DIA**
and 9.375 dia bore & 18" dia face show no indications.

DA NO. _____	REPORTED BY E. G. Patrick	DATE 6-5-72
--------------	-------------------------------------	-----------------------

NON-DESTRUCTIVE TESTING REPORT

[illegible]

2011

0536

TEST CERTIFICATE

COMM-CASE

S.O. U-336 TWA

Notes No. 81P353 #3

3 Westinghouse Elec. Corp.
LRA Fur. Dept.
Mr. G. E. Stepp
E. Pittsburgh, Pa. 15112

MAIL ORDER NO.

57107-1

CUST-2018 7.0

10-PV-47470

HP 1572 DB

SPECIFICATIONS

A-533-EGA Gr. B CL 1 Mod. by Sales Order

21 Jan 1951

LONG TEST

-O.K

NOXOGEN! 7 7 7

CHEMICAL ANALYSIS

PHYSICAL PROPERTIES

Rings and tests heated 1650-1700 F., held 1 hr. per inch min. and water quenched to 500°F., then tempered 1125°F., held 1 hr. per inch min. and air cooled.

Rings and tests stress relieved by heating to 1100°F., held 1 hr. per inch
min. and furnace cooled to 600°F.

We hereby certify the above figures are correct as contained in the records of the company.



Wm. J. Line

INSPECTION DEPARTMENT

CUSTOMER	MAIL ORDER NO.	TYPE TEST	DATE
	8987-14-57107-1	TYPE TEST	1/1/73
	CUSTOMER NO.	EQUIPMENT USED	
	8987-14-57107-1	EQUIPMENT USED	
	P.O. # 10-W-47490	SPENDING IN 73	1
	SEARCH UNIT	AMPLITUDE	COUNT
	SPACING 1-2/3 DIA. 2.25 DIA	AVERAGE	SOAP & WATER
	TRANSDUCER SPENDING	CARD NO.	TYPE OF SURFACE
	TYPE OF PRODS	100 & 25	GROUND
	INSPECTOR'S NAME & QUALIFICATIONS	SIZE	
	WITNESSED BY	2 BATH 75-1/2 IN X 4-1/2 IN X 1	NAME
		09446-23	IT-1

[illegible]

ANY OTHER COUNTRY THAT THE ABOVE IS CONNECT TO THE SEX
WE ARE ENCOURAGED AND BELIEVE.

CONTACT TO THE BEST

A. Parck

NON-DESTRUCTIVE TEST REPORT

QUALITY CONTROL

DESTRUCTION FORM 36300

FILE: SHOP ORDER 81P352 #4

TEST: ULTRASONIC

ZYGLO

DYE PENETRANT

MAGNAFLUX

HARDNESS

C.C.: Miss Jackson

C.C.: ME-2 insp.

C.C.: Mr. Carlson

C.C.:

PURCHASE ORDER NO.

10PV47471

10PV47470

SUPPLIER

LUKENS

SECTION

ME-2

DRAWING NO.

6550D85

HEAT NO.

C9362

C9446

FORGING NO.

1A

2A

MATERIAL

FLYWHEEL ASSY.

RESULTS of dye check of 9.437 dia bore & 18" dia face shows
no indications Exp. 6-8-72

Dye Check of 9.375 Bore & 18" Dia face OK

Robert 6/12/72

DA NO.

REPORTED BY

Robert

DATE

6/12/72

U336

PURCHASER:

3 Westinghouse Elec. Corp.
LRA Pur. Dept.
Mr. G. E. Stepp
E. Pittsburgh, Pa. 15112

LUKENS STEEL COMPANY

CONVENT, PA. 19330

TEST CERTIFICATE

MILL ORDER NO.

57107-1

CUSTOMER P.O.

10-PV-47470

MP 1572 DR

CORRECTED COPY: 1-20-72

DATE 1-11-72 FILE NO 6587-0

CONSIGNEE

SA. U336. TVA
MOTOR # 81P852 #4

SPECIFICATIONS:

A-533-69A Gr. B CL 1 Mod. by Sales Order

M JAN 1

BASIC TEST

O.K.

HOMOGENEITY

CHEMICAL ANALYSIS

MELT NO.	C	Mn	P	S	Cu	Si	Ni	Co	Mo	V	XXX	XXX	XXX	XXX	BASIC PRCC
C9446	22	1.30	007	015		22	57		53		V.I.P. Steel				P.G.P. Electric

PHYSICAL PROPERTIES

MELT NO.	HAS	YIELD	TENSILE	ELONG.	REDUCED	IMPACT	V-Notch +10°F.			DESCRIPTION
C9446	2A	FX 669	917	24	187	T	52	54	48	2-8" x 8-1/4 ID x 75-1/2
		PL 660	901	28	187					
		FX 664	926	23	192					
		PL 705	926	25	192	L	106	70	70	
"	2B	FX 665	886	23	187	T	38	43	45	2- "
		PL 663	905	25	183					
		FX 734	950	24	187					
		EL 715	985	24	192	L	92	89	102	

2728293031-123

Rings and tests heated 1650-1700 F., held 1 hr. per inch min. and water quenched to 500°F., then tempered 1100°F., held 1 hr. per inch min. and air cooled.
1260



Rings and tests stress relieved by heating to 1100°F., held 1 hr. per inch min. and furnace cooled to 500°F.



Motor S/N



NON-DESTRUCTIVE TEST REPORT
QUALITY CONTROL
WESTINGHOUSE FORM 3636

FILE: SHOP ORDER

81P352 #1

TEST: ULTRASONIC ZYGLO DYE PENETRANT MAGNAFLUX HARDNESS

C.C.: Miss Jackson

C.C.: ME-2 Insp

C.C.: Mr Carlson

C.C.:

PURCHASE ORDER NO.

10PV47471

SUPPLIER

Lukens

SECTION

ME-2

DRAWING NO.

6.5.5208.5.5

HEAT NO.

C9362

FORGING NO.

1A

C9446

2B

P.O.S.

MATERIAL

Flywheel Assem.

RESULTS

Dye check of 9.43E bore + 18 face OK

DYE CHECK OF 9.3755 BORE + 18 DIA FACE OK

Conductivity 2-18-72

REPORTED BY

DATE

DA NO.

U336

NON-DESTRUCTIVE TEST REPORT
QUALITY CONTROL
 TESTING CODE FORM 26396

FILE: SHOP ORDER 81 P352 #2

TEST: ULTRASONIC ZYGLO DYE PENETRANT MAGNAFLUX HARDNESS

c.c. Miss Jackson 5th c.c. Mr. 2 Insp.

c.c. Mr. Carlson 6G c.c. _____

PURCHASE ORDER NO.	SUPPLIER	SECTION	DRAWING NO.	HEAT NO.	FORGING NO.
10PV6649	Lukens	MF 2	6550 D81	C9474	3
10PV47470				C9446	21
MATERIAL				P.D.S.	

FLY WHEEL ASSY.

RESULTS of dye check of 9.438 dia bore & 18" dia face shows
 no indications E.G. Patrick 2-23-72
 9.375 bore & 18" dia face shows no indications E.G.P. 2-28-72

DA NC. REPORTED BY E.G. Patrick DATE 2-28-72

NON-DESTRUCTIVE TEST REPORT
QUALITY CONTROL
 WESTINGHOUSE FORM 3039B

FILE: SHOP ORDER 81P352

TEST: ULTRASONIC ZYGLO DYE PENETRANT MAGNAFLUX HARDNESS

c.c. Miss Jackson

c.c.: ME-2 Insp.

c.c. Mr. Carlson

c.c.:

PURCHASE ORDER NO.	SUPPLIER	SECTION	DRAWING NO.	HEAT NO.	FORGING NO.
MPV47470 MPV47471	LUKENS	ME-2	6550D85	C9446 C9362	2B 1A
MATERIAL				P.D.S.	

Flywheel Assy.

RESULTS of dye check of 9.4375 dia bore and 18" dia face
 shows no indications. E.G. Patrick 6-2-72
 and 9.375 dia bore & 18" dia face show no indications.

DA NO.

REPORTED BY

E.G. Patrick

DATE

6-5-72

NON-DESTRUCTIVE TEST REPORT
QUALITY CONTROL
INSTRUMENTS FORM 3432B

FILE: SHOP ORDER 81P352 #4

TEST: ULTRASONIC ZYGLO

DYE PENETRANT

MAGMAFLUX

HARDNESS

C.C.: Miss Jackson

C.C.: ME-2 insp.

C.C.: Mr. Carlson

C.C.:

PURCHASE ORDER NO.	SUPPLIER	SECTION	DRAWING NO.	HEAT NO.	FORGING NO.
10PN47471	LUKENS	ME-2	6550D85	C9362	1A
10PN47470				C9446	2A
P.O.S.					

FLYWHEEL ASSY.

num of dye check of 9.437 dia bore & 18" dia face shows
no indications Ref. 6-8-72

Dye Check of 9.375 Bore & 18" Dia face OK

John C. [signature]

REPORTED BY

DATE

BA NO.

John C. [signature] 6/12/72

U336

NDE FOR FLYWHEELS

Shop Order 88P976

PT per 84350UD of plate prior to assembly.

P.O. P092-237 Ht. No. D5301-4 Insp. & Date T. Canderaky 5-2-78

PT per 84350UD of plate prior to assembly.

P.O. P092-238 Ht. No. B1717-4 Insp. & Date T. Canderaky 4-19-78

PT per 84350UD after first machining.

Insp. & Date T. Canderaky 5-15-78 and 6-2-78

PT per 84350UD after keyway.

Insp. & Date G. Walko 10-18-78

UT per 84351WL of finished flywheel.

Insp. & Date J. Rene & J. C. Rice 12-6-78

C. L. Carter

Original documents are on file at WLRAD East Pittsburgh, Penna. 15112

3. WESTINGHOUSE ELEC. CORP.
QUAL. ASSURANCE DEPT.-26A
EAST PITTSBURGH, PA. 15112

LUKENS STEEL COMPANY

COATESVILLE, PA. 19328

TEST CERTIFICATE

DATE, 4-11-78
CONSIGNEE,

FILE NO 8587-07-5

MAIL ORDER NO.
54173-1

CUSTOMER P.O.
P092-23A

MP 4778 DD
2/10

ALL MATERIAL HAS BEEN MANUFACTURED AND TESTED IN ACCORDANCE WITH PULPAM ORDER REQUIREMENTS AND SPECIFICATIONS.

WEST PDS-10310CR REV. N 77 A-533 GR. B CL. 1

WEND TEST

HOMOGENEITY TEST

CHEMICAL ANALYSIS

CHEMICAL ANALYSIS														BASIC PROCESS	
MELT NO.	C	MN	P	S	CU	SI	NI	CR	MO	V	Ti	AL	XXXX		
B1717	.20	1.33	.011	.002		.25	.68		.59				VIP STEEL		ELEC

PHYSICAL PROPERTIES

MELT NO.	SLAB NO.	W. IN.	THICK. IN.	% FLOW	% R.A.	XXXX	V-NOTCH	IMPACTS	FRACTURE	DESCRIPTION
									APPEARANCE	
B1717	4	701	925	23		LOC.			5 SHEAR	
		719	964	26		T	156	160	99-99-99	2- 5" -1/2 ID X 66 OD
						LATERAL EXPANSION IN INCHES				
							.096	.098		
						L	172	166	99-99-99	
						LATERAL EXPANSION IN INCHES				
							.096	.099		
TRANS. DROP WEIGHT TESTS PER #208 (SIZE P3) @ 200°F. EXHIBIT NO BREAK										
NOT IS +10°F. OR BELOW										
RINGS AND TESTS HEATED 1625-1675°F., HELD 1/2 HR. PER INCH MIN. AND										
WATER QUENCHED, THEN TEMPERED 1260°F., HELD 1/2 HR. PER INCH MIN. AND										
WATER QUENCHED.										
RINGS AND TESTS STRESS RELIEVED BY HEATING TO 1100-1150°F., HELD 1 HR.										
PER INCH MIN. AND FURNACE COOLED TO 600°F.										

RELEASED BY O.C.

TO SEC. 200K

INSP. N. MATEJEVICH DATE 4-18-78

We hereby certify the above information is correct.

RELEASED BY Q.C.

TO SEC. 200 R
INSP. N. MATEJEVICH DATE 4/18/78

LUKENS STEEL COMPANY INSPECTION DEPARTMENT

NON-DESTRUCTIVE TESTING REPORT

CUSTOMER
Clyde: Thomas & Co.
Purchasing Dept.
L.H. Higgins - 3N53
East Pittsburgh, Pa. 15112

CONSIGNEE TO

Lot 11, 200K Steel.
700 Blacklock Ave.
East Pittsburgh, Pa. 15112

MILL ORDER NO

5577-99-54173-1

QUALITY PL. 11210 2 1/2 R. N

11210 11233 G. 15 Ch. 1

CUSTOMER NO

11210 11233

SPACING

TRANSVERSE

TYPE OF PROS

INSPECTOR'S NAME (LEVEL 1-SNT-TCIA)

WITNESSED BY

TYPE TEST

Surf

S. PIFICATION

11278 & 11277 11100.

EQUIPMENT USED

Mark 5 #50 4/13/78

AMPLITUDE

AMPERAGE

GRID REF

11210 11233 200K 112

GAUGE

MET & SLAB

2 pr. 11210-4

DATE

2/23/78

COUPLANT

METHOD

TYPE OF SURFACE

WIDTH

LENGTH

MARK NO

ITEM NO

I HEREBY CERTIFY THAT THE ABOVE IS CORRECT TO THE BEST OF MY KNOWLEDGE AND BELIEF. *A. P. ...*

A. P. ...

PURCHASER:

3. WESTINGHOUSE ELEC. CORP.
QUAL. ASSURANCE DEPT.-2GA
EAST PITTSBURGH, PENNA.
15112

LUKENS STEEL COMPANY

COATESVILLE, PA. 19320

TEST CERTIFICATE

DATE: 2-24-78

FILE NO 8587-07-99

CONSIGNEE

MILL ORDER NO.
52345-1CUSTOMER P.O.
P092-237MP 22378 WM
2/24

88 P4 7.6

(91)

92-237

WE STATE THAT THIS STEEL WAS MANUFACTURED AND TESTED IN ACCORDANCE WITH PURCHASE ORDER REQUIREMENTS AND SPECIFICATIONS

WEST PDS-10310CR REV. N 77 A-533 GR. B CL. 1

BEND TEST

HOMOGENEITY TEST

CHEMICAL ANALYSIS

MELT NO.	C	MN	P	S	CU	SI	NI	CR	MO	V	Ti	AL	AAA	BASIC PROCESS
D5301	.18	1.30	.013	.005		.22	.65		.55				VIP STEEL	ELEC.

PHYSICAL PROPERTIES

MELT NO.	SLAB NO.	YIELD STRENGTH	TENSILE STRENGTH	% ELONG IN 2"	% R.A.	BHN	IMPACTS V+70°F.	FRACURE APPEARANCE	DESCRIPTION
D5302	4	729 707	950 925	24 25			T 142 143 147 L 147 150 146 T.090 .088 .089 L.090 .093 .091	S SHEAR 99-99-99 99-99-99	1- 7.5" X 6.5 ID X 73 OD
TRANS DROP WEIGHT TESTS PER E208(SIZE P-3) @ +20°F., N.D.T. IS +10°F. OR BELOW.							LATERAL EXPANSION IN INCHES	EXHIBIT NO	BREAK.
RINGS AND TESTS HEATED 1025-1675°F., HELD 1/2 HR. PER INCH MIN. AND WATER QUENCHED, THEN TEMPERED 1240°F., HELD 1/2 HR. PER INCH MIN. AND WATER QUENCHED.									
RINGS AND TESTS STRESS RELIEVED BY HEATING TO 1100-1150°F., HELD 1 HR. PER INCH MIN. AND FURNACE COOLED TO 600°F.									

RELEASED BY Q.C.

TO SEC.

INSP. N. MATEJEVICH DATE 3-7-78

We hereby certify the above information is correct.

S. BYRON HESTER

LUKENS STEEL COMPANY
INSPECTION DEPARTMENT

NON-DESTRUCTIVE TESTING REPORT

CUSTOMER <i>West. Penn. Steel Corp. Pittsburgh, Pa. 15111</i>	MILL ORDER NO. <i>887-99-52345-1</i>	TYPE TEST <i>Surf</i>		DATE <i>2/14/78</i>
	QUALITY <i>A572 Gr C</i>	SPECIFICATION <i>A572 F A577</i>		
CONSIGNEE TO <i>State 11, 20 K Steel 710 B. detroit Ave Pittsburgh, Pa 15112</i>	CUSTOMER NO. <i>17 16 92-237</i>	EQUIPMENT USED <i>Mark 5 & 50 4/1/78</i>		
	SPACING	AMPLITUDE	COUPLANT	
	TRANSDUCER <i>2.25 MHz</i>	AMPERAGE	METHOD <i>C.T. 5</i>	
	TYPE OF WELD <i>1/1 2.25 MHz</i>	GRID REF <i>11/16 20/1/1/2</i>	TYPE OF SURFACE <i>Surf</i>	
	INSPECTOR'S NAME (LEVEL I-SNT-TC-1A) <i>J. J. [Signature]</i>	GAUGE <i>7 1/2</i>	WIDTH <i>6.5 ID.</i>	LENGTH <i>73 O.D.</i>
	WITNESSED BY	MELT & SLAB <i>D5301-4</i>	MARK NO.	ITEM NO. <i>1</i>

I HEREBY CERTIFY THAT THE ABOVE IS CORRECT TO THE BEST OF MY KNOWLEDGE AND BELIEF.

J. J. [Signature]

REVISION SURFACE SURF B-SNT-TC-1A

NDE FOR FLYWHEELSShop Order 89P969

PT per 84350UD of plate prior to assembly.

P.O. 179-979 Ht. No. A7503-1 Insp. & Date T. Candresky 11-21-80

PT per 84350UD of plate prior to assembly.

P.O. 179-980 Ht. No. A7503-1 Insp. & Date T. Candresky 11-17-80

PT per 84350UD after first machining.

Insp. & Date T. Candresky & H. O'Grady 1-26-81

PT per 84350UD after keyway.

Insp. & Date L. Vexchek 3-25-81

UT per 84351WL of finished flywheel.

Insp. & Date T. Gaaally & T. Plawcy 3-25-81C. R. CarterOriginal documents are on file at VRAD East Pittsburgh, Penna. 15112

PURCHASER
WEST. ELEC. CORP.
QUAL. ASSURANCE DEPT.

LUKENS STEEL COMPANY

COATESVILLE, PA. 19320

TEST CERTIFICATE

DATE 9-10-80

FILE NO 8587-07

CONVERSION

RAWL ORDER NO.

39437-1

CUSTOMER P.O.

P179-980

MP 9480 VS
L9880 3/6

ALL MATERIALS HAVE BEEN MANUFACTURED AND TESTED IN ACCORDANCE WITH PURCHASER'S ORDER REQUIREMENTS AND SPECIFICATIONS

WEST PDS-10310CR REV. P 78 A-533 GR. B CL. 1 ASME CODE SECT. III SUB NCA N-1160 8/4/81

BEND TEST

HOMOGENEITY TEST

89P969

CHEMICAL ANALYSIS

ITEM	C	Mn	P	S	Si	Fe	Cu	Al	Ni	Mo	V	Ti	As	XX	BASIC PROC
A7503	.19	1.31	.014	.008			.27	.67		.57				VIP STEEL	ELIC.

34

PHYSICAL PROPERTIES

MELT NO.	SLAB NO.	YIELD STRENGTH	TENSILE STRENGTH	% ELONG.	% R.A.	XXX LOC	V +70°F.	IMPACTS	FRACTURE APPEARANCE	DESCRIPTION	
A7503	1	757 724	950 924	24 24		T L	86 130	86 115	70 117	70-70-70 80-80-80	1- 8" X 7 ID X 66.75 OD
LATERAL EXPANSION IN INCHES											
T .056 .061 .062											
L .084 .089 .090											
TRANS. DROP WEIGHT TESTS PER E208 (SIZE P-8) FROM TOP & BOTTOM OF RING @ +20°F. EXHIBIT NO BRLAK.											
RINGS AND TESTS HEATED 1625-1675°F., HELD 1/2 HR. PER INCH MIN. AND WATER											
QUENCHED, THEN TEMPERED 1220°F., HELD 1/2 HR. PER INCH MIN. AND WATER											
RINGS AND TESTS STRESS RELIEVED BY HEATING TO 1100-1150°F., HELD 1 HR. PER INCH MIN. AND FURNACE COOLED TO 800°F.											

MATERIAL TRACEABILITY LABEL

RELEASED BY Q.C.

TO SEC. *ME*

INSP.N. MATEJEVICH DATE *9-17-82*

MATERIAL TRACEABILITY LABEL

RELEASED BY Q.C.

TO SEC.

INSP. N. MATEJEVICH DATE 9/17/80

WEST. ELEC. CORP.
QUAL. ASSURANCE DEPT.

LUKENS STEEL COMPANY

COATED STEEL PL. 1923
TEST CERTIFICATE

DATE 9-10-80 FILE NO. 8587-07-11
CONSIGNEE

MILL ORDER NO.
39438-1

CUSTOMER P.O.
P179-979

MP 9480 VS
L9880 3/7

THIS CERTIFICATE WAS ISSUED IN ACCORDANCE WITH PURCHASER ORDER REQUIREMENTS AND SPECIFICATIONS

WEST PDS-10310CR REV. P 78 A-533 GR. B CL. 1 ASME CODE SECT. III SUB-NCA N-1160 8/4/01

89P969

BEND TEST

HOMOGENEITY TEST

CHEMICAL ANALYSIS

MELT NO.	C	MN	P	S	CU	SI	NI	CR	MO	V	Ti	AL	XB	BASIC PROCESS
A7503	.19	1.31	.014	.008		.27	.67		.57				VIP STEEL	ELEC.

PHYSICAL PROPERTIES

MELT NO.	SLAB NO.	YIELD STRESS	TENSILE STRESS	% RED. IN 2.	% RA	LOC	IMPACTS V +70°F.			FRACTURE APPEARANCE	DESCRIPTION
A7503	1	757 724	950 924	24 24		T L	86 130	86 115	70 117	70-70-70 80-80-80	1- 8" x 7 ID x 76.5 OD
						LATERAL EXPANSION IN INCHES					
						T	.056	.061	.062		
						L	.084	.089	.090		
TRANS. DROP WEIGHT TESTS PER E208 (SIZE P-3) FROM TOP & BOTTOM OF RING @ +20°F. EXHIBIT NO BREAK.											
RINGS AND TESTS HEATED 1625-1675°F., HELD 1/2 HR. PER INCH MIN. AND WATER QUENCHED, THEN TEMPERED 1220°F., HELD 1/2 HR. PER INCH MIN. AND WATER QUENCHED.											
RING AND TESTS STRESS RELIEVED BY HEATING TO 1100-1150°F., HELD 1 HR. PER INCH MIN. AND FURNACE COOLED TO 800°F.											

36

MATERIAL TRACIBILITY RECORD

RELEASED BY O.C.
TO SEC. ME. 2
INSP.N. MATZJEVICH DATE 9-17-64

MATERIAL TRACEABILITY RECORD

RELEASED BY O.C.
TO SEC. ME
INSP.N. MATZJEVICH DATE 9-17-80

I hereby certify the above information is correct.

SUPERVISOR TESTING

NON-DESTRUCTIVE TESTING REPORT

CHRYSLER Westinghouse Elec. Corp. Purchasing Dept. 1200 E. 12th St. - 3rd Fl. East Pittsburgh, Pa. 15112 CONIGNED TO	MILL ORDER NO. 11-39438-1	TYPE TEST None		DATE 9/2/51
	QUALITY 11571 11572 11573 11574 11575 11576 11577 11578 11579 11580 11581 11582 11583 11584 11585 11586 11587 11588 11589 11590 11591 11592 11593 11594 11595 11596 11597 11598 11599 11600 11601 11602 11603 11604 11605 11606 11607 11608 11609 11610 11611 11612 11613 11614 11615 11616 11617 11618 11619 11620 11621 11622 11623 11624 11625 11626 11627 11628 11629 11630 11631 11632 11633 11634 11635 11636 11637 11638 11639 11640 11641 11642 11643 11644 11645 11646 11647 11648 11649 11650 11651 11652 11653 11654 11655 11656 11657 11658 11659 11660 11661 11662 11663 11664 11665 11666 11667 11668 11669 11670 11671 11672 11673 11674 11675 11676 11677 11678 11679 11680 11681 11682 11683 11684 11685 11686 11687 11688 11689 11690 11691 11692 11693 11694 11695 11696 11697 11698 11699 11700 11701 11702 11703 11704 11705 11706 11707 11708 11709 11710 11711 11712 11713 11714 11715 11716 11717 11718 11719 11720 11721 11722 11723 11724 11725 11726 11727 11728 11729 11730 11731 11732 11733 11734 11735 11736 11737 11738 11739 11740 11741 11742 11743 11744 11745 11746 11747 11748 11749 11750 11751 11752 11753 11754 11755 11756 11757 11758 11759 11760 11761 11762 11763 11764 11765 11766 11767 11768 11769 11770 11771 11772 11773 11774 11775 11776 11777 11778 11779 11780 11781 11782 11783 11784 11785 11786 11787 11788 11789 11790 11791 11792 11793 11794 11795 11796 11797 11798 11799 11800 11801 11802 11803 11804 11805 11806 11807 11808 11809 11810 11811 11812 11813 11814 11815 11816 11817 11818 11819 11820 11821 11822 11823 11824 11825 11826 11827 11828 11829 11830 11831 11832 11833 11834 11835 11836 11837 11838 11839 11840 11841 11842 11843 11844 11845 11846 11847 11848 11849 11850 11851 11852 11853 11854 11855 11856 11857 11858 11859 11860 11861 11862 11863 11864 11865 11866 11867 11868 11869 11870 11871 11872 11873 11874 11875 11876 11877 11878 11879 11880 11881 11882 11883 11884 11885 11886 11887 11888 11889 11890 11891 11892 11893 11894 11895 11896 11897 11898 11899 11900 11901 11902 11903 11904 11905 11906 11907 11908 11909 11910 11911 11912 11913 11914 11915 11916 11917 11918 11919 11920 11921 11922 11923 11924 11925 11926 11927 11928 11929 11930 11931 11932 11933 11934 11935 11936 11937 11938 11939 11940 11941 11942 11943 11944 11945 11946 11947 11948 11949 11950 11951 11952 11953 11954 11955 11956 11957 11958 11959 11960 11961 11962 11963 11964 11965 11966 11967 11968 11969 11970 11971 11972 11973 11974 11975 11976 11977 11978 11979 11980 11981 11982 11983 11984 11985 11986 11987 11988 11989 11990 11991 11992 11993 11994 11995 11996 11997 11998 11999 12000 12001 12002 12003 12004 12005 12006 12007 12008 12009 12010 12011 12012 12013 12014 12015 12016 12017 12018 12019 12020 12021 12022 12023 12024 12025 12026 12027 12028 12029 12030 12031 12032 12033 12034 12035 12036 12037 12038 12039 12040 12041 12042 12043 12044 12045 12046 12047 12048 12049 12050 12051 12052 12053 12054 12055 12056 12057 12058 12059 12060 12061 12062 12063 12064 12065 12066 12067 12068 12069 12070 12071 12072 12073 12074 12075 12076 12077 12078 12079 12080 12081 12082 12083 12084 12085 12086 12087 12088 12089 12090 12091 12092 12093 12094 12095 12096 12097 12098 12099 12100 12101 12102 12103 12104 12105 12106 12107 12108 12109 12110 12111 12112 12113 12114 12115 12116 12117 12118 12119 12120 12121 12122 12123 12124 12125 12126 12127 12128 12129 12130 12131 12132 12133 12134 12135 12136 12137 12138 12139 12140 12141 12142 12143 12144 12145 12146 12147 12148 12149 12150 12151 12152 12153 12154 12155 12156 12157 12158 12159 12160 12161 12162 12163 12164 12165 12166 12167 12168 12169 12170 12171 12172 12173 12174 12175 12176 12177 12178 12179 12180 12181 12182 12183 12184 12185 12186 12187 12188 12189 12190 12191 12192 12193 12194 12195 12196 12197 12198 12199 12200 12201 12202 12203 12204 12205 12206 12207 12208 12209 12210 12211 12212 12213 12214 12215 12216 12217 12218 12219 12220 12221 12222 12223			

[illegible]

I HEREBY CERTIFY THAT THE ABOVE IS CORRECT TO THE BEST OF MY KNOWLEDGE AND BELIEF.

IS CORRECT TO THE BEST
H. K. Lee

New York George H.

37

APPENDIX E

RESPONSE TO FIRST NRC REQUEST FOR ADDITIONAL INFORMATION

SUSHIL C. JAIN
Division Vice President
Nuclear Services
Nuclear Power Division(412) 393-5512
Fax (412) 643-8069

June 14, 1996

U. S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, DC 20555-0001

**Subject: Beaver Valley Power Station, Unit No. 1 and No. 2
BV-1 Docket No. 50-334, License No. DPR-66
BV-2 Docket No. 50-412, License No. NPF-73
Response to Request for Additional Information Concerning
WCAP-14535**

Attached is the response to an NRC staff request for additional information provided by letter dated May 1, 1996, concerning WCAP-14535, "Topical Report on Reactor Coolant Pump Flywheel Inspection Elimination." Beaver Valley submitted the subject report by letter dated January 24, 1996, as the industry's lead plant on this issue.

Please direct questions regarding this submittal to Mr. Roy K. Brosi at (412) 393-5210.

Sincerely,



Sushil C. Jain

c: w/enclosure:

Mr. L. W. Rossbach, Sr. Resident Inspector
Mr. T. T. Martin, NRC Region I Administrator
Mr. D. S. Brinkman, Sr. Project Manager - (3 copies)
Ms. Diane Jackson, Westinghouse Electric Corporation

w/o enclosure:

Mr. David Haile, South Carolina Electric and Gas Co.
Mr. Pat Naughton, Virginia Power
Mr. Don Gulling, Florida Power Corporation
Mr. Ben Mays, TU Electric Co.
Mr. Jim Edwards, Georgia Power Co.
Mr. K. J. Voytell, Westinghouse Electric Corporation
Mr. S. A. Binger, Jr., Westinghouse Electric Corporation

DELIVERING
QUALITY
ENERGY

**Westinghouse
Electric Corporation**

Energy Systems

Box 355
Pittsburgh Pennsylvania 15230 C355

ESBU/WOG-96-212

June 17, 1996

**To: Dennis Weakland, Duquesne Light Company
David Haile, South Carolina Electric & Gas
Pat Naughton, Virginia Power
Loretta Cecilia, Florida Power Corporation
Ben Mays, TU Electric Company
Jim Edwards, Southern Nuclear Operating Company**

**Subject: Westinghouse Owners Group
Response to NRC Request for Additional Information on WCAP-14535 "Topical
Report on Reactor Coolant Pump Flywheel Inspection Elimination" (MUHP-5042)**

**Reference: WOG Letter ESBW/WOG-96-173 dated 5/17/96 Subject: NRC Request for Additional
Information on WCAP-14535 "Topical Report on Reactor Coolant Pump Flywheel
Inspection Elimination" (MUHP-5042)**

The original submittal on this subject was made on behalf of the WOG by Duquesne Light Company for Beaver Valley Station on January 24, 1996. A similar submittal was made by Entergy for Arkansas Nuclear One on behalf of the Combustion Engineering Owners Group. The NRC has performed a preliminary review of the Beaver Valley submittal, and has determined that additional information is required to complete the review. A letter dated May 1, 1996 requesting additional information (RAI) was transmitted to Mr. J. E. Cross of Duquesne Light Company from Mr. Donald S. Brinkman of the NRC. The NRC has requested that Duquesne Light Company provide a response to the RAI within 45 days of receipt of the letter.

The purpose of this letter is to provide input to Duquesne Light Company for input to their NRC letter responding to the RAI.

The NRC plans to resolve this issue by the end of this summer. We will keep you informed of any new developments on this subject.

Please contact Warren Bamford at (412) 374-6515 with additional questions or comments.

Regards,



**S.A. Binger, Jr.
Project Engineer
Westinghouse Owners Group**

SAB/ygs

Response to NRC Request for Additional Information on WCAP-14535

Item 1:

Section 1.1 Previous Flywheel Integrity Evaluations, Page 1-3 - It was stated, "Since shrink fit forces would retard the growth of radial cracks in the keyway area, they were omitted from the analysis of the keyway crack." Physically, the shrink fit forces can be considered as internal pressure acting on the inner bore of the reactor coolant pump (RCP) flywheel. Thus, it would accelerate, not retard, the growth of radial cracks in the keyway area. Provide sufficient finite element modelling details and results to validate your claim or revise your results by taking into account the effect due to shrink fit forces, which was shown by the Combustion Engineering Owners Group in report

SIA-94-080, "Relaxation of Reactor Coolant Pump Flywheel Inspection Requirements," which was submitted to the NRC on April 4, 1995, on dockets 50-313 and 50-368. These shrink fit forces were shown in that report to be capable of producing stresses of comparable magnitude to those produced by the centrifugal force when the flywheel was running at the normal operating speed.

Response to Item 1:

The shrink fit forces do add to the stresses at the flywheel bore, but fatigue crack growth is approximately proportional to the cube of the stress range applied during a given cycle. For the flywheel, the stress range is from the rest condition (zero rpm) to normal operating speed. Therefore, if the shrink fit stresses had been used, the stress range would be smaller because the shrink fit stresses are significantly lower at normal operating speed than at the rest condition. Our calculations used a zero stress state at rest, which maximized the crack growth predictions. The amount of conservatism induced by this assumption is discussed below.

Westinghouse has evaluated the effect of shrink fit forces on crack growth. Due to the large number of flywheels in service, actual shrink fit values were not obtained for each pump, but typical shrink fit values for flywheels which are attached directly to the RCP motor shaft are 0.5 to 1.0 mil on the flywheel bore, or 0.00025 inch to 0.0005 inch on the bore radius. For conservatism, and to be consistent with Combustion Engineering Owners Group report SIA-94-080, "Relaxation of Reactor Coolant Pump Flywheel Inspection Requirements," a shrink fit of 0.0052 inch on the bore radius was imposed for evaluation purposes. This is approximately one order of magnitude higher than the typical shrink fit for flywheels which are attached directly to the RCP motor shaft. A shrink fit of 0.0125 inch was used for the spoked flywheel, as was used in the Combustion Engineering Owners Group report.

Hoop stresses control the growth of radially oriented cracks in the flywheel. Shrink fit hoop stresses for the flywheels at rest are on the order of one to three times the hoop stresses produced by centrifugal forces alone, when the flywheels are running at the normal operating speed. However, as the flywheel rotational speed increases, the shrink fit hoop stresses decrease, due to the radial growth of the flywheel bore radius. This growth may be determined by the following equation:

$$\Delta \sigma = \frac{1}{6} \frac{\rho \omega^2}{386 \times 10^4} \frac{a}{E} [(3 + \nu) r^3 + (1 - \nu) a^3]$$

where:

a	=	bore radius (inches)
b	=	outer radius (inches)
ρ	=	flywheel material density (0.283 lb./cubic inch)
ω	=	flywheel angular velocity (radians per second)
E	=	Young's modulus (30×10^6 psi)
ν	=	Poisson's ratio (0.3)

The total hoop stress may be determined by adding the shrink fit and centrifugal force components. The stresses at the flywheel keyway location are shown in Figure 1 for Flywheel Group 1, which is representative of the Beaver Valley Units 1 and 2 flywheels. Stress plots for the other flywheel groups are similar to Figure 1.

Fatigue crack growth rate may be characterized in terms of the range of applied stress intensity factor (ΔK_I), and is generally of the form:

$$\frac{da}{dN} = C_0 (\Delta K_I)^n$$

where

da/dN	=	crack growth rate (inches/cycle)
n	=	slope of the log (da/dN) versus log (ΔK_I)
C_0	=	scaling constant

The fatigue crack growth behavior is affected by the R ratio (K_{min}/K_{max}) and the environment. Reference fatigue crack growth behavior of carbon and low alloy ferritic steels exposed to an air environment is provided by the above equation with $n = 3.07$ and $C_0 = 1.99 \times 10^{-10}$ S. S is a scaling parameter to account for the R ratio and is given by $S = 25.72 (2.88 - R)^{-3.87}$ where $0 \leq R < 1.0$.

In the WCAP-14535 evaluation, the maximum stress intensity factor range occurred between RCP shutdown (zero rpm) and the normal operating speed. Shrink fit was excluded, therefore the R ratio was zero, S was 1, and C_0 was 1.99×10^{-10} .

Including shrink fit results in an R ratio of approximately 0.9, an S of approximately 3.2, and a C_0 of approximately 6.4×10^{-10} . Therefore, the scaling constant (C_0) is approximately 3.2 times higher than not including shrink fit.

The range of applied hoop stress for excluding shrink fit was at least twice that for including shrink fit for all flywheel groups. Therefore, the relative fatigue crack growth rate for including shrink fit may be estimated by the following equation:

$$\frac{\text{Rate with Shrink Fit}}{\text{Rate without Shrink Fit}} = (3.2)(0.5)^{3.07}$$

The fatigue crack growth rate for including shrink fit is at most 40% of the rate for not including shrink fit, for the assumed shrink fit values discussed above. Therefore, shrink fit retards the growth of radial cracks in the keyway area, and excluding shrink fit yields conservative fatigue crack growth results, as reported in WCAP-14535.

Item 2:

Section 1.1 Previous Flywheel Integrity Evaluations, Page 1-3 - The fatigue analysis is dependant on the premise that UT equipment used for examinations of RCP flywheels at these facilities is capable of accurately detecting and sizing 0.24 inch long near surface flaw. Provide your basis supporting the probability of detection (POD) for the examinations performed. Provide details on how the POD values were determined, qualified, and used in concluding the assumed size of the initial flaw.

Response to Item 2:

The initial crack length of 0.24 inch was used in a previous evaluation of RCP flywheel integrity by Babcock and Wilcox (Report BAW-10040, December 1973, "Reactor Coolant Pump Assembly Overspeed Analysis"). This length was assumed to be the largest crack that could be missed in nondestructive testing.

As seen in Table 4-4 of WCAP-14535, crack growth assuming extremely large initial flaw lengths (from 2.04 to 3.28 inches) was found to be insignificantly small over a 60 year extended plant life. In the crack growth evaluation, 6000 RCP start/stop cycles were assumed, which is conservative with respect to actual operation. This evaluation suggests that very large initial flaws can be tolerated. Such flaws are of a size which are expected to be detectable with the examination procedure of Attachment A.

An alternative method of evaluating this issue is to define an "allowable" flaw size based on the application of a margin to the calculated critical flaw size. The approach used here is to apply the margins of ASME Section XI. The results of this approach are provided in Table 1 below. In this table, crack length is measured radially from the keyway, and percentage through the flywheel is the crack length divided by the radial length from the keyway to the flywheel outer radius.

The inspection methods used for flywheels are capable of finding flaws much smaller than the smallest allowable flaw in Table 1.

Table 1: Allowable Crack Lengths for Flywheel Normal Speed and Overspeed

Flywheel Group	Allowable Crack Lengths in Inches and % through Flywheel					
	1200 rpm			1500 rpm		
	RT _{test} = 0°F	RT _{test} = 30°F	RT _{test} = 60°F	RT _{test} = 0°F	RT _{test} = 30°F	RT _{test} = 60°F

1	3.0" (9%)	1.8" (5%)	1.0" (3%)	8.5" (26%)	3.8" (12%)	1.5" (4%)
2	3.4" (10%)	1.9" (6%)	1.1" (3%)	9.4" (29%)	4.2" (13%)	1.8" (5%)
10	3.2" (12%)	1.6" (6%)	1.0" (4%)	8.3" (31%)	3.7" (14%)	1.6" (6%)
14	8.1" (29%)	2.8" (10%)	1.7" (6%)	15.2" (55%)	7.5" (27%)	4.1" (15%)
15	2.6" (13%)	1.1" (5%)	0.7" (3%)	5.7" (28%)	2.6" (13%)	1.3" (6%)
16	5.8" (24%)	1.8" (7%)	1.4" (6%)	12.2" (50%)	5.7" (23%)	3.0" (12%)

Over the past ten years, the examination techniques employed have improved, particularly with the use of the defocused gage hole probe. The detectability of the gage holes at various metal paths displayed in Attachment B indicate that the inspection methods used for flywheels are capable of finding flaws much smaller than those identified in Table 1.

In Attachment B, the 1.25 inch diameter gage holes (effectively side drilled holes) were clearly identified at a metal path which is nearly twice the metal path distance involved in the inspection of the keyway area. It should be noted that it is conservatively estimated that the effective reflective surface of a side drilled hole is a 30° arc. The reflective surface from a 1.25 inch gage hole would therefore be 0.33 inch. This is clearly smaller than the smallest allowable flaw in Table 1.

Item 3:

Inspection, Page 3-1 to 3-6 - Provide additional information regarding whether the UT examinations at Beaver Valley Power Station, Units Nos. 1 and 2 were qualified relative to inspection of RCP flywheels. Regardless of whether a formal qualification was performed, please include in your response the following:

- a. Any information supporting qualification of the examinations of RCP flywheels.*
- b. Any information supporting qualification of the personnel performing the examinations of RCP flywheels.*
- c. Any information regarding the degree of uncertainty in UT measurements based on the procedures and personnel qualification basis.*

Response to Item 3:

All of the plants covered by WCAP-14535, except one, have flywheels which are made of A533 Grade B Class 1 or A516 Grade 70 steel, which is reactor vessel quality steel. (The exception is Haddam Neck, which has flywheels made of boiler plate steel. A discussion on this plant is provided in WCAP-14535, Appendix B. Haddam Neck has conducted a separate demonstration of their inspection capability, as documented in Docket No. 50-213 B15230, dated 08/10/95).

The ultrasonic examination procedure used at Beaver Valley is included as Attachment A. This procedure includes qualification requirements of the personnel and equipment for the RCP flywheels. Additional information supporting requalification of the personnel performing the examinations of RCP flywheels is provided in Attachment B. Attachment B also includes enhancements made to the probe design to improve examination capabilities, and an evaluation of those enhancements.

Examination personnel are qualified to SN-TC1A and are trained in the use of the UT procedure (Attachment A). Duquesne Light Company NDE Level III personnel perform the examinations.

Item 4:

Section 4.3 Nonductile Failure Analysis - It was stated, "It was shown that cracks emanating from the center of the keyway yielded higher stress intensity factors than cracks emanating from the keyway corner, and" Provide the detailed stress plot around the keyway area from your finite element method analysis and provide an estimation of the stress intensity factors for the case when the perturbed stress distribution due to the keyway is used instead of the closed form solution used in this report.

Response to Item 4:

Finite element analyses were completed for cracks emanating from the center of the keyway and from the corner of the keyway. The results clearly show that a crack at the center of the keyway is more severe. This work was documented in an earlier submittal to the NRC in 1974-1975, and in the attached ASME technical paper (Attachment C) entitled "Reactor Coolant Pump Flywheel Overspeed Evaluation," by P. C. Riccardella and W. H. Bamford. The comparison of interest is shown in Figure 4 of the technical paper.

Note that the difference in stress intensity factor occurs only for short crack lengths, and the effect of the keyway on the stress intensity factor is only seen for cracks shorter than one inch. Results of the overall fracture evaluation show that flywheel limiting speed for small crack lengths is governed by ductile failure limits, as shown in Figure 10 of Attachment C. Therefore, this item is not relevant to the flywheel integrity.

Item 5:

Section 4.4 Excessive Deformation Analysis - Table 4-5 listed the change in bore radius at the speed of 1500 rpm for flywheels in various flywheel groups. Provide the amount of original shrink-fit and the percentage of shrink-fit lost at 1500 rpm for the typical flywheel in each flywheel group of the table.

Response to Item 5:

The percentage of shrink fit lost at 1500 rpm is shown in Table 2 below for the assumed worst case shrink fit values discussed in item 1 above. (For the typical shrink fits of 0.00025 to 0.0005 inch for flywheels which are attached directly to the RCP motor shaft, discussed in item 1 above, 100% of the shrink fit would be lost at 1500 rpm for all flywheel groups). Figure 2 provides flywheel bore expansion and corresponding shrink fit for speeds of zero to 1500 rpm, for Flywheel Group 1, which is representative of the Beaver Valley Units 1 and 2 flywheels. Displacement plots for the other flywheel groups are similar to Figure 2.

Table 2: Shrink Fit Lost at 1500 rpm

Flywheel Group	Flywheel Outer Radius (inches)	Flywheel Bore Radius (inches)	Assumed Shrink Fit (inches)	Shaft Radial Expansion (inches)	Flywheel Bore Radial Expansion (inches)	Shrink Fit at 1500 rpm (inches)	Shrink Fit Lost at 1500 rpm (%)
1	38.250	4.6875	0.0052	0.0000	0.0034	0.0018	65
2	37.875	4.1875	0.0052	0.0000	0.0030	0.0022	58
10	36.000	8.0625	0.0052	0.0000	0.0052	0.0000	100
14	32.500	4.1875	0.0052	0.0000	0.0022	0.0030	42
15	36.000	15.2500	0.0125	0.0004	0.0102	0.0027	78
16	32.500	6.900	0.0052	0.0000	0.0037	0.0015	71

Notes for Table 2:

- 1) Shrink Fit at 1500 rpm = Assumed Shrink Fit + Shaft Radial Expansion - Flywheel Bore Radial Expansion.
- 2) Shrink Fit Lost at 1500 rpm = (Assumed Shrink Fit - Shrink Fit at 1500 rpm)/Assumed Shrink Fit.

Based on the worst case assumed shrink fits shown in Table 2, shrink fit will exist at 1500 rpm for all flywheel groups except Flywheel Group 10. The shrink fit stresses at 1500 rpm will reduce the critical crack lengths reported in WCAP-14535, Table 4-3. Critical crack lengths including shrink fit stresses at 1500 rpm are provided in Table 3 below. As shown, these lengths are significantly larger than the lengths which are expected to be detectable with the examination procedure of Attachment A. Stress intensity factor as a function of critical crack length is shown in Figure 3, for Flywheel Group 1, which is representative of the Beaver Valley Units 1 and 2 flywheels. Stress intensity factor plots for the other flywheel groups are similar to Figure 3.

Table 3: Critical Crack Lengths Including Shrink Fit for Flywheel Overspeed of 1500 rpm

Flywheel Group	Critical Crack Length in Inches and % through Flywheel		
	RT _{NDT} = 0°F	RT _{NDT} = 30°F	RT _{NDT} = 60°F
1	15.2" (46%)	5.4" (16%)	1.3" (4%)
2	16.0" (49%)	5.6" (17%)	1.1" (3%)
10	15.1" (56%)	7.5" (27%)	3.3" (12%)
14	18.7" (67%)	10.9" (39%)	2.5" (9%)
15	8.2" (40%)	3.6" (18%)	1.6" (8%)
16	16.1" (66%)	9.3" (38%)	3.7" (15%)


It is important to point out that most flywheels are designed to lose their shrink fit at operating speed. The three keyways maintain the centering of the flywheels, which assures that balance is maintained. The imposition of a very large shrink fit would be detrimental to flywheel reliability, because of the difficulty in installation and removal of the flywheel. This would in turn detract from the consistency of assembly.

A concern was raised about excessive deformation in the Regulatory Guide. Excessive deformation was defined as "any deformation such as an enlargement of the bore that could cause separation directly or could cause an unbalance of the flywheel leading to structural failure or separation of the flywheel from the shaft." Therefore, the concern about excessive deformation is not related to the loss of shrink fit, but instead relates to the amount of deformation which could cause unbalance or failure.

Our extensive calculations have shown that the speed at which excessive deformations could occur is greater than or equal to the limiting flywheel speed for ductile failure. The flywheel would fail due to plastic instability at speeds of 3155 to 4032 rpm, as shown in Table 4-2, page 4-5 of WCAP-14535. Even with large flaws, the failure speed exceeds 3000 rpm, which is twice the maximum overspeed of 1500 rpm. Therefore, there is no concern with excessive deformation.

RCP Flywheel

Hoop Stresses



Flywheel Group 1

Radial Location for Plot =	5.8245 inch
Assumed Shrink Fit (Delta s) =	0.0052 inch
Flywheel Outer Radius (b) =	38.25 inch
Flywheel Bore Radius (a) =	4.8375 inch
Keyway Radial Length =	0.937 inch

Figure 1: Flywheel Group 1 Rotational and Shrink Fit Stresses

FLYWHEEL GROUP 1

FLYWHEEL BORE EXPANSION AND SHRINK FIT





Figure 2: Flywheel Group 1 Bore Expansion and Corresponding Shrink Fit

RCP FLYWHEEL

Stress Intensity Factor



Flywheel Group 1
Outer Radius (b) = 38.25 inches
Flywheel Bore (a) = 4.6875 inches
Keyway Length (d1) = 0.937 inches
Shrink Fit (Delta a) = 0.0018 Inch @ 1500 rpm

Figure 3: Flywheel Group 1 Stress Intensity Factor Including Shrink Fit

ATTACHMENT A
INFORMATION ON QUALIFICATION OF RCP FLYWHEEL EXAMINATIONS
AT BEAVER VALLEY

DUQUESNE LIGHT COMPANY
Nuclear Power Division
Quality Services Unit
Quality Services Inspection & Examination Department

TITLE: Manual Ultrasonic Examination of Reactor Coolant Pump (RCP) Flywheel	NDE PROCEDURE NUMBER UT-304 <table style="width: 100%;"> <tr> <td style="width: 50%;">REVISION 7</td> <td style="width: 50%;">PAGE 1 OF 11</td> </tr> </table>		REVISION 7	PAGE 1 OF 11
REVISION 7	PAGE 1 OF 11			

<u>Paul A. Ray</u>	11/9/94	<u>Thomas E. Hamlin, III</u>	11-14-94
PREPARED BY	DATE	LEVEL III APPROVAL	DATE

<u>M.A. Ryan</u>	11-17-94	<u>Edith Lunn</u>	11/18/94
OSIE DIRECTOR	DATE	ANTI REVIEW	DATE

<u>N/A Non-Intent</u>	11/22/94	<u>K. Homan</u>	11/22/94
OSC REVIEW	DATE	QS MANAGER APPROVAL	DATE

<u>K. Homan for use</u>	11/22/94		
GENERAL MANAGER NUCLEAR OPS.	DATE		

INDEX

<u>PAGE</u>	<u>REVISION</u>	<u>EFFECTIVE DATE</u>
Entire Procedure	4	January 3, 1991
Entire Procedure	5	November 27, 1992
Entire Procedure	6	April 6, 1993
Entire Procedure	7	December 9, 1994

1.0 PURPOSE AND SCOPE

- 1.1 To provide minimum requirements for the manual ultrasonic straight beam examination of RCP flywheels.
- 1.2 This procedure is intended to meet the ultrasonic requirements of NRC Regulatory Guide 1.14 Revision 1 (Reference 6.1).
- 1.3 This procedure is applicable to EVPS Units 1 and 2.

2.0 EXAMINATION REQUIREMENTS

NOTE: When using Ultragel II couplant, safety glasses or goggles are required. Individuals that are sensitive to detergents should wear gloves.

- 2.1 Ensure contact surfaces are clean and free from all foreign matter, pits, nicks, or dents, etc., that would adversely affect or limit the examination. If such conditions are noted, correct them prior to conducting the examination.
- 2.2 Examine the entire volume of the RCP flywheel to the maximum extent possible. Attach a drawing of any limitations encountered to the Flywheel UT Examination Report (Attachment 7.1).
- 2.3 Prior to beginning examinations, calibrate the ultrasonic instrument sweep to represent a linear 40 inch longitudinal wave sound path. This may be accomplished using a carbon steel IIW block and the straight beam search unit specified in Para. 5.2.2.
- 2.4 Keyway Corner Examination.

2.4.1 Calibration

- A. Apply couplant to one of the 1 inch diameter gage holes (A, B, C or D for Unit 1; A, B, C, D, E, or F for Unit 2).
- B. Insert the gage hole probe into the hole and direct the beam toward the flywheel center bore hole.
- C. Measure the distance from the gage hole to the center bore hole. Adjust the delay control only to position the response at the proper sweep position corresponding to the physical measurement.
- D. Obtain the maximum response from the center bore hole and adjust the gain to bring the response to 80% ($\pm 5\%$) FSH.

- E. Record the instrument gain setting and reflector ~~sweep~~ position on the Flywheel UT Examination Report.

2.4.2 Examination

- A. Increase the instrument gain a minimum of 6 dB.
- B. Starting at the top of the gage hole, rotate the probe from the maximum bore signal area to obtain the maximum response from the keyway corner, then back to the bore response. Continue to examine the full length of the keyway by inserting the probe in 1/2" increments.
- C. Examine the keyway corners for indications propagating from the keyway at approximately 90 degrees to the sound path.
- D. Repeat the entire calibration and examination cycle from each of the remaining gage holes, confirming calibration after each examination.

2.4.3 Recording

- A. Record all indications that exhibit a deviation from the normal keyway geometry response observed from each gage hole examination.

2.5 Radial Gage Hole Examination.

2.5.1 Calibration (Unit 1 Attachment 7.2)

- A. Apply couplant to gage hole D.
- B. Insert the gage hole probe into gage hole D and obtain the maximum response from ~~ream~~ bolt hole 5.
- C. Adjust the instrument gain to bring the response to 80% ($\pm 5\%$) FSH.
- D. Rotate the probe to obtain the maximum response from ~~ream~~ bolt hole 2.
- E. Construct a distance-amplitude correction (DAC) curve by connecting the maximum response points with a line.
- F. Record the instrument gain setting, sweep positions and amplitudes on the Flywheel UT Examination Report.

2.5.2 Calibration (Unit 2 Attachment 7.3)

- A. Apply couplant to gage hole F.

- B. Insert the gage hole probe into gage hole F and obtain the maximum response from rear bolt hole 4.
- C. Adjust the instrument gain to bring the response to 80% ($\pm 5\%$) FSH.
- D. Rotate the probe to obtain the maximum response from rear bolt hole 1.
- E. Construct a distance-amplitude correction (DAC) curve by connecting the maximum response points with a line.
- F. Record the instrument gain setting, sweep positions, and amplitudes on the Flywheel UT Examination Report.

2.5.3 Examination

- A. Increase the instrument gain a minimum of 6 dB.
- B. Starting at the top of the gage hole, slowly rotate the probe 360 degrees to examine the volume of the flywheel. Observe reflectors from flywheel geometric features as the probe is rotated, identifying each reflector source as it appears. Continue to examine the volume by inserting the probe in 1/2" increments.
- C. Repeat the examination from the remaining gage holes using the initial calibration settings.
- D. Confirm instrument calibration when radial gage hole examinations are completed using the steps outlined in para. 2.5.1 or 2.5.2.

2.5.4 Recording

- A. Record all unidentified reflectors equal to or greater than 50% DAC.

2.6 Peripheral Examination (Attachment 7.2 and 7.3)

2.6.1 Calibration

- A. Couple the straight beam search unit to the outside edge of the lower flywheel plate and obtain the maximum response from rear bolt hole 5.
- B. Adjust the gain to bring the response to 80% ($\pm 5\%$) FSH and mark the point on the screen.

- C. Couple the straight beam search unit to the outside edge of the upper flywheel plate and obtain the maximum response from ream bolt hole 5. Mark this point on the screen.
- D. Construct a DAC curve by connecting the response points with a line.
- E. Record the instrument gain setting, sweep positions and ~~amplitudes~~ on the Flywheel UT Examination Report.

2.6.2 Examination

- A. Increase the instrument gain a minimum of 6 dB.
- B. Scan the flywheel periphery face to include the area from the edge up to and including the ream bolt holes. Conduct this exam on both the upper and lower plates, 360 degrees, around the periphery.
- C. Where possible, progressively move the probe across and along the flywheel edge so as to scan the entire edge overlapping each previous scan by at least 25% of the transducer diameter.

2.6.3 Recording

- A. Record all unidentified reflectors equal to or greater than 50% DAC.

2.7 Calibration Confirmation

- 2.7.1 Confirm calibration at the intervals specified within each examination category.

- 2.7.2 Evaluate calibration confirmation in accordance with the following criteria:

- A. A DECREASE in sensitivity of more than 2dB requires recalibration and reexamination of all items examined since—the previous acceptable calibration or calibration confirmation.
- B. An INCREASE in sensitivity of more than 2dB requires recalibration and reinvestigation of all indications recorded since the previous acceptable calibration or calibration confirmation.

- C. If any point on the DAC curve has moved more than 10% of the sweep division reading, correct the sweep range calibration and note the correction on the flywheel examination report. If reflectors were recorded, recalibrate and reexamine all items examined since the previous acceptable calibration or calibration confirmation.

2.8 Post-Examination Cleaning

- 2.8.1 Dry-wipe the area to remove any temporary markings and couplant.

3.0 RECORDING REQUIREMENTS

- 3.1 Record data specified within each examination category on the Reactor Coolant Pump Flywheel Ultrasonic Examination Report.
- 3.2 Reports are to be numbered in accordance with QSP 9.4.
- 3.3 Documentation is considered as lifetime and treated as such in accordance with QSP 17.1.

4.0 ACCEPTANCE STANDARDS

- 4.1 Due to the techniques employed and the unique nature of this examination, all recorded reflectors will be evaluated by a UT Level III to determine their origin, size, location and orientation. This evaluation process will be performed and documented in accordance with GP-105.

5.0 PERSONNEL AND EQUIPMENT QUALIFICATIONS

5.1 Personnel Qualifications

- 5.1.1 Personnel performing examinations shall only perform tasks commensurate with their experience and level of certification.

- A. Duquesne Light personnel are certified in accordance with QSP 2.3.
- B. All individuals performing examinations to DDC UT procedure(s) shall receive sufficient training and orientation to ensure understanding of procedural requirements.

- C. Ultrasonic examination personnel who determine which indications ~~are to be recorded~~ shall have successfully completed a qualification program administered by the Quality Services Inspection & Examination Department which demonstrates proficiency in discriminating between ~~flaw~~ indications and indications of geometric or metallurgical origin.

5.2 Equipment Qualifications

- 5.2.1 UT Instrument - Use a pulse-echo instrument capable of establishing a minimum 40 inch metal path in the flywheel material. Additionally the instrument must meet the linearity requirements of UT-301.
- 5.2.2 Search Unit(s) - Use a 1.0 inch diameter, 2.25 MHz straight beam search unit for initial metal path calibration and for the periphery scans. For the gage hole examinations, use a .5" x .1", 2.25 MHz gage hole inspection wand. (Megasonics CI281 1" bore probe).
- 5.2.3 Couplant - Use Ultragel II, Sonotrace 40 or equivalent as permitted by the Pre-Engineered Material List.

6.0 REFERENCES

- 6.1 USNRC Regulatory Guide 1.14, Revision 1, dated August 1975
- 6.2 Duquesne Light Company Quality Services Inspection Examination NDE Procedures
- 6.3 ASME Boiler and Pressure Vessel Code, Section V, 1983 Edition, Summer 1983 Addenda
- 6.4 DLO. Nuclear Engineering Memorandum 90104, dated 4-19-85
- 6.5 ISI Letter ND3ISI:0106, dated 11-8-85
- 6.6 ~~Washington~~ response #DLH-86-512, dated 2-19-86
- 6.7 NPDAP 9.6 Expendable Products Control
- 6.8 Duquesne Light Company Quality Services Procedures 9.4, "Nondestructive Examinations"; 17.1 "Control of the Quality Services Unit QA Records"; 2.3 "Written Practice For Qualification and Certification of Nondestructive Examination and Testing Personnel"
- 6.9 DLO Quality Control Report #638, dated 3-9-93.

7.0 ATTACHMENTS


- 7.1 RCP Flywheel UT Examination Report
- 7.2 Unit 1 Flywheel Hole Identification Drawing
- 7.3 Unit 2 Flywheel Hole Identification Drawing

8.0 CHRONOLOGY OF CHANGES


- 8.1 Revision 7 - Incorporate safety requirements with the use of Ultragel II couplant, add Chronology of Changes Section, made administrative changes, and perform two year review.

9

Flywheel Hole Identification Drawing (Unit 1)



Flywheel Hole Identification Drawing (Unit 2)



ATTACHMENT B

**INFORMATION ON REQUALIFICATION OF PERSONNEL
AND EVALUATION OF MEGASONICS PROBE
FOR RCP FLYWHEEL EXAMINATIONS AT BEAVER VALLEY**

DUQUESNE LIGHT COMPANY
Quality Services Unit
QUALITY CONTROL REPORT

QCR NUMBER

638

STATION BVPS Units 1 & 2EQUIPMENT/SYSTEM Reactor Coolant Pump Flywheel UT ExamsREPORT TITLE Trip Report-Westinghouse Electro-Mechanical Division, Cheswick, PAEvaluation of Megasonics RCP Flywheel UT Examination Probe

On March 8, 1993, the author and George Ruck, Senior NDE Examiner traveled to the Westinghouse Electro-Mechanical Division in Cheswick, PA. The purpose of the trip was to perform an evaluation of the recently purchased reactor coolant pump flywheel UT examination probe.

The trip was arranged as a mutually beneficial evaluation of the Megasonics RCP flywheel probe on an actual RCP flywheel. Mr. Douglas Isman, Westinghouse NDE Level III, assisted in setting up a time when the Cheswick Plant would have a 75" diameter RCP flywheel available. The flywheel being manufactured had 6 gage holes in a circle 29" from the flywheel centerline. This design is similar to the RCP flywheels at BVPS Unit 2. (The Unit 1 flywheel has only 4 gage holes.)

The Megasonics flywheel probe differs in design from previously used probes in that the search unit element is curved to compensate for the convex entry surface required to make contact in the 1" diameter gage holes. The demonstrated net effect of this curvature is that the ultrasonic beam spread is greatly reduced due to the acoustic focusing effect. This focused beam allows easier identification of reflectors encountered as well as reduced signal to noise ratio from material characteristics.

The bore probe is used to perform two separate types of UT examinations on a RCP flywheel. The first type is the examination of the area surrounding the center bore hole and keyway corners from the gage holes. The Megasonics bore probe performed this task readily, exhibiting far less beam spread than the previously used probe, which was used for comparison.

The second type of examination is a 360° scan of the flywheel volume from each of the gage holes. In this examination, the Megasonics bore probe performed exceptionally well, providing excellent resolution of closely spaced holes at significant metal paths. The attached pages show specific calibration scenarios representative of UT-304 procedural requirements. As a result of observations made, several procedure revisions have been requested to fully take advantage of the probe capabilities.

Procedure UT-304 Revision 6 Date 3-16-93

☐ initial qualification
 ☒ requalification*
☐ requalification not required*

TEST OBJECT DESCRIPTION: UNIT 1 REACTOR COOLANT PUMP FLYWHEEL*

QUALIFICATION LIMITATIONS/COMMENTS: * "PRELIMINARY" QUALIFICATION DOCUMENTED
ON ATTACHED QCR #638. ACTUAL QUALIFICATION TO BE CONDUCTED
IN CONJUNCTION WITH EXAMINATION.

ATTACHMENTS:

☐ calibration record☐ test object drawing☐ examination record☒ other QCR #638

Ray Buck II 3-16-93
 Performed By Level Date
N/A N/A N/A
 Witness Level Date

Timothy C. Hines III 3-16-93
 Performed By Level Date
N/A N/A N/A
 Witness Level Date

Procedure qualification results are acceptable and procedure is qualified within the procedure scope and subject to the limitations noted above.

Timothy C. Hines 3-16-93
 DLOO Level III Date

Roger J. [Signature] 3-16-93
 ANII Date

* If requalification is not required, the DLOO. Level III should write a brief explanation in the comments section.

While the configuration of the flywheel examined is similar to the BVPS Unit 2 flywheel design, differences in actual flywheel configuration will necessitate procedure qualification on the actual flywheel(s). This qualification of the revised UT-304 will take place on the BVPS Unit 1 flywheel at Chaswick during April, 1993 in conjunction with the UT examinations. Unit 2 flywheel configuration will also be qualified in conjunction with UT examinations. This report will serve as a preliminary procedure qualification to validate the technique and to document the improved examination capabilities of the Magas.ics focused bore probe.

TCH/lmd

cc: M. A. Pargur
J. J. Giocondi
G. L. Buck
Factory Mutual AUII
OSIE File

REPORTED BY:

~~James E. Hume~~


UT-LTI

DATE: 3-11-93

REVIEWED BY:

J. J. Giocondi

3/11/93



FILE
AD 738K

NDE SUPPLEMENTARY REPORT

REPORT NO.

QCR 63B

PAGE


OF

MEGASONICS FLYWHEEL PROBE

Preliminary Procedure Qualification (Westinghouse Cheswick 3/8/93)

Westinghouse 6 BOLT 75" diameter FLYWHEEL (SIMILAR TO BVPS UNIT 2)

REMARKS/DETAILS




↑
17.6" METAL PATH


RANGE 49.0in
DELAY 0.023in
VEL 0.237 in/us
UNITS in
LEVEL OFF
PWR 29.0in
DEPTH 3.00in
POLARITY +
GAIN 66.0dB
DISPLAY FILT1
FREQ 2.5MHz
REJECT OFF
PULSE 22us
DAMPING 000P
PULSE ECHO
REP RATE 1 Hz
GAIN 66.0dB
REF LVL 49.0in
X CHARGE 1000
AD CHARGE 26.0

RADIAL GAGE HOLE EXAMINATION

PROBE IN GAGE HOLE "F"

REFLECTION FROM REAR BOLT HOLE "4"





FILE
ADJ. 120K

NDE SUPPLEMENTARY REPORT

REPORT NO.

QCR 638

PAGE


OF

MEGASONICS Flywheel Probe

PRELIMINARY PROCEDURE QUALIFICATION (WESTINGHOUSE Cheswick 3/6/93)

WESTINGHOUSE 6 BOLT 75" DIAMETER FLYWHEEL (SIMILAR TO BURS UNIT 2)

REMARKS/DETAILS




↑
28" METAL PATH
↑
(23.2" METAL PATH (GAGE HOLE B))

RANGE 49.0in
 DELAY 1.29in
 VEL 0.237 in/us
 UNITS in
 LEVEL OFF
 PGM 31.0in
 WIDTH 3.00in
 POLARITY +
 GAIN 77.6dB
 DISPLAY FILT
 FREQ 2.25MHz
 REJECT OFF
 PULSE 222ns
 DWTNG 0001
 PULSE EDGE
 REP RATE 1 Hz
 GAIN 77.6dB
 REF LVL 49.0in
 X CORR 100K
 DB CORR 37.4

RADIAL GAGE HOLE EXAMINATION

PROBE IN GAGE HOLE "F"

REFLECTION FROM REAM BOLT HOLE "1"





FILE
AD.738X

Duquesne Light

NDE SUPPLEMENTARY REPORT

REPORT NO

QCR 63E

PAGE


OF

MEGASONICS FLYWHEEL Probe

PRELIMINARY PROCEDURE QUALIFICATION (WESTINGHOUSE CHESWICK 3/8/93)


WESTINGHOUSE 6 BOLT 75" DIAMETER FLYWHEEL (SIMILAR TO BVP5 UNIT 2)

REMARKS/DETAILS



12 1/2" METAL PATH

RANGE 60.0in
DELAY 1.23in
VEL 0.237 in/us
UNITS in
LEVEL OFF
FORM 31.0in
WIDTH 2.00in
PULSIVITY 0
GAIN 75.4dB
DISPLAY FILTER
PULSE 2.230us
REJECT OFF
PULSE 222us
DAMPING 900P
PULSE ECHO
REP RATE 1 Hz
GAIN 75.4dB
REP LVL 60.0dB
X CORRE 1000
dB CORRE 75.4



RADIAL GAGE HOLE EXAMINATION

Probe in GAGE hole "F"

Reflection from GAGE hole "E"



FILE
AD 738K

Duquesne Light

NDE SUPPLEMENTARY REPORT

REPORT NO.

QCR 638

PAGE


OF

MEGASONICS FLYWHEEL PROBS

PRELIMINARY PROCEDURE QUALIFICATION (WESTINGHOUSE CHESWICK 3/6/93)

WESTINGHOUSE 6 BOLT 75" DIAMETER FLYWHEEL (SIMILAR TO BUPS UNIT 2)

REMARKS/DETAILS




23.2" METAL PATH

RANGE 49.0in
DELAY 1.29in
VEL 0.237 in/us
UNITS in
LEVEL OFF
FOUN 31.0in
WIDTH 3.00in
POLARITY +
GAIN 75.4dB
DISPLAY FILTER
FREQ 2.25MHz
REJECT OFF
PULSE 225ns
DAMPING 0.001
PULSE ECHO
REP RATE 1 kHz
GAIN 75.4dB
REF LVL 49.0dB
X CHANGE 100in
dB CHANGE 25.4

RADIAL GAGE HOLE EXAMINATION

PROBE IN GAGE HOLE "F"
REFLECTION FROM GAGE HOLE "D"



ATTACHMENT C

ASME TECHNICAL PUBLICATION

PAPER NO. 74-PVP-25

REACTOR COOLANT PUMP FLYWHEEL OVERSPEED EVALUATION



Reactor Coolant Pump Flywheel Overspeed Evaluation

P. G. RICCARDELLA¹

General Atomic Co.,
San Diego, Calif.

W. H. BAMFORD

Westinghouse Nuclear
Energy Systems,
Pittsburgh, Pa.

The overspeed capability of the large steel flywheels used on light water reactor primary coolant pumps has been evaluated through a combined analytical and experimental effort. Limiting speeds of the prototype flywheel design were calculated for the ductile failure mode using the principles of Section III of the ASME Boiler and Pressure Vessel Code, and for the brittle fracture mode using a fracture mechanics approach in which stress intensity factors were determined from finite element computer analysis. The accuracy of the analytical approach was verified by a scale model test program which demonstrates excellent agreement between experiment and analysis. The results of the evaluation are presented in this paper, and they illustrate the kinds of things which can be accomplished through application of modern fracture mechanics technology, including plasticity considerations, to the solution of hardware problems of real engineering interest.

Introduction

In the event of a postulated loss of coolant accident in a pressurized water reactor plant, it is possible for the reactor primary coolant pump to achieve speeds on the order of two to three times its normal design speed. At speeds of this magnitude, concern arises as to the likelihood of components of the pump-motor assembly fracturing and producing high energy missiles within the containment. Of utmost concern in this regard is the reactor coolant pump flywheel, since it possesses the most rotational inertia in the pump-motor assembly, and thus the highest amount of energy at a given speed.

The Westinghouse coolant pump flywheel design consists of two large steel disks, 75 in. and 65 in. in diameter, which are bolted together in order to provide the necessary rotational inertia to maintain flow and thus prevent core overheating in the event of loss of power to the pump. A sketch of the flywheel assembly, showing the significant details and dimensions is given in Fig. 1. The two plates are 7.5 in. thick and 6.5 in. thick, respectively, and contain numerous holes and keyways as shown. The flywheel is fabricated from A-533, Grade B, Class 1 steel plate.

The purpose of this evaluation is to determine the speed at which this flywheel design becomes critical from the standpoint of fracture and subsequent missile production. An analytical approach is taken, utilizing the methods of Section III of the

ASME Boiler and Pressure Vessel Code for ductile failure considerations, and utilizing the principles of linear elastic fracture mechanics (LEFM) for brittle fracture considerations. Due to plasticity, the LEFM approach is not strictly applicable to this




Fig. 1 Reactor coolant pump flywheel geometry

¹Formerly, of Westinghouse Nuclear Energy Systems.

Numbers in brackets refer to Figures at end of paper.

Contributed by the Pressure Vessels and Piping Division for presentation at the Pressure Vessels and Piping Conference with Nuclear Engineering and Materials Division, Miami Beach, Fla., June 24-28, 1974, of THE AMERICAN SOCIETY OF MECHANICAL ENGINEERS. Manuscript received at ASME Headquarters, March 23, 1974. Paper No. 74-PVP-35.

Copies will be available until March, 1976.




Fig. 2 Notation used in Gyrhwal evaluation

problem, and thus a scale model test program was implemented to verify the analysis. A summary of the Gyrhwal evaluation and the supporting test program is given in this paper. A more detailed report on this work can be found in [1].

Ductile Failure Analysis

Gyrhwal Stress. The stresses in the reactor coolant pump Gyrhwal, neglecting local stress concentrations such as holes and keyways, can be calculated by the following equations [2],

$$\begin{aligned} \sigma_r &= \left(\frac{3+p}{8} \right) \rho \omega^2 \left[b^2 + a^2 - \frac{a^2 b^2}{r^2} - r^2 \right] \\ \sigma_\theta &= \left(\frac{3+p}{8} \right) \rho \omega^2 \left[b^2 + a^2 + \frac{a^2 b^2}{r^2} - \left(\frac{1+3p}{3+p} \right) r^2 \right] \end{aligned} \quad (1)$$

where the notation is defined in Fig. 2. Substituting the appropriate geometric data for the reactor coolant pump Gyrhwal (Fig. 1) into equation (1), and noting that the material density (ρ) is given by 0.238 lbm/in³, the stresses at various radial depths can be described as a function of angular velocity ω (rad/sec)




Fig. 3 Shapes of Gyrhwal stress distributions

as shown in Fig. 3. Note that the circumferential stress (σ_θ) is essentially linear over about 90 percent of the Gyrhwal radius, with a sharp peaking effect due to the stress concentration at the bore. Although the magnitude of the stresses will vary with angular velocity, the shape of the stress distribution shown in Fig. 3 will be the same at any speed. The shape of the stress distribution has an important effect upon the behavior of the Gyrhwal and must be considered explicitly when applying stress limits to the calculated stresses.

Faulted Caststeel Stress Limits. The capacity of a structure to resist ductile failure with sufficient margin of safety during faulted conditions can be demonstrated by meeting the faulted condition criteria of Section III of the ASME Boiler and Pressure Vessel Code [3] (Appendix F). The faulted condition limits for elastic analysis are as follows

$$\begin{aligned} P_m &< 0.7 S_u \\ P_m + P_b &< 1.05 S_u \end{aligned} \quad (2)$$

where S_u is the minimum specified ultimate tensile strength of the material, P_m is the primary membrane stress intensity under faulted condition loading, and P_b is the primary bending stress intensity. (The term stress intensity is defined here as twice the Tresca maximum shear stress in accordance with the Section III definition of the term, and should not be confused with the linear elastic fracture mechanics stress intensity factor which is used later in this paper.)

Since the thickness direction stress (σ_z) in the Gyrhwal is assumed to be negligible, and the radial stress (σ_r) always falls between the thickness direction stress and the circumferential stress (σ_θ), the maximum stress intensity at any point in the Gyrhwal is equal to the circumferential stress. In order to apply the stress limits of equation (2) to a nonlinear stress distribution such as that shown for σ_θ in Fig. 3, the actual stress distribution must be resolved into the membrane and bending components

$$\begin{aligned} P_m &= \frac{1}{(b-a)} \int_a^b \sigma_\theta r dr \\ P_b &= \frac{6}{(b-a)^2} \int_a^b \sigma_\theta (r_m - r) dr, \end{aligned} \quad (3)$$

where r_m is the Gyrhwal mean radius defined as $(a+b)/2$. Substituting the circumferential stress term from equation (1) and carrying out the integrals in (3) yields

$$\begin{aligned} P_m &= \left(\frac{3+p}{8} \right) \frac{\rho \omega^2}{(b-a)} (b^2 - a^2) \left[1 - \frac{1}{3} \left(\frac{1+3p}{3+p} \right) \right] \\ P_b &= \left(\frac{3+p}{8} \right) \frac{6 \rho \omega^2}{(b-a)^2} \left(\frac{b^4}{12} \left(\frac{1+3p}{3+p} \right) \right. \\ &\quad \left. + \frac{ab^3}{2} \left[1 - \frac{1}{3} \left(\frac{1+3p}{3+p} \right) \right] - \frac{a^4 \ln(b/a)}{2} \right. \\ &\quad \left. - \frac{ab^3}{2} \left[1 + \frac{1}{3} \left(\frac{1+3p}{3+p} \right) \right] - \frac{a^4}{12} \left(\frac{1+3p}{3+p} \right) \right) \end{aligned} \quad (4)$$

Finally, substitution of the appropriate geometric data from Fig. 1 into equation (4) yields

$$\begin{aligned} P_m &= 0.40 \omega^2 \text{ (psi)} \\ P_b &= 0.23 \omega^2 \text{ (psi)} \end{aligned} \quad (5)$$

Equations (2) and (5) will now be compared in order to evaluate the speed at which the Gyrhwal stresses exceed the Section III faulted condition criteria.

Results. Values of P_m and ($P_m + P_b$) have been calculated from equation (5) and compared to the faulted condition stress limits of equation (2) to determine the limiting Gyrhwal speed

of 80,000 psi was used in computing the faulted condition limits which is the minimum specified value for A-533 Grade B, Class 1 steel given in [3]. The limiting speed based on the membrane + bending stress limit is 365 rad/sec or 3485 rpm, and the limiting speed based on the membrane stress limit is 372 rad/sec or 3550 rpm. Therefore, the membrane + bending limit is governing.

In summary, the results of the analysis performed in this section demonstrate that the reactor coolant pump flywheel can withstand a rotational speed of 3485 rpm, which corresponds to approximately a 200 percent overspeed condition (Fig. 10) without exceeding the faulted condition criteria (Appendix F) of Section III of the ASME Boiler and Pressure Vessel Code. Compliance with these limits assures that the flywheel can withstand this overspeed condition with sufficient margin from the standpoint of ductile failure.

Brittle Fracture Evaluation

Closed Form Stress Intensity Factor Solution. An approximate solution for the stress intensity factor for a radial crack emanating from the bore of a rotating disk has been reported by Williams and Isherwood [4], and is given by the following expression

$$K_I = \rho \omega^2 R^2 \Phi \left[\frac{\pi \left(\frac{c}{b} - \frac{a}{b} \right)}{(1 - \nu^2)} \right]^{1/2} \quad (6)$$

where

$$\Phi = \left(\frac{3 + \nu}{32} \right) \left[3 \left(1 + \frac{a^2}{b^2} \right) + 3 \left(\frac{a}{b} \right) \left(\frac{b}{c} \right) + \left(1 + \frac{a}{b} + \frac{a^2}{b^2} \right) \frac{\left(1 - \frac{a}{b} \right)}{\left(1 - \frac{c}{b} \right)} \right] - \left(\frac{1 + 3\nu}{32} \right) \left[\frac{\left(\frac{c}{b} \right)^3 - \left(\frac{a}{b} \right)^3}{\left(\frac{c}{b} - \frac{a}{b} \right)} + \frac{1}{2} \frac{\left(1 - \frac{a}{b} \right)^3}{\left(1 - \frac{c}{b} \right)} \right] \quad (7)$$

and where the geometric quantities a , b , and c are defined in Fig. 2. The quantities ρ and ω refer to the material density and angular velocity as before. Substituting appropriate geometric data from Fig. 1 into equations (6) and (7) leads to stress intensity factor as a function of angular velocity for various assumed cracked depths as shown by the solid curve in Fig. 4. Note that for the case of a crack emanating from a keyway, the keyway depth is included as part of the total crack depth for conservatism.

Inspection of Fig. 4 indicates that the closed form solution technique erroneously gives a nonzero value of stress intensity factor for zero crack depth. Thus it becomes obvious that the assumption of adding keyway depth to crack depth is overly conservative for very short crack depths. In order to eliminate this undue conservatism, and to consider the effect of the keyway more accurately, a detailed finite element model of the flywheel with a crack emanating from the keyway was set up and analyzed.

Finite Element Analysis. Approximately 500 constant strain triangular finite elements were used to model the reactor coolant pump flywheel for analysis using the computer program PPCNT [5]. A detailed illustration of the models used in the analyses is shown in Fig. 5. Due to symmetry, only a 60-deg segment of




Fig. 4 Stress intensity factor computations for reactor coolant pump flywheel

the flywheel, including half of one keyway, is required to model the complete flywheel. A number of different crack depths and locations were studied by placing the special cracktip model at various locations within the fine grid region. Elastic solutions were obtained for all cases assuming the loading to be due only to centrifugal forces resulting from flywheel spinning. The effects of contact loading at the inner bore and keyways were assumed to be negligible, and the flywheel was assumed to be in a state of plane strain. Values of stress intensity factor were estimated from the numerical stress results in the vicinity of the cracktip by fitting the data to the first two terms of the series expansion for the crack tip stress field along the plane of the crack given by




Fig. 5 Finite element model of reactor coolant pump flywheel

$$\sigma_r = \frac{\sigma_y}{\sqrt{2\pi r}} + C, \quad (b)$$

where r is the radial distance from the crack tip, C is an arbitrary constant, and K_I is the cracktip stress intensity factor. This procedure is described in detail elsewhere [6], and leads to the finite element stress intensity factor data shown by the dashed curves in Fig. 4.

The agreement between the closed form and numerical results in Fig. 4 is excellent for crack depths of 1.0 in. and greater, thus providing an independent check of one technique against the other for those crack depths. For crack depths less than 1.0 in., however, the closed form solution with its ultraconservative keyway assumption gives unrealistically high stress intensity predictions. It is also noteworthy that, contrary to what one would expect, the stress intensity factor for a 0.5 in. crack emanating from the keyway corner is smaller than that for the same crack emanating from the center of the keyway. This phenomenon can be explained by the fact that the stress concentrating effect of the keyway corner is extremely localized, and thus has no effect at a distance 0.5 in. from the corner. The stress intensity factor for cracks of this size is governed by the overall flywheel stress distribution rather than by local stress concentrations.

The stress intensity factor data of Fig. 4 will now be compared to the material fracture toughness to determine critical speeds for the flywheel as a function of assumed crack depth. Based on the above discussion, the most meaningful stress intensity factor data of Fig. 4 is the finite element curve for a crack emanating from the center of the keyway, and this curve will therefore be used in the remainder of the evaluation.

Fracture Toughness. The fracture toughness and other mechanical properties of A-533 Grade B, Class 1 steel have been studied extensively under the AEC Heavy Section Steel Technology Program [7, 8, 9, 10]. Lower bound fracture toughness versus temperature data for both the longitudinal (RW) and transverse (WR) directions were obtained in this program using the equivalent energy concept for lower bound fracture toughness testing. The data were obtained from several heats of steel, all of which had drop weight nil ductility transition temperatures in the range of 0 deg F to +10 deg F. Therefore this data should be applicable to reactor coolant pump flywheel material with the same transition temperature.

Stress. The flywheel operating temperature is +120 deg F, and the minimum material fracture toughness at this temperature from [9] is 220,000 psi $\sqrt{in}$. This value is for the weak or transverse direction, the longitudinal direction toughness being much higher. Thus, the analysis assumes the worst possible location and orientation of any flaw which may exist. Using this toughness value, and the finite element data for a center keyway crack (Fig. 4), critical flywheel speeds have been determined as a function of crack depth, and are shown along with the ductile failure limit in Fig. 30.

Plasticity Considerations. Strict applicability of linear elastic fracture evaluation is limited to situations in which the extent of plastic flow in the vicinity of the cracktip is small in comparison to the crack depth and other pertinent geometric quantities of the problem. Irwin [11] has suggested the following approximation for plastic zone size in a plane strain crack problem

$$r_p = \frac{1}{6\pi} \left(\frac{K_I}{\sigma_y} \right)^2, \quad (b)$$

where K_I is the applied stress intensity factor and σ_y is the material yield strength. Values of plastic zone size have been calculated according to this expression for the reactor coolant pump flywheel at incipient fracture ($K_I = K_{IC}$), and the results are summarized in Table 1.

Flaw size (d)	Plastic zone size (r_p)	Ratio (r_p/d)
0.5 in	0.52 in	1.04
1.0 in	0.52 in	0.52
2.0 in	0.52 in	0.26

The plastic zone sizes listed in Table 1 are far too large to satisfy the plasticity limitations of linear elastic fracture mechanics. Nonetheless, the critical speed calculations of the previous section are expected to be accurate.

In the pump flywheel problem, the plasticity is completely contained. That is, due to the large stress gradients (Fig. 3), the outer periphery of the flywheel remains elastic even at the calculated critical speed levels. Contained plasticity such as this creates, in effect, a strain controlled loading situation for which experience has shown [12, 13] that elastically calculated strain distributions are accurate well beyond the limits of strict applicability of the theory of elasticity. This concept of "strain equivalence" is well accepted in low cycle fatigue applications, and its extension to fracture problems is straightforward.

Accepting this strain equivalence argument allows one to justify the use of linear elastic fracture mechanics for the flywheel evaluation using Rice's J-integral Concept [14]. It has been shown experimentally [15, 16] that the J-integral is a parameter which takes on a critical value (J_{IC}) at fracture over the complete range from linear elastic to fully plastic behavior. It is well established that in the elastic range the J-integral approach is identical to linear elastic fracture mechanics. However, due to the principle of strain equivalence discussed above, the identity between J and LEFM can be extended well into the elastoplastic range in strain controlled loading situations [17]. Hence, the reactor coolant pump flywheel evaluation presented herein is essentially a J-integral evaluation, and as such is valid regardless of the extensive plastic zone sizes developed.

In summary, the methods used to predict brittle fracture in the reactor coolant pump flywheel are not strictly applicable because of extensive plasticity. However, it is argued that the flywheel is a strain controlled loading situation for which the methods used correspond to an elastoplastic J-integral approach which is applicable. In order to confirm these arguments, a scale model test program was implemented and is discussed later in this paper.

Flywheel Inspection and Quality Assurance

Material Qualification Tests. Wrought reactor coolant pump flywheels are fabricated from A-533 Grade B Class 1 steel plate which is produced by a process that minimizes flaws in the material and improves its fracture toughness properties (vacuum degassing, vacuum melting, or electroslag remelting). Supplier certification reports are available for all plates and they demonstrate the acceptability of the flywheel material on the basis of the following requirements [18]:

- The nil-ductility transition temperature (NDTT) is obtained by two drop weight tests which must exhibit "no-brake" performance at 20 deg F in accordance with the rules of ASTM Testing Procedure E-208 [19]. These drop weight tests ensure that the NDTT of the flywheel material is no higher than +10 deg F.
- A minimum of three Charpy V-notch impact specimens are tested at ambient (+70 deg F) temperature in accordance with ASTM specification E-23 [20]. The Charpy V-notch energy in both the parallel and normal orientation with respect to the rolling direction of the flywheel material must be at least 50 ft-lb.

Compliance with the foregoing criteria insures that all reactor coolant pump flywheel material has a low enough NDT temperature and a high enough upper shelf toughness so that the lower bound fracture toughness data of [9] are applicable.




Fig. 6 Scale model flywheel fabrication procedure

Pre-Test Examination. Each flywheel plate is subjected to 100 percent volumetric ultrasonic examination in accordance with paragraph NB-2532.1 and NB-2532.2 of Section III of the ASME Boiler and Pressure Vessel Code [3] for acceptance. After fabrication, the finished machined bore and keyways are subjected to magnetic particle or liquid penetrant surface examinations. The finished flywheels are also subjected to a 100 percent ultrasonic examination according to the above referenced paragraphs of [3].

In addition to the aforementioned shop inspections, the flywheels receive extensive further examination as part of the required inspection program for reactor coolant pump flywheels [18]. A surface examination and full 100 percent ultrasonic examination are performed at approximate ten-year intervals. Waddinghouse is also introducing a new inspection procedure [21], in which the critical regions of the flywheel (bore, keyway, and bolt hole regions) can be examined ultrasonically by passing a transducer through each of the four gap holes in the flywheel (see Fig. 1). This new procedure provides a more thorough examination of these critical regions, and can be used at more frequent intervals since it does not require removal of the flywheel.

All of the ultrasonic tests discussed in the foregoing are calibrated to provide detectability of flaws as small as 0.25 in. in radial penetration. Thus flaws on the order of 0.5 in. are a factor of two greater than the inspection capability of the techniques being used. Furthermore, inspections of the flywheel are both extensive and frequent. It can, therefore, be concluded that flaws of this size will not escape detection in flywheels and that flywheels containing such flaws will not be accepted for service.

Scale Model Test Program

In order to verify the analytical procedures used in the pressure flywheel over-speed evaluation, a scale model flywheel test pro-

gram was implemented. A 1/4-in. thick model flywheel (quarter-scale in-plane dimensions, full thickness) was fabricated with flaws present in the most critical locations and orientation. Analytical failure predictions were made using the same methods as were used for the prototype flywheel evaluation. The models were then tested to failure and the actual fracture speeds compared favorably with the analytical predictions, thus lending a high degree of credibility to the pump flywheel analysis.

Model Fabrication. Fabrication of scale model flywheels with sharp cracks requires a relatively complex machining procedure (see Fig. 6) which has been developed at the Westinghouse Research and Development Laboratories [22]. In the initial machining phase (Step I), three 21 in. square blanks with thicknesses of 9.5 in. were machined from a 12-in.-thick plate of A533 Grade B Class 1 steel. One-quarter in. holes were then bored at prescribed distances (D) from the centerpoint of the blanks. The holes were also counterbored at the top and bottom surface as shown in Fig. 6 to accommodate the pressure cycling device used for precracking. Finally, an electric arc discharge machining (EDM) technique was used to produce a 1/8-in.-long slot extending from the 1/4 in. hole. Step II in the model fabrication procedure was fatigue precracking. A pressure cycling device was used to pulse pressure in the holes at a frequency of 60 cps, and an ultrasonic flaw detection scheme was used to continuously monitor and control crack growth during the pressure cycling operation. Maximum pressure during fatigue precracking was limited as a function of crack length in order to avoid the problems associated with excessive cracktip plasticity during precracking [22]. In the final phase of fabrication (Step III), the models were machined to their final dimensions by removing the excess peripheral and surface material as shown in Fig. 6. The inner bore, keyway and a slot from the keyway to the 1/4-in. hole were also machined in this step.

The final models thus contained composite cracks of prescribed lengths consisting of a machined slot, a 1/4-in. hole, an EDM slot, and a fatigue precrack, all emanating from the keyways in the flywheel bore. The irregularity of the crack surface does not affect the validity of the experiment since the magnitude of stress intensity factor is only affected by crack shape in the very near cracktip region. Note also that the final crack is oriented in the transverse or weak direction with respect to the rolling direction (WR). The crack also parameter D was chosen so as to yield nominal final crack depths of 1 in., 3 in., and 5 in. The exact value of crack depth could not be determined until after the tests, however, due to variability in the lengths of the fatigue precracks.

Preliminary Pressure Toughness Tests. In order to characterize the fracture toughness of the specific heat of material used to fabricate the scale model flywheels, six standard compact tension specimens [23] were fabricated from the same plate. The specimens were taken in the transverse (WR) orientation and were 2.0 in. in thickness (TICT). Tests were performed at 0 deg F, +60 deg F, and +70 deg F, and values of fracture toughness were determined from the specimen load-deflection curves using Witt's equation as energy concept for lower bound fracture toughness testing. Note that the specimens were not large enough to be interpreted according to the ASTM recommended testing procedure [23]. Fig. 7 shows the fracture toughness data obtained in this manner. For comparison, the lower bound fracture toughness curve used in the flywheel analysis [9] has been indicated to the model material drop weight NDTT and is shown in this figure. Note that the experimental data are significantly higher than the lower bound curve, which is an indication of the conservatism associated with that curve for this heat of steel. The experimental data rather than the lower bound curve will be used in making the fracture predictions for the scale model flywheels in order to provide a meaningful evaluation of the accuracy of the analytical techniques used.




Fig. 7 Fracture toughness data for scale model (Yrwell) materials

Analysis of Fracture Prediction. As in the prototype flywheel overspeed evaluation, the scale model flywheels were evaluated on the basis of both ductile failure and brittle fracture considerations.

The method for ductile failure analysis follows the foregoing description for the prototype flywheel, except the ultimate tensile strength of the material ($S_u = 80,000$) is used in place of the Section III failed condition limit ($0.7 S_u$) since no safety margin is desired when making the failure prediction. Substituting the scale model flywheel dimensions into equations (4) yields

$$P_o = 0.025 \omega^2 R \quad (\text{psi})$$

$$P_b = 0.014 \omega^2 R \quad (\text{psi}) \quad (10)$$

For the scale model flywheel, the predicted cracks represent a significant reduction in load bearing area of the cracked plane. Referring to Fig. 2, the effect of reduced bearing area can be incorporated into equations (10) by the following approximation

$$P_o = 0.025 \omega^2 R \quad (\text{psi})$$

$$P_b = 0.014 \omega^2 R \quad (\text{psi}) \quad (11)$$

where

$$R = \frac{2\theta - \phi}{2\theta - \phi - d} \quad (12)$$

Assuming that failure occurs when P_o exceeds S_u or when $(P_o + P_b)$ exceeds $1.5 S_u$, leads to the following expressions for ductile failure speed as a function of crack size

$$\omega_c = \sqrt{\frac{S_u}{0.025 R}} \quad (13)$$

$$\omega_c = \sqrt{\frac{1.5 S_u}{0.039 R}}$$

where ω_c is the critical speed based on the membrane stress and




Fig. 8 Comparison of analysis and experiment for scale model flywheel stress

ω_c is the critical speed based on the membrane + bending stress. Values of ω_c and ω_b have been calculated as a function of crack depth. As in the case of the prototype flywheel, the two limiting speeds are very close; however, the membrane + bending limit (ω_b) is governing. This limit is shown as a dashed line in Fig. 8.

The method for brittle fracture analysis of the scale models also follows that of the prototype fracture evaluation, however, the experimentally measured material fracture toughness data of Fig. 7 are used in place of the lower bound fracture toughness curve. Substituting the scale model flywheel parameters into equations (6) and (7) yields model flywheel stress intensity factor data which have been compared to the average value of measured fracture toughness of the model material at the test temperature (+75 deg) to predict critical speeds for brittle fracture of the scale model flywheel. These limiting speeds are shown as the solid line in Fig. 8.

A third set of limiting speeds is shown in Fig. 8, which is representative of critical speeds as determined in the prototype flywheel evaluation. The critical speeds for the pump flywheel calculated in the section, entitled "Ductile Failure Analysis" and "Brittle Fracture Evaluation" are not failure speeds since they are based upon $0.7 S_u$ for ductile failure and a lower bound fracture toughness curve for brittle fracture. The safety margins associated with these methods of critical speed determination are illustrated in this figure.



Fig. 9 Typical fracture of scale model flywheel




Fig. 10 Results of reactor coolant pump flywheel overspeed evaluation

Test Results. The three scale model flywheels, fabricated as described above, were tested to failure in the high speed turbine rotor testing machine at Westinghouse Research Laboratories. The tests were performed at room temperature (+75 deg) and test temperature and rotational speed were monitored continuously throughout the test.

The specimens fractured in the manner shown in Fig. 9. The fracture data from these experiments are plotted on Fig. 8, in terms of fracture speed versus actual crack depth for comparison with analysis. The agreement between the fracture predictions and the experimental data is excellent, thus lending a high degree of credibility to the analytical procedures used in the prototype flywheel evaluation, even in the presence of extensive plastic zone sizes.

Conclusions

A detailed evaluation has been performed to determine the critical speed for the Westinghouse reactor coolant pump flywheel design from the standpoint of fracture and subsequent missile production. The results of this study are summarized in Fig. 10.

Ductile failure and brittle fracture of the flywheel were considered separately and limiting speeds were established for each. The limiting speed curve of Fig. 10 shows that the ductile failure limit of 3485 rpm (290 percent overspeed) is governing for crack sizes less than 1.15 in., and that the brittle fracture limit becomes governing for larger crack sizes. Since this crack size is very large in comparison to that which is detectable under current inspection and quality assurance procedures for the flywheel design, it can be concluded that 3485 rpm is the limiting speed for the design.

Finally, a scale model flywheel test program was carried out to verify the analytical procedures used in this evaluation. Three tests were performed, and the results of all three were highly confirmatory. On the basis of this scale model test program, it can be concluded that the methods used to predict flywheel fracture in this report are highly accurate and, in conjunction with the conservative materials property data used, should serve to preclude flywheel fracture under overspeed loading conditions providing the calculated limiting speeds are not exceeded.

Acknowledgment

The authors gratefully acknowledge the assistance of Messrs.

L. R. Singer, G. O. Sankay, and L. J. Ceschini in carrying out the experimental portion of this program.

References

- 1 Ricciardella, P. C., and Bamford, W. A., "Reactor Coolant Pump Overspeed Evaluation," Westinghouse Nuclear Energy Systems, WCAP-8145, Dec. 1973.
- 2 Timoshenko, S., and Goodier, J. N., "Theory of Elasticity," 3rd edition, McGraw-Hill, New York, 1970.
- 3 ASME Boiler and Pressure Vessel Code, Section III, "Rules for Construction of Nuclear Power Plant Components," American Society of Mechanical Engineers, New York, 1971 Edition & Addenda.
- 4 Williams, J. G., and Isherwood, D. P., "Calculation of the Strain-Energy Release Rates of Cracked Plates by an Approximate Method," *Journal of Strain Analysis*, Vol. 3, No. 1, 1968, pp. 17-22.
- 5 Gabriels, S. E., "User's Manual for Westinghouse Research General Purpose Finite Element Programs," Westinghouse Research Report 70-1E7-POPSC-R1, April 23, 1970.
- 6 Oglesby, J. J., and Lomack, O., "An Evaluation of Finite Element Methods for the Computation of Elastic Stress Intensity Factors," *Trans. ASME*, Vol. 95, Series B, 1973, pp. 177-185.
- 7 Mager, T. R., and Thomas, F. O., "Evaluation by Linear Elastic Fracture Mechanics of Radiation Damage to Pressure Vessel Steel," Westinghouse Nuclear Energy Systems, WCAP-7328.
- 8 Mager, T. R., "Fracture Toughness Characterization Study of A533 Grade B, Class 1 Steel," Westinghouse Nuclear Energy Systems, WCAP-7578, Oct. 1970.
- 9 Mager, T. R., and Buchalet, C., "Experimental Verification of Lower Bound K_{IC} Values Utilizing the Equivalent Energy Concept," HSST Program 6th Annual Information Meeting, Paper No. 23, Apr. 1972.
- 10 Witt, F. J., "A Procedure for Determining Bounding Values on Fracture Toughness K_{IC} at any Temperature," Oak Ridge National Laboratory, ORNL-TM-3894, Oct. 1972.
- 11 Irwin, G. R., "Fracture," *Encyclopedia of Physics*, Vol. 6, edited by S. Flügge, Springer-Verlag, NY, 1958, pp. 551-590.
- 12 Manson, S. S., "Thermal Stress and Low-Cycle Fatigue," McGraw-Hill, New York, 1966.
- 13 Langer, B. P., "Design of Pressure Vessels for Low-Cycle Fatigue," *Trans. ASME*, Vol. 84, Series D, 1973, pp. 389-402.
- 14 Rice, J. R., "A Path Integral and the Approximate Analysis of Strain Concentration by Notches and Cracks," *Trans. ASME*, Vol. 90, Series E, 1968, pp. 379-384.
- 15 Begley, J. A., and Landes, J. D., "The J-Integral as a Fracture Criterion," *Fracture Toughness*, ASTM-STP-514, American Society for Testing and Materials, Philadelphia, 1972, pp. 1-23.
- 16 Landes, J. D., and Begley, J. A., "The Effect of Specimen Geometry on J_{IC} ," *Fracture Toughness*, ASTM-STP-514, American Society for Testing and Materials, Philadelphia, 1972, pp. 24-39.
- 17 Ricciardella, P. C., and Swedlow, J. L., "A Combined Analytical-Experimental Fracture Study," presented at Seventh National Symposium on Fracture Mechanics, August 27-29, 1973, University of Maryland, American Society for Testing and Materials, Philadelphia, Pa. (to be published).
- 18 AEC Safety Guide 14, "Reactor Coolant Pump Flywheel Integrity," USAEC, Oct. 1971.
- 19 ASTM Standard E-208, "Standard Method for Conducting Drop Weight Test to Determine Nil-Ductility Transition Temperature of Ferritic Steels," *ASTM Standards (1973)*, Part 31, American Society for Testing and Materials, Philadelphia, Pa., 1973, pp. 507-516.
- 20 ASTM Standard E-23, "Standard Methods for Notched Bar Impact Testing of Metallic Materials," *ASTM Standards (1973)*, Part 31, American Society for Testing and Materials, Philadelphia, Pa., 1973, pp. 277-293.
- 21 Clark, G., "Ultrasonic Procedure for the Examination of Main Coolant Pump Flywheels," Westinghouse Process Specification 94351 RU, Rev. 1, Apr. 1972.
- 22 Clark, W. G., and Ceschini, L. J., "Fatigue Pre-cracking of Spin-Burst Toughness Specimens," *Experimental Mechanics*, Vol. 9, 1969, pp. 123-128.
- 23 ASTM Standard E-399, "Standard Method of Test for Plane-Strain Fracture Toughness of Metallic Materials," *ASTM Standards (1973)* Part 31, American Society for Testing and Materials, Philadelphia, Pa., 1973, pp. 960-979.

Duquesne Light Company

Beaver Valley Power Station
P.O. Box 4
Shippingport, PA 15077-0004

SUSHIL C. JAIN
Division Vice President
Nuclear Services
Nuclear Power Division

(412) 393-5512
Fax (412) 643-8069

U. S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, DC 20555-0001

June 21, 1996

**Subject: Beaver Valley Power Station, Unit No. 1 and No. 2
BV-1 Docket No. 50-334, License No. DPR-66
BV-2 Docket No. 50-412, License No. NPF-73
Response to Request for Additional Information Concerning
WCAP-14535; Revised Item 2 Response**

Attached is a revised response to Item 2 to an NRC staff request for additional information provided by letter dated May 1, 1996, concerning WCAP-14535, "Topical Report on Reactor Coolant Pump Flywheel Inspection Elimination." Beaver Valley submitted the subject report by letter dated January 24, 1996, as the industry's lead plant on this issue, and submitted a response to the request for additional information on June 14, 1996. On June 18, 1996, a teleconference between the NRC staff reviewers, Westinghouse Electric Corporation staff, and members of the Beaver Valley staff discussed the June 14, 1996, submittal, in particular Item 2.

This revised response to Item 2 is intended to clarify the interaction and impact of adding the stresses associated with a conservative shrink fit and flaw sizing conservatism associated typically with Section XI acceptance criteria of the ASME Boiler and Pressure Vessel Code. The response to Item 2 and Table 1 has been revised to reflect additional conservatism in the allowable crack lengths for reactor coolant pump flywheels.

Please direct questions regarding this submittal to Mr. Roy K. Brosi at (412) 393-5210.

Sincerely,



Sushil C. Jain



Response to NRC Request for Additional Information on WCAP-14535 **(Revised Response to Item 2)**

Item 2:

Section 1.1 Previous Flywheel Integrity Evaluations, Page 1-3 - The fatigue analysis is dependant on the premise that UT equipment used for examinations of RCP flywheels at these facilities is capable of accurately detecting and sizing 0.24 inch long near surface flaw. Provide your basis supporting the probability of detection (POD) for the examinations performed. Provide details on how the POD values were determined, qualified, and used in concluding the assumed size of the initial flaw.

Response to Item 2:

The initial crack length of 0.24 inch was used in a previous evaluation of RCP flywheel integrity by Babcock and Wilcox (Report BAW-10040, December 1973, "Reactor Coolant Pump Assembly Overspeed Analysis"). This length was assumed to be the largest crack that could be missed in nondestructive testing.

As seen in Table 4-4 of WCAP-14535, crack growth assuming extremely large initial flaw lengths (from 2.04 to 3.28 inches) was found to be insignificantly small over a 60 year extended plant life. In the crack growth evaluation, 6000 RCP start/stop cycles were assumed, which is conservative with respect to actual operation. Shrink fit was not included in the WCAP-14535 evaluation. This is conservative, since shrink fit retards crack growth, as discussed in the Response to Item 1, above. This evaluation suggests that very large initial flaws can be structurally tolerated, from a crack growth perspective. As noted later in this discussion, the reflective reference area used for calibration of the inspection procedure is nearly an order of magnitude smaller than these structurally stable flaws.

An alternative method of evaluating this issue is to define an "allowable" flaw size based on the application of margins to the calculated critical flaw size and the calculated stress intensity factor. The approach used here is to apply the Code pressure boundary margins of ASME Section XI to the flywheel, which is a non-pressure boundary, non-Code component. This application is considered to be extremely conservative. The Section XI criteria are as follows:

Criteria based on flaw size:	$a_{allow} = 0.1 a_{critical}$	(Normal, Upset and Test Conditions)
	$a_{allow} = 0.5 a_{critical}$	(Emergency and Faulted Conditions)

Criteria based on stress intensity factor:	$K_I = \text{Toughness} / 10$	(Normal, Upset and Test Conditions)
	$K_I = \text{Toughness} / 2$	(Emergency and Faulted Conditions)

The normal condition for the flywheel is the normal operating speed of 1200 rpm. The faulted condition for the flywheel is the overspeed of 1500 rpm.

The results of this approach are provided in Table I below. Shrink fit is included in these results, since shrink fit increases the magnitude of the hoop stresses (as shown in Figure 1) and consequently, the stress intensity factor. In Table I, crack length is measured radially from the keyway, and percentage through the flywheel is the crack length divided by the radial length from the keyway to the flywheel outer radius.

**Table 1: Allowable Crack Lengths for Flywheels
Including the Effect of Shrink Fit and Section XI Criteria**

Flywheel Group	Allowable Crack Lengths in Inches and % through Flywheel					
	1200 rpm (Normal Speed)			1500 rpm (Overspeed)		
	RT _{NDT} = 0°F	RT _{NDT} = 30°F	RT _{NDT} = 60°F	RT _{NDT} = 0°F	RT _{NDT} = 30°F	RT _{NDT} = 60°F
1	2.3" (7%)	1.4" (4%)	0.4" (1%)	7.6" (23%)	2.7" (8%)	0.6" (2%)
2	2.3" (7%)	1.5" (4%)	0.4" (1%)	8.0" (24%)	2.8" (8%)	0.5" (2%)
10	1.9" (7%)	1.3" (5%)	0.6" (2%)	8.3" (31%)	3.7" (14%)	1.6" (6%)
14	2.2" (8%)	1.8" (7%)	1.1" (4%)	12.0" (43%)	5.4" (20%)	1.2" (4%)
15	1.0" (5%)	0.5" (2%)	0.2" (1%)	4.3" (21%)	1.9" (9%)	0.9" (4%)
16	1.9" (8%)	1.4" (6%)	0.7" (3%)	10.2" (42%)	4.6" (19%)	1.8" (7%)

It is important to note that several conservative assumptions were included in the determination of the allowable crack lengths provided in Table 1. These are discussed as follows:

a) The closed form solution for the stress intensity factor was used. This solution assumes that the keyway radial length is included in the crack length, which is conservative for smaller crack lengths. This conservatism is evident in Figure 3 for Flywheel Group 1, which indicates that a zero length crack has a stress intensity factor of about 42 ksi $\sqrt{\text{inch}}$, since a crack of 0.937 inches (the keyway length) is assumed. As shown in Figure 4 of the attached ASME technical paper (Attachment C), finite element analysis shows that the stress intensity factor for cracks less than about one inch long is significantly less than the closed form solution would predict. Therefore, there is significant conservatism in the smaller allowable crack lengths (1 inch and smaller) provided in Table 1 above.

b) A conservative shrink fit was assumed, as discussed in the Response to Item 1.

c) A lower bound fracture toughness for ferritic steels was used, as discussed in Section 4.3, page 4-7 of WCAP-14535.

d) The very conservative criteria of Section XI were used. These criteria apply margins of ten (10) to normal, upset and test conditions, and two (2) to emergency and faulted conditions. These margins account for uncertainties in flaw sizing and loading. It should be noted that the loadings associated with the flywheel (centrifugal forces and shrink fit) are well defined and were conservatively applied in this evaluation.

e) The ambient temperature used for the fracture evaluation (70°F) represents a much lower temperature than would be expected in the containment building during normal plant operating conditions (typically 100°F to 120°F).

f) The stress intensity factor is calculated using the methods of linear elastic fracture mechanics. This method assumes rapid crack extension in a linear elastic material (i.e., material properties below RT_{NDT}). The flywheel material would remain highly ductile since the operating temperature is well above the RT_{NDT} of the material. The conservatism using this method is therefore inherent.

Over the past ten years, the examination techniques employed have improved, particularly with the use of the defocused gage hole probe. The detectability of the gage holes at various metal paths displayed in Attachment B indicate that the inspection methods used for flywheels are capable of finding flaws of the sizes identified in Table I.

In Attachment B, the 1.25 inch diameter gage holes (effectively side drilled holes) were clearly identified at a metal path which is nearly twice the metal path distance involved in the inspection of the keyway area. It should be noted that it is conservatively estimated that the effective reflective surface of a side drilled hole is a 30° arc. The reflective surface from a 1.25 inch gage hole would therefore be 0.33 inch. This length is smaller than all but the smallest of the allowable crack lengths in Table I (0.2 inch, Flywheel Group 15, RT_{NDT} of $60^\circ F$, 1200 rpm). As discussed above, a significant amount of conservatism is inherent in the smaller allowable crack lengths (1 inch and smaller) provided in Table I. In addition, Flywheel Group 15 includes only one plant, Three Mile Island Unit 1. Per Babcock and Wilcox Power Generation Group, Nuclear Power Generation Division Topical Report BAW-10040, December 1973, "Reactor Coolant Pump Assembly Overspeed Analysis," the RT_{NDT} value of the flywheel material is estimated to be $-10^\circ F$. Therefore, a crack length of greater than one inch would be allowed, which is larger than the 0.33 inch reflective surface from a 1.25 inch gage hole discussed above.

Therefore, the inspection methods used for flywheels are capable of finding the flaw sizes shown in Table I.

APPENDIX F

RESPONSE TO SECOND NRC REQUEST FOR ADDITIONAL INFORMATION

Duquesne Light Company

Beaver Valley Power Station
P.O. Box 4
Shippingport, PA 15077-0004

SUSHIL C. JAIN
Division Vice President
Nuclear Services
Nuclear Power Division

(412) 393-5512
Fax (412) 643-8069

August 2, 1996

U. S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, DC 20555-0001

**Subject: Beaver Valley Power Station, Unit No. 1 and No. 2
BV-1 Docket No. 50-334, License No. DPR-66
BV-2 Docket No. 50-412, License No. NPF-73
Response to Request for Additional Information Concerning
WCAP-14535; RAI Dated July 24, 1996**

Attached is our response to an NRC staff request for additional information provided by letter dated July 24, 1996, following a meeting between Duquesne Light Company and NRC staff on July 17, 1996. This response concerns the maintenance history and frequency of pump motor overhauls for the types of pumps proposed to be covered by WCAP-14535, "Topical Report on Reactor Coolant Pump Flywheel Inspection Elimination."

Currently a reactor coolant pump flywheel inspection would be required during the Beaver Valley Power Station Unit No. 2 sixth refueling outage scheduled to begin on August 30, 1996. Therefore, NRC approval is requested by this date.

Please direct questions regarding this submittal to Mr. Roy K. Brosi at (412) 393-5210.

Sincerely,



Sushil C. Jain

c: w/enclosure:

Mr. L. W. Rossbach, Sr. Resident Inspector
Mr. H. J. Miller, NRC Region I Administrator
Mr. D. S. Brinkman, Sr. Project Manager (3 copies)
Ms. Diane Jackson, Westinghouse Electric Corporation



Response to NRC Request for Additional Information on WCAP-14535
RAI Dated July 24, 1996

On July 17, 1996, a meeting with the NRC staff was held to provide information concerning the costs of reactor coolant pump (RCP) motor flywheel inspections, and the frequency of RCP motor disassembly for maintenance. Duquesne Light Company (DLC) personnel discussed actions performed at the Beaver Valley Power Station. The applicability of the responses to the industry as a whole could not be addressed; accordingly, a survey of the flywheel group was conducted. The results of this survey are discussed below along with an alternative flywheel inspection.

Survey responses were received for 35 of the 57 plants which are covered by WCAP-14535. The results show a wide range of responses to the question of how often RCP motors are disassembled for maintenance, but most are disassembled on an average frequency of about every 8 years. The other two questions concerned the cost and exposure involved with flywheel inspections now being done per Regulatory Guide 1.14 (dollars and man-rem). For inspections with the flywheel in place (not removed from the motor shaft), the average cost and exposure are \$5,300 and 0.34 man-rem, respectively. For the flywheel removed from the motor shaft, the average cost and exposure are \$28,100 and 0.88 man-rem, respectively.

WCAP-14535 presents a strong technical case for the elimination of RCP flywheel inspections. This elimination would not affect the frequency of RCP motor maintenance, but would significantly reduce the risk of RCP motor flywheel failure, since the only credible mechanism for flywheel damage is from removal, handling and reassembly, as discussed in WCAP-14535. This potential for damage during handling was also discussed at the meeting, and in response to the concerns raised by the staff concerning flywheel integrity following RCP motor maintenance, the following is proposed.

An alternative inspection patterned after Code Case N481 for RCP casings which integrates inspections into normal maintenance activities is recommended. Inspections using visual, liquid penetrant or ultrasonic techniques would be performed on the bore and keyway region whenever the flywheel is removed from the shaft for RCP maintenance. This is in concert with the conclusion of the technical assessment that only the bore and keyway regions need to be inspected, not 100% of the flywheel volume, as presently required by the regulatory guide.

Therefore, the following will be incorporated in DLC's maintenance program:

Upon disassembly (removal of the flywheel from the shaft of the RCP motor) for normal maintenance activities, the bore and keyway region of the RCP motor flywheel shall be inspected by visual, surface or ultrasonic techniques.

APPENDIX G

UNITED STATES NUCLEAR REGULATORY COMMISSION SAFETY EVALUATION REPORT



UNITED STATES
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

SEP 12 1996

Nuclear Safety Dept.

SEP 24 1996

Mr. Sushil C. Jain, Division Vice President
Nuclear Power Division
Duquesne Light Company
Beaver Valley Power Station
P.O. Box 4
Shippingport, Pennsylvania 15077-0004

SUBJECT: ACCEPTANCE FOR REFERENCING OF TOPICAL REPORT WCAP-14535, "TOPICAL REPORT ON REACTOR COOLANT PUMP FLYWHEEL INSPECTION ELIMINATION"

Dear Mr. Jain:

We have completed our review of the subject topical report submitted by Duquesne Light Company (DLC) for Beaver Valley 1 & 2 as the two leading plants by letter dated January 24, 1996. We find the report to be acceptable for referencing in license applications to the extent specified and under the limitations delineated in the report and the associated NRC safety evaluation (SE), which is enclosed. The evaluation defines the basis for acceptance of the report as limited by an inspection period acceptable to the staff.

We do not intend to repeat our review of the matters described in the report when the report appears as a reference in license applications, except to ensure that the material presented is applicable to the specific plant involved as indicated in the conclusion section of the SE. Our acceptance applies only to the matters described in the report.

In accordance with procedures established in NUREG-0390, it is requested that DLC coordinate with the Westinghouse Owners Group and publish this report within three months of receipt of this letter. The final version shall incorporate this letter, the enclosed evaluation, and DLC's responses to the NRC RAI dated June 14 (without attachments) and June 21, 1996, between the title page and the abstract. The final version shall include an -A (designating accepted) following the report identification symbol.

Licensees having Group-15 flywheels need to demonstrate that material properties of their A516 material is equivalent to SA 533 B material, and its reference temperature, RT_{NDT} , is less than 30°F. Licensees with Group-10 flywheels need to confirm in the near term that their flywheels have an adequate shrink fit to preclude loss of shrink fit of the flywheel at maximum overspeed or to provide an evaluation demonstrating that no detrimental effects would occur if the shrink fit was lost at maximum overspeed.

Sincerely,

Brian W. Sherron

Brian W. Sherron, Director
Division of Engineering
Office of Nuclear Reactor Regulation

Enclosure: As stated

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION
TOPICAL REPORT ON REACTOR COOLANT PUMP FLYWHEEL INSPECTION ELIMINATION
BEAVER VALLEY 1 & 2
MATERIALS AND CHEMICAL ENGINEERING BRANCH
DIVISION OF ENGINEERING

1.0 INTRODUCTION

On January 24, 1996, Duquesne Light Company (DLC), the licensee for Beaver Valley 1 & 2) submitted a Westinghouse report, WCAP-14535 [1], "Topical Report on Reactor Coolant Pump Flywheel Inspection Elimination," for NRC review. This report, which provides an engineering analysis based on fracture mechanics, is intended to eliminate reactor coolant pump (RCP) flywheel inservice inspection (ISI) requirements for all operating Westinghouse plants and some Babcock and Wilcox Plants. Presently, Beaver Valley's RCP flywheel inspection is performed in accordance with its licensing commitment to Regulatory Guide (RG) 1.14 [2], which provides guidelines on conducting surface and ultrasonic volumetric examinations of RCP flywheels coinciding with each individual plant's ISI schedule as required by Section XI of the American Society of Mechanical Engineers (ASME) Code.

2.0 BACKGROUND

The function of the RCP in the reactor coolant system (RCS) of a pressurized water reactor plant is to maintain an adequate cooling flow rate by circulating a large volume of primary coolant water at high temperature and pressure through the RCS. A concern over overspeed of the RCP and its potential for failure led to the issuance of RG 1.14 in 1971. The regulatory position of RG 1.14 concerning ISI calls for an in-place ultrasonic volumetric examination of the areas of higher stress concentration at the bore and keyway at approximately 3-year intervals and a surface examination of all exposed surfaces and complete ultrasonic volumetric examination at approximately 10-year intervals. The flywheel inspection schedule is to coincide with the individual plant's ISI schedule as required by Section XI of the ASME Code.

Operating power plants have been inspecting their flywheels for over twenty years, and no flaws have been identified which affect flywheel integrity. This inspection record, plus the licensee's concern over inspection costs and personnel radiation exposure, prompted it to submit this topical report to demonstrate through fracture mechanics analysis that flywheel inspections can be eliminated without impairing plant safety.

3.0 EVALUATION AND VERIFICATION

The primary regulatory position of RG 1.14 regarding flywheel design concerns three critical speeds: (a) the critical speed for ductile fracture, (b) the critical speed for nonductile fracture, and (c) the critical speed for

excessive deformation of the flywheel. This regulatory position specifies, as a design criterion, that the normal speed of the flywheel should be less than one-half of the lowest of these three critical speeds, and the LOCA overspeed should be less than the lowest of these three critical speeds.

3.1 MATERIAL INFORMATION

As shown in Table 2-1 of WCAP-14535, all flywheels have been classified into 16 groups according to their material and geometric information. Except for flywheels in Groups 14 to 16, all flywheels were made of reactor pressure vessel plate steel, SA 533 Grade B (SA 533 B). The analytical results presented in this report are for SA 533 B material. To cover a wide range of flywheels, the results were presented for three reference temperatures, that is, $RT_{MOT} = 0^{\circ}F$, $30^{\circ}F$, and $60^{\circ}F$. A reference temperature of $60^{\circ}F$ is a reasonable bounding value for material SA 533 B, and has been used in the subsequent evaluation.

3.2 ANALYSIS FOR CRITICAL SPEED BASED ON DUCTILE FRACTURE

RG 1.14 permits the use of elastic stress analysis methods and the acceptance criteria of Section III of the ASME Code to predict the critical speed based on ductile fracture of the flywheel. The ASME Code requires that the stress limits for the general primary membrane stress intensity P_m and the primary membrane plus primary bending stress intensity $P_m + P_b$ be $0.7S_u$ and $1.05S_u$ for the faulted loading combination, where S_u is the minimum specified ultimate tensile stress of the material. The topical report used these limits and employed the minimum specified S_u value of 80 ksi for flywheel material SA-533 B to arrive at the critical speeds for six groups of flywheels under ductile fracture conditions shown in Table 4-2. These six groups were selected from a total of 16 groups so that they cover all flywheel dimensions. Table 4-2 indicates that the lowest calculated critical speed is 2698 rpm (Group 15 flywheels), and the normal speed of 1200 rpm is clearly less than one-half of that value. The type of analyses performed above satisfies RG 1.14. However, since RG 1.14 was published in 1975, more appropriate elastic-plastic fracture mechanics (EPFM) methodology has been developed to predict ductile fracture. Performing an EPFM analysis is not necessary because the linear elastic fracture mechanics (LEFM) analysis in Section 3.3 is the appropriate analysis method for the thick section of the flywheel and temperature regime of operation.

3.3 ANALYSIS FOR CRITICAL SPEED BASED ON NONDUCTILE FRACTURE

The topical report provided a linear elastic fracture mechanics analysis to address the prediction of critical speed for nonductile fracture of the flywheel specified in Item 2.d of RG 1.14.

The analysis used the closed-form solution for a radial full-depth crack emanating from the bore of a rotating disk to calculate the applied stress intensity factor (applied K). The fracture resistance for the SA-533 B plate was obtained from the lower bound K_{Ic} curve of Section XI of the ASME Code. Use of K_{Ic} was suggested by RG 1.14. The loads used in calculating the applied K were from an overspeed of 1500 rpm. Further, three values of RT_{MOT} , $0^{\circ}F$, $30^{\circ}F$, and $60^{\circ}F$, were used in calculating the K_{Ic} . The resulting critical

crack lengths for the six groups of flywheels were summarized in Table 4-3. It showed that the smallest critical crack length is 2.6 inches for Group-15 flywheels having an assumed RT_{NDT} value of 60°F.

The flaw evaluation including fatigue analysis in the original submittal did not determine a critical speed based on an assumed initial flaw size as requested by RG 1.14, or show that the acceptance criteria of IWB-3610 of Section XI of the ASME Code were satisfied. In response to this, the licensee applied in Reference 3 the margins of IWB-3610 of Section XI of the ASME Code and expanded Table 4-3 of the topical report to include critical crack lengths at the normal speed for the six groups of flywheels. The new table was called Table 1. The staff also determined that the applied K due to shrink-fit stresses were not considered in the initial response. In the second response to the staff's RAI [4], the licensee revised Table 1 one more time to include the shrink-fit effect. This table indicates that normal/upset conditions are controlling for the flywheels. The allowable crack lengths, with IWB-3610 margins applied, are 0.2 inch for Group 15 and 0.4 inch for the remaining groups of flywheels. In Attachment B to Reference 3, the 1.25 inch diameter gage holes were identified at a metal path which is about twice the metal path distance involved in the inspection of the keyway area. The reflective surface from a 1.25 inch gage hole would therefore be 0.33 inch. Since the ASME IWB-3610 minimum allowable crack length, 0.4 inch, for all groups except for Group 15 is greater than the 0.33 inch that was demonstrated to be detected, all flywheels except those in Group 15 satisfy the nonductile fracture criterion. For licensees having Group-15 flywheels, they need to demonstrate that the reference temperature, RT_{NDT} , for their SA 533 B material or its equivalent is less than 30°F because Table 1 of Reference 4 indicates that the allowable crack length for this RT_{NDT} value is greater than 0.4 inch. Further, it should be noted that the minimum initial crack length, considering shrink fit but not the ASME margin, is 1.0 inches at the normal speed of 1200 rpm for all groups. Based on experience with the inspection of ferritic components with short metal paths, the staff considers that it is unlikely that any defect that could challenge flywheel integrity would be missed by the inspection. In addition, the staff agrees that other conservatisms that are identified in Reference 4 were not accounted for in the analysis.

RG 1.14 requires the normal speed of the flywheel be one half the critical speed. Meeting the margins based on applied K of IWB-3610 of Section XI of the ASME Code is acceptable to the staff for satisfying this criterion. When this is translated into the concept of factor of safety on applied stress, it is equivalent to a factor of 4. Since the toughness used is K_{Ic} in the ASME Code (for the limiting normal condition) and K_{Ic} in RG 1.14, and K_{Ic} is larger than K_{Ia} , the RG margin will be very close to the ASME margin of $(10)^{1/2}$ after having applied the ratio of K_{Ia} to K_{Ic} .

Fatigue crack growth was determined from the rate formula in Appendix A of Section XI. For the flywheel in each group, an initial crack length of 10% of the distance from the keyway to the flywheel outer radius was assumed (ranging from 2.04 inches to 3.28 inches). As to the loading, 6000 cycles of RCP starts and stops were assumed for a 60-year plant life. The crack growth after 6000 cycles are tabulated in Table 4-4 of WCAP-14535 for the six groups of flywheels. The largest growth is for cracks in Groups 1 and 2 flywheels, for which a value of 0.08 inch is reported.

The fatigue crack growth calculation did not include the stresses due to shrink fit. However, in Reference 3 it was demonstrated that excluding the shrink-fit stresses is conservative in the crack growth calculation. This is because the key parameter now is ΔK instead of K . The explanation provided in Reference 3 is acceptable and the staff agrees that the crack growth calculation is conservative. The staff concludes that after 10 years the maximum fatigue growth would be expected to be about 0.013 inch. If it is assumed that a crack of 0.33 inches were missed and the maximum expected fatigue crack growth were applied, the end of cycle crack size would be 0.343 inch. Therefore, the ASME margins would be maintained during the service period and a 10-year inspection period appears reasonable.

3.4 COMPLIANCE WITH THE EXCESSIVE DEFORMATION FAILURE CRITERION

The analyses in the report used standard closed-form formulas for rotating disks to calculate the change of flywheel inner and outer radii at 1500 rpm. The results are tabulated in Table 4-5 for the six groups of flywheels. The largest value is 0.010 inch for the change in the inner radius. Without referring to any criterion, this report stated that these increases would not result in any adverse conditions.

The primary concern of RG 1.14 over excessive deformation is the enlargement of the bore that could cause a separation of the flywheel from the shaft or could cause an unbalance of the flywheel leading to structural failure. The staff believes that the concern here is the loss of shrink-fit at high speed. Once it happens, the keys on the flywheels may not be able to prevent the slight relative displacement between the wheel and the shaft from happening. Consequently, the balance of the flywheel might be altered. The staff concludes that most flywheels satisfy the excessive deformation failure criterion based on loss of shrink-fit. However, it appears that using the generic initial shrink-fit assumed in the topical report, the shrink fit may be lost for Group-10 flywheels at a speed of 1500 rpm. Licensees having these flywheels need to use the plant-specific shrink-fit value to check the loss of shrink-fit of the flywheel at this speed.

3.5 COMPLIANCE WITH THE LOCA OVERSPEED CRITERION

RG 1.14 requires that the LOCA overspeed should be less than the lowest of the three critical speeds mentioned in Section 3.0. Since the predicted LOCA overspeed reported in the submittal is in all cases less than 1500 rpm, which happens to be the lowest critical speed discussed above, the LOCA overspeed criterion is satisfied.

3.6 RISK ASSESSMENT

The staff relied solely on deterministic methodology to review this submittal. The risk assessment in Section 5, which used a Monte-Carlo simulation with importance sampling for assessing the effect of inspections, concluded that flywheel inspections beyond ten years of plant life have no significant benefit on reducing the risk of flywheel failure. Since the risk assessment was not reviewed, acceptance of this report shall not be interpreted as the staff accepting the probabilistic methodology in Section 5.

4.0 CONCLUSIONS

The Materials and Chemical Engineering Branch has completed its review of the licensee's submittals and has determined that the evaluation methodology in the reports is appropriate and the criteria are in accordance with the design criteria of RG 1.14.

For the RG criteria on the three critical speeds, the staff concluded that (1) all flywheels satisfy the ductile fracture criterion of RG 1.14; (2) except for Group-15 flywheels, all flywheels satisfy the nonductile fracture criteria of Section XI of the ASME Code because their allowable crack length (≥ 0.4 inch) is greater than the minimum flaw size that would be found by periodic inspections used for flywheels describes in Attachment B to Reference 3; and (3) all flywheels except those in Group 10 satisfy the excessive deformation criterion of RG 1.14.

This report requests complete flywheel inspection elimination. The staff believes that even for flywheels meeting all the design criteria of RG 1.14, as modified in this SER, inspections should not be completely eliminated. Inspections are performed in part to protect against events or degradation that is not anticipated and has not been considered in the analysis. This philosophy is consistent with the requirements in the ASME Code for successive inspections for flaws evaluated to the Section XI acceptance criteria. Therefore, the staff will not accept elimination of flywheel inspection. However, conducting flywheel inspection when RCP motor maintenance is required (about every 8 years from a limited survey [5]), the staff finds the following acceptable:

(1) Licensees who plan to submit a plant-specific application of this topical report for flywheels made of SA 533 B material need to confirm that their flywheels are made of SA 533 B material. Further, licensees having Group-15 flywheels need to demonstrate that material properties of their A516 material is equivalent to SA 533 B material, and its reference temperature, RT_{NDT} , is less than 30°F.

(2) Licensees who plan to submit a plant-specific application of this topical report for their flywheels not made of SA 533 B or A516 material need to either demonstrate that their flywheel material properties are bounded by those of SA 533 B material, or provide the minimum specified ultimate tensile stress, S_u , the fracture toughness, K_{Ic} , and the reference temperature, RT_{NDT} , for that material. For the latter, the licensees should employ these material properties, and use the methodology in the topical report, as extended in the two responses to the staff's RAI, to provide an assessment to justify a change in inspection schedule for their plants.

(3) Licensees meeting either (1) or (2) above should either conduct a qualified in-place UT examination over the volume from the inner bore of the flywheel to the circle of one-half the outer radius or conduct a surface examination (MT and/or PT) of exposed surfaces defined by the volume of the disassembled flywheels once every 10 years. The staff considers this 10-year inspection requirement not burdensome when the flywheel inspection is conducted during scheduled ISI inspection or RCP motor maintenance. This

would provide an appropriate level of defence in depth.

Licensees with Gro p-10 flywheels need to confirm in the near term that their flywheels have an adequate shrink fit to preclude loss of shrink fit of the flywheel at maximum overspeed or to provide an evaluation demonstrating that no detrimental effects would occur if the shrink fit was lost at maximum overspeed.

Since this topical report and all related documents were submitted by DLC, no demonstration of plant-specific applicability is required from DLC.

5.0 REFERENCES

- 1.0 Duquesne Light Co., letter from George S. Thomas (DLC) to USNRC Document Control Desk with enclosed report, WCAP-14535, "Topical Report on Reactor Coolant Pump Flywheel Inspection Elimination," January 24, 1996.
- 2.0 USNRC, Regulatory Guide 1.14, "Reactor Coolant Pump Flywheel Integrity," 1971; Revision 1, August 1975.
- 3.0 Duquesne Light Co., letter from George Sushil C. Jain (DLC) to USNRC Document Control Desk, "Response to Request for Additional Information Concerning WCAP-14535," June 14, 1996.
- 4.0 Duquesne Light Co., letter from George Sushil C. Jain (DLC) to USNRC Document Control Desk, "Response to Request for Additional Information Concerning WCAP-14535; Revised Item 2 Response" June 21, 1996.
- 5.0 Duquesne Light Co., letter from George Sushil C. Jain (DLC) to USNRC Document Control Desk, "Response to Request for Additional Information Concerning WCAP-14535; RAI Dated July 24, 1996" August, 2, 1996.

APPENDIX H

KEY PROVISIONS AND FOLLOWUP CLARIFICATIONS

Safety Evaluation Report on RC Pump Flywheel Inspection

The NRC staff has completed their review of the topical report submitted by Duquesne Light Company on your behalf, and has issued a Safety Evaluation Report, which is attached. The report is dated September 12, 1996, but was not received by Duquesne Light until September 19. Our review of the SER has revealed several mistakes, and a number of areas where the wording is not clear. We have obtained clarifications through several phone calls with the NRC staff, and these are discussed below. First, a brief summary of the key provisions of the SER.

Key Provisions

1. Inspections need only be done on a ten year interval, instead of 40 months.
2. Acceptable inspection methods are either UT or surface exams (magnetic particle or liquid penetrant).
3. UT inspection coverage is required only on the inner half of the flywheel radius.
4. Surface examination coverage is the exposed surfaces of the flywheel when the pump is disassembled for maintenance.
5. All licensees can reference this SER in license applications, and detailed technical reviews of the submittals will not be required, unless new technical information is presented.

Follow-up Clarifications

1. The new inspections are meant to be a relief from those contained in Regulatory Guide 1.14.
2. The term "qualified" as applied to the UT has no hidden meaning. The inspections under this SER should be qualified in the same way the inspections under RG 1.14 were qualified. Specifically, the staff said that Appendix VIII of Section XI does not apply.
3. Referring to item (3) on page 5, the area to be examined by surface examination is stated as the "exposed surfaces defined by the volume of the disassembled flywheels". This was clarified to mean the "exposed surfaces of the disassembled flywheels".
4. The questions about the toughness of the Group 15 flywheels and the shrink fit for Group 10 flywheels have been answered earlier in response to the staff request for additional information, but for some reason were missed by the staff when they issued the SER. The staff suggested that this information be included in the submittals of the affected utilities, with a note mentioning the earlier submittal.

Follow-up Actions

The original WCAP-14535 will be republished, along with the two requests for additional information and the responses, and the SER. The information needed by Group 15 and Group 10 owners will be clearly laid out. This report will be numbered WCAP-14535A.

Conclusions

The SER provides some relief, but the extent of relief was somewhat disappointing. The NRC staff said that technically the basis for further minimizing flywheel inspections has been established, but they felt they could go no further at the present time. This leaves the door open for future actions on this subject.