



November 13, 2018

ULNRC-06468

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555-0001

10 CFR 50.73

Ladies and Gentlemen:

**DOCKET NUMBER 50-483
CALLAWAY PLANT UNIT 1
UNION ELECTRIC CO.
RENEWED FACILITY OPERATING LICENSE NPF-30
NOTICE OF CANCELLATION FOR LICENSEE EVENT REPORT 2018-003-00**

Reference: 1. ULNRC-06444, LER 2018-003-00 for Callaway, Unit 1, "Violation of TS 3.7.10 'Control Room Emergency Ventilation System (CREVS),' " dated July 18, 2018 (ADAMS Accession Number ML18201A570)

In accordance with the guidance provided in Section 5.1.2 of NUREG-1022 Revision 3, "Event Report Guidelines – 10 CFR 50.72 and 50.73," the Licensee Event Report (LER) submitted to the NRC per Reference 1 is being canceled.

The LER submitted per Reference 1, i.e., LER 2018-003-00, "Violation of TS 3.7.10, 'Control Room Emergency Ventilation System (CREVS),' " resulted from discovery of damage to two of the six filter media trays in a filter adsorber unit in one of the two independent and redundant CREVS trains. The degraded condition of the filter media trays allowed a small quantity of the charcoal filter media to be spilled from the trays. Based on an initial determination that past Operability of the affected CREVS train could not be supported, the degraded condition was reported in accordance with 10 CFR 50.73(a)(2)(i)(B) as a violation of TS 3.7.10. Since there were concurrent periods of inoperability of the redundant CREVS train during the degraded condition, the condition was also reported in accordance with 10 CFR 50.73(a)(2)(v)(D) as one that could have caused a loss of safety function for CREVS.

Subsequent to Ameren Missouri's submittal of the LER, the results of vendor laboratory tests that were performed on the more severely damaged filter media tray have been obtained. Those results now provide reasonable assurance that the degraded condition would not have caused the performance of the affected filter adsorber unit to significantly degrade during its credited mission time.

ULNRC-06468
November 13, 2018
Page 2 of 4

Based on the acceptable results of bypass leakage testing that was performed on-site for the affected filter adsorber unit after the degraded condition was discovered, coupled with the results obtained from the noted laboratory testing, Ameren Missouri has concluded that past Operability of the unit was supported. Therefore, as no violation of TS 3.7.10 occurred and there was no loss of safety function for CREVS as a result of the degraded condition, the identified condition does not meet the criteria for reporting under 10 CFR 50.73(a)(2)(i)(B) or 10 CFR 50.73(a)(2)(v)(D). As a result, Ameren Missouri is cancelling LER 2018-003-00.

This letter does not contain new commitments.

If you have any questions concerning this notice of cancellation, please contact Tom Elwood, Supervising Engineer, Regulatory Affairs and Licensing at (314) 225-1905.

Sincerely,

A handwritten signature in black ink, appearing to read "Frederick J. Bianco", with a large, stylized flourish at the end.

Frederick J. Bianco
Senior Director, Nuclear Operations

cc: Mr. Kriss M. Kennedy
Regional Administrator
U. S. Nuclear Regulatory Commission
Region IV
1600 East Lamar Boulevard
Arlington, TX 76011-4511

Senior Resident Inspector
Callaway Resident Office
U.S. Nuclear Regulatory Commission
8201 NRC Road
Steedman, MO 65077

Mr. L. John Klos
Project Manager, Callaway Plant
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Mail Stop O9E3
Washington, DC 20555-0001



Index and send hardcopy to QA File A160.0761

Hardcopy:

Certrec Corporation
6100 Western Place, Suite 1050
Fort Worth, TX 76107
(Certrec receives ALL attachments as long as they are non-safeguards and may be publicly disclosed.)

Electronic distribution for the following can be made via LER ULNRC Distribution:

F. M. Diya
B. L. Cox
F. J. Bianco
T. E. Herrmann
S. P. Banker
R. C. Wink
T. B. Elwood
K. A. Mills
K. J. Tipton
J. C. Pitts
S. P. Steeves
Corporate Oversight
Corporate Communications
NSRB Secretary
Performance Improvement Coordinator
Resident Inspectors (NRC)
STARS Regulatory Affairs
Mr. Jay Silberg (Pillsbury Winthrop Shaw Pittman LLP)
Missouri Public Service Commission

