## ERRATA SHEET

- A. Page 6 of the cover letter under the heading of \*Auxiliary Feedwater

  Valves . . . , Paragraph 2, second line; change "1524 psid" to "1523" psid.
- B. Table 2, Note: 1, second sentence; change designated to designed.
- C. Table 4, for Operator Number VOP-3052; change Opening thrust as left unseating value from "39,000" to "29,000."
- D. Table 5; see revisions on attached page.
- E. Table 6; see revisions on attached page.
- F. Attachment A, Page 2, for valve tag numbers MO-3080 and MO-3081, under column Valve Function, change "Open for Hot Leg Injection" to "Close for Hot Leg Injection."
- G. Attachment A, Page 2, for valve tag numbers MO-3082 and MO-3083, under column Valve Function, change "Close for Hot Let Injection" to "Open for Hot Leg Injection."

## RESULTS OF DIFFERENTIAL PRESSURE TESTING \*\* CLOSING ONLY \*\*

VALVE TAG NO.	MAXIMUM DELTA-P DESIGN	ACTUAL DELTA-P TESTED	THRUST MEASURED TEST DP	THRUST REQ. @ MAX DP	THRUST AT CST	MARGIN (CST-DP)	RUNNING LOAD THRUST	ı
MO-0743 **	1714	1524	l 7600	7742	10580	2838(8)	<pl 6460<="" td=""><td>! }</td></pl>	! }
MO-0748 **	1354	1239	5940	6454	10120	3666	400	i
MO-0753 **	1714	1523	10700	11214	10700	-514(8)	<pl 6600<="" td=""><td>Ĺ</td></pl>	Ĺ
MO-0754 **	1354	1239	6100	6584	9510		<pl 880<="" td=""><td>ĺ</td></pl>	ĺ
MO-0755 **	1351	1243	5730	6115	9120		<pl 1300<="" td=""><td>ĺ</td></pl>	ĺ
MO-0759 **	1351	1244	7060	7607	9380	1773(8)	<pl 700<="" td=""><td>ĺ</td></pl>	ĺ
MO-0760 **	1711	1526	8940	9386	11240	1854(8)	<pl 5260<="" td=""><td>l</td></pl>	l
MO-0798 **	1711	1525	8680	9019	11080	2061(8)	<pl 5900<="" td=""><td>Ĺ</td></pl>	Ĺ
MO-3007	1245	NOTE 3	]	1	1			l
MO-3009	1245	NOTE 3	·			,	·	1
MO-3011	1245	NOTE 3	<b>!</b>		1	l		1
MO-3013	1245	NOTE 3			[	<b>†</b>		1
MO-3041	1885	NOTE 2		l .	1			ĺ
MO-3045	1885	NOTE 2		<b>l</b> .		j ·		1
MO-3049	1885	NOTE 2		· .		j ·		Ì
[MO-3052]	1885	NOTE 2		1		}		l
MO-3062 *	1245	1240	NOTE 6	<b>l</b> .		· ·		ĺ.
MO-3064 *	1245	1240				<b>!</b>		ľ
MO-3066 *	1245	1240	·			l .	1	i
MO-3068 **	1245	1240						Ι.
MO-3080 **	1238	1050	5220	5362	15531	10169	5285	١
MO-3081	1239	NOTE 4			i	ļ	1	1
MO-3082 **	1235	1050	10395	11185	10395	790	5913	ľ
MO-3083	1235	NOTE 5			İ	l		ļ

## NOTES

- 1 \* INDICATES DP TESTING & \*\* INDICATES DP TESTING WITH MOVATS EQUIPMENT ATTACHED.
- 2 DP TEST COULD NOT BE PERFORMED, VALVES ARE ELECTRICALLY LOCKED OPEN.
- 3 DP TESTING WAS NOT PERFORMED, SINCE THE VALVES ARE IDENTICAL TO THE TESTED REDUNDANT HPSI VALVES (MO-3062, 64, 66 & 68).
- 4 DP TESTING WAS NOT PERFORMED, SINCE THIS VALVE IS IDENTICAL TO MO-3080, WHICH WAS TESTED.
- 5 DP TESTING WAS NOT PERFORMED, SINCE THIS VALVE IS IDENTICAL TO MO-3082, WHICH WAS TESTED.
- 6 MOVATS DATA WAS NOT OBTAINED ON THIS VALVE DUE TO AN EQUIPMENT MALFUNCTION.
- 7 <PL INDICATES THAT THE RUNNING LOAD IS LESS THAN THE REPORTED SPRING PACK PRELOAD.
- 8 VALVES LISTED FOR MARGIN ARE OVERLY CONSERVATIVE SINCE PRELOAD WAS USED IN PLACE OF RUNNING LOAD TO CALCULATE MARGIN.

## RESULTS OF DIFFERENTIAL PRESSURE TESTING \*\* OPENING ONLY \*\*

VALVE TAG NO.	MAXIMUM DELTA-P DESIGN	ACTUAL DELTA-P TESTED	THRUST MEASURED TEST DP	THRUST REQ. @ MAX DP	THRUST AT CRACKING	RUNNING LOAD THRUST	- 1
=====================================	1714	1524	< PL	< PL	< PL	<pl 6460<="" td=""><td></td></pl>	
MO-0748   **	1354	1239	4494	4865	5580	500	1
MO-0753 **	1714	1523	6900	6938	6900	<pl 6600<="" td=""><td>1 /</td></pl>	1 /
MO-0754 **	1354	1239	4470	4801	4600	900	1 /
MO-0755 **	1351	1243	4170	4419	4600	<pl 1300<="" td=""><td>1/</td></pl>	1/
MO-0759 **	1351	1244	4800	5153	4960	<pl 700<="" td=""><td>1</td></pl>	1
MO-0760 **	1711	1526	5820	5888	6060	<pl 5260<="" td=""><td>1</td></pl>	1
MO-0798 **	1711	1525	6080	6102	6080	<pl 5900<="" td=""><td>1/</td></pl>	1/
MO-3007	1245	NOTE 3	j	ļ	1.	· ·	1 .
[MO-3009]	1245	NOTE 3	1	1	1	1	1
MO-3011	1245	NOTE 3	1	1	ŀ	· ·	1
MO-3013	1245	NOTE 3	1	1	ļ		1
MO-3041	1885	NOTE 2	}	1	1	1	1
MO-3045	1885	NOTE 2			l	† ·	1
MO-3049	1885	NOTE 2	1		t	!	1
MO-3052	1885	NOTE 2	l	1		l	1
MO-3062 *	1245	1240	NOTE 6	l	1		1 /
MO-3064 *	1245	1240	1	1	!	ĺ	ļ
MO-3066 *	1245	1240	<b>!</b>	-	1		1
MO-3068 *	1245	1240	1		1	1	1/
MO-3080 **	1238	1050	124	-53	6211	1120	
MO-3081	1239	NOTE 4	1		1	l	[
MO-3082 **	1235	1050	10395	10963	8154	7169	
MO-3083	1235	NOTE 5	,		l	1	
							· [

- NOTES
  - 1 \* INDICATES DP TESTING & \*\* INDICATES DP TESTING WITH MOVATS EQUIPMENT ATTACHED.
  - 2 DP TEST COULD NOT BE PERFORMED, VALVES ARE ELECTRICALLY LOCKED.
  - 3 DP TESTING WAS NOT PERFORMED, SINCE THE VALVES ARE IDENTICAL TO THE REDUNDANT HPSI VALVES (MO-3062, 64, 66 & 68).
  - 4 DP TESTING WAS NOT PERFORMED, SINCE THIS VALVE IS IDENTICAL MO-3080, WHICH WAS TESTED.
  - 5 DP TESTING WAS NOT PERFORMED, SINCE THIS VALVE IS IDENTICAL MO-3082, WHICH WAS TESTED.
  - 6 MOVATS DATA WAS NOT OBTAINED ON THIS VALVE DUE TO AN EQUIPMENT MALFUNCTION
  - 7 <PL INDICATES THAT THE RUNNING LOAD IS LESS THAN THE REPORTED SPRING PACK PRELOAD.