



**Consumers
Power
Company**

Palisades Nuclear Plant: Route 2, Box 154, Covert, Michigan 49043


October 6, 1975

Regulatory

File Cy.

U.S. Nuclear Regulatory Commission
Mail and Records Section
Washington, D.C. 20555

RE: License Reports of Monthly Operating Data
DPR-20, Docket No. 50-255




Gentlemen:

Enclosed is a copy of the Monthly Operating Data for the Palisades Plant for the month of September, 1975.

Kenneth D. Brienzo

Kenneth D. Brienzo
Associate Engineer

cc: JGKepler, NRC
RBDeWitt
RBSewell



10829

APPENDIX D

UNIT Palisades
 DATE 10-6-75
616-764-8913
 COMPLETED BY KDBrienzo
 DOCKET NO. 50-255

OPERATING STATUS

1. REPORTING PERIOD: 750901 THROUGH 750930
 HOURS IN REPORTING PERIOD: 720
 2. CURRENTLY AUTHORIZED POWER LEVEL (MWth) 2200 MAX. DEPENDABLE CAPACITY (MWe-NET) 684
 3. LOWEST POWER LEVEL TO WHICH SPECIFICALLY RESTRICTED (IF ANY) (MWe-NET): 630
 4. REASONS FOR RESTRICTION (IF ANY): Power restricted to 2100 MWT due to reduced Primary Coolant Flow as a result of Steam Generator Tube plugging.

	THIS REPORTING PERIOD	YR TO DATE	CUMULATIVE TO DATE
5. HOURS REACTOR WAS CRITICAL	<u>632.4</u>	<u>3,921.5</u>	<u>14,158.4</u>
6. REACTOR RESERVE SHUTDOWN HOURS	<u>0</u>	<u>0</u>	<u>0</u>
7. HOURS GENERATOR ON LINE	<u>625.3</u>	<u>3,794.8</u>	<u>13,115.9</u>
8. UNIT RESERVE SHUTDOWN HOURS	<u>0</u>	<u>0</u>	<u>0</u>
9. GROSS THERMAL ENERGY GENERATED (MWH)	<u>977,856</u>	<u>6,019,320</u>	<u>20,132,880</u>
10. GROSS ELECTRICAL ENERGY GENERATED (MWH)	<u>294,260</u>	<u>1,774,000</u>	<u>6,278,250</u>
11. NET ELECTRICAL ENERGY GENERATED (MWH)	<u>270,114</u>	<u>1,629,035</u>	<u>5,882,740</u>
12. REACTOR AVAILABILITY FACTOR (1)	<u>87.8%</u>	<u>59.9%</u>	<u>43.1%</u>
13. UNIT AVAILABILITY FACTOR (2)	<u>86.8%</u>	<u>57.9%</u>	<u>39.8%</u>
14. UNIT CAPACITY FACTOR (3)	<u>54.8%</u>	<u>36.3%</u>	<u>29.8%</u>
15. UNIT FORCED OUTAGE RATE (4)	<u>12.3%</u>	<u>41.9%</u>	<u>57.4%</u>
16. SHUTDOWNS SCHEDULED TO BEGIN IN NEXT 6 MONTHS (STATE TYPE, DATE, AND DURATION OF EACH):			

17. IF SHUT DOWN AT END OF REPORT PERIOD, ESTIMATED DATE OF STARTUP: _____
 18. UNITS IN TEST STATUS (PRIOR TO COMMERCIAL OPERATION) REPORT THE FOLLOWING:

	DATE LAST FORECAST	DATE ACHIEVED
INITIAL CRITICALITY	_____	_____
INITIAL ELECTRICAL POWER GENERATION	_____	_____
COMMERCIAL OPERATION	_____	_____

- (1) REACTOR AVAILABILITY FACTOR = $\frac{\text{HOURS REACTOR WAS CRITICAL}}{\text{HOURS IN REPORTING PERIOD}} \times 100$
 (2) UNIT AVAILABILITY FACTOR = $\frac{\text{HOURS GENERATOR ON LINE}}{\text{HOURS IN REPORTING PERIOD}} \times 100$
 (3) UNIT CAPACITY FACTOR = $\frac{\text{NET ELECTRICAL POWER GENERATED}}{\text{MAX. DEPENDABLE CAPACITY (MWe-NET) X HOURS IN REPORTING PERIOD}}$
 (4) UNIT FORCED OUTAGE RATE = $\frac{\text{FORCED OUTAGE HOURS}}{\text{HOURS GENERATOR ON LINE + FORCED OUTAGE HOURS}} \times 100$

APPENDIX C

DOCKET NO. 50-255

UNIT Palissades

DATE 10-6-75

COMPLETED BY KDBrienzo

AVERAGE DAILY UNIT POWER LEVEL

MONTH September 1975

DAY	AVERAGE DAILY POWER LEVEL (MWe-net)	DAY	AVERAGE DAILY POWER LEVEL (MWe-net)
1	<u>422</u>	17	<u>543</u>
2	<u>423</u>	18	<u>458</u>
3	<u>424</u>	19	<u>498</u>
4	<u>432</u>	20	<u>506</u>
5	<u>415</u>	21	<u>508</u>
6	<u>0</u>	22	<u>509</u>
7	<u>0</u>	23	<u>511</u>
8	<u>0</u>	24	<u>508</u>
9	<u>0</u>	25	<u>508</u>
10	<u>65</u>	26	<u>507</u>
11	<u>145</u>	27	<u>511</u>
12	<u>225</u>	28	<u>511</u>
13	<u>290</u>	29	<u>511</u>
14	<u>373</u>	30	<u>510</u>
15	<u>447</u>	31	<u></u>
16	<u>497</u>		

DAILY UNIT POWER LEVEL FORM INSTRUCTIONS

On this form, list the average daily unit power level in MWe-net for each day in the reporting month. Compute to the nearest whole megawatt.

These figures will be used to plot a graph for each reporting month. Note that by using maximum dependable capacity for the net electrical rating of the unit, there may be occasions when the daily average power level exceeds the 100% line (or the restricted power level line). In such cases, the average daily unit power output sheet should be footnoted to explain the apparent anomaly.

APPENDIX E
UNIT SHUTDOWNS

DOCKET NO. 50-255

UNIT NAME Palisades

DATE -6-75

COMPLETED BY KDBrienzo

REPORT MONTH September 1975

NO.	DATE	TYPE F-FORCED S-SCHEDULED	DURATION (HOURS)	REASON (1)	METHOD OF SHUTTING DOWN THE REACTOR (2)	CORRECTIVE ACTIONS/COMMENTS
8	750906	F	87.6	A	1	Shutdown to repair Control Rod drive mechanisms.

- (1) REASON
A--EQUIPMENT FAILURE (EXPLAIN)
B--MAINT. OR TEST
C- REFUELING
D-REGULATORY RESTRICTION
E-OPERATOR TRAINING AND
LICENSE EXAMINATION
F-ADMINISTRATIVE
G-OPERATIONAL ERROR
(EXPLAIN)
H-OTHER (EXPLAIN)
- (2) METHOD
1-MANUAL
2-MANUAL
SCRAM
3-AUTOMATIC
SCRAM

SUMMARY: The unit operated for the month of September at 70% to 80% except for the outage noted for work on Control Rod Drive mechanisms.

1.16-E-1