37.00

MV AGCY WHEA

WU MVN ILL
WUA166 HH 1200P CDT
VEB085(1042)(I-008804C138)PD 05/17/76 1039
TLX CONSPOWER JKN
ZCZC 0001 DLY JACKSON MICHIGAN 5-17-76
PMS US NUCLEAR REGULATORY COM
(FORMERLY US ATOMIC ENERGY COM)
MR J G KEEPLER
799 ROOSEVELT ROAD
GLEN ELLYN, IL 50137
SUBJECT CONFIRMATION OF PROMPT REPORTABLE EVENT
MSIV VALVE INTEGRITY (ER-PAL-76-16)

36

THIS IS TO CONFIRM MY TELEPHONE REPORT ON MAY 14, 1976 WITH MR E JORDAN, CONCERNING THE PRELIMINARY RESULTS OF AN ANALYSIS OF THE PALISADES MSIVS. WE HAVE CONCLUDED THAT VALVE INTEGRITY MAY BE LOST, IN THE EVENT OF A MAIN STEAM LINE BREAK, FOR THE VALVE ASSOCIATED WITH THE BREAK. A REVIEW OF THE PALISADES FSAR SHOWS THAT THE

STEAM LINE RUPTURE INCIDENT ASSUMED COMPLETE BLOWDOWN OF THE STEAM GENERATOR ASSOCIATED WITH THE STEAM LINE BREAK AND, THEREFORE, THAT THIS TYPE OF INCIDENT HAS BEEN REVIEWED.

D A BIXEL
NCULEAR LICENSING
CONSUMERS POWER CO
ALL HO
:
WU AGCY WHEA

UNITED, STATES

NUCLEAR REGULATORY COMMISSION

REGION III 799 ROOSEVELT ROAD GLEN ELLYN, ILLINOIS 60137

2/4/26

Incident Notification From:

Consumers Power Company 50-255'
(Licensee & Docket No. (or License No.))

Transmittal Date:

June 4, 1976 Palisades Plant

Distribution:

IE Chief, FOSB
IE Chief, FC&EB
IE:HQ(4)
Licensing(4)
DR•Central Files

IE Files

Distribution:

IE Files

IE Chief, FOSB
IE Chief, FC&EB
IE:HQ(4)
L:D/D for Fuels & Materials
DR Central Files