

D. Lannan




**Consumers  
Power  
Company**

General Offices: 212 West Michigan Avenue, Jackson, Michigan 49201 • Area Code 517 788-0550

May 7, 1976

Regulatory Docket File

Mr James G. Keppler  
Office of Inspection Enforcement  
Region III  
US Nuclear Regulatory Commission  
799 Roosevelt Road  
Glen Ellyn, IL 60137




DOCKET 50-255, LICENSE DPR-20 -  
PALISADES PLANT, ER-76-011  
CONTAINMENT ISOLATION VALVE

Attached is a Licensee Event Report which relates to the Palisades Plant. This event was originally thought to be nonreportable since containment integrity was not required at the time the problem was observed and a second isolation valve performed satisfactorily. Later review disclosed that it may be reportable as "abnormal degradation discovered in the primary containment." Such an interpretation must conclude that degradation of one of two in series valves designed to isolate containment is intended to be reported under the prompt notification requirements.

*Karen J. McElroy for*

David A. Bixel  
Assistant Nuclear Licensing Administrator

CC: R. A. Purple, USNRC



5037

MAY 10 1976

# LICENSEE EVENT REPORT

CONTROL BLOCK:           

(PLEASE PRINT ALL REQUIRED INFORMATION)

LICENSEE NAME	LICENSE NUMBER	LICENSE TYPE	EVENT TYPE
<span style="border: 1px solid black; padding: 0 5px;">01</span> M I P A L L	<span style="border: 1px solid black; padding: 0 5px;">00</span> <span style="border: 1px solid black; padding: 0 5px;">-00</span> <span style="border: 1px solid black; padding: 0 5px;">00</span> <span style="border: 1px solid black; padding: 0 5px;">00</span> <span style="border: 1px solid black; padding: 0 5px;">-00</span> <span style="border: 1px solid black; padding: 0 5px;">00</span>	<span style="border: 1px solid black; padding: 0 5px;">41</span> <span style="border: 1px solid black; padding: 0 5px;">11</span> <span style="border: 1px solid black; padding: 0 5px;">11</span> <span style="border: 1px solid black; padding: 0 5px;">11</span>	<span style="border: 1px solid black; padding: 0 5px;">01</span>
7 8 9 14 15 25 26 30 31 32			

CONT	REPORT TYPE	REPORT SOURCE	DOCKET NUMBER	EVENT DATE	REPORT DATE
<span style="border: 1px solid black; padding: 0 5px;">01</span> CONT	<span style="border: 1px solid black; padding: 0 5px;">T</span>	<span style="border: 1px solid black; padding: 0 5px;">L</span>	<span style="border: 1px solid black; padding: 0 5px;">05</span> <span style="border: 1px solid black; padding: 0 5px;">0-02</span> <span style="border: 1px solid black; padding: 0 5px;">55</span>	<span style="border: 1px solid black; padding: 0 5px;">03</span> <span style="border: 1px solid black; padding: 0 5px;">28</span> <span style="border: 1px solid black; padding: 0 5px;">76</span>	<span style="border: 1px solid black; padding: 0 5px;">05</span> <span style="border: 1px solid black; padding: 0 5px;">06</span> <span style="border: 1px solid black; padding: 0 5px;">76</span>
7 8 57 58 59 60 61 68 69 74 75 80					

## EVENT DESCRIPTION

02 During the Palisades local leak rate testing, the test on penetration #46 showed

03 leakage above acceptable limits (about 111 liters/min). The leakage was associated

04 with one of two in series valves. The second valve performed satisfactorily.

05 Affected parts replaced. (ER-76-011)

06

SYSTEM CODE	CAUSE CODE	COMPONENT CODE	PRIME COMPONENT SUPPLIER	COMPONENT MANUFACTURER	VIOLATION
<span style="border: 1px solid black; padding: 0 5px;">07</span> S D	<span style="border: 1px solid black; padding: 0 5px;">E</span>	<span style="border: 1px solid black; padding: 0 5px;">V A L V E X</span>	<span style="border: 1px solid black; padding: 0 5px;">A</span>	<span style="border: 1px solid black; padding: 0 5px;">M 1 2 0</span>	<span style="border: 1px solid black; padding: 0 5px;">N</span>
7 8 9 10 11 12 17 43 44 47 48					

## CAUSE DESCRIPTION

08 The valve (CV-1101) is a 4" globe valve with Teflon soft seats. Inspection dis-

09 closed that the seats were worn from use (normal wear). The valve is a 150 psi ASA

10 rated valve made of carbon steel, Model 38-20571, and is air operated.

FACILITY STATUS	% POWER	OTHER STATUS	METHOD OF DISCOVERY	DISCOVERY DESCRIPTION
<span style="border: 1px solid black; padding: 0 5px;">11</span> H	<span style="border: 1px solid black; padding: 0 5px;">000</span>	<span style="border: 1px solid black; padding: 0 5px;">NA</span>	<span style="border: 1px solid black; padding: 0 5px;">b</span>	<span style="border: 1px solid black; padding: 0 5px;">NA</span>
7 8 9 10 12 13 44 45 46 80				

FORM OF ACTIVITY RELEASED	CONTENT OF RELEASE	AMOUNT OF ACTIVITY	LOCATION OF RELEASE
<span style="border: 1px solid black; padding: 0 5px;">12</span> Z	<span style="border: 1px solid black; padding: 0 5px;">Z</span>	<span style="border: 1px solid black; padding: 0 5px;">NA</span>	<span style="border: 1px solid black; padding: 0 5px;">NA</span>
7 8 9 10 11 44 45 80			

## PERSONNEL EXPOSURES

NUMBER	TYPE	DESCRIPTION
<span style="border: 1px solid black; padding: 0 5px;">13</span> 000	<span style="border: 1px solid black; padding: 0 5px;">Z</span>	<span style="border: 1px solid black; padding: 0 5px;">NA</span>
7 8 9 11 12 13 80		

## PERSONNEL INJURIES

NUMBER	DESCRIPTION
<span style="border: 1px solid black; padding: 0 5px;">14</span> 000	<span style="border: 1px solid black; padding: 0 5px;">NA</span>
7 8 9 11 12 80	

## PROBABLE CONSEQUENCES

15 None. Redundant valve operated properly.

## LOSS OR DAMAGE TO FACILITY

TYPE	DESCRIPTION
<span style="border: 1px solid black; padding: 0 5px;">16</span> Z	<span style="border: 1px solid black; padding: 0 5px;">NA</span>
7 8 9 10 80	

## PUBLICITY

17 NA

## ADDITIONAL FACTORS

18 NA

19