



Telegram

VEB257(1712)(1-031234035 S)PD 12/22/75 1715 DEC 22 PM 4:15

TLX CONSPower JKN

ZCZC 0005 DLY JACKSON MICHIGAN 12-22-75

PWS US NUCLEAR REGULATORY COM
(FORMERLY US ATOMIC ENERGY COM)

ATT: K R BAKER

799 ROOSEVELT RD

GLENN, IL 60137

SUBJECT: REPORTABLE OCCURRENCE

312
TELEPHONE NO. 858-2660
TELETYPE TO 428 BY 45
DATE DED. 12-22 TIME 538P
ATTEMPTS TO DELIVER:
None

THIS IS TO CONFIRM A TELECON WITH K R BAKER TODAY CONCERNING A REPORTABLE OCCURRENCE AT PALISADES YESTERDAY. DURING PLANT COOLDOWN AND REMOVAL OF THE A COOLING TOWER FROM SERVICE, PLANT DISCHARGE WATER TEMPERATURE EXCEEDED THE FIVE DEGREE DELTA T LIMIT OF TS 3.3.3. THIS CONDITION IS DIFFICULT TO AVOID DURING CT SHUTDOWN AND LASTED ONLY ONE HALF HOUR.

DEC 24 1975

SF-1201 (R5-69)

J G LEVIS

PALISADES PLANT

CONSUMERS POWER CO

CC: R B DE WITT, R B SEWELL

50-255

ALL NO

NNNN

SF-1201 (R5-69)

UNITED STATES
NUCLEAR REGULATORY COMMISSION
REGION III
799 ROOSEVELT ROAD
GLEN ELLYN, ILLINOIS 60137

12/29/75

Incident Notification From: Consumers Power Company 50-255
(Licensee & Docket No. (or License No.))

Transmittal Date : December 29, 1975 Palisades Plant

Distribution:

IE Chief, FOSB
IE Chief, FC&EB
IE:HQ(4)
Licensing(4)
DR Central Files
IE Files

Distribution:

IE Chief, FSOB
IE Chief, FC&EB
IE:HQ(4)
L:D/D for Fuels & Materials
DR Central Files
IE Files

