

# **Official Transcript of Proceedings**

## **NUCLEAR REGULATORY COMMISSION**

Title: Advisory Committee on Reactor Safeguards

Docket Number: (n/a)

Location: Rockville, Maryland

Date: Thursday, December 6, 2018

Work Order No.: NRC-4025

Pages 1-200

**NEAL R. GROSS AND CO., INC.**  
**Court Reporters and Transcribers**  
**1323 Rhode Island Avenue, N.W.**  
**Washington, D.C. 20005**  
**(202) 234-4433**

DISCLAIMER

UNITED STATES NUCLEAR REGULATORY COMMISSION'S  
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

The contents of this transcript of the proceeding of the United States Nuclear Regulatory Commission Advisory Committee on Reactor Safeguards, as reported herein, is a record of the discussions recorded at the meeting.

This transcript has not been reviewed, corrected, and edited, and it may contain inaccuracies.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

UNITED STATES OF AMERICA  
NUCLEAR REGULATORY COMMISSION

+ + + + +

659TH MEETING

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

(ACRS)

+ + + + +

THURSDAY

DECEMBER 6, 2018

+ + + + +

ROCKVILLE, MARYLAND

+ + + + +

The Advisory Committee met at the Nuclear  
Regulatory Commission, Three White Flint North, Room  
1C3 & 1C5, 11601 Landsdown Street, at 1:00 p.m.,  
Michael L. Corradini, Chairman, presiding.

COMMITTEE MEMBERS:

MICHAEL L. CORRADINI, Chairman

PETER RICCARDELLA, Vice Chairman

RONALD G. BALLINGER, Member

DENNIS C. BLEY, Member

CHARLES H. BROWN, JR. Member

MARGARET SZE-TAI Y. CHU, Member

VESNA B. DIMITRIJEVIC, Member

1 WALTER L. KIRCHNER, Member

2 JOSE MARCH-LEUBA, Member

3 HAROLD B. RAY, Member

4 JOY L. REMPE, Member

5 GORDON R. SKILLMAN, Member

6 MATTHEW W. SUNSERI, Member

7

8 ACRS CONSULTANT:

9 STEPHEN SCHULTZ

10

11 DESIGNATED FEDERAL OFFICIALS:

12 QUYNH NGUYEN

13 KENT HOWARD

14

15 ALSO PRESENT:

16 KENNETH BROWNE, NextEra

17 WILLIAM BURTON, NRR

18 ANDY CAMPBELL, NRO

19 EDWARD CARLEY, NextEra

20 MICHAEL COLLINS, NextEra

21 JOSEPH DONOGHUE, NRR

22 ALLEN FETTER, NRO

23 RUDY GIL, NextEra

24 MICHELLE HART, NRO

25 ALLEN HISER, NRR

1 ARCHIE MANOHARAN, Tennessee Valley Authority  
2 ERIC MCCARTNEY, NextEra  
3 BRUCE MUSICO, NSIR  
4 ERIC OESTERLE, NRR  
5 RAYMOND SCHIELE, Tennessee Valley Authority  
6 MICHAEL SCOTT, NSIR  
7 DANIEL STOUT, Tennessee Valley Authority  
8 MALLECIA SUTTON, NRO  
9 ALEX YOUNG, Tennessee Valley Authority  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

## C-O-N-T-E-N-T-S

Clinch River Early Site Permit . . . . .	5
Seabrook License Renewal Application . . . . .	97
Adjourn . . . . .	123

## P R O C E E D I N G S

(1:00 p.m.)

CHAIRMAN CORRADINI: Okay. The meeting will come to order. This is the first day of the 659th meeting of the Advisory Committee on Reactor Safeguards.

During today's meeting the Committee will consider the following. Clinch River early site permit, Seabrook License Renewal Application, and then preparation of ACRS reports.

The ACRS was established by statute, and is governed by the Federal Advisory Committee Act, or FACA. As such, this meeting is being conducted in accordance with the provisions of FACA. That means that the Committee can only speak through its published letter reports.

We hold meetings to gather information to support our deliberations. Interested parties who wish to provide comments can contact our offices requesting time after the Federal Register notice describing the meeting as published.

That said, we also set aside ten minutes for extemporaneous comments from members of the public attending or listening to our meetings. Written comments are also welcome.

1           Mr. Quynh Nguyen is the designated Federal  
2           Official for the initial portion of the Meeting. The  
3           ACRS section of the US NRC public website provides our  
4           charter, by-laws, letter reports, and full transcripts  
5           of all our full and Subcommittee meetings, including  
6           all the slides presented at those meetings.

7           At this time we've not received any  
8           written comments, or requests to make oral statements  
9           from members of the public regarding today's session.  
10          There will be phone bridge line. To preclude  
11          interruption of the meeting the phone will placed in  
12          a listen in only mode during the presentation of the  
13          Committee discussion.

14          Also, a transcript of portions of the  
15          meeting is being kept, and it is requested that  
16          speakers use one of the microphones, identify  
17          themselves, and speak with sufficient clarity and  
18          volume so they can be readily heard.

19          So, at this time I'll just remind  
20          everybody, take all your things and turn them off, or  
21          put them in mute, so we don't have to hear buzzing or  
22          beeping. And with that I'll turn to Member Kirchner  
23          to lead us through the first topic.

24                 MEMBER KIRCHNER: Thank you, Chairman.  
25                 Apologies for the slight delay in arriving. We have



1 heard from the applicant and staff over the course of  
2 the last year.

3 We had a informational briefing on  
4 November 15th of last year. Then we had four  
5 additional informative meetings with both parties.  
6 So, with that I'm ready to turn it over to the staff,  
7 to Andy Campbell to proceed, please.

8 MR. CAMPBELL: If I can remember how to  
9 turn these things on. I'm Andy Campbell. I'm the  
10 Deputy Director of the Division of Licensing, Siting,  
11 and Environmental Analysis in the Office of New  
12 Reactors at the NRC.

13 Mr. Chairman, it is a great pleasure to be  
14 here today for the full Committee meeting on the  
15 Clinch River Nuclear site, early site permit, what  
16 we'll call the SP, application safety review submitted  
17 to the NRC May 26, 2016.

18 This submittal is the first ESP for a  
19 small modular reactor plant design. And it was prior  
20 to staff's work on the small modular reactor and other  
21 new technologies rulemaking. Accordingly, the  
22 application and the review of the application by the  
23 staff is based on current regulations and guidance.

24 Staff has presented a series of ACRS  
25 Subcommittee meetings on the staff's safety review of

1 the application. And today staff will be presenting  
2 our final overview, with no open items, for the Clinch  
3 River ESP safety evaluation report.

4 The ESP review has been progressing  
5 consistent with the schedule, and completion of  
6 today's full Committee now puts the project ahead of  
7 schedule.

8 For example, staff provided an overview to  
9 ACRS in November 15, 2017, a little over a year ago.  
10 Previous staff presentations for the relevant SER  
11 chapters to several ACR Subcommittee meetings, from  
12 May 15 of this year, 2018, to November 14, 2018.

13 The NRC staff safety review of the  
14 application included the execution and completion of  
15 five audits and one inspection, and the issuances of  
16 12 RAIs comprising 50 questions.

17 The staff completed all the advance safety  
18 evaluation with no open items.

19 Staff's presentation, and then the  
20 applicant's presentations today are, we're going to  
21 focus on, the staff will focus on the EPZ, with an  
22 overview of the other Subcommittee presentations.

23 One key point is, if the exemptions are  
24 approved for the ESP, the COL applicant can adopt  
25 these exemptions if it shows that a COLA PEPE EPZ

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 source term release to the atmosphere are bounded by  
2 the non-design specific plant parameter source term  
3 information developed for the ESP.

4 A future COL application featuring an SMR  
5 design that fits within the plant parameter envelope  
6 established in the ESP could apply the approved  
7 methodology to the design selected, to determine the  
8 appropriate PEP EPZ, and for the site, and also to  
9 demonstrate whether the conditions for either of the  
10 two sets of exemptions have been met.

11 Also in the audience today, besides NRC  
12 staff and applicant staff are representatives from the  
13 Federal Emergency Management Agency, FEMA,  
14 Technological Hazards Division. And representatives  
15 from Tennessee Emergency Management Agency are on the  
16 conference bridge. So, now I'm going to turn it back  
17 to you.

18 MEMBER KIRCHNER: So, thank you. I think  
19 we're going to turn to the applicant at this point.  
20 Okay. Dan, please proceed.

21 MR. STOUT: Thank you. Good afternoon.  
22 I want to start by expressing our appreciation for the  
23 flexibility to adjust the schedule, and get this done.  
24 We took advantage of the opportunity and got to go pay  
25 our respects at the Capital yesterday morning early.

1 And so, win, win.

2 So, I'm Dan Stout. I'm the Director of  
3 Nuclear Technology and Innovation for the Tennessee  
4 Valley Authority, managing this small module reactor  
5 activity, particularly the early site permanent  
6 application.

7 I'll be kicking off an introduction,  
8 talking about the site and the SMR program. And then  
9 I'm going to turn it over to Ray Schiele, Licensing  
10 Manager, who's going to cover the specifics of the  
11 early site permanent application itself. And then, as  
12 requested, Archie Manoharan will be doing a deeper  
13 dive into the emergency preparedness portion of the  
14 application.

15 So, I'd like to acknowledge the Department  
16 of Energy, who has been an integral partner in  
17 supporting the SMR activities that TVA is undertaking,  
18 particularly with financial assistance. However, the  
19 views expressed are TVA's alone.

20 So, on Slide 5, I'll remind everyone that  
21 Tennessee Valley Authority's mission is broader than  
22 just making electricity. It's also important to be a  
23 good steward of the environmental resources, and to be  
24 a partner in economic development.

25 TVA has been focused on the Clinch River

1 site in Oak Ridge, Tennessee. It's a 1,200 acre site.  
2 The project is confined to 335 acres on that 1,200  
3 acre reservation.

4 And it is a good site. Has access to both  
5 500 and 161 KV transmission, which cut through the  
6 site. It is a neighbor to the Department of Energy,  
7 a customer that is interested in the output from this  
8 project.

9 The site was disturbed back in the 1970s  
10 and '80s. It was the site of the former Clinch River  
11 breeder reactors. So, there's some basic  
12 infrastructure, roads, storm water retention, things  
13 like that.

14 The community of Oak Ridge, you couldn't  
15 ask for a better place to want to do something  
16 nuclear. Not only is there strong community support,  
17 but there's an abundant and skilled nuclear workforce  
18 there. And it's a site that's within TVA's ownership  
19 and control. So, it makes proceeding rather easy.

20 Next. So, the early site permit  
21 application itself consists of site safety analysis  
22 report, environmental report, Part 5 emergency plans.  
23 And we actually submitted two different emergency  
24 plans, one for site boundary, one for two mile.  
25 Archie will get into those details. And a consistent

1 set of exemptions that go along with those emergency  
2 plans.

3 Our early site permit application is based  
4 upon a plant parameter envelope that was informed by  
5 the designs of the four U.S. light water reactors that  
6 were under development over the previous few years.  
7 That includes the B&W mPower, Holtec, NuScale, and  
8 Westinghouse.

9 The application was developed, and the  
10 plant parameter envelope was developed based upon NE  
11 1001 guidance. It assume that two or more reactors of  
12 the same design deployed, and a maximum of 800  
13 megawatts thermal for an individual reactor, and a  
14 maximum of 2,420 megawatts thermal for the site.

15 Next. So, the schedule, we're here  
16 focused on the safety element, which is the, kind of  
17 the top row. There's the other track, environmental,  
18 and then the hearings.

19 So, on the safety side the NRC schedule  
20 calls for issuance of the final safety evaluation  
21 report in August. We're hopeful that we're ahead of  
22 that schedule.

23 The environmental, the staff issued the  
24 draft environmental impact statement in April. And it  
25 looks like we're on track to be ahead of the June

1 schedule goal.

2 On the hearing side there were four  
3 contentions filed. Two were admitted. In July the  
4 Atomic Safety and Licensing Board dismissed all  
5 outstanding contentions, and terminated the contested  
6 hearing. Subsequently, the Commission indicated that  
7 it's their intent to run the mandatory hearing.

8 Next. So, I'd like to hit some highlights  
9 of the early site permit application, and the review  
10 process itself. The NRC commenced the review in the  
11 very beginning of 2017. The application as originally  
12 submitted had about 8,000 pages, supported by about  
13 80,000 pages of technical information.

14 One of the highlights I'd like to point  
15 out is the efficient use of audits. The staff did a  
16 great job of preparing well in advance, and listing  
17 out all of their questions, all of the information  
18 needs, well in advance of the audit.

19 So then, when the audit occurred we were  
20 able to prepare responses to all of those open items  
21 well, all of those information needs well in advance,  
22 so that when they were there face to face there was  
23 meaningful discussion on the challenges.

24 By the end of the audits we had clarity on  
25 how to resolve all the issues. That manifested itself

1 in very few RAIs. As Andy mentioned, it's about a  
2 dozen, as compared to hundreds for prior applications.

3 And I'm going to attribute a lot of that  
4 success to very frequent, clear, and candid  
5 communication. We, both staff and the applicant, we  
6 identified issues early, and we escalated them, put  
7 the resources on those issues early.

8 So, next. So, I'd like to turn it over to  
9 Ray Schiele now to talk about the early site permit  
10 application.

11 MR. SCHIELE: Thank you, Dan. Good  
12 afternoon. I'm Ray Schiele, currently the Licensing  
13 Manager for the Clinch River Nuclear Early Site Permit  
14 Application. I have 44 years in this industry,  
15 primarily operations and licensing. And since 2016  
16 the Licensing Manager for the Clinch River project.

17 Quick overview of the organization of the  
18 application. The Clinch River application contains  
19 the information required by 10 C.F.R. 52.17, contents  
20 of applications for an early site permit. And was  
21 submitted in accordance with NRC guidance on  
22 electronic submittals.

23 Part 1, administrative information. This  
24 section contains an overview of the early site permit  
25 application, a general description of the format,



1 content of the application, and corporate information,  
2 including ownership, management, and Board of  
3 Directors.

4 Part 2, the SSAR, includes a discussion of  
5 the site description, safety assessment, quality  
6 assurance, general location of the site, site  
7 suitability, design parameters postulated for the CRN  
8 site, population profiles, and an assessment of site  
9 features that may affect the design chosen for the  
10 facility.

11 Part 3, environmental report. The ER  
12 addresses the environmental impacts associated with  
13 construction and operation of new SMRs.

14 Part 4, site redress plan. TVA is not  
15 pursuing a limited work authorization with this  
16 application. Therefore, there is no redress plan.

17 Part 5, emergency planning information.  
18 The emergency planning information includes major  
19 features of the emergency plan. And there will be  
20 more information with Archie.

21 Part 6, exemptions and departures. This  
22 part lists applicant requested exemptions that are  
23 authorized by law, would not endanger life, property,  
24 or common defense and security, and are otherwise in  
25 the public interest. A discussion and justification

1 for each of the requests is included in this part.  
2 There were no departures requested in Part 6.

3 Part 7, withheld information. This part  
4 contains information redacted from other parts of the  
5 application due to sensitive or proprietary nature of  
6 the information.

7 And last, Part 8, enclosures. All  
8 enclosures submitted with the early site permit  
9 application are provided in Part 8.

10 ESPA development, the regulatory bases.  
11 This slide illustrates the regulatory bases for the  
12 development of both the SSAR and ER. The regulatory  
13 bases consist of various regulations, standard review  
14 plans, reg guides, and review standards.

15 NRC interactions. Prior to the ESPA  
16 submittal in May of 2016 the NRC performed pre-  
17 application site visits, alternative site visits, and  
18 pre-application readiness review.

19 After submittal the NRC performed three  
20 major audits in the spring and summer of 2017,  
21 supporting hydrology, ground water, seismic, geotech,  
22 and environmental.

23 In addition, a comprehensive four month EP  
24 audit not listed on this slide commenced in the fall  
25 of 2017, and was supplemented by an additional audit

1 in the spring of 2018. In the spring of 2018 the NRC  
2 conducted a QA inspection, covering Chapter 17.5 of  
3 the SSAR.

4 Community timeline. In 2018 the ACRS  
5 Committee met in May, August, October, and November to  
6 review selected SSAR sections, as shown on the slide.  
7 And today, as the slide illustrates, we're here for  
8 the final full Committee meeting.

9 TVA was asked to provide additional  
10 information associated with the approach to emergency  
11 preparedness. I would now like to introduce Archie to  
12 discuss the EP. Archie.

13 MS. MANOHARAN: Thank you, Ray. Good  
14 afternoon. Thank you for the opportunity to present  
15 today. As we mentioned I'm Archie Manoharan. I've  
16 been working in the nuclear industry for the last ten  
17 years, joined the licensing team at Clinch River in  
18 2017.

19 And I would like to begin with the layout  
20 of the emergency preparedness approach in the  
21 application. To fully understand the emergency  
22 preparedness approach for Clinch River it's important  
23 to consider the information in three parts of the  
24 application.

25 Part 2, SSAR Section 13.3 in Section,

1 emergency preparedness, describes a dose based  
2 consequence or entered methodology for determining a  
3 plume exposure pathway EPZ for the site.

4 We have not selected a reactor design for  
5 the site. So, in this section the application is only  
6 seeking approval to use the methodology at a later  
7 stage, with design specific information, say in a  
8 COLA.

9 This methodology, along with the SMR  
10 design features is sort of the basis for the emergency  
11 preparedness approach described in the application.  
12 Based on the methodology Part 5 of the application has  
13 two distinct emergency plans.

14 Part 5 Alpha has major features of an  
15 emergency plan for a site boundary EPZ. And Part 5  
16 Bravo has major features of an emergency plan for a  
17 two mile EPZ. Again, only major features are  
18 discussed in Part 5. There is no design specific  
19 information.

20 At a COLA, once the reactor design has  
21 been selected, and the dose based methodology that's  
22 described in 13.3 is adequately demonstrated, we would  
23 pick one of the emergency plans described in Part 5.

24 For example, if the selected reactor  
25 design meets the dose criteria at site boundary, we

1 would go ahead and use Part 5 Alpha to create a  
2 integrated and complete emergency plan and COLA. If  
3 the reactor design meets the dose criteria at two mile  
4 EPZ, then Part 5 Bravo would be used.

5 The information in Part 5 meets the  
6 regulatory requirements if you consider it with the  
7 exemption requests described in Part 6. In Part 6 of  
8 the application two sets of exemption requests have  
9 been described, one to support the site boundary EPZ,  
10 and the other for the two mile.

11 Next slide. We're on Slide 17. And the  
12 dose based methodology described in Section 13.3 is  
13 consistent with the sizing rationale described in  
14 NUREG 0396. The NUREG introduced the concept of a  
15 generic EPZ, and recommends that a spectrum of  
16 accidents be addressed for the EPZ sizing.

17 So, consistent with that approach the  
18 methodology we are proposing in the application also  
19 describes, also addresses a spectrum of accidents.  
20 And more importantly, it has the same dose criteria  
21 for the plume exposure pathway EPZ as a recommendation  
22 in NUREG 0396, which is the one rem total effective  
23 dose equivalent, the early phase EPA PAG.

24 Consistent with the NUREG the technical  
25 criteria in the dose based methodology can be

1 understood as Criteria Alpha, Bravo, and Charlie.  
2 Alpha can be understood as the plume exposure EPZ  
3 should be of, encompass of those areas where projected  
4 dose from design basis accidents could exceed the one  
5 rem TEDE.

6 Bravo the same, except for dose  
7 consequences from less severe core melt accidents.  
8 Criterion Charlie would verify that the plume exposure  
9 pathway EPZ is of sufficient size to provide for  
10 substantial reduction in early health effects in the  
11 case of more severe core melt accidents.

12 Next slide. So, we're on Slide 18. And  
13 this slide here describes the steps involved in  
14 implementing the methodology. The methodology at a  
15 high level contains four steps, starting with accident  
16 scenario selection. This is where you would rely on  
17 design and site specific information to do the  
18 appropriate accident selection.

19 For Criterion Alpha accidents you would  
20 rely on the bounding design basis accidents from  
21 Chapter 15 of the COLA. For the severe accident  
22 scenarios you would rely on the site and design  
23 specific PRA. And the criteria is actually shown  
24 here.

25 So, sequence. Firstly we'll start with

1 sequences with a mean core damage frequency greater  
2 than E to the negative eight per reactor year. And  
3 then you would further categorize them into criteria.

4 Bravo accident scenarios would be mean  
5 core damage frequency greater than E to the negative  
6 six, with intact containment.

7 And Charlie, the more severe core melt  
8 accidents, would be accidents with mean core damage  
9 frequency greater than E to the negative seven, or  
10 with containment bypass of the --

11 MEMBER KIRCHNER: Archie, may I interrupt  
12 here? So, I think this is mentioned in your  
13 application. For rhetorical purposes, if the design  
14 you choose, the PRA doesn't show any accidents  
15 greater, severe accidents. I'm looking at in  
16 particular greater than one E to the minus seven.  
17 Then I think you suggest putting in an alternate  
18 source term. Is that --

19 MS. MANOHARAN: That is correct. So, for  
20 Criterion Bravo, it's not listed on this slide, but  
21 there is an additional note in the methodology that  
22 even if you pick a reactor design that has no accident  
23 screened in for Criterion Bravo you still have to  
24 create alternate --

25 MEMBER KIRCHNER: Now, is -- Well, I'll

1 get a chance to ask the staff whether they're in  
2 agreement with this approach. But then, how would you  
3 come about, go about picking that source term?

4 MS. MANOHARAN: I think we can actually  
5 explain that during the example analysis.

6 MEMBER KIRCHNER: Okay. I'll wait.

7 MS. MANOHARAN: Which is in the next  
8 slide. Because we encountered that exact scenario in  
9 the example analysis. So, okay. So, moving on to the  
10 next slide, 19.

11 So, you would, after the steps one through  
12 -- I apologize. Can we go back to 18? Yes. So,  
13 after the accident selection, based on the cut off  
14 frequencies described here, Step 2 would be to  
15 determine the source term releases from the selected  
16 accidents.

17 Step 3 would be to calculate the dose  
18 resulting from these accidents at a distance from the  
19 plant. Four obviously would be to compare that to the  
20 EPA PAG limits to ensure that we are within that one  
21 rem limit. Next slide, please.

22 So, Criteria Alpha and Bravo, as I just  
23 mentioned, you would compare the dose calculated to  
24 one rem, and make sure you're not exceeding that. For  
25 Criterion Charlie, consistent with NUREG 0396



1 approach, you would calculate the distance at which  
2 the conditional probability to exceed 200 rem whole  
3 body exceeds in the negative three per reactor year.

4 CHAIRMAN CORRADINI: So, with that one,  
5 can you tell me how the one in a thousand is computed?  
6 I go back to 0396, and I'm lost. Tell me how that's  
7 computed. I understand the dose criteria. I don't  
8 understand what the frequency represents.

9 MS. MANOHARAN: Okay. I will bring in  
10 Alex to --

11 CHAIRMAN CORRADINI: If you want to do it  
12 later, that's fine. I, whenever it's suitable. I  
13 just want to understand what that is.

14 MS. MANOHARAN: We can do it now.

15 CHAIRMAN CORRADINI: Okay.

16 MR. YOUNG: So, my name's Alex Young. I'm  
17 working as a design engineer on the SMR project. Been  
18 here since September of 2014. So, the question is,  
19 you know, about the Criterion C dose criteria.

20 The conditional probably to exceed 200 rem  
21 whole body is one E minus three. So, we look at that.  
22 As you go out in distance from the release point, the  
23 reactor building, the probability of acquiring a  
24 certain dose goes down, based on meteorology.

25 So, we're looking at the distance at which

1 the probability of acquiring the 200 rem whole body  
2 dose exceeds the one E minus 3.

3 CHAIRMAN CORRADINI: I got that part. I  
4 don't understand why -- So, let me, so, here's where  
5 I'm confused. I've now got accidents that fit in a  
6 range of greater than ten to the minus seven, but less  
7 than ten to the minus six. Yes, the frequency is one  
8 ten minus three.

9 So, have you subtracted a way, or taken  
10 out the initiating even frequency? This, the number  
11 sounds high to me, one in a thousand. I'm confused  
12 about one in ten to the seventh, ten to the minus  
13 seventh, versus ten to the minus three. That's where  
14 I'm struggling.

15 MR. YOUNG: Sure. So, for the Criterion  
16 C piece, on the previous line we kind of highlight the  
17 main CDF greater than one E minus seven per reactor  
18 year. So, that's looking at the probability of the  
19 event.

20 So, once you have the event, and you have  
21 a release, primarily based on meteorology statistics  
22 you have the probability changing as you go out in  
23 distance for that release. So, it's an additional  
24 factor in addition to the screening piece that's added  
25 in Criterion C.

1                   MEMBER MARCH-LEUBA: So, in terms I can  
2 understand. Sometime we talk about a 500 year flood,  
3 100 year flood. This is equivalent to that? So, you  
4 have the same, the initial source term. And now you  
5 consider the one thousand worst year that can possibly  
6 happen? Correct?

7                   MR. YOUNG: Yes. That's a good analogy to  
8 categorize it.

9                   CHAIRMAN CORRADINI: Okay. I'm still not  
10 there. Sorry. So, I've taken away the initiating  
11 event frequency, and all the estimates. And I've  
12 developed the source term. Then I release the source  
13 term, and I ask, what's the probability of getting a  
14 dose greater than 200 rem at a distance?

15                  MR. YOUNG: You find out what distance it  
16 is at which the probability of getting that dose is  
17 one E minus --

18                  MEMBER MARCH-LEUBA: But you run a  
19 thousand different years and pick the worst.  
20 Basically that's what you do, right? So, you start  
21 with a source term. And then, you propagate it, year  
22 one, year two, year three, using different winds,  
23 rain, different meteorological conditions, and pick  
24 the worst in a thousand.

25                  MR. YOUNG: So, that's where the

1 meteorology comes into play, is looking at, you know,  
2 the meteorology that we have over time, how the  
3 statistics play out in that. What are the  
4 probabilities of having certain meteorological  
5 conditions that, you know, make it, you know, how that  
6 disburses.

7 CHAIRMAN CORRADINI: Okay. But if I might  
8 just jump in? So, the one in a thousand is due to the  
9 meteorology at the site? It's not due to the  
10 production of the source term?

11 MR. YOUNG: It's both. It's the  
12 combination. Because you have the initial even, which  
13 allows the probability of the release.

14 CHAIRMAN CORRADINI: No. That part I got.  
15 But once I get the source term, because it sits in  
16 this band between ten minus seven and ten to the minus  
17 six, now I have a source term. And the one in a  
18 thousand is just a meteorological uncertainty, or  
19 meteorological distribution?

20 MR. YOUNG: That's the additional factor  
21 that is applied to the propagation of the source term.

22 CHAIRMAN CORRADINI: Okay.

23 MEMBER REMPE: So, if I went to the next  
24 slide here, and I looked at that number. You call it  
25 a probability. But it's got a frequency unit.

1 MR. YOUNG: Yes.

2 MEMBER REMPE: So, wouldn't it be a  
3 probability? Doesn't have a unit -- Why does it have  
4 units of frequency if, I mean, earlier you called it  
5 a core damage frequency, something per reactor year.

6 Now you're calling this a conditional  
7 probability. Shouldn't it just be ten to the minus  
8 three, instead of per reactor year? This is kind of  
9 a basic question here. But I thought probabilities  
10 wouldn't be in per reactor year.

11 MR. YOUNG: Sure. So, we think, and a lot  
12 of times we think of, you know, probability. And we  
13 tie that to a frequency here. So, we're looking at,  
14 you know, the probability that you have that 200 rem  
15 dose at what distance for one E minus three per  
16 reactor year.

17 MEMBER SKILLMAN: Alex, I'd like to ask  
18 this. At least two times, and maybe three, you  
19 mentioned the coupling of the probability of the event  
20 with meteorology.

21 MR. YOUNG: Yes.

22 MEMBER SKILLMAN: And I'll just tell you,  
23 my background was Bellefonte. I was one of the  
24 original managers for, or B&W managers for Bellefonte.  
25 So, we got well-schooled in the Sequatchie anticline,

1 and the Lake Guntersville, and the meteorology down in  
2 that section of Alabama.

3 But we were interacting with the teams  
4 that were doing the other TVA plants at Sequoya and  
5 Watts Bar, at Browns Ferry. And so, we got tuned into  
6 different meteorologies at different locations.

7 I understand you to say, if you look at  
8 the event frequency, and look at the meteorology, you  
9 then come up with a probability of someone getting  
10 dosed at 200 rem.

11 Does that say that if you put the plant at  
12 Clinch River it might have one probability? And if  
13 you put the plant at Sequoya or Watts Bar with a  
14 different meteorology, that will be a different?

15 Okay. Now, hold that thought. How do you  
16 predict that meteorology? Because it sounds to me  
17 like you're using a probability riddle for a natural  
18 event that, at least in my judgment is very variable.  
19 The uncertainty has to be huge.

20 MR. YOUNG: So, the meteorology that we  
21 used for this analysis, and for the additional pieces  
22 of this are based on data collected from the site, and  
23 analyzed over, you know, a period of time, in  
24 accordance with, you know, applicable regulatory  
25 guidance.

1                   MEMBER SKILLMAN:   Over what period of  
2                   time?

3                   MR. YOUNG:   So, for SSAR Section 2.3, in  
4                   accordance with regulatory guidance 1.23, that comes  
5                   down to a minimum of two years of data.

6                   MEMBER SKILLMAN:   Why is two years  
7                   sufficient for a siting decision, when that site will  
8                   be employed potentially for 60 or 80 years?

9                   MR. YOUNG:   So, there are additional steps  
10                  that continue to -- So, in addition with monitoring  
11                  the site specific data over two years, you have to  
12                  compare that to historical pieces as well, and  
13                  different pieces in the area, to make sure that it's  
14                  representative of the site, and over a period of time.

15                  In addition to that, there's also on site  
16                  monitoring that you continue to do over the life of  
17                  the plant.

18                  MEMBER SKILLMAN:   Thank you.

19                  MEMBER MARCH-LEUBA:   That's scary. You're  
20                  saying that I build my plant, I pay the money, and now  
21                  I have to monitor the wind. And if the wind gets off  
22                  outside you assume I lose my license?

23                  MR. YOUNG:   So, there's, to that question,  
24                  what we're looking at is, we have changes in  
25                  meteorology. We do a lot of analysis to, you know,

1 show that that meteorology is consistent over a long  
2 period of time. And we include abundant margin within  
3 that meteorology to account for potential changes like  
4 that.

5 MEMBER MARCH-LEUBA: So, you're hoping  
6 that your monitoring is large enough that you'll never  
7 get caught?

8 MR. YOUNG: Absolutely. Yes.

9 MEMBER MARCH-LEUBA: But you are running  
10 the risk?

11 MR. YOUNG: That's an operational risk we  
12 take.

13 MS. MANOHARAN: Okay. So --

14 CHAIRMAN CORRADINI: So, let me summarize,  
15 since I started this. I want to make sure I am clear.  
16 So, the one in a thousand is based on the site  
17 meteorology, conditional on the fact that I've had a  
18 severe accident of a certain frequency band. And is  
19 it all those accidents that, and you look for the  
20 worst source term of that grouping of accidents?

21 MR. YOUNG: So, that comes down to the  
22 step of, you know, determine source term releases from  
23 selected accidents in determining the selected  
24 accident, that appropriate evaluation. So, you know,  
25 as you go through this you'll come up with the, for



1 the accidents that screen in you would come up with  
2 the, you know, the bounding accident --

3 CHAIRMAN CORRADINI: Okay.

4 MR. YOUNG: -- evaluation.

5 CHAIRMAN CORRADINI: So, you're looking  
6 for the bounding source term within that frequency  
7 band. You then do the computation on some sort of  
8 weather variability. And the weather variability is  
9 what essentially the term is a one in a thousand? I  
10 want to make sure I'm clear. Have I said it  
11 correctly?

12 MR. YOUNG: Yes. The, yes.

13 MEMBER RICCARDELLA: So then, are we  
14 really talking like probability to ten to the minus  
15 nine? Yes. If we have a event probability of ten to  
16 the minus six, and then the, if that event occurs the  
17 probability of achieving this dose is --

18 MR. YOUNG: Yes.

19 MEMBER RICCARDELLA: -- ten to the minus  
20 third. So, we're talking ten to the minus ninth?

21 PARTICIPANT: No.

22 MR. YOUNG: The essential. So, you would  
23 have the even probability, which would be greater than  
24 one E minus 7.

25 MEMBER RICCARDELLA: Yes. Somewhere

1 between seven, six and seven.

2 MR. YOUNG: And then you would apply the  
3 factor to it, based on meteorology. And if the total  
4 frequency of the 200 rem dose exceeds one E minus --  
5 It has to be, at that distance you have to be within  
6 a probability of one E minus three for the 200 rem.

7 MEMBER RICCARDELLA: So --

8 CHAIRMAN CORRADINI: You said it now.

9 MEMBER RICCARDELLA: So then, the real  
10 probability of that occurring, of that event  
11 occurring, and a person getting that dose is ten is to  
12 the minus nine, or somewhere between ten to the minus  
13 tenth and ten to the minus ninth, right?

14 MR. YOUNG: Yes. You'd have to have the  
15 probability of the event --

16 MEMBER RICCARDELLA: Yes.

17 MR. YOUNG: -- first.

18 MEMBER RICCARDELLA: Yes.

19 MR. YOUNG: And actually --

20 MEMBER MARCH-LEUBA: You would have to  
21 integrate --

22 MEMBER RICCARDELLA: It's a condition.  
23 Yes.

24 MEMBER MARCH-LEUBA: -- year one through  
25 1,000 what the consequences are. So, it's not ten to

1 the minus nine. It's much, much higher.

2 MEMBER RICCARDELLA: Why?

3 MEMBER MARCH-LEUBA: Well, because --

4 MEMBER RICCARDELLA: Multiple events.

5 MEMBER MARCH-LEUBA: This is the 1,000  
6 year methodology. You can have the 500 year  
7 methodology, the 100 year methodology. All of those  
8 give you those. So, you have to do the interval of  
9 all of those to get that average. It's math.

10 MEMBER RICCARDELLA: But regardless,  
11 that's a conditional probability, right? So, that  
12 only applies if you have the event.

13 MEMBER MARCH-LEUBA: Ten to minus seven  
14 you're giving with.

15 MEMBER RICCARDELLA: Yes.

16 MEMBER MARCH-LEUBA: Because that's when  
17 you have the event.

18 MEMBER RICCARDELLA: Yes.

19 MEMBER MARCH-LEUBA: Now you're picking  
20 the worst possible year in a 1,000 --

21 MEMBER RICCARDELLA: Yes.

22 MEMBER MARCH-LEUBA: -- to propagate it to  
23 the end of EPZ. But if you had a better way you will  
24 still propagate some dose.

25 CHAIRMAN CORRADINI: But a lower dose.

1                   MEMBER MARCH-LEUBA: It will be a little  
2 lower dose with higher probability. So, you will have  
3 to do some kind of interval. And I don't know how to  
4 write it out right now.

5                   MEMBER RICCARDELLA: I'll have Dennis,  
6 I'll ask Dennis to explain it to me after the meeting.

7                   MS. MANOHARAN: So, back on this slide,  
8 this is the example analysis that was conducted as a  
9 result of the staff's RAI. So, we use the NuScale  
10 design at Clinch River site to do a demonstration, an  
11 example demonstration, to show what the dose at site  
12 boundary would result from the NuScale design.

13                   So, as you can see for Criterion Alpha and  
14 Bravo the doses are on, in that table. And they have  
15 significant margin to the one rem limit. And there's  
16 also additional margin built in within the calculation  
17 that resulted in that example analysis.

18                   Moving on to next slide, Slide number 20.  
19 So as, both Dan and Ray had mentioned earlier, Part 5  
20 of the application contains two major feature, two  
21 emergency plans, major features of emergency plan.  
22 One to support the site boundary EPZ, and the other  
23 for the two mile EPZ.

24                   Now, what they do is they, both of the  
25 address the 16 planning standards of NUREG 0654. Once

1 a reactor design is selected for COLA you would do the  
2 dose based methodology that Section 13.3 describes to  
3 pick your EPZ size.

4 So, if it is site boundary, then you go  
5 with 5 Alpha, and you would incorporate design  
6 specific information, and create a complete and  
7 integrated emergency plan.

8 If the dose is met at two miles you would  
9 take the Part 5 Bravo, incorporate the rest of the  
10 elements to make a complete and integrated emergency  
11 plan.

12 If for some reason you pick a reactor  
13 design that doesn't meet either site boundary or two  
14 mile, then we would have to come up with a new  
15 emergency plan and COLA. Next slide, please.

16 CHAIRMAN CORRADINI: Just one  
17 clarification. The thinking that you guys have come  
18 with, with this either or approach is, the two miles  
19 is bound to the EAB?

20 MS. MANOHARAN: So, the reason for two  
21 emergency plans is, when the plant parameter envelope  
22 was being developed at least one of them, we were  
23 confident that at least one design would meet site  
24 boundary EPZ. So, we pursued the site boundary  
25 emergency plan.

1 CHAIRMAN CORRADINI: But not all of them?

2 MS. MANOHARAN: We were confident that all  
3 of them would meet --

4 CHAIRMAN CORRADINI: Okay.

5 MS. MANOHARAN: -- two mile.

6 CHAIRMAN CORRADINI: Okay.

7 MS. MANOHARAN: Therefore, the two mile.

8 MR. STOUT: And two miles was a surrogate  
9 for scalable. You know, we, the staff had indicated  
10 through SECYs a willingness to consider scalable EPZ.  
11 We picked the number that we thought would bound all  
12 four designs, and be representative of scalable.

13 CHAIRMAN CORRADINI: Can I torture you one  
14 last time? So, did you do any sort -- Well, maybe I  
15 should ask the staff this. Somebody should ask  
16 someone this question, which is, if I did two years  
17 and had the appropriate meteorology, and then I looked  
18 back ten years, and I did the same thing, did I see a  
19 big difference in the, I'll call it the uncertainty,  
20 or the distribution function of the various types of  
21 meteorology. Was this done?

22 MR. YOUNG: So, you're asking, so, we did,  
23 we collected two years of onsite data. Did we look at  
24 how that compared to, you know, a longer period of  
25 time? Yes, we did.

1                   We did comparisons, you know, from data  
2                   that was collected from the breeder reactor project.  
3                   We also did comparisons to operating fleets, or our  
4                   operating fleet, data collected in surrounding stuff.

5                   CHAIRMAN CORRADINI: Thank you.

6                   MS. MANOHARAN: So, moving on to Slide  
7                   number 21. Part 6 of the application describes the  
8                   exemption requests that support the emergency  
9                   preparedness approach in the application.

10                  So, if you look at Part 6 there are two  
11                  sets of exemption requests. One that support the side  
12                  boundary EPZ, and one that support two mile. As Dan  
13                  had mentioned, two mile is a surrogate for scalable.

14                  And the only real exemption request we're  
15                  asking for in two mile EPZ is to deviate from the ten  
16                  mile. We understand that if we go with two mile then  
17                  there would be a need for formal offsite emergency  
18                  plans.

19                  And for the site boundary, in addition to  
20                  deviate from the ten mile EPZ, some, various elements  
21                  of, let's say off site exercises and notifications,  
22                  evacuation time estimate analysis, we're taking  
23                  exemption, we're requesting exemptions from that.

24                  MEMBER RAY: Excuse me. You said, if we  
25                  go with two mile. And then I couldn't understand what

1       you said after that.

2               MS. MANOHARAN: That there would be a need  
3       for formal off site emergency response plans. So,  
4       even if it is two mile, and not a ten mile, there  
5       would still need to be an off site response structure,  
6       if you will.

7               So, the site boundary EPZ is, let's say  
8       the most restrictive, and has the most number of  
9       exemption requests. And two mile is only asking to  
10      deviate from the size of the EPZ.

11              MEMBER RAY: Thank you.

12              MS. MANOHARAN: Next slide, please. So  
13      lastly, this is a summary slide that shows the  
14      emergency preparedness information in the ESPA, and  
15      how each of these pieces will be used in the COLA if  
16      at all the COLA is pursued.

17              So, in Section 13.3, as we've been  
18      discussing throughout this presentation, there's a  
19      dose based, consequence oriented methodology  
20      described. It's design neutral. It's not specific to  
21      any one particular design that informs the PPE. And  
22      we're asking approval of the methodology.

23              At COLA, once the reactor design has been  
24      selected, we would implement the methodology with  
25      design specific implementation, and figure out what

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 the EPZ size for that particular reactor design at the  
2 site would be.

3 In Part 6 of the ESPA the set of exemption  
4 requests that have been requested. And those would be  
5 implemented based on the dose based methodology  
6 results at COLA. So, at COLA we would seek approval  
7 of a design specific plume exposure pathway EPZ size  
8 for the reactor design selected.

9 Lastly, the emergency plan, Part 5, two  
10 distinct major features of an emergency plan for site  
11 boundary and two mile are represented in the ESPA. At  
12 COLA, after the dose based methodology is implemented,  
13 the final EPZ size has been determined, we would pick  
14 the appropriate emergency plan.

15 It could be the site boundary in Part 5  
16 Alpha, or Part 5 Bravo, or a new design, a new EP  
17 based on the reactor design. And we'll create a  
18 complete and integrated plan. And the next one? And  
19 that concludes our portion of the presentation. Thank  
20 you for the opportunity today.

21 MEMBER KIRCHNER: Thank you. I think what  
22 we, what you're hearing from us is, we, since we met  
23 last we've been struggling with understanding exactly  
24 how -- In NUREG 0396 they have a figure. It's, for  
25 the record I'll cite it.

1           It's Figure I-11, Page I-38, which is how  
2           that task force actually came to the recommendation  
3           for the ten mile EPZ for the larger fleet of reactors  
4           that existed. And this was shortly after WASH-1400,  
5           the Reactor Safety Study.

6           So, it appears to us that this is an  
7           integrated curve, as Member Rempe is pointing out.  
8           It's giving us probability, but not per reactor year.  
9           It takes a probability based on a conditional core  
10          melt of, on the order of ten to the minus five at the  
11          time.

12          And then, with that source term,  
13          propagates with, in this case they use straight line  
14          plume trajectories for the weather. And then we're  
15          able to come up with isoclines, so to speak, of dose  
16          versus distance.

17          So, that's the historical basis and  
18          background for the current ten mile. What has been  
19          puzzling us is, and what you're proposing, how you go  
20          through the calculation once you have a given, either  
21          a class of accidents that are severe, or even a  
22          dominant accident.

23          It's clear to us how you used meteorology  
24          to propagate dose. But it's not clear how this  
25          probability of ten to the minus third is arrived at.

1 So, perhaps that's a question we also take up with the  
2 staff. Okay. So, that's the concern. I hope I've  
3 summarized well enough why we're puzzling collectively  
4 here.

5 The methodology in principle makes sense.  
6 But we're, we have been puzzling over just why this is  
7 probability per reactor year. As Member Riccardella  
8 pointed out, a simplistic approach might be to  
9 multiply the two together and get very low numbers,  
10 not what are reason -- what are indicated as a fairly  
11 high number, one in a thousand.

12 CHAIRMAN CORRADINI: We're engineers. We  
13 want to get the mechanics right.

14 MEMBER KIRCHNER: Thank you.

15 MEMBER REMPE: Actually, again, because we  
16 were chatting, and trying to figure out what was going  
17 on, and I have not attended all your Subcommittee  
18 meetings.

19 But you mentioned at the beginning what if  
20 the, or someone asked, what if they don't even have a  
21 source term at something ten to the minus eight? They  
22 can't get something out. And you said that there was  
23 some sort of example you were going to show us.

24 And, was I distracted, and I missed what  
25 you were going to do if they have no source term, for

1 example?

2 MS. MANOHARAN: So, what I was mentioning  
3 for that question is that for severe accidents if,  
4 what if you pick a reactor design that does not have  
5 a accident that screens in -- Can you go to one?

6 MEMBER REMPE: Yes. What if it's like ten  
7 to the minus ten?

8 CHAIRMAN CORRADINI: Screen it out.

9 MEMBER REMPE: Yes.

10 CHAIRMAN CORRADINI: Then it's not there.

11 MEMBER REMPE: If you totally --

12 MS. MANOHARAN: Yes.

13 MEMBER REMPE: And what, you're going to  
14 force them, you said earlier, to come up with  
15 something.

16 MS. MANOHARAN: Yes. So, there is an  
17 additional --

18 (Off microphone comments.)

19 MS. MANOHARAN: Yes. So, for Criterion  
20 Bravo there is an additional note in our methodology  
21 that says that even if there are accidents that are,  
22 that screen in based on your reactor design, you still  
23 have to create a source term, an alternative source  
24 term to analyze the severe accident. So --

25 MEMBER REMPE: And again, I haven't

1 attended your Subcommittee meeting, but remind me what  
2 are you going to do for how they created? Or that's  
3 to be determined, on how they're going to generate  
4 something?

5 MS. MANOHARAN: So, I think Alex can speak  
6 a little bit on that. But I will say, for example --  
7 let's go to the next one. Sorry to keep jumping. So,  
8 this is the NuScale example, as I was mentioning.  
9 It's just an example to show how the methodology would  
10 be implemented.

11 So, Criterion Alpha would be the design  
12 basis accidents from NuScale's Chapter 16 analysis.  
13 And then Bravo would be the severe, less severe core  
14 melt accidents.

15 So, I will walk through the example, and  
16 what accidents screened in, and why it would make  
17 sense to have an alternative source. So, if we pick  
18 a reactor design that doesn't have screening.

19 MEMBER REMPE: So, with your example,  
20 which you claim is associated with NuScale, they  
21 generated an alternate source term? And that's really  
22 beyond your methodology. You don't know how they did  
23 it. They just came up with something that was their  
24 alternate source term?

25 MS. MANOHARAN: Not quite. So, they

1 don't, for example, the accidents that resulted in  
2 this example analysis for Criterion A would be the  
3 design based accidents, which is a combination of  
4 what, their LOCA and other accidents.

5 So, it's not just the design based  
6 accidents. So, it's more representative of their  
7 Criteria Bravo also. And then, Bravo was their most  
8 probable accident, which is the loss of DC power  
9 sequence, the most probably accident.

10 MEMBER REMPE: So, they didn't have to go  
11 to some -- Or did they tell you what the frequency was  
12 for those type of events?

13 MS. MANOHARAN: I think we know the  
14 answer.

15 MR. YOUNG: So, we do know what the  
16 frequencies are associated with those sequences that  
17 informed their design basis accident analysis. But  
18 those are proprietary to NuScale.

19 MEMBER REMPE: Okay. So, let's ask it in  
20 a way that -- They basically picked something below  
21 ten to the minus eight, and they went ahead and moved  
22 it up.

23 So, basically you're kind of forcing them.  
24 So, I'm glad I brought this up, even though I may have  
25 missed some of the details.

1 MS. MANOHARAN: You may, yes.

2 MEMBER REMPE: But they basically agreed  
3 to just take a hit --

4 MS. MANOHARAN: It's several magnitudes  
5 lower. So --

6 MEMBER REMPE: Yes. So, they basically  
7 agreed to take a hit, just so that they could do  
8 something.

9 MS. MANOHARAN: Because of the note in our  
10 methodology that you have to do the analysis.

11 MEMBER REMPE: Okay. And they were okay  
12 with that? Okay. Thank you.

13 MS. MANOHARAN: And that information, I do  
14 want to just, that information is in an RAI response  
15 to the staff. So, the staff has seen that analysis.

16 MEMBER REMPE: Thank you.

17 MEMBER RICCARDELLA: Could I ask why Row  
18 B has a higher dose, site boundary dose, than Row A?  
19 And it's less severe?

20 MR. YOUNG: So, Row A is based on  
21 NuScale's Chapter 15 design basis accident analysis.  
22 And Criterion A, the accident or sequences that were  
23 evaluated for that are based on several accidents, you  
24 know, happening. Criterion B is just looking at one  
25 of those accident sequences that informs A, which is

1 a --

2 MEMBER RICCARDELLA: Okay.

3 MR. YOUNG: It's a more severe accident.

4 MEMBER BLEY: Design basis accidents  
5 aren't core melt accidents.

6 MEMBER RICCARDELLA: Okay.

7 MEMBER BLEY: Are not. So, the next one  
8 is more severe.

9 MEMBER KIRCHNER: Okay. Well, at this  
10 point then, if there are no further questions of the  
11 applicant from the members at this point? Okay.  
12 Well, let's change then to your team. Andy, please.

13 (Pause.)

14 CHAIRMAN CORRADINI: Okay. Mallecia,  
15 Allen? Who's going to lead off?

16 MR. FETTER: I'm going to start. Just  
17 getting us started here.

18 (Off microphone comments.)

19 MR. FETTER: Okay. Just my screen looked  
20 a little different. So, I was a little confused  
21 there. Good afternoon. I'm Allen Fetter. Mallecia  
22 Sutton and I are the safety project managers for the  
23 Clinch River nuclear site, early site permit  
24 application.

25 And I will be presenting an overview of



1 the staff's findings and recommendations, which were  
2 discussed at the four previous ACRS Subcommittee  
3 meetings. The technical reviewers are also here to  
4 address questions in their technical areas that, any  
5 questions you have during the presentation.

6 TVA submitted an early site permit  
7 application for the Clinch River nuclear site on May  
8 26, 2016. The application was accepted for detailed  
9 technical review and docketing on December 30th, 2016.

10 TVA requested a permit approval for a 20  
11 year term, along with approval for a plume exposure  
12 pathway, or PEP, emergency planning zone, sizing  
13 methodology, two major features, on site emergency  
14 plans and exemption requests for site boundary and two  
15 mile PEP EPZs. The plant perimeter envelope was based  
16 on four small modular reactor designs.

17 A staff overview presentation to ACRS on  
18 the Clinch River ESP was given on November 15th, 2017.  
19 The NRC staff's safety review of the application  
20 included execution of five audits, and one inspection,  
21 and issuance of 12 RAIs, comprising 50 questions.

22 The staff completed all advanced safety  
23 evaluations with no open items, and presented their  
24 findings at four ACRS Subcommittee meetings between  
25 May 15th, 2018 and November 14th, 2018. The advanced

1 safety evaluations include 42 COL action items and  
2 eight permit conditions.

3 Staff cooperated with the U.S. Army Corps  
4 of Engineers, consulted with the Federal Emergency  
5 Management Agency, and engaged with the Department of  
6 Energy, the Tennessee Department of Environment and  
7 Conservation, and the U.S. Geological Survey, and the  
8 Tennessee Emergency Management Agency.

9 So, an early site permit plant parameter  
10 envelope values can bound a variety of reactor  
11 technologies, rather than one specific technology, an  
12 amalgam of values representing a surrogate nuclear  
13 plant.

14 The PPE values are bounding criteria used  
15 by staff to determine the suitability of an ESP site  
16 for construction and operation of a nuclear plant.

17 In the combined license application, when  
18 a specific technology is identified the PPE values are  
19 compared to those of the selected technology.

20 If design parameters of the selected  
21 technology exceed bounding ESP PPE values additional  
22 reviews are conducted to ensure that the site remains  
23 suitable from a safety and environmental standpoint  
24 for the construction and operation of the selected  
25 nuclear plant technology.

1 MEMBER KIRCHNER: Allen?

2 MR. FETTER: Yes.

3 MEMBER KIRCHNER: I'm going to interrupt  
4 at this point. I was going to ask this later in your  
5 presentation. Maybe I'll just put this down. And  
6 maybe you can address it later.

7 The, one of your permit conditions that  
8 you're going to share with us is the use of the Table  
9 13.3-1, which is the PPE set of source terms by  
10 isotopes. And what if there's a variance in that?

11 Or are you confident that, maybe it's a  
12 question of the applicant as well, that if something  
13 in the fuel cycle that is used, we know that they're  
14 using LWR derivative fuel in most of the concepts that  
15 are under consideration.

16 But what if there's a variance in that  
17 table, that they exceeded one of these radionuclide  
18 amounts with the concept that they chose to go forward  
19 with, that COL point? What happens then?

20 MS. SUTTON: So, during the exemption and  
21 presentation Michelle will discuss that --

22 MEMBER KIRCHNER: Okay.

23 MS. SUTTON: -- in more detail.

24 MEMBER KIRCHNER: Excellent. Okay.

25 MS. SUTTON: Thank you.

1 MEMBER KIRCHNER: Thank you.

2 MS. SUTTON: You're welcome.

3 MR. FETTER: Okay. As stated before, the  
4 plant parameter envelope is based on four modular  
5 reactor designs, mPower, NuScale, Holtec, and  
6 Westinghouse. TVA's PPA is based on construction and  
7 operation of two or more SMRs at the Clinch River  
8 nuclear site, with a generating capacity of 2,420  
9 megawatts thermal, or 800 megawatts electric.

10 Okay. This slide is for ACRS records. It  
11 depicts all of the advanced safety evaluations, and  
12 their associated accession numbers in ADAMS, that were  
13 provided for all the ACRS Subcommittee meetings.

14 MEMBER RAY: There's no assumption at this  
15 point as to the number of units that might be affected  
16 by any of the events described, right? It could be  
17 one. It could be all. Is that correct?

18 MS. SUTTON: So, during the exemption  
19 presentation -- This is just a overview of the staff's  
20 safety evaluation. We will address all those in  
21 details for you. I promise. So, hold that thought.

22 MEMBER RAY: So, I will indeed. But so,  
23 we're going to find, the answer is different for each  
24 of these. Is that what I just heard you say?

25 MS. SUTTON: No. That's not what I said,

1       sir.  So, Michelle, do you want to --

2                       (Off microphone comments.)

3                       MS. SUTTON:  Okay.  Go ahead.  Ask the  
4       question one more time.

5                       MEMBER RAY:  Is there any assumption in  
6       what we're reviewing here, in a multi module site,  
7       that only one of the modules will be affected at a  
8       time?  I'm looking at events here that include  
9       vibratory ground motion, for example.

10                      MS. SUTTON:  Does any of the staff like to  
11       address the question?

12                      MR. CAMPBELL:  Well, let me address that.  
13       This is a plant parameter envelope for an ESP.  There  
14       are a variety of assumptions that are put in by both  
15       the applicant and the staff in its review.

16                      And with that said, we're looking at a  
17       number of different scenarios within that plant  
18       parameter envelope.  So, that's how it's developed.  
19       And the plant parameter envelope encompasses all the  
20       designs.  So, I don't know if TVA wants to  
21       specifically --

22                      MR. FETTER:  It looks like Alex --

23                      MR. CAMPBELL:  -- address that question.

24                      MR. FETTER:  -- wants to come to the --

25                      MEMBER RAY:  Before they do, let me just

1 say I would interpret what you just said to be that  
2 no, there's no assumption in what we're reviewing now  
3 that only one module would be affected by an event.  
4 That's how I interpret what you just said.

5 MR. CAMPBELL: In some scenarios that go  
6 into the plant parameter envelope, and someone who's  
7 actually an expert in this can correct me if I'm  
8 wrong.

9 There are scenarios where there's one  
10 module. There are scenarios where there's more than  
11 one module, if it makes sense. And, you know, the  
12 frequency of occurrence of more than one module is  
13 within that range that should be considered.

14 MEMBER RAY: Okay. Well, I think that  
15 you've answered the question. I'm at least going to  
16 understand it to be that we aren't limiting  
17 consideration to only a single module being affected  
18 in what we're discussing now. But that's my  
19 understanding of what you just said.

20 MR. CAMPBELL: And we'll confirm that.

21 MEMBER RAY: Thank you.

22 MR. CAMPBELL: Okay.

23 MEMBER REMPE: Actually, there was a guy  
24 from TVA who might be able to confirm it now.

25 MR. CAMPBELL: Yes.

1 MEMBER REMPE: And since we're doing our  
2 letter in the next --

3 MR. CAMPBELL: Yes.

4 MEMBER REMPE: -- few hours --

5 MEMBER RAY: Thank you.

6 MEMBER REMPE: Yes. I'd like to hear --

7 MEMBER RAY: Yes.

8 MEMBER REMPE: -- his response --

9 MEMBER RAY: We would too.

10 MEMBER REMPE: -- to my --

11 MR. YOUNG: Sure. So, my name's Alex  
12 Young. So, the question was about multi module  
13 accidents for the ESPA. Currently the way we've  
14 assessed the ESPA, based on the plant parameter  
15 envelope, the inputs that we have do not assume any  
16 multi module accidents. They're all based on single  
17 unit accidents, or single units events.

18 At the COLA stage, depending on the design  
19 selected, that's something that would have to be  
20 evaluated based on the design. But currently the  
21 assumption for the ESPA is only single module events.

22 MEMBER RAY: But what's the basis for  
23 that?

24 MR. YOUNG: The basis for that is based on  
25 the design information that we have available at the

1 time for input into the ESPA for the PPE. We don't  
2 project, or believe that there are going to be multi  
3 module events that have to be considered for this.

4 MEMBER RAY: But that's a belief, as you  
5 express it, that I don't understand the basis for.

6 MEMBER RICCARDELLA: But if your plant  
7 parameter -- Excuse me, Hal, I'm sorry. If your plant  
8 parameter envelope is based on 800 megawatts, then  
9 doesn't that automatically address, doesn't that  
10 automatically cover multi-unit accidents for the  
11 smaller module, for the smaller units?

12 MEMBER RAY: Well, I don't know if you're  
13 asking me or not --

14 MEMBER RICCARDELLA: No. I'm asking TVA.

15 MR. YOUNG: So, part of the piece here is  
16 design basis accidents versus beyond design basis  
17 accidents. So, there's Chapter 15 analysis, design  
18 basis accidents, which for the information we have  
19 right now doesn't consider those multi module  
20 accidents, based on the design information that we  
21 have currently, when we developed this.

22 For the EPZ portion, you know, we have to  
23 consider those multi module accidents. And at COLA we  
24 still have to, you know, go and consider the  
25 possibility of those multi module accidents for

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 Chapter 15 as well. So --

2 MEMBER RAY: Yes. I understand it at the  
3 COLA period. Whether or not the early site permit  
4 parameters fit within what is then being proposed of  
5 the COLA is one of the issues that is, necessarily has  
6 to be addressed at that time.

7 But I guess it's just, you said, based on  
8 your understanding of the plants, this -- What's being  
9 described here isn't just a early site permit boundary  
10 based on a limiting size accident. You're actually  
11 talking about multiple units.

12 And now you're saying that the assumption  
13 is based on an understanding which is not part of this  
14 process. That only one of them at a time will be  
15 affected. And I just want to be clear that that's  
16 what's going on.

17 MR. CAMPBELL: At the stage of the COL the  
18 applicant would have to, with the specific design.  
19 Because the applicant here for the ESP looked at a  
20 range of different designs.

21 At the COL stage, when you have a specific  
22 design, then you can do that type of analysis, and  
23 establish what that is. And if that exceeds the  
24 parameter, then they would have to take a deviation or  
25 exemption.

1 MEMBER REMPE: So --

2 MEMBER RAY: Although the applicant did  
3 what you described, it doesn't sound like we did what  
4 you describe.

5 MR. CAMPBELL: our review is based upon  
6 the ESP, not on what will be done at the COL stage.

7 MEMBER RAY: I guess I'm asking, why is  
8 it, why are we even talking about multiple units, only  
9 one of which has an accident at a time? Why is that  
10 part of the discussion at this point?

11 I mean, I understand establishing an ESP.  
12 I don't understand talking about multiple units, only  
13 one of which is assumed to have an accident at a time,  
14 based on information that isn't part of this  
15 application.

16 I mean, I know that when the COL comes up  
17 this can be addressed. I grant that. But I don't  
18 understand why we're doing what we're doing at this  
19 point, relative to limiting the assumed event to one  
20 of several units that will be at the site that we're  
21 talking about.

22 And with that, I guess we ought to just  
23 leave it there and move on. I just don't understand  
24 it. At least we ought to be clear that that's what's  
25 happening.

1                   MEMBER REMPE: If we could have TVA come  
2 back up for a second to the mic? I had a question,  
3 and I didn't get to get it in in the discussion.  
4 Okay. So, you did, as we talked about, you came up  
5 with some alternate source term based on a  
6 hypothetical

7                   What if you learn more about one of these  
8 plants, and they determine that multiple modules are  
9 involved. How do you think that would affect your  
10 process you've developed here?

11                  MR. YOUNG: So, our process does, you  
12 know, this is specifically talking about the EPZ  
13 methodology. So, that methodology does require us to  
14 look at those multi module events. And we'll look at  
15 those.

16                  In our example analysis, for instance, for  
17 one of the events that we did look at as we were going  
18 through the screening criteria for Criterion C, one of  
19 those was considered a multi module event. It's a  
20 beyond design basis event. But it was required to be  
21 considered based on our methodology in the initial  
22 screening.

23                  The second screening portion, so we have  
24 the E to the minus eight screening, and then we have  
25 the second screening for, at a greater frequency. It

1 was then excluded from that, because it was only a  
2 single event. So, it didn't meet the second screening  
3 criteria.

4 MEMBER REMPE: So, basically if you, if  
5 they learn something new about their plant, and not  
6 picking on any particular one, and they decide  
7 suddenly, well, both modules or all 12 modules are  
8 going to be impacted by an event at a much higher  
9 frequency, your process could accommodate it?

10 MR. YOUNG: Yes. We have to consider  
11 that, yes.

12 MEMBER REMPE: Okay.

13 MEMBER SKILLMAN: Can you accommodate it  
14 without shopping for new meteorology? Yes. I'm  
15 pulling your leg. But I'm serious on the question.

16 MR. YOUNG: So, from what we know about  
17 the example analysis we considered, we would be able  
18 to meet our Criterion C dose requirements based on  
19 that, you know, assumed, if we assume that that multi  
20 module accident screened in. That would meet the dose  
21 criteria. It depends on the accident that would  
22 screen in. So --

23 MEMBER SKILLMAN: Okay. Thank you.

24 MEMBER RAY: Well, I just want to talk to  
25 the NRC at this point, not to the applicant. I just

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 think it needs to be really clear what our  
2 understanding is of what the applicant is assuming in  
3 connection with this ESP. Because it was not  
4 something that I thought was explicit or clear at all.

5 MEMBER KIRCHNER: If I might summarize my  
6 understanding at this point? It's going in, the  
7 applicant has bounded the source term up to a single  
8 unit of 800 megawatts thermal.

9 And they've deferred on the multi-unit,  
10 say common cause, common mode failure kind of concerns  
11 until the COLA application, the COL application. And  
12 a PRA that would then have to be examined to see  
13 whether a multi-unit failure of some kind, or accident  
14 sequence would then lead to a source term that would  
15 exceed what they're currently asking for, as an  
16 exemption for either the one mile or, not one mile,  
17 the site boundary or two mile boundary.

18 If they come in at that point, and don't  
19 screen out multi-unit failures, and find that the dose  
20 exceeds the envelope, then they are not going to be in  
21 a position to get this exemption. Of course --

22 MR. CAMPBELL: They would have to develop  
23 additional information at the COL stage to demonstrate  
24 what that boundary, what the size of the EPZ would be,  
25 given those considerations. There's a full blown PRA

1 done at the COL stage for a specific design.

2 Part of the issue here is, we're not  
3 approving results on the basis of only one specific  
4 design. What we're approving is a methodology. As I  
5 said in my opening, this is an approval of a  
6 methodology that can then be applied at the COL stage.

7 And the exemptions are to the, essentially  
8 the requirements with respect to the ten mile EPZ.  
9 That doesn't mean we're automatically approving either  
10 a site boundary or a two mile EPZ for a COL applicant.  
11 They have to make their case.

12 MEMBER RAY: Well, it's, I'm not sure that  
13 the issue of multi-unit failure isn't going to be  
14 addressed through the DCD, much less, not necessarily  
15 in the COL stage. But in any event, all I'm trying to  
16 do is figure out why, what we're assuming, and why  
17 we're assuming it. So that it's clear.

18 MEMBER DIMITRIJEVIC: Can we go to Slide  
19 number 5? Because it will be clear what we are  
20 asking. Because it says in that, PPEs based on  
21 construction and operation of two or more SMRs at the  
22 Clinch River site.

23 MEMBER RAY: Where, what are you saying,  
24 Vesna? I'm sorry.

25 MEMBER DIMITRIJEVIC: That in the last

1 paragraph, says that this PPE, the plan parameter  
2 envelope is based on construction and operation of two  
3 or more SMRs.

4 MEMBER RAY: Yes. So let's --

5 MEMBER DIMITRIJEVIC: So, why are we  
6 talking two or more?

7 MEMBER RAY: That's why I'm asking the  
8 question is, whether or not we assumed only one of  
9 these, or more, suffered a release that, is what we're  
10 talking about here in setting a boundary. And if we  
11 only assumed one, why?

12 (Off microphone comments.)

13 MS. HART: All right. This is Michelle  
14 Hart, from the staff. I didn't do the Chapter 15  
15 analysis. But I understand the Chapter 15 analysis.

16 So, in general terms, the plan parameter  
17 envelope is developed based on current information,  
18 and does include consideration of one unit at a time,  
19 because we are, there's a presumption that GDCs 2, 4,  
20 and 5 will be complied with, so that you won't have  
21 common cause failures.

22 That you won't have, you know, much like  
23 you don't look at siting for more than one unit, at  
24 the currently operating plants we thought that that  
25 would also apply to a multi module site, until told

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 differently from the specific design.

2 MEMBER RAY: Well, I understand. And I've  
3 operated a multi-unit site. An I know exactly what  
4 you're talking about. But it's also why I'm asking  
5 the question. Because it's not a resolved issue. And  
6 the only thing at the end of the day I'm seeking, is  
7 for us to be clear about what we're doing.

8 And I don't want anybody later to believe  
9 that what we have done here is agree that only a  
10 single unit in a multi-unit site need be assumed to  
11 fail. Notwithstanding multi-unit sites today that  
12 exist today elsewhere. I understand that very well.

13 MS. HART: I think the thing is that the  
14 information that we have, Chapter 15 was based on a  
15 non multi module unit. And so, the single unit was  
16 bounding --

17 MEMBER RAY: Exactly. That's right.

18 MS. HART: And so, it's, I hope it's clear  
19 that that's what we did. But there's no prevention of  
20 saying that if something came in for the COLA to use  
21 this ESP, if it doesn't fit within that PPE, whether  
22 it's a single unit or multi module event, that they  
23 would have to take a variance, and have to describe it  
24 more clearly.

25 MEMBER RAY: Yes. I mean, we think about



1 this in the DCD world also. And so, it's not just  
2 when a COLA comes in on an ESP, for a given site, I  
3 mean. Anyway, I think we've taken enough time here.  
4 Again, my goal isn't to try and change what's  
5 happened. I just wanted to be really clear about the  
6 basis for what I --

7 MEMBER RICCARDELLA: But isn't it fair to  
8 say we're approving a methodology to set the EPZ based  
9 on probabilities of various events? And when you get  
10 to either the DCD stage or for the COL stage, you're  
11 going to have a PRA that talks about the probability  
12 of single unit --

13 MEMBER KIRCHNER: And multi-unit.

14 MEMBER RICCARDELLA: -- and multi-unit  
15 events. And if any of those multi-unit events trigger  
16 these probability limits, they're going to have to be  
17 considered, right?

18 MEMBER RAY: Well, you're not going to be  
19 able to do that given the way the DCDs are envisioned  
20 today, as the design certification being approved.  
21 You're not going to have the information you're  
22 talking about.

23 MEMBER RICCARDELLA: Yes. So, maybe it's  
24 the COL stage. But at some stage you have to --

25 MEMBER KIRCHNER: I think it is the COL

1 stage.

2 MR. CAMPBELL: Yes. That is correct.  
3 It's at the COL stage when they have to do a full  
4 blown PRA.

5 MEMBER RICCARDELLA: Yes.

6 MR. CAMPBELL: If the frequencies of a  
7 multi-unit failure at a site are low enough that they  
8 don't have to be considered, they aren't considered.  
9 But if they're high enough, for a variety of reasons  
10 that may not be apparent at this stage, when we don't  
11 really have --

12 We have designs. But we have designs  
13 with, that really aren't solid, not necessarily  
14 approved at this point in time. In fact, we have no  
15 approved design at this point.

16 When you get to that, that's where you  
17 apply this detailed look at multi-unit failures that  
18 could exceed the cut off likelihood in terms of CDF.  
19 That's where this is done. It's done at the COL.

20 There are a lot of COL action items within  
21 an ESP that are simply saying, this is not an item we  
22 can make a decision on at this time, because we just  
23 simply don't have a design. We have a range of  
24 designs we're considering. And that's the way we've  
25 been doing ESPs now for five ESP permits so far. And

1 we're in, we are consistent with that approach.

2 There are a lot of things that don't have  
3 all the information for at this time. But we have  
4 enough information to establish what the methodology  
5 is, and enough information to establish that one could  
6 come in with a design that might meet the site  
7 boundary, or two mile, or some other EPZ distance.

8 It might not be two miles. It might be  
9 three, or it might be one. But if it goes beyond the  
10 site boundary -- So, all of those things are covered  
11 in the COL.

12 And they're, I don't know the exact number  
13 from the SEs. But there are a large number of COL  
14 action items that we'll notify the COL applicant, you  
15 have to deal with this.

16 MEMBER RAY: You know, having sought an  
17 ESP I do understand and agree. What I was trying to  
18 understand is why we were going beyond what I think  
19 you said, to talk about multi module plants, implying,  
20 I thought, that we were only going to assume one of  
21 the modules have an event at a time.

22 And it was the additional small modular  
23 concept that I was questioning, not that the ESP goes  
24 beyond where it has traditionally gone in the past.

25 MEMBER BLEY: I kind of like everything

1     you said.     What we're so, the one thing I would  
2     mention twice, you've said at the COL stage there's a  
3     full blown PRA.     So far no COL applicant has performed  
4     a full blown PRA.     They've deferred a lot of the  
5     detailed issues until just before fuel load.

6                   MEMBER RICCARDELLA:     Getting later and  
7     later.     What do you do if you get to that stage and  
8     you say, woops.     The zone has to be three miles, not  
9     two miles.     That would probably be problematic.

10                  MEMBER KIRCHNER:     Harold, thank you.     The  
11     clarity is needed.     Let us address that when we  
12     deliberate over our letter on this matter and move on  
13     in the interest of time, Allen, if you could.

14                  MR. FETTER:     Yes.     And in the interest of  
15     time I'm going to go over the next few slides rather  
16     quickly so that we can get to the staff's review of  
17     13.3 and the exemption request.     With that being said,  
18     if ACRS has any questions, please don't hesitate to  
19     interrupt.

20                  Okay.     For geography and demography, the  
21     staff review is based on information provided by the  
22     Applicant and the staff's independent confirmatory  
23     evaluation.     Staff found that information to be  
24     acceptable.     It meets the requirements of 10 C.F.R.  
25     100.20.

1                   For Section 2.2, nearby industrial  
2                   transportation and military facilities, based on the  
3                   information provided -- oops, we're still on that --  
4                   by the Applicant and staff's independent confirmatory  
5                   evaluation, the staff found the information to be  
6                   acceptable as information meets the guidance provided  
7                   in NUREG 0800, Section 2.2.1 to 2.2.2.

8                   Meteorology, discuss the site-specific  
9                   information related to regional climatology, local  
10                  meteorology, onsite meteorological monitoring, and  
11                  long and short term atmospheric dispersion estimates.

12                  As noted on the slide, site  
13                  characteristics related to extreme weather were found  
14                  to be acceptable for the Clinch River site. The  
15                  onsite meteorological monitoring system was found to  
16                  provide adequate data to represent the meteorological  
17                  dispersing conditions at the site.

18                  Site characteristics related to short term  
19                  and long term atmospheric dispersion estimates were  
20                  found to be acceptable. Based on information provided  
21                  by the Applicant, the staff found all regulatory  
22                  requirements to have been satisfied with no open  
23                  items.

24                  Okay, Slide 10, short term or accident  
25                  atmospheric dispersion factors are X/Q. Estimates

1 were developed for the exclusion area boundary and  
2 outer boundary of the Low Population Zone.

3 The exclusion area is defined in 10 C.F.R.  
4 50.2 as that area surrounding the reactor in which the  
5 reactor licensee has the authority to determine all  
6 activities, including exclusion or removal of  
7 personnel and property from the area.

8 10 C.F.R. 50.2 also defines the Low  
9 Population Zone as the area immediately surrounding  
10 the exclusion area which contains residents, the total  
11 number and density of which are such that there is  
12 reasonable probability that the appropriate protective  
13 measures can be taken on their behalf in the event of  
14 a serious accident.

15 TVA used the NRC endorsed PAVAN  
16 Atmospheric Dispersion Model to estimate X/Q values  
17 for the zero to two-hour timeframe at the exclusion  
18 area boundary as well as the longer timeframes noted  
19 on the slide for the outer boundary of the Low  
20 Population Zone.

21 These X/Q values are intended to represent  
22 dispersion conditions that exceed no more than five  
23 percent of the time for the Clinch River site. The  
24 X/Q values, in conjunction with the estimated source  
25 term discussed in Chapter 15, are used to demonstrate

1 compliance with 10 C.F.R. 5217 dose guidelines for  
2 design basis accidents.

3 Those dose guidelines include 25 rem TEDE  
4 for any individual located at the exclusion area  
5 boundary for two hours and 25 rem TEDE for any  
6 individual located at the outer boundary of the Low  
7 Population Zone for 30 days. I will now turn it over  
8 to Mallecia.

9 MS. SUTTON: For Slide 11, for Section  
10 2.4, hydrologic engineering, TVA proposed adequate  
11 site characteristics and boundary design parameters  
12 for the inclusion in the early site permit. Design  
13 basis flood and maximum groundwater levels, and the  
14 accidental release, those estimates meet the  
15 regulatory requirements.

16 Staff concludes that the Applicant meets  
17 the early site permit regulatory requirements  
18 associated with the hydrologic engineering.

19 Slide 12, please. For geological site  
20 characterization, Section 2.5.1, vibratory ground  
21 motion, Section 2.5.2, surface deformation, Section  
22 2.5.3, stability of subsurface materials and  
23 foundations, Section 2.5.4, stability of slopes,  
24 Section 2.5, based on evaluation of the information  
25 provided by the Applicant, and supplemented by

1 knowledge gained through staff direct examination  
2 during site audits, the staff found Applicant  
3 adequately characterized the site in these topic areas  
4 in accordance with the applicable guidance.

5 Slide 13, please. Section 3.5.1.6,  
6 aircraft hazards, staff agrees with Applicant's  
7 conclusion that an aircraft crash probability is about  
8 an order of magnitude of ten to the negative seven per  
9 year or less and meets the provided NRC guidelines.  
10 Staff finds that the Applicant's approach is  
11 reasonable, and the probability value is acceptable.

12 Slide 14, please. So Chapter 11,  
13 radioactive waste management, Section 11.2.3 and  
14 11.3.3, based on the staff's review of TVA's early  
15 site permit application, and subject to the staff's  
16 identifying several action items, the staff concludes  
17 that the normal plant permit, effluent source terms,  
18 and offsite dose meet the applicable regulatory  
19 requirements and are without undue risk to the public  
20 health and safety.

21 Slide 15, please. Chapter 15, accident  
22 analysis, staff evaluated the application and  
23 concluded that the Applicant's analysis meets the dose  
24 criteria specified in the PPE, includes a bounding  
25 accident release for the determination.



1 Slide 16, please. Section 17.5, quality  
2 assurance program description, staff evaluated the  
3 application and concluded that the Applicant's quality  
4 assurance program description for the Clinch River  
5 nuclear site ESP application meets the requirements of  
6 10 C.F.R. Part 50, Appendix B, and 10 C.F.R.  
7 50.17(a) (1).

8 Slide 17, please. Now that we have  
9 discussed all of the topic areas and their findings,  
10 the staff will now describe the evaluation emergency  
11 planning and related exemption requests. Recognize  
12 that TVA early site permit application was submitted  
13 in May --- in 2016.

14 This was before the staff started work on  
15 the small module reactor and other new technologies'  
16 rulemaking. According, the application and the review  
17 of the application by the staff is based on the  
18 current regulations and guidance.

19 TVA's early site permit application  
20 includes a methodology that, if approved in the early  
21 site permit, would be used in future combined license  
22 application and represents the specific merger reactor  
23 design and early site permit to determine the  
24 appropriate site-specific plume exposure pathway  
25 emergency planning zone size for the Clinch River

1 nuclear site.

2 The submitted early site permit  
3 application requests exemption from certain emergency  
4 planning zone requirements if certain conditions are  
5 met. If these sorts of exemptions are approved as  
6 part of the early site permit, they will be  
7 accompanied by permit conditions specifying the  
8 circumstances under which these plans can be used in  
9 the combined license application.

10 If the exemptions are approved in the ESP,  
11 this Applicant can adopt these exemptions if it shows  
12 that its COLA PEP EPZ source term releases to the  
13 atmosphere are bounded by the non-design specific  
14 plant parameter source term information developed for  
15 the early site permit.

16 A future CO application featuring an SMR  
17 design, that fits within the plant parameter envelope  
18 established in the ESP, could apply the plume  
19 methodology to the design selected to determine the  
20 appropriate PEP EPZ size for the site and also  
21 demonstrate whether the conditions for either of the  
22 two sets of exemptions have been met.

23 The safety evaluation report for Chapter  
24 13, Section 13.3 for the TVA Clinch River nuclear site  
25 --- early site plan application addresses the plans,

1 design features, facilities, functions, and equipment  
2 necessary for the meteorological emergency planning  
3 that must be considered in an early site permit  
4 application that includes proposed major features of  
5 the emergency plans.

6 Now I'll turn the presentation over to  
7 Bruce and Michelle.

8 MR. MUSICO: Thank you. My name is Bruce  
9 Musico. I'm a senior emergency preparedness  
10 specialist. I and Michelle Hart reviewed the  
11 emergency planning information that TVA submitted in  
12 its ESP application.

13 The next two slides are a somewhat reduced  
14 version of the slides we presented before the  
15 subcommittee on August 22nd. And I refer you to the  
16 transcript from that day, because it provides more  
17 detailed explanation as well as answers to many of  
18 your questions from the subcommittee.

19 For emergency planning, the ESP  
20 application requested review of three key areas, and  
21 you're going to see an overlap with TVA's presentation  
22 as well, three key areas which consist of, first, the  
23 plume exposure pathway, the emergency planning zone  
24 sizing methodology, which Michelle Hart will discuss  
25 in detail shortly.

1            Secondly, the two major features, onsite  
2 emergency plans which were contained in Part 5 of the  
3 application, these include Part 5(a) which reflects a  
4 site boundary plume exposure pathway emergency  
5 planning zone, and Part 5(b) which reflects the two-  
6 mile EPZ, and it also includes the evacuation time  
7 estimate, or ETE.

8            The third review area was the 25 exemption  
9 requests that they provided. These include the two  
10 exemption requests which are applicable to both the  
11 site boundary and the two-mile plume exposure pathway  
12 emergency planning zone. And the remaining 23  
13 exemption requests address portions of 10 C.F.R. 5047  
14 (b), and Appendix E for offsite emergency planning  
15 related to the site boundary EPZ only.

16           Next slide, please. With regard to the 25  
17 --- make sure I have the right slide --- with regard  
18 to the 25 exemption requests, the two exemption  
19 requests from 10 C.F.R. 50.33(g) and 50.47<sup>©</sup> would  
20 remove the ten-mile plume exposure pathway EPZ  
21 requirement. That same requirement is in both of  
22 those regulations.

23           The remaining 23 exemption requests, which  
24 are from 10 C.F.R. 50.47 and Appendix E to Part 50,  
25 would remove emergency planning requirements

1 associated with offsite emergency planning. These  
2 requirements are associated with state and local  
3 emergency plans, public alert and notification,  
4 evacuation time estimate, and offsite exercises.

5 Next slide, please. This slide provides  
6 the basis for the staff's acceptance of the requested  
7 exemptions. The ESP application provides a basis for  
8 the establishment in the COLA of either a site  
9 boundary or two-mile plume exposure pathway emergency  
10 planning zone, and this is important, which maintains  
11 the same level of protection, that is dose savings in  
12 the event of a radiological emergency in the environs  
13 of the Clinch River site, as that which exists in the  
14 basis for a ten-mile plume exposure pathway EPZ,  
15 similar to what we used for the large light water  
16 reactors.

17 Next slide. This slide addresses the  
18 combined license application, or COLA. Upon issuance  
19 of the ESP the Applicant, TVA, acquires approval that  
20 is finality with conditions of the three key review  
21 areas that I just spoke of, first of all, the plume  
22 exposure pathway EPZ sizing methodology, the two major  
23 features emergency plan, the site boundary or the two-  
24 mile PEP EPZ, and the 25 requested exemption requests.

25 A COLA that incorporates, by reference,

1 the early site permit must identify the chosen SMR  
2 technology for the Clinch River Nuclear site and  
3 demonstrate that the EPZ sizing methodology supports  
4 either the site boundary or the two-mile plume  
5 exposure pathway emergency planning zone. The COLA  
6 must also provide a complete and integrated emergency  
7 plan.

8 For the two-mile plume exposure pathway  
9 EPZ, the COLA must provide both onsite and offsite  
10 emergency plans. For the site boundary plume exposure  
11 pathway EPZ, the COLA must provide an onsite emergency  
12 plan. And the COLA must also address all 16 of the  
13 COL action items and the four permit conditions.  
14 Those are 16 action items and four permit conditions  
15 associated with emergency planning.

16 Next slide, please. This slide addresses  
17 the EPZ size determination in the COLA. The  
18 determination of the EPZ size by the COL Applicant is  
19 required by two parts, two things, the COL action  
20 item, 13.3-1, and this particular action item reflects  
21 the language that was in the application Part 2 in  
22 Section 1333-14.

23 The COLA must identify the chosen SMR  
24 technology and the major features emergency plan,  
25 that'll be in the two-miles of the site boundary. It

1 must provide detailed information that shows the  
2 ability of the small modular reactor to meet the  
3 chosen EPZ. And that would be utilized in the  
4 methodology. And the selected SMR technology must be  
5 the EPA early phase protective action guides.

6 Michelle Hart will address Permit  
7 Condition 1.

8 MS. HART: Hello again, my name is  
9 Michelle Hart. I'm a senior reactor engineer in the  
10 Office of New Reactors, the Radiation Protection and  
11 Accident Consequences Branch.

12 So for Permit Condition 1, this is related  
13 to, with the exemptions approved for the ESP, the COL  
14 Applicant can adopt the exemptions if it shows that  
15 the plume exposure pathway EPZ source term releases to  
16 the atmosphere are bounded by those in the non-design  
17 specific plant parameter source term information  
18 developed for the ESP. That's that table that's  
19 attached to Permit Condition 1, that's 13.3-1.

20 And as stated on the slide, the permit  
21 condition is that the Applicant would provide detailed  
22 information to demonstrate that the accident release  
23 source term information for the plume exposure pathway  
24 EPZ size determination analysis, using the selected  
25 SMR design, is bounded by the non-design specific

1 plant parameter source term information used in the  
2 analysis supporting the exemption requests.

3 And that analysis would be done in  
4 accordance with COL Action Item 13.3-1 using the  
5 methodology in the SSAR, Chapter 13.3.

6 To go to your question, Dr. Kirchner,  
7 about what would happen if one of --- let's just say  
8 one of the isotopes is not less than the rest of the  
9 --- or the isotope in that table. My understanding  
10 is, because of the ministerial nature of the permit  
11 condition, if they cannot show that they are within  
12 that condition specifically, they may ask for an  
13 exemption, but they do not --- or a variance, but they  
14 do not automatically get to use the exemption requests  
15 that were approved in the ESP based on the condition  
16 with that design envelope, that source term  
17 information.

18 However, they may still be able to prove,  
19 through the use of the methodology, that although the  
20 source term is slightly different, or it may slightly  
21 exceed, that they still can prove that they have a  
22 site boundary or a two-mile emergency planning zone  
23 size according to the methodology.

24 MEMBER KIRCHNER: You've hit my question.  
25 Because it struck me, reviewing all the material, that



1       it's almost --- you have to have agreement on the  
2       source term, of course. But the real thing you're  
3       regulating against is not the composition of the  
4       source term, it's the dose to the public.

5               MS. HART: That's correct. And there's  
6       some ---

7               MEMBER KIRCHNER: I had just worried that  
8       you might have an over-defined boundary value problem  
9       where ---

10              MS. HART: Right. In the subcommittee  
11       meeting, we did have a more full discussion of how  
12       they developed that source term. And I can discuss  
13       that again a little bit later if you would like. But  
14       they did add in a lot of uncertainty or a lot of  
15       margin to try to address that concern.

16              Next slide, please. So as TVA had told  
17       you earlier today that they ---

18              MEMBER REMPE: Michelle, can you ---

19              MS. HART: I'm sorry.

20              MEMBER REMPE: -- go back. I think I  
21       brought this up at the subcommittee meeting, but I  
22       can't remember how it was addressed. What if one of  
23       these designs happens to have a burp immediately after  
24       an event? And then something comes out starting on  
25       three and a half days, and it keeps going along. So

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 what will you do if you see that kind of analysis? Or  
2 do they just get to stop after four days, and they  
3 don't have to keep it going?

4 MS. HART: Right.

5 MEMBER REMPE: And I've forgotten what  
6 your response was.

7 MS. HART: Right. Well, how I answered  
8 that at the subcommittee phase, and this is what I  
9 still believe, is that that's part of the  
10 implementation. And when we review their actual  
11 implementation, we will be looking at all the  
12 information that they have. And so if there is an  
13 issue there, it can be addressed.

14 What the permit condition non-design  
15 specific source term information is, is a 96-hour  
16 integrated. And so their release is longer than that,  
17 you know, we'll have to look at that when it comes in  
18 if there's --

19 MEMBER REMPE: And did I ---

20 MS. HART: -- some problem there.

21 MEMBER REMPE: -- mention that somewhere  
22 in whatever you --- again, I wasn't on the  
23 subcommittee itself, I just happened to be at that one  
24 meeting. And is that in your documentation somewhere,  
25 that you aren't allowed to just stop it at 96 hours?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 You need to look for some sort of reduction or  
2 truncation of releases.

3 MS. HART: It is not specifically  
4 addressed. It's just the permit condition is written  
5 in such a manner, and we will have to say if your 96-  
6 hour integrated release does not meet that, that it  
7 would not meet the requirement to do the exemption.

8 MEMBER REMPE: Well, I can trust that  
9 you'll --- this will be adhered to even if you go on  
10 and get promoted to be a manager at a high level, that  
11 the staff will know to do that without any ---

12 MS. HART: That should be true, correct.

13 MEMBER REMPE: Cool, thank you.

14 MS. HART: Okay, Slide 22. So as TVA had  
15 mentioned earlier, they did have some technical  
16 criteria for developing their EPZ size methodology,  
17 that the plume exposure pathway EPZ should encompass  
18 those areas in which projected dose from design-basis  
19 accidents could exceed the EPA early phase PAGs.

20 The plume exposure pathway should also  
21 encompass those areas in which consequences of less  
22 severe core melt accidents could exceed the EPA early  
23 phase PAG, and that the plume exposure pathway EPZ  
24 should be of sufficient size to provide for  
25 substantial reduction in early health effects in the

1 event of a more severe core melt accident.

2 Next slide, please. TVA did go through  
3 this earlier. I guess I probably don't need to repeat  
4 it in detail. But certainly the features of the EPZ  
5 size methodology are that they will select their  
6 accident scenarios, and that would include design-  
7 basis accidents, just taking that directly from the  
8 siting analysis that they do in Chapter 15.

9 And then you look at the severe accidents  
10 using the COLA site and design specific probabilistic  
11 risk assessment, should include all modes, internal  
12 and external events, applicable fuel handling, and  
13 spent fuel pool accidents, and also consider multi-  
14 module accident considerations.

15 And then you would categorize that in the  
16 two different categories, the more probable less  
17 severe core melt accidents with intact containment and  
18 then less probable, more severe, core melt accidents  
19 with either containment bypass or containment failure.

20 Once you categorize those accidents, you  
21 would determine the source term releases to atmosphere  
22 and its --- there's not a specific discussion as to  
23 whether you can do bounding or should do all of them.  
24 They can choose at that time. It's an implementation  
25 thing we would also evaluate.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1           So the source terms, there may be several  
2       scenarios in a different category, and they may  
3       determine to look at them all or they may categorize  
4       them and get us the bounding. When you calculate the  
5       dose consequences at distance from the plant, and then  
6       you compare those doses to the dose base criteria.

7           Next slide, please. So to go in a little  
8       bit more detail about the TVA dose-based plume  
9       exposure pathway EPZ size criteria, the quantity that  
10      we're looking at is the dose to an individual from  
11      exposure to the airborne plume during its passage and  
12      to groundshine using average atmospheric dispersion  
13      characteristics for the site.

14           And what we mean by average atmospheric  
15      dispersion characteristics for the site is not  
16      referring to the same analysis that was done in SSAR  
17      Chapter 2 and approved for the ESPS site  
18      characteristics. Instead, it's referring to  
19      evaluating the accident consequences using site-  
20      specific meteorological data to determine doses that  
21      are based on 50th percentile atmospheric dispersion  
22      factors.

23           And the staff expects that the Applicant  
24      may use the calculation tools that are used for a  
25      severe accident consequence analysis. For example, in

1 the environmental report there's no specific tool  
2 identified in TVA's methodology.

3 But for example, the tool that is mostly  
4 used is the MACCS code, and so it can take a year's  
5 worth of hourly meteorological data. And you can run  
6 --- it can account for uncertainty in weather,  
7 including over the duration of the accident release.

8 It models atmospheric transport and  
9 dispersion by sampling one year of hourly weather data  
10 for the site, and it can model shifts in wind  
11 direction. It uses a Gaussian plume segment model,  
12 and so each plume segment, the start time and duration  
13 is chosen by the user. So it can be adjusted to the  
14 shape of the accident release, if that makes some  
15 sense.

16 We'll head in the wind direction and  
17 speed, as sampled from the site-specific data, and the  
18 start time of that sampling is random over the year.  
19 So therefore, two plume segments released at adjacent  
20 times may be traveling in different directions at  
21 different speeds the way that MACCS does the modeling.

22 In practice, when we're saying that they  
23 would look at the 50th percentile, or the mean doses,  
24 excuse me, in practice the analysis would run several  
25 weather trials with the same release source term for

1 each weather trial but differing atmospheric  
2 dispersion and transport based on the sampling of the  
3 year's worth of data. And the resulting mean dose of  
4 our weather trials would be taken as the output.

5 Yes?

6 MEMBER DIMITRIJEVIC: I don't have a  
7 question, I just have a little correction, not for  
8 just slide, but there was a slide there, the airplane  
9 crashes where you have probability with the reactor.  
10 Every time when you have a pattern, it's not  
11 probability. Probability doesn't have a unit that's  
12 frequent. And you should change that throughout,  
13 because of the issue.

14 MS. HART: Thank you.

15 MEMBER REMPE: And if you agree with that  
16 statement, and hopefully, you'll help the TVA folks  
17 come to that conclusion too --

18 MS. HART: Yeah. And I think I understand  
19 what you're saying. And it's not something that I  
20 brought up with them before. So hopefully, we'll see  
21 what happens.

22 Okay, so for the rest of this slide, it  
23 reiterates the actual criteria that they have  
24 proposed, is that for design-basis accidents and more  
25 probable less severe accidents, those are the ones

1 with intact containment, that the dose criterion is  
2 one rem, total effect of dose equivalent from a 96-  
3 hour exposure. And that is the lower end of the dose  
4 range of the EPA PAG for early phase protective action  
5 such as evacuation and sheltering.

6 And for the less probable, more severe  
7 accidents, and you see that I have repeated it, but  
8 they would calculate the distance at which the  
9 conditional probability to exceed 200 rem whole body  
10 from a 24-hour exposure exceeds ten to the minus  
11 three. And they did say per reactor year. The 200  
12 rem is, of course, the acute dose at which radiation  
13 induced early health effects may begin to be noted.  
14 And so I've heard ---

15 MEMBER KIRCHNER: Once more, we belabored  
16 this earlier.

17 MS. HART: Yeah.

18 MEMBER KIRCHNER: But just so we're on the  
19 same page, this is an integral effect, this ten to the  
20 minus three?

21 MS. HART: I have to admit that this did  
22 not get practiced in the example calculation, because  
23 there was nothing that screened into that category.  
24 In general, what we are seeing from some of these  
25 small modular reactors, there's not very many



1 accidents that may be in that category, if any at all.

2 So I don't know that you would have more  
3 than one source term affecting that evaluation. There  
4 may be, depending on the design. I think it's mostly  
5 going to be an effect of the weather.

6 And one of the things that we can do with  
7 this is up to the implementation phase, it's not  
8 discussed in their methodology or discussed in our  
9 evaluation. But in implementation, you know, MACCS  
10 runs one year at a time. But you can do more than one  
11 year by running another set of MACCS analyses.

12 And so if there's some concern or  
13 question, if you're not able to tell from the pre-  
14 processing of the weather, you know, to determine if  
15 you've got a bad year, or a worse year or, you know,  
16 from that perspective, if there's some need to have to  
17 do more than one year's worth of MACCS runs, then that  
18 is something that can be done. It would be evaluated  
19 based on the information that we have at the time of  
20 the implementation at the COL though.

21 MEMBER BLEY: Let me jump in here, Walt.  
22 I've been trying to catch up a little. But this deal  
23 about the ten to minus three, if you go back to 0396,  
24 and you go back to the figure, and Walt asked me about  
25 this last night, Figure 1-11, there's a curve for 200

1 rem. And what that curve says is, right at the site,  
2 only eight percent of core melts can get you 200 rem,  
3 even right at the site.

4 And by the time you get out to 20 miles,  
5 and these are results from WASH-1400 that got adapted  
6 for this report, when you get out to 20 miles, the  
7 curve's dropping off so fast that you hit only one in  
8 1,000 core melts can have an effect on you. 0396  
9 talked about, for severe core melt accidents, you  
10 ought to have a substantial reduction in health  
11 effects.

12 MS. HART: Right.

13 MEMBER BLEY: And nowhere does it say that  
14 substantial drop is ten to the minus three. But  
15 that's kind of what everybody is doing. And it's  
16 based on that one curve and then applying it to new  
17 reactors as well. I thought that worth throwing in.

18 MS. HART: Are there any further  
19 questions, concerns about that?

20 (No audible response.)

21 MS. HART: Okay. So next slide please.  
22 So the staff's review of TVA's proposed plume exposure  
23 pathway ETZ size methodology, we did compare the  
24 methodology and the dose criteria to the study used as  
25 the technical basis for the current regulatory

1 requirement for a ten mile plume exposure pathway EPZ  
2 requirement, that is as we've been discussing NUREG  
3 0396.

4 And the staff has determined that the  
5 features of TVA's methodology are consistent with the  
6 study that was done in NUREG 0396 in that it  
7 considered a range of accidents. It performs an  
8 accident consequence analysis and determines an area  
9 outside of which early protective actions are not  
10 likely to be necessary to protect the public from  
11 radiological releases.

12 And so therefore, the staff concludes that  
13 the Applicant's proposed methodology is reasonable and  
14 consistent with the analyses that form the technical  
15 basis for the current regulatory requirements of a  
16 plume exposure pathway EPZ of about ten miles in  
17 radius.

18 Next slide, please.

19 MEMBER BLEY: Michelle?

20 MS. HART: Yes?

21 MEMBER BLEY: For several reasons, I've  
22 been going through 0396 in great detail recently.  
23 This is one of them. Some 50 years ago, all the  
24 quantitative judgements in it were based on Wash 1400  
25 which was, at that point, three or four years old.

1                   Has anybody on the staff revisited 0396  
2                   and thought about it in light of what's been learned  
3                   in the last 50 years?

4                   MS. HART: I can let somebody from the  
5                   Office of Nuclear Incident Response respond to that if  
6                   they would like.

7                   MEMBER BLEY: They must have run out the  
8                   door.

9                   MS. HART: Yeah. There're some folks  
10                  here. I mean, certainly, we are going through the  
11                  rulemaking for the emergency preparedness and for SMRs  
12                  and other new technologies.

13                  MEMBER BLEY: Still point at 0396. The  
14                  logic there is great.

15                  MS. HART: The logic is what we're using.  
16                  Now, if you're asking have we re-evaluated it in the  
17                  context of the currently operating reactors, I can't  
18                  necessarily speak to that. And I don't know that  
19                  that's what you're asking.

20                  MEMBER BLEY: I think we're using more  
21                  than the logic. I think we're using some of the  
22                  quantitative information as well.

23                  MS. HART: Well, I think certainly  
24                  continuing to use the EPA PAGs for the early phase as  
25                  the basis for how you determine EPZ size, we're still

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 sticking with that idea.

2 MEMBER BLEY: Yeah, but we're picking the  
3 chance of what the dose is at some distance from very  
4 old information.

5 MS. HART: In TVA's methodology, yes, they  
6 did.

7 MEMBER BLEY: I didn't see anything in the  
8 rulemaking. I mean, there would be a change in that.

9 MS. HART: The rulemaking, as I recall,  
10 does not have that specific evaluation in the rule  
11 language itself.

12 MEMBER BLEY: That's true.

13 MS. HART: About the very severe  
14 accidents.

15 MR. SCOTT: I figured it out, thank you,  
16 with help. This is Mike Scott of the NCR staff.  
17 Talking to my colleagues here, we're not aware --- the  
18 question is is there a current effort ongoing to  
19 update 0396. Our answer is we're not aware of one.  
20 Was that the --

21 MEMBER BLEY: Thanks. I'm not either.  
22 And it just struck me, you know, it might be worth  
23 somebody doing that.

24 MR. SCOTT: It's an interesting question  
25 that we'll consider. Thank you.

1           MEMBER BLEY: Not that I'd hang it on this  
2 particular application. But I think it's about time  
3 we thought about it.

4           MS. HART: Okay. So then to Slide -- what  
5 is this, 26 -- so for the exemption requests to  
6 determine if --- to put a boundary around what we  
7 considered when we were looking at it in the ESP,  
8 since there is not a specific design included in this,  
9 TVA developed a non-design specific accident release  
10 source term that would meet the plume exposure pathway  
11 EPZ size criteria which are intended to be used as  
12 plant parameters for the purposes of the exemption  
13 request.

14           This source term is in Table 13.3-1. It  
15 is an isotopic total release activity over 96 hours  
16 which results in a Total Effective Dose Equivalent of  
17 about 0.9 rem at the site boundary. It's the same  
18 idea as the plant parameter envelope in general that's  
19 done for the ESP, specifically for the design basis  
20 accident source term. And it's intended to envelope  
21 an unknown design. And it's referenced in Permit  
22 Condition 1 for the adoption of the EP exemptions.

23           This non-design specific source term used  
24 information from two different designs from three  
25 accidents, two DBAs, and one severe accident. The two

1 SMRs were at the lower end of the range of the PPE and  
2 at the upper end of the range of the PPE as far as  
3 reactor thermal power.

4 And when they did this, they took the  
5 maximum activity that could be released in any time  
6 period from any of those three accidents from the two  
7 reactors. They added a 25 percent margin, and when  
8 they tried to back calculate from the 1 rem criterion,  
9 there was also some additional adjustment to some of  
10 the isotopic values. And then they calculated the  
11 final source term to result in some margin to the dose  
12 criterion, so about 0.9 rem at the site boundary.

13 And so it's the plant condition, plant  
14 parameters for the condition to use it for either the  
15 site boundary or the two-mile emergency planning zone.  
16 There's not a separate table for those two different  
17 distances.

18 And that concludes my portion of the  
19 presentation. I will turn it back over to Mallecia.

20 MS. SUTTON: The staff presented its  
21 review on findings on emergency planning for TVA  
22 Clinch River early site permit application. The staff  
23 concludes that the PEP EPZ size methodology is  
24 acceptable for determining the appropriate size of the  
25 PEP EPZ for the Clinch River nuclear site. Because

1 it's consistent with analysis that formed the clinical  
2 basis for the current ten-mile PEP EPZ.

3 The two major features in emergency plans  
4 are acceptable, because they meet the applicable  
5 standards of 10 C.F.R. 5047 and requirements of  
6 Appendix E to 10 C.F.R. Part 50. If the exemptions  
7 are approved for the ESP, the Applicant can adopt  
8 exemptions if it shows that its COLA PEP EPZ source  
9 term release to the atmosphere is bounded by the non-  
10 design specific plant parameters source term  
11 information developed for the ESP.

12 The exemption requests are acceptable,  
13 because they are authorized by law, will not present  
14 an undue risk to the public health and safety, are  
15 consistent with the common defense and security, and  
16 special circumstances are present.

17 In previous subcommittee meetings, we have  
18 presented the staff's review and findings relative to  
19 this application for an early site permit at the  
20 Clinch River nuclear site. Today we presented an  
21 overview including more details in the emergency  
22 planning and related exemption request. The safety  
23 evaluation is complete with no open items.

24 The next step in the process is the  
25 mandatory hearing in front of the Commission in 2019.



1 The staff looks forward to an ACRS letter on the staff  
2 review. And this completes the staff presentation.

3 MEMBER KIRCHNER: Thank you, Mallecia.

4 MEMBER BLEY: I want to make just a ---

5 MEMBER KIRCHNER: Yes?

6 MEMBER BLEY: -- very minor comment which  
7 could --

8 MEMBER KIRCHNER: Go ahead, Dennis.

9 MEMBER BLEY: -- be editorial. In the  
10 licensee's report, Chapter 13, they go through the  
11 steps and the methodology. And they do that well, and  
12 they say find these scenarios, then group the  
13 scenarios by the kind of things that failed and what  
14 the consequences are. The next step should say for  
15 the groups, scenario groups, find the frequency. And  
16 it doesn't. It just says for the scenario. Just a  
17 comment for you.

18 MEMBER KIRCHNER: Other members, any  
19 questions of the staff while they're here in front of  
20 us? Then if not, we'll turn to the public.

21 (No audible response.)

22 MEMBER KIRCHNER: Okay, thank you again.  
23 Are there any members of the public in the room who  
24 wish to make a statement or a concern? Please step  
25 forward, identify yourself at the mic, and make your

1 comment.

2 Seeing no one coming forward, is there  
3 anyone, member of the public, on our bridge line who  
4 wishes to make a comment? If so, state your name,  
5 please, and make your comment.

6 (No audible response.)

7 MEMBER KIRCHNER: Hearing none, at this  
8 point, Mr. Chairman, I'll turn it over to you.

9 CHAIRMAN CORRADINI: Thank you. So I'll  
10 thank members of TVA and the staff. And I think we're  
11 done with this subject. So we're going to take a  
12 short break, so we change out and talk about Seabrook  
13 next. So we'll be coming back at 3:15.

14 MEMBER BLEY: We're ahead of time. We  
15 can't start that until the scheduled time.

16 (Off the record comments.)

17 MEMBER BLEY: 2:30 or 2:45. I don't have  
18 my glasses.

19 (Off the record comments.)

20 MEMBER BLEY: That's 45 minutes, not 50.

21 (Off the record comments.)

22 (Laughter.)

23 CHAIRMAN CORRADINI: So once again, we'll  
24 see you in 15 minutes. Thank you all.

25 (Whereupon, the above-entitled matter went

1 off the record at 2:59 p.m. and resumed at 3:13 p.m.)

2 CHAIRMAN CORRADINI: Okay, why don't we  
3 come back into session. Our next topic is going to be  
4 Seabrook, Unit 1, license renewal application. And  
5 I'll turn it over to Member Skillman.

6 MEMBER SKILLMAN: Yes sir, thank you,  
7 Mike. Ladies and gentlemen, this meeting this  
8 afternoon brings us to a very important time in  
9 Seabrook's life. We have been involved in license  
10 renewal of Seabrook since our meeting in 2012. It has  
11 been over six years. And in intervening time, from an  
12 original application, and then updates to the  
13 application and the safety evaluation, through years  
14 of work on Alkali-Silica Reaction, we come to today.

15 And so through the presentation and letter  
16 writing we will address both the license renewal  
17 application and Alkali-Silica Reaction. And with that  
18 opening comment, I will turn it over Joe Donoghue,  
19 please.

20 MR. DONOGHUE: Okay, good afternoon.  
21 Thank you, Chairman Corradini, and Mr. Skillman, and  
22 members of the ACRS full committee. I'm Joe Donoghue,  
23 I'm the deputy director of the Division of Materials  
24 and License Renewal in NRR.

25 We thank you for the opportunity given us

1 to present the results of the staff's review of the  
2 license for an application for Seabrook Station, Unit  
3 1. This review began many years ago, and as Mr.  
4 Skillman alluded to, one of the main technical issues  
5 that prolonged the review was the Alkali-Silica  
6 Reaction affecting concrete structures and then the  
7 licensee's development of methods. And I'll review  
8 those methods for managing the phenomenon.

9 On October 31st, the License Renewal  
10 Subcommittee of the ACRS heard detailed presentations  
11 from both the Applicant and the staff on ASR and the  
12 basis for closing out that one open item of the  
13 license renewal. On November 15th, the subcommittee  
14 heard from the Applicant and the staff on the closeout  
15 of the remaining open items in the SER.

16 Our presentation will be led by our  
17 project manager, Butch Burton, and other members of  
18 the staff and the management that are here, Dr. Allen  
19 Hiser, our senior technical advisor, Eric Oesterle,  
20 chief of the project's branch in our division, and  
21 there's other managers and other technical staff that  
22 contributed to the review that are present and that  
23 will support answering any questions you have.

24 We also have, I think, maybe on the phone,  
25 Region I staff who will provide inspection support and

1 provided presentations to you during the subcommittee  
2 meetings.

3 Again, we look forward to answering any  
4 questions you have and having a full discussion. And  
5 I'll turn the presentation over at this point to the  
6 NextEra team and their regional vice president from  
7 the northern region, Mr. Eric McCartney.

8 MR. MCCARTNEY: Thank you, Mr. Donoghue.  
9 Good afternoon. My name is Eric McCartney. I'm the  
10 regional vice president for NextEra Energy with  
11 responsibility for the Seabrook Station, Point Beach  
12 Station in Wisconsin, and the Duane Arnold Station in  
13 Iowa.

14 Today we're here to talk about the  
15 Seabrook Station. We appreciate the opportunity to  
16 come and provide our presentation of our license  
17 renewal application and all the work we've done over  
18 the last six years, as Mr. Skillman mentioned. And we  
19 look forward to a good discussion and answering any  
20 questions that the Committee may have about our  
21 program and our process.

22 We are committed to the safe, and  
23 reliable, and sustained operation of our nuclear  
24 fleet. And as we do that --- if you'll turn the  
25 slide, please --- there we go. This is our nuclear

1 excellence model. And this provides the framework for  
2 how our fleet has operated since 2008. It's based on  
3 a set of core values and principles, and those have  
4 not changed since its inception, and they will not  
5 change.

6 And we use this as a road map of how we  
7 operate our fleet going forward. So I won't go  
8 through this as we've discussed this a number of times  
9 already. But this continues to be at the heart of how  
10 we manage our stations and our leadership model to  
11 drive safe, reliable, and sustainable operations of  
12 our fleet.

13 Today I have with me Mr. Mike Collins.  
14 He's our engineering director. Next to him is Mr. Ed  
15 Carley. Ed Carley's our license renewal supervisor.  
16 And next to Ed is Ken Browne. Ken Browne is our  
17 licensing manager. And then seated over here to my  
18 right is Rudy Gil. And Rudy Gil is our engineering  
19 program manager. And they will provide the technical  
20 responses to your questions today.

21 And with that, I'll turn the presentation  
22 over to Mr. Collins.

23 MR. BROWNE: Thank you, Eric. Good  
24 afternoon, Mr. Chairman. I'm Ken Browne, licensing  
25 manager for NextEra Seabrook. I've been at Seabrook

1 for approximately 28 years, beginning in the  
2 Operations Department as a non-licensed operator, then  
3 as a licensed senior reactor operator working and  
4 controlling various positions, including shift manager  
5 and eventually director of operations.

6 I've also held the position of training  
7 manager of accredited programs and most recently as  
8 the licensing regulatory compliance manager and also  
9 the management sponsor for the Alkali-Silica Reaction  
10 project at Seabrook.

11 As we discussed at our ACRS Subcommittee  
12 meeting last month, this station has continued to  
13 engage in accumulating the best practices from the  
14 industry in developing our existing engineering  
15 programs as well as enhancing our aging management  
16 plans to ensure Seabrook is maintained to the highest  
17 safety and material standards.

18 Since we've been operating, NextEra  
19 Seabrook has always made it our highest priority to  
20 operate our facility with nuclear and public safety as  
21 the overriding focus in all that we do. Each of us  
22 that work there and live near the area recognize the  
23 location of our facility places a personal  
24 responsibility and accountability on all of us to  
25 protect the health and safety of the public

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 surrounding Seabrook.

2 We also recognize the valuable resource  
3 that Seabrook represents and continues to provide for  
4 many years as a major proportion of safe, reliable,  
5 and clean energy in the New England area. We look  
6 forward to the Committee's questions. And I'm going  
7 to turn the panel over to Mike Collins, our  
8 engineering director, to guide us through the  
9 presentation, including some background on the  
10 station. Mike?

11 MR. COLLINS: Good afternoon. Again, my  
12 name is Mike Collins, Director of Engineering at  
13 Seabrook Station, 37 years in the industry, 17 years  
14 with Stone and Webster Engineering, with new build and  
15 continuing services, the last 20 years with NextEra  
16 Energy, Seabrook Station, five of which as engineering  
17 director.

18 (No audible response.)

19 MR. COLLINS: So our agenda for this  
20 afternoon, again, our introductions, I'll provide an  
21 overview of site and station description. Ed Carley  
22 will then review our license renewal application and  
23 our Aging Management Programs, review the safety  
24 evaluation report and closure of the previous open  
25 items. There'll be then closing remarks. And in

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 summary, we'll end with NextEra Seabrook has met the  
2 requirements of 10 C.F.R. 54 for issuance of a renewed  
3 license for Seabrook Station, Unit 1.

4 Just so we won't bore the group, I've  
5 changed up the slide from previous. This is a picture  
6 of the station and some of the main structures, our  
7 intake, excuse me, discharge and intake structure, a  
8 circ water and service water pumphouse, certainly our  
9 containment enclosure building where the reactor  
10 building is housed within, our Unit 1 turbine  
11 building, fuel storage building, waste process  
12 building. And this area of the plant is our primary  
13 auxiliary building, our control building which houses  
14 our two emergency diesel generators.

15 As you know, the Atlantic Ocean is the  
16 normal heatsink for cooling at 100 percent power. We  
17 also have a standby cooling tower which is a seismic  
18 Cat 1 mechanical draft cooling tower which provides  
19 additional safe shutdown capability for the station.

20 Next slide, please. Plant status,  
21 recently completed our latest refueling outage,  
22 fueling outage OR-19, which we completed 10/29/18.  
23 Our next refueling outage at the end of Cycle 20 is  
24 spring 2020 in the April timeframe.

25 Our capacity factor for 15 of 19 cycles

1 has been greater than 94 percent with a lifetime  
2 capacity factor of 87 percent. As you can see with  
3 the listing of our cycle capacity factors, we've had  
4 an excellent operating history over the last cycle.  
5 Capacity factor performance is representative of our  
6 solid equipment reliability and our material condition  
7 for the station.

8 Next slide, please. In order to maintain  
9 high capacity factors, Seabrook continues to improve  
10 equipment reliability and material conditions of the  
11 station. Running down just through some items, for  
12 equipment reliability improvements, our main generator  
13 stator rewind, in the process replacing our vital  
14 batteries and our vital inverters, our generator step-  
15 up transformers replaced --- there's three of those  
16 that we fully replaced two outages ago.

17 As part of our Aging Management Program,  
18 our mechanical stress improvement process completed  
19 for all reactor vessel nozzles. Also Aging  
20 Management, we continue with our process of replacing  
21 all our above-ground service water piping with the  
22 high chroma AL6XN material. We've upgraded our incore  
23 detectors and have been aggressive with replacing our  
24 process control circuit cards and our solid state  
25 system circuit cards.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1           Two outages ago, we sent out our rod  
2           control motor and generator sets for refurbishment.  
3           And lastly, for all four reactor coolant pumps, we now  
4           have shutdown reactor coolant pump seals.

5           We are committed, NextEra Energy Seabrook,  
6           to maintain high levels of safety, reliability, and  
7           performance of our plant equipment.

8           DR. SCHULTZ:     Mike, excuse me.     You  
9           mentioned two of the items on the list that you  
10          attributed to the Aging Management Programs. And then  
11          you stopped listing what the remainder were for. You  
12          mentioned reliability and Aging Management halfway  
13          down the list. Is that the full characterization of  
14          why you made these changes?

15          MR. COLLINS:    Yes, it is. With the ones  
16          that I didn't mention, Aging Management, those are  
17          driven by system engineer advocacy, trends of  
18          equipment such as the GSU. We're watching very  
19          closely the offgassing of the old generator step-up  
20          transformers. Those go in for our long term plant  
21          reliability plans. And we put them through the  
22          process, do the engineering, do the maintenance, and  
23          do the replacements either online or during the  
24          outages.

25          DR. SCHULTZ:    So that's how you separate

1       them from what you would term an Aging Management  
2       Program improvement?

3                   MR. COLLINS:   That's correct.

4                   DR. SCHULTZ:   Okay, thank you.

5                   MR. COLLINS:   Thank you.   At this time,  
6       I'll turn the program over to Ed Carley to start our  
7       discussions on our license renewal application.

8                   MR. CARLEY:    Good afternoon.   I'm Ed  
9       Carley.   I am a 35-year veteran of Seabrook Station  
10      and been in various organizations, quality assurance,  
11      licensing, engineering projects.   In 2008 I joined  
12      the team developing the license renewal application as  
13      the time limit aging analysis lead and the  
14      environmental lead.      And shortly after, the  
15      application was submitted in 2010.   I also took on the  
16      role as licensing lead.

17                   For the last four years, I've been the  
18      project manager for the license renewal application  
19      and resolution of ASR and the current licensing basis  
20      for concrete affected structures.

21                   The original license renewal application  
22      was prepared onsite by Seabrook Station personnel.  
23      The team was supplemented by staff and contractors  
24      with various experience in license renewal and those  
25      that were former plant employees that were familiar

1 with the history of the plant. Our corporate fleet  
2 also provided experienced personnel in license renewal  
3 and provided oversight to the project.

4 Our application was prepared in accordance  
5 with the standard review plan that's listed up here,  
6 followed the standard format for an application. We  
7 filed the guidance of NEI 95-10. And we developed our  
8 Aging Managing Programs in accordance with NUREG-1801,  
9 commonly referred to as GALL. Our initial application  
10 was submitted as GALL Rev 1.

11 Since that time of submittal, we have  
12 performed over 65 updates, some of those were  
13 proactive, some were related to REIs, and also  
14 produced eight annual updates to keep the application  
15 current.

16 We've addressed all ISGs that have been  
17 issued since the initial application was submitted.  
18 And we have performed a consistent review to GALL Rev  
19 1 and GALL Rev 2, and provided updates to our program  
20 where we felt necessary to come in compliance with  
21 GALL Rev 2 for those programs.

22 Next slide, please. This is a table of  
23 our relationship in the final SER to the GALL.  
24 Fifteen of our programs we consider new. We consider  
25 29 that were existing. We do have six plant-specific

1 programs to which we have discussed in very much  
2 detail being the ASR and Building Deformation  
3 Programs.

4 Next slide, please. In relation to the  
5 Safety Evaluation Report that was issued by the staff  
6 on September 28th, it documented no open items and no  
7 confirmatory items. There were seven open items in  
8 the previous SER in 2012 as discussed earlier which  
9 are listed here. The first six we did discuss on  
10 November 15th. Of those, the programs for treated  
11 borated water, operating experience, and part of the  
12 Steam Generator Tube Integrity Program were resolved  
13 by adoption and incorporation of the ISG guidance that  
14 was applicable to those programs.

15 The other portion of the steam generator  
16 tube integrity and the pressure temperature limit open  
17 item were addressed by licensing actions in Part 50  
18 for license amendments that changed our operating  
19 license to resolve the open item. Pressure-  
20 temperature limits have been approved out to 55  
21 effective full power years which will take us through  
22 the period of extended operation.

23 Of the remaining open items that we  
24 haven't discussed, Bolting Integrity Program was  
25 related to a seal cap enclosure that was placed on a

1 safety injector valve that was leaking during one of  
2 our operating cycles. We have, following cycle  
3 outage, we removed the seal cap enclosure, replaced  
4 the valve to eliminate the leakage of that valve.

5 In relationship to the IWE program, this  
6 was in relationship to the water that had accumulated  
7 in our annulus area. And there was a concern that we  
8 may have had degradation against our liner. To  
9 resolve that issue, we have established a weekly PM  
10 that verifies that area is in a dewatered state.

11 We have performed UT measurements around  
12 the liner at the area of the moisture barrier,  
13 confirmed there is no degradation of the liner in  
14 those areas. And we also have a commitment to perform  
15 that UT every five years, excuse me, every five  
16 cycles.

17 And the last item, which is the Structures  
18 Monitoring Program, we discussed quite extensively on  
19 October 30th -- can I have the next slide there -- and  
20 this is related to our Structures Monitoring Program.  
21 Structures Monitoring Program was developed in  
22 accordance with the GALL. However, because of ASR and  
23 building deformation, it is now augmented by  
24 supplemental plant-specific Aging Management Programs,  
25 one for ASR and one for building deformation.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1           As we discussed use of this flow chart  
2           earlier, the structural capacity that came out of the  
3           large scale test program at the University of Texas,  
4           dose limits have been incorporated, that keep us bound  
5           by that testing program, have been incorporated in the  
6           Structures Monitoring Program.

7           And also, the structural demand portion  
8           where we have performed -- in our performing analysis  
9           of our seismic category Cat 1 structures, those  
10          parameters to maintain us within the bounds of those  
11          evaluations area also incorporated into the Structures  
12          Monitoring Program. Frequencies, limits, and trending  
13          are performed in accordance with the Structures  
14          Monitoring Program to verify that we will not exceed  
15          the limits prior to reaching the next inspection  
16          interval.

17                   MEMBER REMPE: Excuse me.

18                   MEMBER MARCH-LEUBA: Go ahead.

19                   MEMBER REMPE: Just to make sure that we  
20          have the facts correct, because we've seen some  
21          different states, I believe, and so just confirm for  
22          me, that you first detected visual indications of ASR  
23          in year of 2009. Is that correct to your  
24          understanding.

25                   MR. CARLEY: That is correct, in the Bravo



1 electrical tunnel.

2 MEMBER REMPE: That's okay. I just wanted  
3 to make sure. Thank you.

4 MR. CARLEY: You're welcome.

5 MEMBER MARCH-LEUBA: With respect this  
6 slide, you said NextEra has implemented the two ASR  
7 programs, ASR and building deformation. Is that  
8 correct?

9 MR. CARLEY: That is correct.

10 MEMBER MARCH-LEUBA: And the moment the  
11 licensee's amendment request gets signed, you'll be  
12 caring for it. Right now, you're doing it on your  
13 own. At the moment this licensee's amendment request  
14 related to the ASR methodology, correct?

15 MR. CARLEY: Yes.

16 MEMBER MARCH-LEUBA: At this point, you're  
17 doing it on your own. At the moment that LRA gets  
18 signed, you will be able to take care for it.

19 MR. CARLEY: We'll be able to close our  
20 PODs that are related to building deformation.

21 MEMBER MARCH-LEUBA: Okay. The real  
22 question is on Unit 41, after you get the LRA,  
23 anything will change, or everything will be solved  
24 before that?

25 MR. CARLEY: Everything -- we do have a

1 commitment. And I apologize, I do not remember the  
2 commitment number. We have two structures that are  
3 non-seismic Category 1 structures, intake and  
4 discharge structures, that we have committed to  
5 analyze before 2020 and will implement the program for  
6 those structures when that analysis is done. So  
7 that'll be --

8 MEMBER MARCH-LEUBA: So the only --

9 MR. CARLEY: -- a couple of years prior.

10 MEMBER MARCH-LEUBA: The only change that  
11 will happen on Unit 41 will be those addition of two  
12 additional non-Category 1 structures?

13 MR. CARLEY: Those will actually be  
14 incorporated in 2020.

15 MEMBER MARCH-LEUBA: Before the LRA gets  
16 issued.

17 MR. CARLEY: No, before the period of  
18 extended operation.

19 MEMBER MARCH-LEUBA: Correct. That's the  
20 appropriate terminology. Okay, thank you.

21 MEMBER SKILLMAN: Ed, anything else?

22 MR. CARLEY: With that, I'll turn it over  
23 for concluding remarks.

24 MEMBER SKILLMAN: Okay.

25 MR. COLLINS: With regards to our

1 concluding remarks, as presented, Seabrook is  
2 committed to the continuous improvement and long term  
3 operation of NextEra Seabrook Station. Seabrook will  
4 manage the effective agency in accordance with 10  
5 C.F.R. 5421(a)(1). Seabrook has conducted time  
6 limited aging analysis that require evaluation under  
7 10 C.F.R. 5421(c).

8 In summary, in closing, NextEra Energy  
9 Seabrook has demonstrated compliance with the  
10 requirement of 10 C.F.R. 54 for issuance of a renewed  
11 license for Seabrook Station, Unit 1.

12 This concludes our presentation at this  
13 time. I'll turn it over to Ken Browne.

14 MR. BROWNE: Now, as Mr. Collins noted,  
15 Mr. Chairman, that concludes NextEra's presentation  
16 for license renewal.

17 MEMBER SKILLMAN: Okay, Seabrook team,  
18 anything else? No? Call-ins, any questions for the  
19 Seabrook team before we change out to the NRC team?

20 (No audible response.)

21 MEMBER SKILLMAN: Seabrook team, thank  
22 you. Please stay in the room. And we call out the  
23 NRC team.

24 (Pause.)

25 MEMBER SKILLMAN: Thank you, Kendra.

1 Butch? Take it away, please.

2 MR. BURTON: All right. Good afternoon.  
3 Chairman Corradini, Chairman Skillman, and members of  
4 the ACRS. My name is Butch Burton, and I am the  
5 license renewal project manager for the Seabrook  
6 Station, Unit 1 Safety Review.

7 We're here today to discuss the staff's  
8 review of the Seabrook License Renewal Application  
9 which we -- otherwise known as the LRA, as documented  
10 in the safety evaluation report that was issued on  
11 September 28, 2018.

12 Joining me here at the table today are Dr.  
13 Allen Hiser, senior technical advisor in NRR's  
14 Division of Materials and License Renewal, and Mr.  
15 Eric Oesterle, branch chief of the projects branch in  
16 the division.

17 Also seated in the audience and available  
18 on the phone are members of the NRC technical staff  
19 who participated in the review of the license renewal  
20 application and conducted onsite audits and  
21 inspections.

22 The presentation is short and sweet. I'll  
23 begin the presentation with a general overview of the  
24 staff's review. And since there are no open or  
25 confirmatory items in the SCR, we'll then proceed to

1 the staff's conclusions.

2 On May 25th, 2010, NextEra Energy Seabrook  
3 submitted an application for renewal of the Seabrook  
4 operating license for an additional 20 years or until  
5 March 15th, 2050. For the review of the Seabrook  
6 license renewal application, the following audits and  
7 inspections were conducted onsite.

8 First, in September 2010, the staff  
9 conducted an audit to review NextEra's administrative  
10 controls governing the scoping and screening  
11 methodology and the technical basis for the scoping  
12 and screening results. The staff documented the  
13 scoping and screening methodology audit results in a  
14 report dated February 4th, 2011.

15 Second, during two weeks in October 2010,  
16 the staff audited NextEra's Aging Management Programs,  
17 which we call AMPs, and relayed a documentation to  
18 verify NextEra's claim that the programs were  
19 consistent with those described in the NRC's Generic  
20 Aging Lessons Learned or GALL report and, considering  
21 any enhancements or exceptions to the AMPs, whether  
22 the programs were adequate to manage aging during the  
23 period of extended operation.

24 The staff considered plant conditions and  
25 operating experience during the audits and documented

1 the results in a report dated March 21st, 2011.

2 Third, during three weeks in March and  
3 April 2011, Region I inspectors conducted a 71002  
4 inspection in support of the review of the Seabrook  
5 LRA and documented the results in a report dated May  
6 23rd, 2011.

7 Fourth, during the last week of April  
8 2018, Region I inspectors conducted a second 71002  
9 inspection on Aging Management programs for concrete  
10 structures affected by alkali silica reaction, known  
11 as ASR. Region I documented the results of this  
12 focused inspection in a report dated August 10th,  
13 2018. And this issue was discussed with the ACRS  
14 Subcommittee on Plant License Renewal at its October  
15 31st meeting.

16 In June 2012, the staff issued a safety  
17 evaluation report for the Seabrook LRA with seven open  
18 items which are listed on this table. In September of  
19 2018, the staff issued a second safety evaluation  
20 report which resolved these seven open items.

21 Following issuance of the SER with open  
22 items, the staff and NextEra met with the ACRS  
23 Subcommittee on Plant License Renewal in July 2012 to  
24 discuss the staff's findings. Of the seven open items  
25 documented in the SER, the open item associated with

1 the structure's monitoring program, and how it manages  
2 aging associated with ASR, dominated the discussions  
3 between the ACRS Subcommittee, NextEra and the staff.

4 The resolution and closure of the seven  
5 open items was documented in the staff's SER issued in  
6 September of 2018. During the staff's in depth  
7 technical review of the LRA over the last eight years,  
8 including two audits and two inspections, a total of  
9 291 RAIs were issued, 58 of which were follow-up RAIs.

10 Following issuance of the SER in September  
11 2018, the ACRS Subcommittee on Plant License Renewal  
12 held meetings with the NRC staff and NextEra, as I  
13 mentioned, on October 31st and on November 15th, 2018.

14 The October 31st meeting was focused on  
15 ASR at Seabrook including resolution of the open item  
16 associated with the structure's monitoring program,  
17 and how the aging effects on structures and components  
18 affected by ASR would be managed during the period of  
19 extended operation. The November 15th subcommittee  
20 meeting focused on the closeout of the remaining open  
21 items.

22 SER Section 2 describes the scoping of  
23 systems, structures, and components, known as SSCs,  
24 and screening of structures and components to identify  
25 those subject to an aging management review, known as

1 an AMR. The staff reviewed NextEra's scoping and  
2 screening methodology, procedures, quality controls  
3 applicable to the development of the LRA, and training  
4 of its project personnel.

5 The staff also reviewed the various  
6 summaries of safety related SSCs, non-safety related  
7 SSCs affecting safety functions, and SSCs relied upon  
8 to perform functions applicable to Seabrook in  
9 compliance with the Commission's regulations for fire  
10 protection, environmental qualification, station  
11 blackout, and anticipated transients without scram.

12 Based on its review, results from the  
13 scoping and screening audit and additional information  
14 provided by NextEra, the staff concludes that  
15 NextEra's scoping and screening methodology and its  
16 implementation were consistent with the standard  
17 review plan for license renewal, known as the SRP, and  
18 the requirements of 10 C.F.R. 54.4(a).

19 SER Chapter 3 and its subsections cover  
20 the staff's review of NextEra's programs for managing  
21 aging in accordance with 10 C.F.R. 54.21(a)(3).  
22 Sections 3.1 through 3.6 include the AMR items in each  
23 of the general system areas within the scope of  
24 license renewal. For a given AMR item, the staff  
25 reviewed the item to determine whether it is



1 consistent with the GALL report.

2 For the AMR items not consistent with the  
3 GALL report, the staff reviewed NextEra's evaluation  
4 to determine whether NextEra has demonstrated  
5 reasonable assurance that the effects of aging will be  
6 adequately managed so that the intended functions will  
7 be maintained consistent with the current licensing  
8 basis for the period of extended operation, as  
9 required by 10 C.F.R. 5421(a)(3).

10 The license renewal application was  
11 submitted in 2010 and described a total of 42 Aging  
12 Management Programs, 13 of which were new and 29 of  
13 which were existing. As a result of the staff's  
14 review, two additional plant-specific Aging Management  
15 Programs, the ASR Monitoring Program and the Building  
16 Deformation Monitoring Program, were developed to  
17 address the management of structures affected by ASR,  
18 for a total of 44 Aging Management Programs.

19 All AMPs, with the exception of the plant-  
20 specific AMPs, were evaluated by the staff for  
21 consistency with Revision 2 of the GALL report. For  
22 the plant-specific AMPs, the staff evaluated them  
23 against the program elements defined in Appendix A.1  
24 of the SRP.

25 Section 4 of the SER identifies time

1 limited aging analyses, or TLAAs. Section 4.1  
2 documents the staff's evaluation of NextEra's  
3 identification of applicable TLAAs. The staff  
4 evaluated NextEra's basis for identifying those plant-  
5 specific or generic analyses that need to be  
6 identified as TLAAs and determined that NextEra has  
7 provided an accurate list of TLAAs as required by 10  
8 C.F.R. 5421(c)(1).

9 Section 4.2 through 4.7 document the  
10 staff's review of the applicable TLAAs as shown.  
11 Based on its review, and the information provided by  
12 NextEra, the staff concludes that either the analyses  
13 remain valid for the period of extended operation, or  
14 the analyses have been projected to the end of the  
15 period of extended operation, or the effects of aging  
16 on the intended functions will be adequately managed  
17 for the period of extended operations as required by  
18 54(c)(1), Subparagraphs I, ii, and iii.

19 The staff's reviewed NextEra's responses  
20 to the open items identified in the safety evaluation  
21 report with open items that was issued in June 2012  
22 and finds that all the open items have been  
23 satisfactorily resolved and closed. With the closure  
24 of the open items, the staff finds that NextEra has  
25 met the requirements of 10 C.F.R. 5429(a) for the

1 license renewal of Seabrook Station, Unit 1.

2 More specifically, the staff finds that  
3 actions have been identified and have been or will be  
4 taken at Seabrook Station, Unit 1 such that there is  
5 reasonable assurance that the activities authorized by  
6 the renewed license will continue to be conducted in  
7 accordance with the current licensing basis and that  
8 any changes made to the plant's current licensing  
9 basis are in accordance with the Atomic Energy Act and  
10 the Commission's regulations.

11 This concludes the staff's presentation,  
12 and we'll be happy to take any remaining questions you  
13 may have.

14 MEMBER SKILLMAN: Butch, thank you. Dr.  
15 Hiser, Eric, thank you.

16 Colleagues, any questions for the NRC  
17 team, please?

18 (No audible response.)

19 MEMBER SKILLMAN: If not, I would ask you  
20 to stand by. Let's go to the public. Are there any  
21 individuals in the room that would care to make a  
22 comment? If so, I invite you to come to the  
23 microphone and ---

24 (Telephonic interference.)

25 MEMBER SKILLMAN: -- I ask you to come to

1 the microphone, and introduce yourself and speak  
2 clearly into the microphone, please.

3 Seeing none, we go to the phone line.  
4 Ladies and gentlemen on the phone line, if one or some  
5 of you are out there, would you just please simply say  
6 hello so that we know that you are there?

7 MR. OSSING: Hello?

8 MEMBER SKILLMAN: Thank you. All right.  
9 For any individual on the phone line that would like  
10 to make a comment, please introduce yourself and then  
11 make your comment, please.

12 MR. OSSING: Hello, my name is Michael  
13 Ossing from Marlborough, Massachusetts. I'd first  
14 like to acknowledge the efforts by the NRC staff, and  
15 the ACRS, as well as NextEra during this eight-year  
16 process.

17 Seabrook is in compliance with the license  
18 renewal and Aging Management Program position --- and  
19 positioned, rather, for the station to operate safely  
20 during the license renewal process. I would support  
21 the ACRS providing a favorable recommendation to issue  
22 Seabrook a license renewal for the period of extended  
23 operation. Thank you.

24 MEMBER SKILLMAN: Thank you, sir. Is  
25 there another individual out there that would like to

1 make a comment, please?

2 (No audible response.)

3 MEMBER SKILLMAN: Hearing none, please  
4 close the phone line. And Chairman Corradini, back to  
5 you.

6 CHAIRMAN CORRADINI: Well, thank you. I  
7 was expecting there would be more public comments.  
8 Okay, thank you very much to NextEra and the staff.  
9 And we're going to go off the record, take a couple of  
10 minutes to rearrange, and we will probably take up the  
11 NextEra letters. And, Dick, you'll lead us through.

12 MEMBER SKILLMAN: Yes. Let me make one  
13 comment. We are going to process two letters this  
14 afternoon, we hope. One letter is on the license  
15 renewal amendment that is plus 20 years. And the  
16 second letter is devoted to Alkali-Silica Reaction.  
17 And our desire is to process the ASR letter first and  
18 then the license extension letter second. So that's  
19 the plan going forward. And we're prepared. Thank  
20 you.

21 CHAIRMAN CORRADINI: We'll take a few  
22 minutes to kind of rearrange.

23 (Whereupon, the above-entitled matter went  
24 off the record at 3:51 p.m.)

25





# TVA Clinch River SMR Project Early Site Permit Application

---

December 6th, 2018

Advisory Committee on Reactor Safeguards  
Full Committee Meeting

# Acknowledgement and Disclaimer

Acknowledgment: "This material is based upon work supported by the Department of Energy under Award Number DE-NE0008336."

Disclaimer: "This presentation was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof."

# Presentation Outline

- Clinch River Nuclear Site – Overview
  - Dan Stout
- Early Site Permit Application – Overview
  - Ray Schiele
- Emergency Preparedness
  - Archie Manoharan




# **Clinch River Nuclear Site - Overview**

**Dan Stout**

**Director, Nuclear Technology & Innovation**


# TVA's Mission

## ENERGY



Provide *affordable, reliable* power.

## ENVIRONMENT



Steward the Valley's *natural resources*.

## ECONOMIC DEVELOPMENT



Partner for *economic growth*.

# TVA Clinch River Site



- Access to 500 KV and 161 KV transmission
- Neighbor to DOE, an interested customer
- Basic Infrastructure
- Abundant and skilled workforce
- Strong community support
- TVA owned/controlled

# Early Site Permit Application (ESPA)

An Early Site Permit assesses site suitability for potential construction and operation of a nuclear power plant.


## Application includes:

- Site Safety Analysis Report to address impacts of the environment on the plant
- Environmental Report
- Emergency Plans (Part 5A and Part 5B)
- Exemptions (Part 6)

## ESPA based on a “plant parameter envelope” (PPE)

- Composite of reactor and engineered parameters from four U.S. light-water SMR designs with unique design features that bound the safety and environmental impact of plant construction and operation
- Developed based on NEI 10-01 guidance with margin added to specific parameters
- Assumes two or more SMR units of a single design
- Up to 800MWt for a single unit with a combined nuclear generating capacity not exceeding 2420 MWt (800 MWe)

# NRC Review of ESPA



# ESPA Summary

- NRC Commenced Review in FY 17'
- Contains more than 8000 Pages
- Supported by over 80,000 pages in referenced documents
- Efficient Use of Audits
- Few Requests for Additional Information (RAIs)
- Frequent, Clear, and Candid Communication

# **Early Site Permit- Overview**

**Ray Schiele**

**Licensing Manager**

# Application Organization

Part 1 – Administrative Information

Part 2 – Site Safety Analysis Report

- Chapter 1 – Introduction and General Description
- Chapter 2 – Site Characteristics
- Chapter 3 – Aircraft Hazards
- Chapter 11 – Radioactive Waste Management
- Chapter 13 – Emergency Planning
- Chapter 15 – Transient and Accident Analysis
- Chapter 17 – Quality Assurance

Part 3 – Environmental Report

Part 4 – Limited Work Authorization – Not Used

Part 5 – Emergency Plan

Part 6 – Exemptions and Departures

Part 7 – Withheld Information

Part 8 – Enclosures



# ESPA Development

## Regulatory bases for the SSAR:

- NRC Regulations—10 CFR 20, 10 CFR 50, 10 CFR 52, and 10 CFR 100
- NUREG-0800, Standard Review Plan for the Review of Safety Analysis Reports for Nuclear Power Plants: LWR Edition
- NRC Regulatory Guide 1.206, Combined License Applications for Nuclear Power Plants (LWR Edition)
- RS-002, Processing Applications for Early Site Permits

## Regulatory bases for the ER:

- National Environmental Policy Act,
- NRC Regulations—10 CFR 51 and 10 CFR 52,
- NRC Regulatory Guide 4.2, Preparation of Environmental Reports for Nuclear Power Stations,
- NRC Regulatory Guide 4.7, General Site Suitability Criteria for Nuclear Power Stations,
- NUREG-1555, Federal, regional, state and local environmental statutes, as applicable, and
- RS-002, Processing Applications for Early Site Permits.

# ESPA NRC Interactions

- Pre-Environmental Report Visit March 2013
- PPE Development September 2014
- Pre-application Site Visit October 2014
- Alternative Sites Visit June 2015
- ESPA Readiness Review August 2015
- Hydrology and Health Physics Audit April 2017
- Seismic/Geotechnical Audit May 2017
- Environmental and Meteorology Audit May 2017
- QA Inspection April 2018
- Meteorology and Health Physics Audit May 2018

# ASER/ACRS Committee Timeline

- 1<sup>st</sup> Set ASERs Issued April 2018
- ACRS Subcommittee Meeting May 2018
  - SSAR Sections 2.1, 2.2, 3.5.1.6, 15.0.3
- ASER – SSAR 13.3 Issued July 2018
- ACRS Subcommittee Meeting August 2018
  - SSAR Section 13.3
- ASER – SSAR 2.5 Issued September 2018
- ACRS Subcommittee Meeting October 2018
  - SSAR Section 2.5
- 2<sup>nd</sup> Set ASERs Issued October 2018
- ACRS Subcommittee Meeting November 2018
  - SSAR Sections 2.3, 2.4, 11.2/11.3, 17.0
- ACRS Full Committee Meeting December 2018

# **Emergency Preparedness**

## **Archie Manoharan**

### **Licensing Engineer**

# ESPA – Emergency Preparedness Approach

## Emergency Planning (EP) Information Layout – 3 Areas

- Part 2, SSAR, Section 13.3, Emergency Preparedness
  - Plume exposure pathway (PEP) emergency planning size (EPZ) sizing methodology
- Part 5, Emergency Plan
  - Two major features (Onsite) Emergency Plans
  - Part 5A – Site Boundary EPZ Emergency Plan
  - Part 5B – 2-Mile EPZ Emergency Plan
- Part 6, Exemptions and Departures
  - 2 sets of exemption requests
  - Exemption requests for a PEP EPZ at Site Boundary
  - Exemption requests for a 2-mile PEP EPZ

The final EPZ size for the Clinch River Site will be determined at COLA stage

# PEP EPZ Sizing Methodology

- Takes SMR design and safety advancements into consideration
- Dose-based, consequence-oriented approach to determine an appropriate EPZ size
- Consistent with the NUREG-0396 sizing rationale – spectrum of accidents are addressed
- **Approach has the same dose criteria as NUREG-0396 – 1 rem total effective dose equivalent (TEDE)**

## Technical Criteria - PEP EPZ should:

- **Criterion A** – encompass those areas in which projected dose from **design basis accidents** (DBAs) could exceed the U.S. Environmental Protection Agency (EPA) early phase protective action guide (PAG)
- **Criterion B** – encompass those areas in which consequences of **less severe core melt accidents** could exceed the EPA early phase PAG
- **Criterion C** – be of sufficient size to provide for substantial reduction in early health effects in the event of **more severe core melt accidents**

# PEP EPZ Sizing Methodology

- Step 1 - Accident scenario selection
  - DBA from Chapter 15
  - Design and site specific Probabilistic Risk Assessment (PRA) for severe accident scenarios
    - Considers – all modes, internal & external events, applicable fuel handling, spent fuel pool, and multi-module accidents
    - Sequences with mean core damage frequency (CDF) greater than  $1\text{E-}8$  per reactor-year (rx-yr)
    - **Criterion B: Less severe core melt scenarios – Mean CDF greater than  $1\text{E-}6$  per rx-yr, intact containment**
    - **Criterion C: More severe core melt scenarios – Mean CDF greater than  $1\text{E-}7$  per rx-yr, containment bypass or failure**
- Step 2 - Determine source term releases from selected accidents
- Step 3 - Calculate dose consequences at distance
- Step 4 - Compare the dose at distance to EPA early phase PAG

COL applicant would perform an analysis using the PEP EPZ size methodology, with site- and design-specific input, to justify the PEP EPZ size for the COLA

# PEP EPZ Sizing Methodology – Example Analysis

Criteria A & B: DBA and less severe accidents

- Dose consequences do not exceed the early phase EPA PAG – 1 rem total effective dose equivalent (TEDE)

Criterion C: More severe accidents

- Calculate distance at which conditional probability to exceed 200 rem whole body exceeds  $1\text{E-}3$  per rx-yr
- Verify the PEP EPZ is of sufficient size to provide for substantial reduction in early health effects

**Design-Specific Example Analysis – Evaluates NuScale Power Plant at Clinch River Site**

Criteria	Site Boundary Dose TEDE (rem)	EPA Early Phase PAG Limit TEDE (rem)
A: Design Basis Accidents	0.104	1
B: Less Severe Core Melt Accidents	0.158	1
C: Reduction in Early Severe Health Effects	No accident scenarios met the required screening criteria.	



# Part 5 – Emergency Plan

Part 5 of the ESPA contains the major features of two distinct Emergency Plans for Clinch River Site in accordance with 10 CFR 52.17(b)(2)(i).

## Part 5A

- Describes major features of an Emergency Plan for a PEP EPZ consisting of the area encompassed by the Site Boundary.

## Part 5B

- Describes major features of an Emergency Plan for a PEP EPZ consisting of an area approximately two miles in radius surrounding the Clinch River Site.

Both plans address the 16 planning standards in NUREG-0654, Section II, which reflects the requirements in 10 CFR 50.47(b)(1) through 10 CFR 50.47(b)(16) and Appendix E to 10 CFR Part 50 considering the requested exemptions described in Part 6 of the ESPA

# Part 6 – Exemptions and Departures

Pursuant to 10 CFR 52.7, Specific Exemptions, which is governed by 10 CFR 50.12, Specific Exemptions, TVA requested exemptions from the following emergency preparedness requirements for the Clinch River Site:

- Certain standards in 10 CFR 50.47(b) regarding onsite and offsite emergency response plans for nuclear power reactor
- Certain requirements of 10 CFR 50.33(g) and 10 CFR 50.47(c)(2) to establish PEP EPZ for nuclear power plants
- Certain requirements of 10 CFR Part 50, Appendix E, which establish the elements that make up the content of emergency plans

## Two Sets of Exemptions

- Exemptions for a PEP EPZ established at the **Site Boundary**
  - Deviate from 10-mile PEP EPZ
  - Various elements of a formal offsite emergency plan
  - Evacuation time estimates
  - Certain elements of offsite notifications and exercises
- Exemptions for an approximate **2-mile PEP EPZ**
  - Deviate from 10-mile PEP EPZ

# Emergency Preparedness Approach – Summary

	ESPA	COLA
<b>PEP EPZ Methodology</b> (Part 2, SSAR, Section 13.3)	Approval of the <u>dose-based, consequence oriented methodology</u> for determining the PEP EPZ size	Approval of <u>design specific implementation</u> of the methodology approved in the ESPA
<b>EPZ Size</b> (Part 6)	Approval <u>to deviate from the current 10-mile PEP EPZ requirements</u> based on the methodology to determine PEP EPZ size	Approval of <u>design specific PEP EPZ size</u> based on design specific implementation of the methodology
<b>Emergency Plan</b> (Part 5)	Approval of the <u>major features</u> of the Site Boundary and 2-mile emergency plans presented in Part 5	Approval of the <u>remaining elements</u> of either the Site Boundary or 2-mile emergency plans OR a new plan based on design specific PEP EPZ size using methodology





# **Presentation to the ACRS Full Committee Clinch River Nuclear Site - Early Site Permit Application (ESPA) Safety Review**

**December 6, 2018**

---

Mallecia Sutton, Project Manager, NRO/DLSE/LB3

Allen Fetter, Project Manager, NRO/DLSE/LB3

Section 13.3 Emergency Planning

Michelle Hart, Technical Reviewer, NRO/DLSE/RPAC

Bruce Musico, Technical Reviewer, NSIR/DPR/RLB

# Clinch River Nuclear Site ESP Application Review Overview

- Tennessee Valley Authority (TVA) submitted an ESPA for the Clinch River Nuclear Site to NRC (May 26, 2016)
- Application accepted for docketing and detailed technical review on December 30, 2016. Federal Register Notice on acceptance decision (January 12, 2017)
- TVA requested permit approval for a 20-year term along with approval for a plume exposure pathway (PEP) emergency planning zone (EPZ) sizing methodology, 2 major features (onsite) emergency plans, and exemption requests for site boundary and 2-mile PEP EPZs
- Plant Parameter Envelope (PPE) based on four small modular reactor (SMR) designs



# Staff Review

- Staff overview presentation to ACRS on ESP, PPE and Clinch River ESP review schedule (November 15, 2017)
- NRC Staff's safety review of the application included 5 audits and 1 inspection, and issuance of 12 request for additional information (RAIs) (comprising 50 questions)
- Staff completed all Advanced Safety Evaluations (ASEs) with no Open Items and presented to ACRS Subcommittee (May 15, 2018 – November 14, 2018)
- ASEs include 42 combine license application (COL) Action Items and 8 Permit Conditions
- Staff cooperated with U.S. Army Corps of Engineers, consulted with Federal Emergency Management Agency, and engaged with U.S. Department of Energy, Tennessee Department of Environment and Conservation, the U.S. Geological Survey and the Tennessee Emergency Management Agency

# ESP Plant Parameter Envelope

## **Approving an ESP Site without a Selected Reactor Technology**

- ESP Plant Parameter Envelope (PPE) values can bound a variety of reactor technologies rather than one specific technology (an amalgam of values representing a surrogate nuclear plant)
- The PPE values are bounding criteria used by staff to determine the suitability of an ESP site for construction and operation of a nuclear plant
- In the combined license application (COLA), when a specific technology is identified, the PPE values are compared to those of the selected technology. If design parameters of the selected technology exceed bounding ESP PPE values, additional reviews are conducted to ensure that the site remains suitable from a safety and environmental standpoint for construction and operation of the selected nuclear plant technology



# ESP Plant Parameter Envelope (cont'd)

TVA used the following reactor designs to develop the Plant Parameter Envelope (PPE):

- BWXT mPower SMR, 530 megawatts thermal (MWt) (180 megawatts electric (MWe))
- NuScale SMR, 160 MWt (50 MWe)
- Holtec SMR-160, 525 MWt (160 MWe)
- Westinghouse SMR, 800 MWt (225 MWe)

TVA's PPE is based on construction and operation of two or more SMRs at the Clinch River Nuclear Site with a maximum site nuclear generating capacity of 2420 MWt (800 MWe)

# Safety Evaluation Sections

Chapter Sections	Accession Numbers
2.1 Geography and Demography	ML18102B203
2.2 Nearby Industrial Transportation and Military Facilities	ML18102B203
2.3 Meteorology	ML17289B148
2.4 Hydrologic Engineering	ML17289B151 (NP) ML18290A685 (P)
2.5.1 Geologic Characterization	ML17289B252
2.5.2 Vibratory Ground Motion	ML17289B253
2.5.3 Surface Deformation	ML17289B254
2.5.4 Stability of Subsurface Materials and Foundations	ML17289B255
2.5.5 Stability of Slopes	ML17289B255
3.5.1.6 Aircraft Hazards	ML18102B150
11.2 & 11.3 Radioactive Waste Management	ML17289A625
13.3 Emergency Planning	ML17291A052
15.0.3 Radiological Consequences of Design Basis Accidents	ML18102B149
17.5 Quality Assurance Program Description	ML17291A547

## Section 2.1 Geography and Demography

- TVA provided adequate information pertaining to;
  - the site setting and boundaries
  - Exclusion Area Boundary (EAB) authority and control
  - current and future population projections
  - low population zone (LPZ) distance, population center distance and population density
- Based on the information provided by the applicant and staff's independent confirmatory evaluation, the staff found the information to be acceptable as it meets the requirements of 10 CFR 100.20

## Section 2.2 Nearby Industrial, Transportation, and Military Facilities

- TVA adequately identified potential sources and hazards in site vicinity
- TVA adequately evaluated potential accidents pertaining to explosions, vapor cloud explosions, hazardous/toxic chemical vapors, and fires
- Based on the information provided by the applicant and staff's independent confirmatory evaluation, the staff found the information to be acceptable as the information meets the guidance provided in NUREG-0800 Section 2.2.1-2.2.2

## Section 2.3 - Meteorology

- Site characteristics related to **extreme weather** (hurricane and tornado winds, winter precipitation, temperature and humidity extremes) are acceptable
- Onsite **meteorological monitoring system** provides adequate data to represent meteorological dispersion conditions
- Site characteristics related to **Short-Term (Accident) and Long-Term (Routine Release) dispersion estimates** (X/Q and D/Q values) are acceptable
- Based on the information provided by the applicant, the staff found all regulatory requirements have been satisfied with no open items

# Short-Term (Accident) X/Q Values

- Short-Term (Accident) X/Q Values
  - Exclusion Area Boundary (335 meters)
  - Low Population Zone (1609 meters)
- Based on PAVAN Atmospheric Dispersion Model
  - Gaussian model
  - Various time averaging periods
    - 0-2 hr @ EAB
    - 0-8 hr, 8-24 hr, 1-4 days, and 4-30 days @ LPZ
  - Intended to represent dispersion conditions that are exceeded no more than 5% of the time
- Used to demonstrate compliance with 10 CFR 52.17(a)(1)(ix) dose guidelines for design basis accidents
  - 25 rem at the EAB for any 2-hour period following the onset of the release
  - 25 rem at the outer boundary of the LPZ for the duration of the release



## Section 2.4 Hydrologic Engineering

- TVA proposed adequate site characteristics and bounding design parameters for inclusion in the ESP
- Design basis flood and maximum groundwater levels, and the accidental release dose estimate meet regulatory requirements
- Staff concludes that applicant meets ESP regulatory requirements associated with hydrologic engineering

## Section 2.5 Geology, Seismology and Geotechnical Engineering

- Geologic Site Characterization (Section 2.5.1) - No tectonic features with the potential for adversely affecting suitability of the site occur in the site region, site vicinity, site area, or at the site location
- Vibratory Ground Motion (Section 2.5.2) - Applicant's ground motion response spectrum adequately represents the regional and local seismic hazards, and accurately includes the potential effects of local site-specific subsurface properties
- Surface Deformation (Section 2.5.3) - Negligible potential exists for tectonic surface deformation at the site. Karst is the primary potential hazard for non-tectonic surface deformation that could adversely affect the site
- Stability of Subsurface Materials and Foundations (Section 2.5.4) - Applicant adequately determined the engineering properties of subsurface materials at the site, and properly evaluated the stability of subsurface materials and foundations based on results of field and laboratory tests and state-of-the-art methodology
- Stability of Slopes (Section 2.5.5) - Applicant provided necessary information on site topography and geologic conditions, and adequately described characteristics of slopes at the site



## Section 3.5.1.6 Aircraft Hazards

- For site suitability, aircraft accidents should not lead to radiological consequences in excess of the exposure guidelines of 10 CFR 50.34(a)(1) with a probability of occurrence greater than about  $10^{-7}$  per year
- The applicant determined an aircraft crash probability of  $7.53 \times 10^{-7}$  per year from two nearby airways not associated with local airport operations
- The staff conservatively estimates a potential aircraft crash probability of  $1.5 \times 10^{-8}$  per year (bounding the applicant's probability), assuming all flights within 10 miles of the site follow the two airways passing near the site
- Staff finds that the applicant's approach is reasonable and the probability value is acceptable

# Chapter 11 Radioactive Waste Management, Sections 11.2.3 and 11.3.3

- Applicant's methodology to develop the normal PPE liquid and gaseous effluent release source terms for use in calculating offsite doses is reasonable
- Normal PPE liquid and gaseous effluent release concentrations meet the unity rule in 10 CFR Part 20, Appendix B, Table 2, Columns 1 and 2
- Offsite doses from normal PPE liquid and gaseous effluent release source terms meet the design objectives in 10 CFR Part 50, Appendix I, Sections II.A, II.B, and II.C; Environmental Protection Agency's (EPA) radiation standards in 40 CFR Part 190, as implemented under 10 CFR 20.1301(e); and public dose limit in 10 CFR 20.1301
- Reactor designs falling within the normal PPE effluent release source terms and offsite doses for the Clinch River Nuclear Site are without undue risk to public health and safety

# Chapter 15 Accident Analysis

- Evaluation of the radiological consequences of postulated design basis accidents (DBAs) is based on the PPE accident source term for DBA isotopic releases to the environment (in lieu of specific plant design information) in conjunction with site characteristic short term (accident) atmospheric dispersion factors
- The same dose criteria are used for siting and postulated accident dose analysis requirements:  
The evaluation must determine that:
  1. An individual located at any point on the boundary of the exclusion area for any 2 hour period following the onset of the postulated fission product release would not receive a radiation dose in excess of 25 rem total effective dose equivalent (TEDE).
  2. An individual located at any point on the outer boundary of the low population zone, who is exposed to the radioactive cloud resulting from the postulated fission product release (during the entire period of its passage) would not receive a radiation dose in excess of 25 rem TEDE
- Staff concluded that the applicant's analysis meets the dose criteria specified, and the PPE includes the bounding accident releases for the determination

# Section 17.5 Quality Assurance Program Description

- NRC Staff identified one RAI, March 9, 2018
- NRC Staff conducted Quality Assurance Implementation Inspection, April 16-20th 2018.
- TVA issued Nuclear Quality Assurance Plan, Revision 36; May 8, 2018
- Staff concluded that the applicant's quality assurance program description for the Clinch River Nuclear site ESP application meets the requirements of 10 CFR Part 50, Appendix B and 10 CFR 52.17(a)(1)(xi) and (xii)

## 13.3 Emergency Planning

The ESPA requested review of 3 key areas, which consist of:

- Plume exposure pathway (PEP) emergency planning zone (EPZ) sizing methodology
- 2 major features (onsite) emergency plans (ESPA Part 5)
  - ESPA Part 5A reflects a site boundary PEP EPZ
  - ESPA Part 5B reflects a 2-Mile PEP EPZ (including an ETE)
- 25 Exemption Requests (ESPA Part 6)
  - 2 exemption requests (applicable to both the site boundary and 2-mile PEP EPZs)
  - 23 exemption requests address portions of 10 CFR 50.47(b) and Appendix E to 10 CFR Part 50 for offsite emergency planning (EP) related to the site boundary PEP EPZ only



# 25 Exemption Requests (EP)

- 10 CFR 50.33(g) & 50.47(c)
  - 2 requests for exemptions from the 10-mile PEP EPZ requirement
- 10 CFR 50.47 & Appendix E to 10 CFR Part 50
  - 23 requests for exemption from the emergency planning requirements associated with offsite emergency planning
    - State & local emergency plans
    - Public alert & notification
    - Evacuation Time Estimate (ETE)
    - Offsite exercises

# Basis for Acceptance

- The ESPA provides a basis for the establishment (in the COLA) of either a Site Boundary or 2-mi PEP EPZ, which maintains the same level of protection (i.e., dose savings in the event of a radiological emergency) in the environs of the Clinch River Nuclear Site as that which exists in the basis for a 10-mi PEP EPZ

# Combined License Application

- Upon issuance of the ESP, the applicant acquires approval, with conditions, of:
  - The PEP EPZ sizing methodology
  - The 2 major features emergency plans (site boundary/2-mile PEP EPZ)
  - The 25 requested exemptions
- A COLA that incorporates by reference the ESP must:
  - Identify the chosen SMR technology for the Clinch River Nuclear site
    - Demonstrate that the EPZ sizing methodology supports either the site boundary or 2-mile PEP EPZ
  - Provide a complete & integrated emergency plan
    - 2-mile PEP EPZ must provide onsite & offsite emergency plans
    - site boundary PEP EPZ must provide an onsite emergency plan
  - Address all 16 COL Action Items and 4 Permit Conditions



# EPZ Size Determination in COLA

- COL Action Item 13.3-1 (reflects ESPA Part 2 Section 13.3.3.1.4)
  - Identify chosen SMR technology & major features emergency plan
  - Provide detailed information that shows the ability of the SMR to meet the chosen PEP EPZ
  - The selected SMR technology must meet the EPA early phase protective action guide (PAG)
- Permit Condition 1
  - Provide detailed information to demonstrate that the accident release source term information for the PEP EPZ size determination analysis using the selected SMR design is bounded by the non-design-specific plant parameter source term information used in the analysis supporting the exemption requests (ASER Table 13.3-1)
  - Based on non-design-specific bounding 4-day accident release source term that meets EPZ size criteria

# TVA PEP EPZ Size Methodology

## Technical Criteria

- PEP EPZ should encompass those areas in which projected dose from DBAs could exceed the EPA early phase PAG
- PEP EPZ should encompass those areas in which consequences of less severe core melt accidents could exceed the EPA early phase PAG
- PEP EPZ should be of sufficient size to provide for substantial reduction in early health effects in the event of more severe core melt accidents

# TVA PEP EPZ Size Methodology

## SSAR Section 13.3.3.1

- Accident scenario selection
  - Use bounding DBA from COLA Final Safety Analysis Report Chapter 15
  - Use COLA site- and design-specific probabilistic risk assessment to categorize severe accident scenarios
    - All modes, internal and external events, applicable fuel handling and spent fuel pool accidents, multi-module considerations
    - Assess all sequences with mean core damage frequency (CDF)  $> 10^{-8}$  per rx-yr
    - More probable, less severe core melt scenarios
      - Mean CDF  $> 10^{-6}$  per rx-yr
      - Intact containment
    - Less probable, more severe core melt scenarios
      - Mean CDF  $> 10^{-7}$  per rx-yr
      - Includes containment bypass or failure
- Determine source term releases to atmosphere
- Calculate dose consequences at distance from plant
- Determine PEP EPZ size that meets the dose-based criteria

# TVA Dose-Based PEP EPZ Size Criteria

- Dose to individual from exposure to the airborne plume during its passage and to groundshine, using average atmospheric dispersion characteristics for site
  - Staff expects the applicant may use the calculation tools used for severe accident consequence analysis in environmental report
- DBA and more probable, less severe accidents
  - 1 rem TEDE from 96-hr exposure
  - Lower end of dose range EPA PAG for early phase protective actions (e.g., evacuation and sheltering)
  - Verify that dose consequences do not exceed the EPA PAG beyond the site boundary (within owner controlled area) and 2-mile PEP EPZs
- Less probable, more severe accidents
  - Calculate the distance at which the conditional probability to exceed 200 rem whole body from 24-hr exposure exceeds  $10^{-3}$  per rx-yr
  - Acute dose at which radiation-induced early health effects may begin to be noted (e.g., nausea)
  - Verify that the PEP EPZ supports substantial reduction in early health effects

# Review of PEP EPZ Size Methodology

- Staff compared TVA's methodology and dose criteria to the study used as technical basis for current 10-mile PEP EPZ requirement (NUREG-0396)
  - The features of TVA's methodology are consistent with NUREG-0396
    - Considered a range of accidents
    - Performed accident consequence analyses
    - Determined an area outside of which early protective actions are not likely to be necessary to protect the public from radiological releases
- The staff concludes that the applicant's proposed methodology is reasonable, and consistent with the analyses that form the technical basis for the current regulatory requirement of a PEP EPZ of about 10 miles in radius



# EP Exemption Plant Parameters

- TVA developed a non-design-specific accident release source term that would meet the PEP EPZ size criteria to be used as plant parameters (ASER Table 13.3-1)
  - Isotopic total release activity over 96 hrs results in TEDE of about 0.9 rem at site boundary
  - Same idea as PPE DBA source term to envelope an unknown design
  - Referenced in Permit Condition 1 for adoption of EP exemptions

## Section 13.3 EP Conclusions

- The staff concludes that:
  - The PEP EPZ sizing methodology is acceptable for determining the appropriate size of the PEP EPZ for the Clinch River Nuclear site because it is consistent with the analyses that form the technical basis for the current 10-mile PEP EPZ
  - The 2 major features emergency plans are acceptable because they meet the applicable standards of 10 CFR 50.47 and requirements of Appendix E to 10 CFR Part 50
  - The exemption requests are acceptable because they are authorized by law, will not present an undue risk to the public health and safety, are consistent with the common defense and security, and special circumstances are present

# Questions?



# Technical Reviewers

Dan Barss

Luisette Candelario

Yuan Cheng

Richard Clement

Joseph Giacinto

Michelle Hart

David Heeszal

Michael Mazaika

Bruce Musico

Kevin Quinlan

Nicholas Savvoir

Gerry Stirewalt

Seshagiri (Rao) Tammara

Jenise Thompson

Weijun Wang

Jason White

# Acronyms

ASE – Advanced Safety Evaluation

CFR – Code of Federal Regulations

COL – Combined License

COLA – Combined License Application

CDF – Core Damage Frequency

CP – Construction Permit

CRN – Clinch River Nuclear

DBA – Design Basis Accidents

DBF – Design Basis Flood

EAB – Exclusion Area Boundary

EP – Emergency Planning

EPA – Environmental Protection Agency

EPZ – Emergency Planning Zone

ESP – Early Site Permit

ESPA – Early Site Permit Application

ETE – Evacuation Time Estimate

FRN – Federal Register Notice

LOCA – Loss of Coolant Accident

LPZ – Low Population Zone

NP-Non-Public

MWe – Megawatts Electric

MWt – Megawatts Thermal

NP-Non-Public

NRC – Nuclear Regulatory Commission

P-Public

PAG – Protective Action Guide

PEP – Plume Exposure Pathway

PPE – Plant Parameter Envelope

RAI – Request for Additional Information

SER – Safety Evaluation Report

SMR – Small Modular Reactor

SSCs – Structures, Systems and Components

TEDE – Total Effective Dose Equivalent

TVA – Tennessee Valley Authority

USGS - U.S. Geological Survey

# Seabrook Station Unit 1 License Renewal Application



**Advisory Committee on Reactor Safeguards  
Full Committee Meeting  
December 5, 2018**



# Nuclear Excellence Model



**The foundation for everything we do are the Values and Core Principles of our Nuclear Excellence Model**



# Agenda

- **Introduction**
- **Site and Station Description**
- **License Renewal Application and Aging Management Programs**
- **Safety Evaluation Report and Closure of Previous Open Items**
- **Closing Remarks**

**NextEra Energy Seabrook has met the requirements of  
10 CFR 54 for issuance of a renewed license for  
Seabrook Station Unit 1**

## Personnel in Attendance

- Eric McCartney Regional Vice President - Northern Region
- Michael Collins Engineering Director
- Ken Browne Licensing Manager
- Edward Carley License Renewal Supervisor
- Rudy Gil Programs Engineering Manager

# Site and Station Description



## Plant Status

- **Completed latest refuel outage (OR19) 10/29/18**
- **Next Refuel Outage – Spring 2020 (End of Cycle 20)**
- **Capacity Factor 15 of 19 cycles > 94%**
  - Lifetime 87%
  - Lifetime excluding refueling outages 95.2%
  - Cycle 19: 99.86%
  - Cycle 18: 98.34%
  - Cycle 17: 99.27%
  - Cycle 16: 99.71%

**Capacity factor performance is representative of solid equipment reliability and material condition**



## Recent Station Improvements

- Main Generator Stator Rewind
- Vital Batteries
- Vital Inverters
- Generator Step-Up Transformers
- Mechanical Stress Improvement Process completed for all Reactor Vessel Nozzles
- Service Water Piping (AL6XN)
- Incore Detectors
- Process Control Single Point Vulnerability Circuit Cards
- Solid State Protection System Circuit Cards
- Rod Control Motor/Generator Sets
- Shutdown Reactor Coolant Pump Seals

**NextEra Energy Seabrook is committed to maintaining high levels of safety, reliability and performance**

# **License Renewal Application**

## **Scoping and Screening**

- Aging Management Review

## **Time Limited Aging Analysis (TLAA)**

## **UFSAR Supplement**

- Commitments

## **Aging Management Programs**

## **Environmental Report**

- Severe Accident Mitigation Alternatives (SAMA) Analysis

## GALL Consistency

AMPS		Consistent	Consistent with Enhancements	Consistent with Exceptions	Consistent with Exception and Enhancements	Plant Specific
New	15	7	1	2	1	4
Existing	29	8	12	2	5	2
Total	44					

# Safety Evaluation Report


SER Issued September 28, 2018

- No open items
- No confirmatory items

Closure of Open Items from previous SER (2012)

- OI 3.0.3.2.2-1— Steam Generator Tube Integrity
- OI 4.2.4-1— Pressure-Temperature Limit
- OI 3.2.2.1-1— Treated Borated Water
- OI 3.0.3.1.7-1— Bolting Integrity Program
- OI B.1.4-2— Operating Experience
- OI 3.0.3.1.9-1— ASME Section XI, IWE Program
- OI 3.0.3.2.18-1— Structures Monitoring Program

# Approach for Addressing ASR at Seabrook Station



**NextEra Energy Seabrook has implemented an effective program for evaluating and managing the impacts of ASR on affected concrete structures and associated SSCs**

## Concluding Remarks

- Seabrook is committed to the continuous improvement and long-term operation of Seabrook Station
- Seabrook will manage the effects of aging in accordance with 10 CFR 54.21(a)(1)
- Seabrook has evaluated time-limited aging analyses that require evaluation under 10 CFR 54.21(c)
- Seabrook has met the provisions of 10 CFR 54 for issuance of a renewed license

**NextEra Energy Seabrook has demonstrated compliance with the requirements of 10 CFR 54 for issuance of a renewed license for Seabrook Station Unit 1**



# **Advisory Committee on Reactor Safeguards** **Full Committee**

## **Seabrook Station, Unit 1** **Safety Evaluation Report (SER)**

December 6, 2018

William “Butch” Burton, Project Manager  
Office of Nuclear Reactor Regulation

# Presentation Outline

- **Overview of Seabrook license renewal review**
- **Conclusion**



# License Renewal Review: Audits and Inspections Onsite

Audit / Inspection	Dates
Scoping & Screening Methodology Audit (ML110270026)	September 20 – 23, 2010
Aging Management Program (AMP) Audits (ML110280424)	October 12 – 15, 2010 October 18 – 22, 2010
Region I 71002 Inspection: Scoping, Screening, and AMPs (ML111360432)	March 7 – 11, 2011 March 21 – 25, 2011 April 4 – 8, 2011
Region I 71002 Inspection: AMPs for Alkali-Silica Reaction (ASR) (ML18222A292)	April 30 – May 3, 2018

# SER Overview

- SER with 7 Open Items issued June 2012
  1. Bolting Integrity Program
  2. ASME Code Section XI, Subsection IWE Program
  3. Steam Generator Tube Integrity Program
  4. Operating Experience
  5. Treated Borated Water
  6. Pressure-Temperature Limit
  7. Structures Monitoring Program/ASR
- Open items closed on September 28, 2018

# SER Overview

- SER with 7 Open Items issued June 8, 2012
- Staff met with ACRS Subcommittee on Plant License Renewal on July 10, 2012
- Final SER issued September 28, 2018
  - No open items or confirmatory items
  - Total of 291 RAIs issued
    - 58 follow-up RAIs
- Additional meetings with ACRS Subcommittee on Plant License Renewal held October 31 and November 15, 2018

# SER Section 2

- **Structures and Components Subject to Aging Management Review (AMR)**
  - Section 2.1: Scoping and Screening Methodology
  - Section 2.2: Plant-Level Scoping Results
  - Sections 2.3, 2.4, 2.5: Scoping and Screening Results

# SER Section 3

- **Aging Management Review (AMR) Results**
  - Section 3.1: Aging Management of Reactor Vessel, Internals, and Reactor Coolant System
  - Section 3.2: Aging Management of Engineered Safety Features
  - Section 3.3: Aging Management of Auxiliary Systems
  - Section 3.4: Aging Management of Steam and Power Conversion Systems
  - Section 3.5: Aging Management of Containments, Structures and Component Supports
  - Section 3.6: Aging Management of Electrical Commodity Group

# SER Section 3

## Section 3.0.3 - Aging Management Programs (AMPs)

### NextEra's Disposition of AMPs

- 13 new programs
  - 6 consistent
  - 1 consistent with enhancements
  - 3 consistent with exceptions
  - 3 consistent with enhancements and exceptions
- 29 existing programs
  - 10 consistent
  - 10 consistent with enhancements
  - 3 consistent with exceptions
  - 4 consistent with enhancements and exceptions
  - 2 plant specific

### Final Disposition of AMPs in SER

- 15 new programs
  - 7 consistent
  - 1 consistent with enhancement
  - 2 consistent with exceptions
  - 1 consistent with enhancements and exceptions
  - 4 plant specific
- 29 existing programs
  - 8 consistent
  - 12 consistent with enhancements
  - 2 consistent with exceptions
  - 5 consistent with enhancements and exceptions
  - 2 plant specific

# SER Section 4

- **Time-Limited Aging Analyses (TLAAs)**
  - 4.1: Identification of TLAAs
  - 4.2: Reactor Vessel Neutron Embrittlement Analyses
  - 4.3: Metal Fatigue Analyses
  - 4.4: Environmental Qualification of Electric Equipment
  - 4.5: Concrete Containment Tendon Prestress Analyses
  - 4.6: Containment Liner Plate, Metal Containment, and Penetrations Fatigue Analyses
  - 4.7: Other Plant-Specific TLAAs

# Conclusion

On the basis of its review, the staff finds that the requirements of 10 CFR 54.29(a) have been met for the license renewal of Seabrook Station, Unit 1.