

JAN 12 1983

**DISTRIBUTION**

~~DOCK~~ File  
NRC PDR  
Local PDR  
NSIC  
PRC

**DOCK # 18-481**

LB#2 File  
HAbelson  
EHylton  
Region I  
Goddard, OELD  
ELJordan, DEQA:IE  
JMTaylor, DRP:IE  
ACRS (16)  
B. Jagannath  
R. Jackson  
G. Lear

Mr. George Muller  
Supervisor - Licensing  
Illinois Power Company  
500 South 27th Street  
Decatur, Illinois 62525

Dear Mr. Muller:

**Subject:** Request for Further Clarification on the Soil Amplification Issue - Clinton Power Station, Units 1 and 2

**Reference:** IPC Letter U-0533, August 26, 1982 G. E. Muller to H. Bernard, NRC

The material provided with the above letter was intended to serve as verification of the method used to assess the soil amplification effects to be considered for Category I structures not founded on bedrock. As noted, the results were obtained by using the "SHAKE" program and the input parameters listed in Table 1 of Enclosure 1.

The staff has reviewed this material and has compared amplification factors obtained by using the SHAKE program (Sargent & Lundy calculations for IPC) to those factors reported in the Weston Geophysical report of May 1982, Revision 1 (Vanmarcke's calculations). Based on this review, the staff has concluded that although the SHAKE runs predict a somewhat higher amplification, there is good agreement between the predicted amplifications as a function of frequency between the two methods (Figures 1 and 2 of Enclosure 1). The annotations "upper bound" and "lower bound" in these figures pertain to the predicted range of soil properties for the Clinton site as delineated in your (IPC) letter U-0374, dated December 3, 1981, in reply to NRC's question 220.21. In your analysis, you elected to define a resultant set of amplification factors by weighting the "upper bound", "mean", and "lower bound" amplification factors by 0.25, 0.50 and 0.25 respectively. The "weighted average" amplification curve for the Weston Geophysical study is shown in Figure 1.

The staff has constructed a similar curve for the amplification factor curves obtained by using the SHAKE Program and the results show that the differences between the "weighted average" obtained by Sargent & Lundy (SHAKE) and Weston Geophysical (Vanmarcke) are negligible (Figure 3 of Enclosure 1).

OFFICE							
SUBNAME	8301140448	830112					
DATE	PDR	ADOCK	05000461				
	A		PDR				

However, the staff has noted that the "weighted average" amplification peaks are considerably lower than the peaks on the "mean soil property" amplification curve (Figure 1). In the case of the amplification factors obtained from the SHAKE program, the "weighted average" peaks fall outside (below) the range of peaks predicted by the range of soil properties (upper/lower bound) assumed for the site (Figure 2). In past safety reviews the NRC has recommended a conservative approach of enveloping the effects of soil amplification if uncertainties existed.

Therefore, we request that you discuss the resulting fluctuations in the theoretical soil design response spectrum caused by assuming a range of soil properties. Subsequently you should justify, statistically or otherwise, the use of the weighting procedure referred to earlier in this letter in light of past NRC positions. Any questions concerning this information request should be directed to Dr. Harvey Abelson, the Clinton Project Manager, at (301) 492-9774.

Sincerely,

A. Schwencer, Chief  
Licensing Branch No. 2  
Division of Licensing

Enclosures:  
As stated

cc: See next page

OFFICE	DL: B&E/PM	DL: B&E/BC					
SUBMITTED	H/Abelson:pt	ASchwencer					
DATE	1/11/83	1/12/83					

Clinton

Mr. L. J. Koch  
Vice President  
Illinois Power Company  
500 South 27th Street  
Decatur, Illinois 62525

cc: Mr. George Muller  
Supervisor - Licensing  
Illinois Power Company  
500 South 27th Street  
Decatur, Illinois 62525

Mr. Julius Geier  
Illinois Power Company  
500 South 27th Street  
Decatur, Illinois 62525

Sheldon Zabel, Esquire  
Schiff, Hardin & Walte  
7200 Sears Tower  
233 Wacker Drive  
Chicago, Illinois 60606

Dr. H. H. Livermore  
Resident Inspector  
U. S. Nuclear Regulatory Commission  
RR 3, Box 229 A  
Clinton, Illinois 61727

Mr. R. C. Heider  
Project Manager  
Sargent & Lundy Engineers  
55 East Monroe Street  
Chicago, Illinois 60603

Mr. D. L. Foreman  
Project Manager  
General Electric Company  
175 Curtner Avenue, N/C 682  
San Jose, California 95125

Reed Neuman, Esquire  
Assistant Attorney General  
500 South 2nd Street  
Springfield, Illinois 62701

Prairie Alliance  
P. O. Box 2424  
Station A  
Champaign, Illinois 61820

Philip L. Willman, Esquire  
Assistant Attorney General  
Environmental Control Division  
188 W. Randolph Street - 2315  
Chicago, Illinois 60610

Jean Foy, Esquire  
401 South Busey  
Urbana, Illinois 61801

TABLE - I DYNAMIC SOIL PROPERTIES USED FOR SSI ANALYSIS

ENCLOSURE 1

SCIL LAYER No.	LAYER DEPTH (FT)	WEIGHT DENSITY (K/FT <sup>3</sup> )	POISSON'S RATIO	UPPER BOUND SOIL		MEAN VALUE SOIL		LOWER BOUND SOIL	
				SHEAR	DAMPING	SHEAR	DAMPING	SHEAR	DAMPING
				MODULUS (K/FT <sup>2</sup> )	RATIO	MODULUS (K/FT <sup>2</sup> )	RATIO	MODULUS (K/FT <sup>2</sup> )	RATIO
1	20.0	0.132	0.40	60003.0	0.084	4547.0	0.084	3032.0	0.084
2	105.0	0.150	0.55	7000.0	0.101	5250.0	0.101	3500.0	0.101
3	10.0	0.134	0.35	5500.0	0.059	4125.0	0.059	2750.0	0.059
4	75.0	0.145	0.40	5500.0	0.089	4125.0	0.089	2750.0	0.089
5	HALF- SPACE	0.159	0.29	300000.0	0	300,000.0	0	300000.0	0

8  
15/5/13





Figure 1 - Weston Geoph. (Vanmarcke's) calculations

..... Weighted average  
(25% 25% 50%)



(cont. p. 1)

Weighted average  
25% + 25% + 50%

Figure 2 - Illinois Power Co. (Sal) calculations  
(SHAKE runs)




FIGURE 3 - "WEIGHTED AVERAGE" FOR CLINTON SOIL PROPERTIES

# Illinois Power Company

0-0630

150-82(04-05)-1

Docket No. 50-461

April 5, 1983

Director of Nuclear Reactor Regulation  
Attention: Mr. A. Schwencer, Chief  
Licensing Branch No. 1  
Division of Licensing  
U. S. Nuclear Regulatory Commission  
Washington, D.C. 20545

Dear Mr. Schwencer:

Subject: Clinton Power Station Unit #1  
Safe Shutdown Analysis

- References:
- 1) Clinton Power Station Unit #1 meeting on site (7/13/82) participants: Mr. Nick Fioravante and Illinois Power representatives.
  - 2) Clinton Power Station Unit #1 Safe Shutdown Analysis Report, I-0586 12/15/82.
  - 3) Joint telephone conversation among Mr. Nick Fioravante of NRC and Illinois Power representatives.

In accordance with conversations held with Mr. Nick Fioravante of NRC (references 1 and 3), Illinois Power is providing supplemental information to IES Safe Shutdown Analysis Report, reference (2).

Page 2: A revised Table of Contents including section 1.6, "High Pressure/Low Pressure Interface Valves" (HP/LP) is attached.

Pages 10 and 10a: The attached new section 1.6 describes the HP/LP interface valves of concern. The Clinton Plant's operation staff has agreed to develop procedures in accommodating the section 1.6 actions.




U-0630  
L-0-83(04-05)-1  
April 5, 1983  
Page 2

Page 13: A recent analysis was conducted to determine if the RCIC equipment in fire zone A.1.4 is qualified for 72 hours following a fire in zone A.1.1. That analysis was confirming and is reflected in the revised page 13 (attached).

Page 47: A footnote was added to page 47 indicating that a dedicated spool of control wire (about 1300' minimum) will be stored on site in a specific location strictly for the replacement of Division 11 control wiring in the event of a fire in zone A.4.6. The Clinton plant's maintenance staff has agreed to this action and to the development of its required procedures.

We trust that these latest revisions to our Safe Shutdown Analysis meet with NRC approval.

Sincerely,

  
G. E. Miller  
Supervisor - Licensing  
Nuclear Station Engineering

RW/lt

cc: Dr. H. Abelson, NRC Clinton Project Manager  
Mr. J. E. Stang, Jr., NRC CEB  
Mr. H. H. Livermore, NRC Resident Inspector  
Illinois Department of Nuclear Safety

## TABLE OF CONTENTS

- 1 Introduction
- 1.1 Purpose
- 1.2 Analysis Criterion
- 1.3 Evaluation Method
- 1.4 Assumptions
- 1.5 Associated Circuits
- 1.6 High Pressure/Low Pressure Interface Valves
- 2 Fire Area/Zone Shutdown Analysis
- 3 Modifications

## LIST OF TABLES

- 1 Divisional Equipment or Cable Located in Each Fire Zone
- 1.1 Systems Necessary for Safe Shutdown
- 1.2 Method #1 Mechanical Equipment List
- 1.3 Method #2 Mechanical Equipment List
- 1.4 Electrical Equipment List
- 1.5 Instrumentation List
- 1.6 Fire Areas/Zones not Containing Safe Shutdown Equipment or Cable
- 1.7 Fire Areas/Zones Containing only one Division of Safe Shutdown Equipment or Cable
- 1.8 Panel Locations

all cables are shorted out cables and will not allow significant temperature beyond the adjustment of the flow control.

1.5.6 High Pressure/Flow Pressure Interlock Valve  
There are only 4 valves that could be opened by a fire alarm in the control circuit in the event of a fire. They are:

- 1112-7002                      1112-7003                      1112-7004
- 1112-7005                      1112-7006                      1112-7007

1.5.7 Valves 1112-7005 and 1112-7006 are installed in series. In order to prevent the automatic operation of valve 1112-7005 in the event of a short, the breaker to valve 1112-7005 will be locked open.

1.5.8 To prevent a short from opening valves 1112-7002 and 3, the power to these control circuits will be controlled by a magnetic switch (Division 1 & 3) in the main control room. Each division switch will be in the OFF position as long as the RCSC system is not in the stand-by mode. When a valve (1112-7002 or 3) needs to be opened, the circuit will be activated by changing the position of the division switch and then, sequentially, the control signal for that valve will be conditioned for the desired valve motion. Because the circuit is not

1. The Government will continue  
to support the...  
2. The Government will continue  
to support the...  
3. The Government will continue  
to support the...  
4. The Government will continue  
to support the...  
5. The Government will continue  
to support the...

qualified to function for 72 hours following the loss of the RCR from (2) the RCR A.I. (3) HVAC system and in the event that will be present following a fire in some A.I. It should be noted that the parameters for equipment qualification in some A.I. are more severe for the high energy fire hazard. Therefore, even with the loss of the standby fire, cold shutdown could be achieved using the Division 1 systems.

The primary fire zones are Division 1 and 2 main areas. These areas are separated by a 1-hour fire barrier (see the Fire Protection Report figure 22-2). The fire barrier is a concrete wall/door to horizontal barrier. The Division 2 areas have been protected so that the outer side of the wall is filled with the outer side of the barrier. Therefore, in the unlikely event of a fire in this area or beyond, means of being the reactor to cold shutdown would be available. The performance goals for cold shutdown functions (Appendix B, Section 2.1) are assured by the systems listed below:

<u>Performance Goal</u>	<u>Systems Which Meet Goal</u>
1. Reactor coolant backup	RWC (Div. 1) or RCT (Div. 2)
2. Reactor pressure control	RPV (Div. 1) or APR (Div. 2)
3. Suppression pool cooling	RHR A (Div. 1) or RHR (Div. 2)
4. Process variable indication	Division 1 or 2 instrumentation for:

