

Enclosure 1

SUPPLEMENTAL ATTACHMENT TO LICENSE AMENDMENT NO. 128

TO FACILITY COMBINED LICENSE NO. NPF-91

DOCKET NO. 52-025

Replace the following page of the Facility Combined License No. NPF-91 with the attached revised page. The revised page is identified by amendment number and contains marginal lines indicating the areas of change.

Appendix C to Facility Combined License No. NPF-91

REMOVE

C-419

INSERT

C-419

**Table 3.3-1 (cont.)  
Definition of Wall Thicknesses for Nuclear Island Buildings, Turbine Building, and Annex Building<sup>(1)</sup>**

<b>Wall or Section Description</b>	<b>Column Lines<sup>(7)</sup></b>	<b>Floor Elevation or Elevation Range<sup>(7)(8)</sup></b>	<b>Concrete Thickness<sup>(2)(3)(4)(5)(9)</sup></b>	<b>Applicable Radiation Shielding Wall (Yes/No)</b>
Corridor Wall between G and H	From 9 to 13	From 117'-6" to 135'-3"	1'-6"	Yes
Column Line 9 wall	From E to H	From 117'-6" to 158'-0"	2'-0"	Yes
Floor	From 2 to 4 and E to H	135'-3"	0'-8"	Yes
Floor	From 4 to 4.1 and E to H	135'-3"	1'-0" <sup>(12)</sup>	Yes
Floor	From 9 to 13 and E to I.1	117'-6"	0'-8" <sup>(12)(13)</sup>	Yes
Floor	From 9 to 13 and E to I.1	135'-3"	0'-8" <sup>(12)</sup>	Yes
Containment Filtration Rms A and B (North Wall)	Between column line E to H	From 135'-3" to 158'-0"	1'-0"	Yes
Containment Filtration Rms A and B (East wall)	Between column line E to F	From 135'-3" to 158'-0"	1'-0"	Yes
Containment Filtration Rm A (Floor)	Between column line E to H	135'-3"	1'-0" <sup>(12)</sup>	Yes
Containment Filtration Rm B (Floor)	Between column line E to H	150'-3"	0'-8" <sup>(12)</sup>	Yes
<b>Turbine Building</b>				
Wall adjacent to Column Line I.2	From Col. Line 11.05 to 11.2	From 100'-0" to 169'-0"	3'-0"	No
Wall along Column Line 11.2	From near I.2 to near Col. Line R	From 100'-0" to 169'-0"	2'-0"	No
Wall adjacent to Column Line R	From Col. Line 11.2 to Col. Line 11.02	From 100'-0" to 169'-0"	3'-0"	No
Wall along Column Line 11.02	From near Col. Line R to near Col. Line Q	From 100'-0" to 169'-0"	2'-0"	No
Wall along Column Line 11.05	From Col. Line K.4 to near Col. Line I.2	From 100'-0" to 169'-0"	2'-0"	No