

NRR-DMPSPEm Resource

From: Valentin-Olmeda, Milton
Sent: Monday, November 5, 2018 12:22 PM
To: Diane Aitken
Subject: On the plant mod question...

Diane,

After discussing with the plant-response reviewers, we still have some questions that we are considering to submit as follow-ups. However, there might be a way to avoid them.

To do so, it might be worth considering to add the following items to the pending response for plant-modifications (the response for Question 4 on Topic #16 to be submitted on 11/16/18). Please consider the following inputs for the SPRA model run and include the final results (SCDF & SLERF importance values for the basic events in tables 5.4-2, 5.4-3, and 5.4-5 of the submittal) in your response:

- Use a FLEX DG failure rate of 10
- Use a high HEP value

Please call me if you have any questions.

Respectfully,

Milton Valentin, PM
US NRC Division of Licensing Projects
Beyond Design Basis Management (Fukushima)
Office of Nuclear Reactor Regulation
Milton.Valentin@nrc.gov
301-415-2864

Hearing Identifier: NRR_DMPS
Email Number: 801

Mail Envelope Properties (Milton.Valentin-Olmeda@nrc.gov20181105122200)

Subject: On the plant mod question...
Sent Date: 11/5/2018 12:22:08 PM
Received Date: 11/5/2018 12:22:00 PM
From: Valentin-Olmeda, Milton

Created By: Milton.Valentin-Olmeda@nrc.gov

Recipients:
"Diane Aitken" <diane.aitken@dominionenergy.com>
Tracking Status: None

Post Office:

Files	Size	Date & Time
MESSAGE	1000	11/5/2018 12:22:00 PM

Options
Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received: