

NUCLEAR REGULATORY COMMISSION

[NRC-2019-0065]

Biweekly Notice

**Applications and Amendments to Facility Operating Licenses and Combined
Licenses Involving No Significant Hazards Considerations**

AGENCY: Nuclear Regulatory Commission.

ACTION: Biweekly notice.

SUMMARY: Pursuant to the Atomic Energy Act of 1954, as amended (the Act), the U.S. Nuclear Regulatory Commission (NRC) is publishing this regular biweekly notice. The Act requires the Commission to publish notice of any amendments issued, or proposed to be issued, and grants the Commission the authority to issue and make immediately effective any amendment to an operating license or combined license, as applicable, upon a determination by the Commission that such amendment involves no significant hazards consideration, notwithstanding the pendency before the Commission of a request for a hearing from any person.

This biweekly notice includes all notices of amendments issued, or proposed to be issued, from February 12, 2019 to February 25, 2019. The last biweekly notice was published on February 26, 2019.

DATES: Comments must be filed by April 11, 2019. A request for a hearing must be filed by May 13, 2019. Comments received after this date will be considered if it is practical to do so, but the Commission is able to ensure consideration only for comments received before this date.

ADDRESSES: You may submit comments by any of the following methods:

- **Federal Rulemaking Web Site:** Go to <http://www.regulations.gov> and search for Docket ID **NRC-2019-0065**. Address questions about NRC Docket IDs in Regulations.gov to Krupskaya Castellon; telephone: 301-287-9221; e-mail: Krupskaya.Castellon@nrc.gov. For technical questions, contact the individual listed in the **FOR FURTHER INFORMATION CONTACT** section of this document.

- **Mail comments to:** Office of Administration, Mail Stop: TWFN-7-A60M, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001, ATTN: Program Management, Announcements and Editing Staff.

- For additional direction on obtaining information and submitting comments, see “Obtaining Information and Submitting Comments” in the **SUPPLEMENTARY INFORMATION** section of this document.

FOR FURTHER INFORMATION CONTACT: Kay Goldstein, Office of Nuclear Reactor Regulation, U.S. Nuclear Regulatory Commission, Washington DC 20555-0001; telephone: 301-415-1506, e-mail: Kay.Goldstein@nrc.gov.

SUPPLEMENTARY INFORMATION:

I. Obtaining Information and Submitting Comments

A. Obtaining Information

Please refer to Docket ID **NRC-2019-0065**, facility name, unit number(s), plant docket number, application date, and subject when contacting the NRC about the availability of information for this action. You may obtain publicly-available information related to this action by any of the following methods:

- **Federal Rulemaking Web Site:** Go to <http://www.regulations.gov> and search for Docket ID **NRC-2019-0065**.

- **NRC’s Agencywide Documents Access and Management System (ADAMS):** You may obtain publicly-available documents online in the ADAMS Public

Documents collection at <http://www.nrc.gov/reading-rm/adams.html>. To begin the search, select "[Begin Web-based ADAMS Search](#)." For problems with ADAMS, please contact the NRC's Public Document Room (PDR) reference staff at 1-800-397-4209, 301-415-4737, or by e-mail to pdr.resource@nrc.gov. The ADAMS accession number for each document referenced (if it is available in ADAMS) is provided the first time that it is mentioned in this document.

- **NRC's PDR:** You may examine and purchase copies of public documents at the NRC's PDR, Room O1-F21, One White Flint North, 11555 Rockville Pike, Rockville, Maryland 20852.

B. Submitting Comments

Please include Docket ID **NRC-2019-0065**, facility name, unit number(s), plant docket number, application date, and subject in your comment submission.

The NRC cautions you not to include identifying or contact information that you do not want to be publicly disclosed in your comment submission. The NRC will post all comment submissions at <http://www.regulations.gov> as well as enter the comment submissions into ADAMS. The NRC does not routinely edit comment submissions to remove identifying or contact information.

If you are requesting or aggregating comments from other persons for submission to the NRC, then you should inform those persons not to include identifying or contact information that they do not want to be publicly disclosed in their comment submission. Your request should state that the NRC does not routinely edit comment submissions to remove such information before making the comment submissions available to the public or entering the comment into ADAMS.

II. Background

Pursuant to Section 189a.(2) of the Atomic Energy Act of 1954, as amended (the Act), the U.S. Nuclear Regulatory Commission (NRC) is publishing this regular biweekly

notice. The Act requires the Commission to publish notice of any amendments issued, or proposed to be issued, and grants the Commission the authority to issue and make immediately effective any amendment to an operating license or combined license, as applicable, upon a determination by the Commission that such amendment involves no significant hazards consideration, notwithstanding the pendency before the Commission of a request for a hearing from any person.

**III. Notice of Consideration of Issuance of Amendments to Facility
Operating Licenses and Combined Licenses and Proposed No
Significant Hazards Consideration Determination**

The Commission has made a proposed determination that the following amendment requests involve no significant hazards consideration. Under the Commission's regulations in § 50.92 of title 10 of the *Code of Federal Regulations* (10 CFR), this means that operation of the facility in accordance with the proposed amendment would not (1) involve a significant increase in the probability or consequences of an accident previously evaluated; or (2) create the possibility of a new or different kind of accident from any accident previously evaluated; or (3) involve a significant reduction in a margin of safety. The basis for this proposed determination for each amendment request is shown below.

The Commission is seeking public comments on this proposed determination. Any comments received within 30 days after the date of publication of this notice will be considered in making any final determination.

Normally, the Commission will not issue the amendment until the expiration of 60 days after the date of publication of this notice. The Commission may issue the license amendment before expiration of the 60-day period provided that its final determination is that the amendment involves no significant hazards consideration. In addition, the Commission may issue the amendment prior to the expiration of the 30-day comment

period if circumstances change during the 30-day comment period such that failure to act in a timely way would result, for example in derating or shutdown of the facility. If the Commission takes action prior to the expiration of either the comment period or the notice period, it will publish in the *Federal Register* a notice of issuance. If the Commission makes a final no significant hazards consideration determination, any hearing will take place after issuance. The Commission expects that the need to take this action will occur very infrequently.

A. Opportunity to Request a Hearing and Petition for Leave to Intervene

Within 60 days after the date of publication of this notice, any persons (petitioner) whose interest may be affected by this action may file a request for a hearing and petition for leave to intervene (petition) with respect to the action. Petitions shall be filed in accordance with the Commission's "Agency Rules of Practice and Procedure" in 10 CFR part 2. Interested persons should consult a current copy of 10 CFR 2.309. The NRC's regulations are accessible electronically from the NRC Library on the NRC's Web site at <http://www.nrc.gov/reading-rm/doc-collections/cfr/>. Alternatively, a copy of the regulations is available at the NRC's Public Document Room, located at One White Flint North, Room O1-F21, 11555 Rockville Pike (first floor), Rockville, Maryland 20852. If a petition is filed, the Commission or a presiding officer will rule on the petition and, if appropriate, a notice of a hearing will be issued.

As required by 10 CFR 2.309(d) the petition should specifically explain the reasons why intervention should be permitted with particular reference to the following general requirements for standing: (1) the name, address, and telephone number of the petitioner; (2) the nature of the petitioner's right under the Act to be made a party to the proceeding; (3) the nature and extent of the petitioner's property, financial, or other interest in the proceeding; and (4) the possible effect of any decision or order which may be entered in the proceeding on the petitioner's interest.

In accordance with 10 CFR 2.309(f), the petition must also set forth the specific contentions which the petitioner seeks to have litigated in the proceeding. Each contention must consist of a specific statement of the issue of law or fact to be raised or controverted. In addition, the petitioner must provide a brief explanation of the bases for the contention and a concise statement of the alleged facts or expert opinion which support the contention and on which the petitioner intends to rely in proving the contention at the hearing. The petitioner must also provide references to the specific sources and documents on which the petitioner intends to rely to support its position on the issue. The petition must include sufficient information to show that a genuine dispute exists with the applicant or licensee on a material issue of law or fact. Contentions must be limited to matters within the scope of the proceeding. The contention must be one which, if proven, would entitle the petitioner to relief. A petitioner who fails to satisfy the requirements at 10 CFR 2.309(f) with respect to at least one contention will not be permitted to participate as a party.

Those permitted to intervene become parties to the proceeding, subject to any limitations in the order granting leave to intervene. Parties have the opportunity to participate fully in the conduct of the hearing with respect to resolution of that party's admitted contentions, including the opportunity to present evidence, consistent with the NRC's regulations, policies, and procedures.

Petitions must be filed no later than 60 days from the date of publication of this notice. Petitions and motions for leave to file new or amended contentions that are filed after the deadline will not be entertained absent a determination by the presiding officer that the filing demonstrates good cause by satisfying the three factors in 10 CFR 2.309(c)(1)(i) through (iii). The petition must be filed in accordance with the filing instructions in the "Electronic Submissions (E-Filing)" section of this document.

If a hearing is requested, and the Commission has not made a final determination on the issue of no significant hazards consideration, the Commission will make a final determination on the issue of no significant hazards consideration. The final determination will serve to establish when the hearing is held. If the final determination is that the amendment request involves no significant hazards consideration, the Commission may issue the amendment and make it immediately effective, notwithstanding the request for a hearing. Any hearing would take place after issuance of the amendment. If the final determination is that the amendment request involves a significant hazards consideration, then any hearing held would take place before the issuance of the amendment unless the Commission finds an imminent danger to the health or safety of the public, in which case it will issue an appropriate order or rule under 10 CFR part 2.

A State, local governmental body, Federally-recognized Indian Tribe, or agency thereof, may submit a petition to the Commission to participate as a party under 10 CFR 2.309(h)(1). The petition should state the nature and extent of the petitioner's interest in the proceeding. The petition should be submitted to the Commission no later than 60 days from the date of publication of this notice. The petition must be filed in accordance with the filing instructions in the "Electronic Submissions (E-Filing)" section of this document, and should meet the requirements for petitions set forth in this section, except that under 10 CFR 2.309(h)(2) a State, local governmental body, or Federally-recognized Indian Tribe, or agency thereof does not need to address the standing requirements in 10 CFR 2.309(d) if the facility is located within its boundaries. Alternatively, a State, local governmental body, Federally-recognized Indian Tribe, or agency thereof may participate as a non-party under 10 CFR 2.315(c).

If a hearing is granted, any person who is not a party to the proceeding and is not affiliated with or represented by a party may, at the discretion of the presiding officer, be

permitted to make a limited appearance pursuant to the provisions of 10 CFR 2.315(a). A person making a limited appearance may make an oral or written statement of his or her position on the issues but may not otherwise participate in the proceeding. A limited appearance may be made at any session of the hearing or at any prehearing conference, subject to the limits and conditions as may be imposed by the presiding officer. Details regarding the opportunity to make a limited appearance will be provided by the presiding officer if such sessions are scheduled.

B. Electronic Submissions (E-Filing)

All documents filed in NRC adjudicatory proceedings, including a request for hearing and petition for leave to intervene (petition), any motion or other document filed in the proceeding prior to the submission of a request for hearing or petition to intervene, and documents filed by interested governmental entities that request to participate under 10 CFR 2.315(c), must be filed in accordance with the NRC's E-Filing rule (72 FR 49139; August 28, 2007, as amended at 77 FR 46562; August 3, 2012). The E-Filing process requires participants to submit and serve all adjudicatory documents over the internet, or in some cases to mail copies on electronic storage media. Detailed guidance on making electronic submissions may be found in the Guidance for Electronic Submissions to the NRC and on the NRC Web site at <http://www.nrc.gov/site-help/e-submittals.html>. Participants may not submit paper copies of their filings unless they seek an exemption in accordance with the procedures described below.

To comply with the procedural requirements of E-Filing, at least 10 days prior to the filing deadline, the participant should contact the Office of the Secretary by e-mail at hearing.docket@nrc.gov, or by telephone at 301-415-1677, to (1) request a digital identification (ID) certificate, which allows the participant (or its counsel or representative) to digitally sign submissions and access the E-Filing system for any proceeding in which it is participating; and (2) advise the Secretary that the participant

will be submitting a petition or other adjudicatory document (even in instances in which the participant, or its counsel or representative, already holds an NRC-issued digital ID certificate). Based upon this information, the Secretary will establish an electronic docket for the hearing in this proceeding if the Secretary has not already established an electronic docket.

Information about applying for a digital ID certificate is available on the NRC's public Web site at <http://www.nrc.gov/site-help/e-submittals/getting-started.html>. Once a participant has obtained a digital ID certificate and a docket has been created, the participant can then submit adjudicatory documents. Submissions must be in Portable Document Format (PDF). Additional guidance on PDF submissions is available on the NRC's public Web site at <http://www.nrc.gov/site-help/electronic-sub-ref-mat.html>. A filing is considered complete at the time the document is submitted through the NRC's E-Filing system. To be timely, an electronic filing must be submitted to the E-Filing system no later than 11:59 p.m. Eastern Time on the due date. Upon receipt of a transmission, the E-Filing system time-stamps the document and sends the submitter an e-mail notice confirming receipt of the document. The E-Filing system also distributes an e-mail notice that provides access to the document to the NRC's Office of the General Counsel and any others who have advised the Office of the Secretary that they wish to participate in the proceeding, so that the filer need not serve the document on those participants separately. Therefore, applicants and other participants (or their counsel or representative) must apply for and receive a digital ID certificate before adjudicatory documents are filed so that they can obtain access to the documents via the E-Filing system.

A person filing electronically using the NRC's adjudicatory E-Filing system may seek assistance by contacting the NRC's Electronic Filing Help Desk through the "Contact Us" link located on the NRC's public Web site at <http://www.nrc.gov/site-help/e->

[submittals.html](#), by e-mail to MSHD.Resource@nrc.gov, or by a toll-free call at 1-866-672-7640. The NRC Electronic Filing Help Desk is available between 9 a.m. and 6 p.m., Eastern Time, Monday through Friday, excluding government holidays.

Participants who believe that they have a good cause for not submitting documents electronically must file an exemption request, in accordance with 10 CFR 2.302(g), with their initial paper filing stating why there is good cause for not filing electronically and requesting authorization to continue to submit documents in paper format. Such filings must be submitted by: (1) first class mail addressed to the Office of the Secretary of the Commission, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001, Attention: Rulemaking and Adjudications Staff; or (2) courier, express mail, or expedited delivery service to the Office of the Secretary, 11555 Rockville Pike, Rockville, Maryland 20852, Attention: Rulemaking and Adjudications Staff. Participants filing adjudicatory documents in this manner are responsible for serving the document on all other participants. Filing is considered complete by first-class mail as of the time of deposit in the mail, or by courier, express mail, or expedited delivery service upon depositing the document with the provider of the service. A presiding officer, having granted an exemption request from using E-Filing, may require a participant or party to use E-Filing if the presiding officer subsequently determines that the reason for granting the exemption from use of E-Filing no longer exists.

Documents submitted in adjudicatory proceedings will appear in the NRC's electronic hearing docket which is available to the public at <https://adams.nrc.gov/ehd>, unless excluded pursuant to an order of the Commission or the presiding officer. If you do not have an NRC-issued digital ID certificate as described above, click "Cancel" when the link requests certificates and you will be automatically directed to the NRC's electronic hearing dockets where you will be able to access any publicly available documents in a particular hearing docket. Participants are requested not to include

personal privacy information, such as social security numbers, home addresses, or personal phone numbers in their filings, unless an NRC regulation or other law requires submission of such information. For example, in some instances, individuals provide home addresses in order to demonstrate proximity to a facility or site. With respect to copyrighted works, except for limited excerpts that serve the purpose of the adjudicatory filings and would constitute a Fair Use application, participants are requested not to include copyrighted materials in their submission.

For further details with respect to these license amendment applications, see the application for amendment which is available for public inspection in ADAMS and at the NRC's PDR. For additional direction on accessing information related to this document, see the "Obtaining Information and Submitting Comments" section of this document.

Entergy Operations, Inc., Docket No. 50-368, Arkansas Nuclear One, Unit 2 (ANO-2), Pope County, Arkansas

Date of amendment request: December 19, 2018. A publicly-available version is in ADAMS under Accession No. ML18353B049.

Description of amendment request: The amendment would revise the ANO-2 Technical Specifications by establishing Actions and Allowable Outage Times applicable to conditions where the ANO-2 containment building sump is inoperable. The proposed changes are intended to support the licensee's resolution of Generic Safety Issue (GSI)-191, "Assessment of Debris Accumulation on PWR [Pressurized-Water Reactor] Sump Performance."

Basis for proposed no significant hazards consideration determination: As required by 10 CFR 50.91(a), the licensee has provided its analysis of the issue of no significant hazards consideration, which is presented below:

1. Does the proposed change involve a significant increase in the probability or consequences of an accident previously evaluated?

Response: No.

The proposed change adds a new specification to the TS for the containment sump. An existing SR [surveillance requirement] on the containment sump is moved to the new specification. The new specification retains the existing requirements on the containment sump and the actions to be taken when the containment sump is inoperable with the exception of adding new actions to be taken when the containment sump is inoperable due to containment accident generated and transported debris exceeding the analyzed limits. The new action provides time to evaluate and correct the condition instead of requiring an immediate plant shutdown.

The containment sump is not an initiator of any accident previously evaluated. The containment sump is a passive component and the proposed change does not increase the likelihood of the malfunction. As a result, the probability of an accident is unaffected by the proposed change.

The containment sump is used to mitigate accidents previously evaluated by providing a borated water source for the Emergency Core Cooling System and Containment Spray System. The design of the containment sump and the capability of the containment sump assumed in the accident analysis are not changed. The proposed action requires implementation of mitigating actions while the containment sump is inoperable and more frequent monitoring of reactor coolant leakage to detect any increased potential for an accident that would require the containment sump. The consequences of an accident during the proposed action are no different than the current consequences of an accident if the containment sump is inoperable.

Therefore, the proposed change does not involve a significant increase in the probability or consequences of an accident previously evaluated.

2. Does the proposed change create the possibility of a new or different kind of accident from any accident previously evaluated?

Response: No.

The proposed change adds a new specification to the TS for the containment sump. An existing SR on the containment sump is moved to the new specification. The new specification retains the existing requirements on the containment sump and the actions to be taken when the containment sump is inoperable with the exception of adding new actions to be taken when the

containment sump is inoperable due to containment accident generated and transported debris exceeding the analyzed limits. The new action provides time to evaluate and correct the condition instead of requiring an immediate plant shutdown.

The proposed change does not alter the design or design function of the containment sump or the plant. No new systems are installed or removed as part of the proposed change. The containment sump is a passive component and cannot initiate a malfunction or accident. No new credible accident is created that is not encompassed by the existing accident analyses that assume the function of the containment sump.

Therefore, the proposed change does not create the possibility of a new or different kind of accident from an accident previously evaluated.

3. Does the proposed change involve a significant reduction in a margin of safety?

Response: No.

The proposed change adds a new specification to the TS for the containment sump. An existing SR on the containment sump is moved to the new specification. The new specification retains the existing requirements on the containment sump and the actions to be taken when the containment sump is inoperable with the exception of adding new actions to be taken when the containment sump is inoperable due to containment accident generated and transported debris exceeding the analyzed limits. The new action provides time to evaluate and correct the condition instead of requiring an immediate plant shutdown.

The proposed change does not affect the controlling values of parameters used to avoid exceeding regulatory or licensing limits. No Safety Limits are affected by the proposed change. The proposed change does not affect any assumptions in the accident analyses that demonstrate compliance with regulatory and licensing requirements.

Therefore, the proposed change does not involve a significant reduction in a margin of safety.

The NRC staff has reviewed the licensee's analysis and, based on this review, it appears that the three standards of 10 CFR 50.92(c) are satisfied. Therefore, the NRC staff proposes to determine that the amendment request involves no significant hazards consideration.

Attorney for licensee: Anna Vinson Jones, Senior Counsel, Entergy Services, Inc., 101 Constitution Avenue, NW, Suite 200 East, L-ENT-WDC, Washington, DC 20001.

NRC Branch Chief: Robert J. Pascarelli.

Entergy Operations, Inc., System Energy Resources, Inc., Cooperative Energy, A Mississippi Electric Cooperative, and Entergy Mississippi, LLC, Docket No. 50-416,

Grand Gulf Nuclear Station, Unit 1, Claiborne County, Mississippi

Date of amendment request: January 23, 2019. A publicly-available version is in ADAMS under Accession No. ML19023A555.

Description of amendment request: The proposed amendment revises Technical Specification (TS) Table 3.3.1.1-1, "Reactor Protection System Instrumentation," Function 9, "Turbine Stop Valve Closure, Trip Oil Pressure - Low," and Function 10, "Turbine Control Valve Fast Closure, Trip Oil Pressure - Low," and TS 3.3.4.1, "End of Cycle Recirculation Pump Trip (EOC-RPT) Instrumentation," Surveillance Requirement (SR) 3.3.4.1.2 and SR 3.3.4.1.3. The proposed change revises the Allowable Value (AV) for the Turbine Stop Valve Closure Trip Oil Pressure Function and Turbine Control Valve Fast Closure Trip Oil Pressure Function. Additionally, the proposed amendment adds new Notes to assess channel performance during testing that verifies instrument channel setting values established by the Entergy setpoint methodology.

Basis for proposed no significant hazards consideration determination: As required by 10 CFR 50.91(a), the licensee has provided its analysis of the issue of no significant hazards consideration, which is presented below:

1. Does the proposed amendment involve a significant increase in the probability or consequences of an accident previously evaluated?

Response: No.

The proposed change to the TS is due to the replacement of the pressure transmitters that sense Electrohydraulic Control (EHC) System pressure and provide signals to the Reactor Protection System (RPS). The turbine control valve fast closure signal is monitored by the turbine control fluid pressure transmitters and trip units which sense control fluid pressure decay which is indicative of fast control valve closure. The turbine stop valve closure signal originates from pressure transmitters and trip units which sense hydraulic trip fluid pressure decay which is indicative of stop valve motion away from fully open.

A change in the turbine stop valve closure trip oil pressure and turbine control valve fast closure trip oil pressure TS AVs does not introduce any mechanisms that would increase the probability of an accident previously analyzed. The reactor trip on turbine stop valve closure or turbine control valve fast closure is initiated by the same protective signals. There is no change in form or function of this signal and the probability or consequences of previously analyzed accidents are not impacted.

The proposed change also adds test requirements to the turbine stop valve closure trip oil pressure and turbine control valve fast closure trip oil pressure instrument functions related to those variables to ensure that instruments will function as required to initiate protective systems or actuate mitigating systems at the point assumed in the applicable setpoint calculation. Surveillance tests are not an initiator to any accident previously evaluated. As a result, the probability of any accident previously evaluated is not significantly increased. The systems and components required by these functions for which surveillance tests are added are still required to be operable, meet the acceptance criteria for the surveillance requirements, and be capable of performing any mitigation function.

The capacity and the characteristics of both the original and replacement equipment meet the original plant design criteria. The proposed TS changes will not prevent the capability of structures, systems, and components (SSCs) to perform their intended functions for mitigating the consequences of an accident and meeting applicable acceptance limits.

Therefore, the proposed change does not involve a significant increase in the probability or consequences of an accident previously evaluated.

2. Does the proposed amendment create the possibility of a new or different kind of accident from any accident previously evaluated?

Response: No.

The proposed change involves a physical alteration of the plant, i.e., a change in instrument setpoint. The proposed change reflects the higher pressure that will be sensed after the replacement of the pressure transmitters with changing of the EHC System from a low pressure system to a high pressure system. Failure of the new pressure transmitters would not result in a different outcome than is considered in the current design basis. The new hardware (e.g., components, equipment, structure, etc.) serves (provides) the same purpose (e.g., function, integrity, etc.) as the hardware it replaces. Further, the change does not alter assumptions made in the safety analysis but ensures that the instruments perform as assumed in the accident analysis.

Thus, the proposed amendment does not create the possibility of a new or different kind of accident from an accident previously evaluated.

3. Does the proposed amendment involve a significant reduction in a margin of safety?

Response: No.

The original pressure transmitter configuration and the new pressure transmitter configuration both generate the same reactor trip signal. The difference is that the initiation of the trip will now be adjusted to a system of higher pressure. This system function of sensing and transmitting a reactor trip signal on turbine stop valve closure or turbine control valve fast closure remains the same. Also, the proposed change adds test requirements that will assure that TS instrumentation AVs: (1) will be limiting settings for assessing instrument channel operability and; (2) will be conservatively determined so that evaluation of instrument performance history and the as-left tolerance requirements of the calibration procedures will not have an adverse effect on equipment operability. The testing methods and acceptance criteria for systems, structures, and components, specified in applicable codes and standards, or alternatives approved for use by the NRC, will continue to be met as described in the plant licensing basis including the Updated Final Safety Analysis Report. The safety function of the setpoint is not altered as a result of the setpoint change and uncertainties are adequately accounted for.

There will be no adverse effect on margins of safety since equal or more stringent design and surveillance requirements will be applied to the new component (e.g., equipment, system, etc.).

Therefore, the proposed amendment does not involve a significant reduction in a margin of safety

The NRC staff has reviewed the licensee's analysis and, based on this review, it appears that the three standards of 10 CFR 50.92(c) are satisfied. Therefore, the NRC staff proposes to determine that the amendment request involves no significant hazards consideration.

Attorney for licensee: Anna Vinson Jones, Senior Counsel/Legal Department, Entergy Services, Inc., 101 Constitution Avenue, NW, Suite 200 East, Washington, DC 20001.

NRC Branch Chief: Robert J. Pascarelli.

FirstEnergy Nuclear Operating Company, et al., Docket No. 50-346, Davis-Besse Nuclear Power Station, Unit No. 1 (DBNPS), Ottawa County, Ohio

Date of amendment request: February 5, 2019. A publicly-available version is in ADAMS under Accession No. ML19036A524.

Description of amendment request: The proposed amendment would revise the emergency plan for DBNPS following the permanent cessation of power operations to reflect the post-shutdown and permanently defueled condition. The proposed changes include revision of the emergency response organization (ERO) staffing and editorial changes.

Basis for proposed no significant hazards consideration determination: As required by 10 CFR 50.91(a), the licensee has provided its analysis of the issue of no significant hazards consideration, which is presented below:

1. Does the proposed amendment involve a significant increase in the probability or consequences of an accident previously evaluated?

Response: No.

The proposed changes to the DBNPS Emergency Plan do not impact the function of plant structures, systems, or components (SSCs). The proposed changes do not involve the modification of any plant equipment or affect plant operation. The proposed changes do not affect accident initiators or precursors, nor does it alter design assumptions. The proposed changes do not prevent the ability of the on-shift staff and

augmented ERO to perform their intended functions to mitigate the consequences of any accident or event that will be credible in the permanently shutdown and defueled condition. The proposed changes only remove positions that will no longer be credited in the DBNPS Emergency Plan.

Therefore, the proposed amendment does not involve a significant increase in the probability or consequences of an accident previously evaluated.

2. Does the proposed amendment create the possibility of a new or different kind of accident from any accident previously evaluated?

Response: No.

The proposed changes reduce the number of on-shift and augmented ERO positions commensurate with the hazards associated with a permanently shutdown and defueled facility. The proposed changes do not involve installation of new equipment or modification of existing equipment, so that no new equipment failure modes are introduced. Also, the proposed changes do not result in a change to the way that the equipment or facility is operated so that no new accident initiators are created.

Therefore, the proposed amendment does not create the possibility of a new or different kind of accident from any previously evaluated.

3. Does the proposed amendment involve a significant reduction in a margin of safety?

Response: No.

Margin of safety is associated with confidence in the ability of the fission product barriers (fuel cladding, reactor coolant system pressure boundary, and containment structure) to limit the level of radiation dose to the public. The proposed changes do not adversely affect existing plant safety analysis assumptions, safety limits, or limiting safety system settings that would adversely affect plant safety as a result of the proposed changes. The proposed changes are associated with the DBNPS Emergency Plan and do not impact operation of the plant or its response to transients or accidents. The change does not affect the Technical Specifications. The proposed changes do not involve a change in the method of plant operation, and no accident analyses will be affected by the proposed changes. Safety analysis acceptance criteria are not affected by the proposed changes. The revised DBNPS Emergency Plan will continue to provide the necessary response staff with the proposed changes.

Therefore, the proposed amendment does not involve a significant reduction in a margin of safety.

The NRC staff has reviewed the licensee's analysis and, based on this review, it appears that the three standards of 10 CFR 50.92(c) are satisfied. Therefore, the NRC staff proposes to determine that the amendment request involves no significant hazards consideration.

Attorney for licensee: Rick Giannantonio, General Counsel, FirstEnergy Corporation, Mail Stop A-GO-15, 76 South Main Street, Akron, OH 44308.

NRC Branch Chief: David J. Wrona.

Southern Nuclear Operating Company, Inc., Docket Nos. 50-424 and 50-425, Vogtle Electric Generating Plant, Units 1 and 2, Burke County, Georgia

Date of amendment request: December 19, 2018. A publicly-available version is in ADAMS under Accession No. ML18353B056.

Description of amendment request: The amendments would revise the Conditions, Required Actions, and Completion Times in the Technical Specifications (TSs) for the Condition where one steam supply to the turbine driven Auxiliary Feedwater (AFW) pump is inoperable concurrent with an inoperable motor driven AFW train. In addition, the amendments would change the TSs to establish specific Actions: (1) for when two motor-driven AFW trains are inoperable at the same time, and (2) for when the turbine-driven AFW train is inoperable either (a) due solely to one inoperable steam supply, or (b) due to reasons other than one inoperable steam supply. The proposed amendments are consistent with NRC-approved Technical Specification Task Force (TSTF) Traveler, TSTF-412, Revision 3, "Provide Actions for One Steam Supply to Turbine Driven AFW/EFW Pump Inoperable." The availability of the TSTF was announced in the *Federal Register* on July 17, 2007 as part of the consolidated line item improvement process.

Basis for proposed no significant hazards consideration determination: As required by 10 CFR 50.91(a), the licensee has provided its analysis of the issue of no significant hazards consideration, which is presented below:

1. Does the proposed change involve a significant increase in the probability or consequences of any accident previously evaluated?

Response: No

The Auxiliary/Emergency Feedwater (AFW/EFW) System is not an initiator of any design basis accident or event, and therefore the proposed changes do not increase the probability of any accident previously evaluated. The proposed changes to address the condition of one or two motor driven AFW/EFW trains inoperable and the turbine driven AFW/EFW train inoperable due to one steam supply inoperable do not change the response of the plant to any accidents.

The proposed changes do not adversely affect accident initiators or precursors nor alter the design assumptions, conditions, and configuration of the facility or the manner in which the plant is operated and maintained. The proposed changes do not adversely affect the ability of structures, systems, and components (SSCs) to perform their intended safety function to mitigate the consequences of an initiating event within the assumed acceptance limits. The proposed changes do not affect the source term, containment isolation, or radiological release assumptions used in evaluating the radiological consequences of any accident previously evaluated. Further, the proposed changes do not increase the types and amounts of radioactive effluent that may be released offsite, nor significantly increase individual or cumulative occupational/public radiation exposures.

Therefore, the changes do not involve a significant increase in the probability or consequences of any accident previously evaluated.

2. Does the proposed change create the possibility of a new or different kind of accident from any accident previously evaluated?

Response: No

The proposed changes do not result in a change in the manner in which the AFW/EFW System provides plant protection. The AFW/EFW System will continue to supply water to the steam generators to remove decay heat and other residual heat by delivering at least the minimum required flow rate to the steam generators. There are no design changes associated with the proposed changes. The changes to the Conditions and Required Actions do not change any existing accident scenarios, nor create any new or different accident scenarios. The changes do not involve a physical alteration of the plant (*i.e.*, no new or different type of equipment will be installed) or a change in the methods governing normal

plant operation. In addition, the changes do not impose any new or different requirements or eliminate any existing requirements.

The changes do not alter assumptions made in the safety analysis. The proposed changes are consistent with the safety analysis assumptions and current plant operating practice.

Therefore, the changes do not create the possibility of a new or different kind of accident from any accident previously evaluated.

3. Does the proposed change involve a significant reduction in a margin of safety?

Response: No

The proposed changes do not alter the manner in which safety limits, limiting safety system settings or limiting conditions for operation are determined.

The safety analysis acceptance criteria are not impacted by these changes. The proposed changes will not result in plant operation in a configuration outside the design basis.

Therefore, it is concluded that the proposed change does not involve a significant reduction in a margin of safety.

The NRC staff has reviewed the licensee's analysis and, based on this review, it appears that the three standards of 10 CFR 50.92(c) are satisfied. Therefore, the NRC staff proposes to determine that the amendment request involves no significant hazards consideration.

Attorney for licensee: Millicent Ronnlund, Vice President and General Counsel,
Southern Nuclear Operating Co., Inc., P. O. Box 1295, Birmingham, AL 35201-1295.

NRC Branch Chief: Michael T. Markley.

IV. Previously Published Notices of Consideration of Issuance of Amendments to Facility Operating Licenses and Combined Licenses, Proposed No Significant Hazards Consideration Determination, and Opportunity for a Hearing

The following notices were previously published as separate individual notices. The notice content was the same as above. They were published as individual notices either because time did not allow the Commission to wait for this biweekly notice or because the action involved exigent circumstances. They are repeated here because the biweekly notice lists all amendments issued or proposed to be issued involving no significant hazards consideration.

For details, see the individual notice in the *Federal Register* on the day and page cited. This notice does not extend the notice period of the original notice.

V. Notice of Issuance of Amendments to Facility Operating Licenses and Combined Licenses

During the period since publication of the last biweekly notice, the Commission has issued the following amendments. The Commission has determined for each of these amendments that the application complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations. The Commission has made appropriate findings as required by the Act and the Commission's rules and regulations in 10 CFR chapter I, which are set forth in the license amendment.

A notice of consideration of issuance of amendment to facility operating license or combined license, as applicable, proposed no significant hazards consideration determination, and opportunity for a hearing in connection with these actions, was published in the *Federal Register* as indicated.

Unless otherwise indicated, the Commission has determined that these amendments satisfy the criteria for categorical exclusion in accordance with 10 CFR 51.22. Therefore, pursuant to 10 CFR 51.22(b), no environmental impact statement or environmental assessment need be prepared for these amendments. If the Commission has prepared an environmental assessment under the special circumstances provision in 10 CFR 51.22(b) and has made a determination based on that assessment, it is so indicated.

For further details with respect to the action see (1) the applications for amendment, (2) the amendment, and (3) the Commission's related letter, Safety Evaluation and/or Environmental Assessment as indicated. All of these items can be accessed as described in the "Obtaining Information and Submitting Comments" section of this document.

Entergy Operations, Inc., Docket No. 50-382, Waterford Steam Electric Station, Unit 3 (Waterford 3), St. Charles Parish, Louisiana

Date of amendment request: March 8, 2018, as supplemented by letter dated October 18, 2018.

Brief description of amendment: The amendment updated Section 15.4.3.1 of the Updated Final Safety Analysis Report for Waterford 3, which describes the dose consequence of the worst undetectable single fuel assembly misload. The updated analysis would reflect the use of Next Generation Fuel and integrated fuel burnable absorbers.

Date of issuance: February 13, 2019.

Effective date: As of the date of issuance and shall be implemented before the Waterford 3 restart following Refueling Outage 22.

Amendment No.: 253. A publicly-available version is in ADAMS under Accession No. ML19022A337; documents related to this amendment are listed in the Safety Evaluation enclosed with the amendment.

Renewed Facility Operating License No. NPF-38: The amendment revised the Updated Final Safety Analysis Report.

Date of initial notice in *Federal Register*: June 19, 2018 (83 FR 28459). The supplement dated October 18, 2018, provided additional information that clarified the application, did not expand the scope of the application as originally noticed, and did not change the NRC staff's original proposed no significant hazards consideration determination as published in the *Federal Register*.

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated February 13, 2019.

No significant hazards consideration comments received: No.

Exelon Generation Company, LLC, Docket Nos. 50-373 and 50-374, LaSalle County Station (LSCS), Units 1 and 2, LaSalle County, Illinois

Date of amendment request: February 7, 2018.

Brief description of amendment: LSCS Surveillance Requirement (SR) 3.6.1.3.8 associated with Technical Specifications (TS) 3.6 1.3, "Primary Containment Isolation Valves (PCIVs)," currently requires testing of each excess flow check valve (EFCV) during each refueling outage. The amendments implemented Technical Specification Task Force (TSTF)-334, Revision 2, "Relaxed Surveillance Frequency for Excess Flow Check Valve Testing," by revising the number of EFCVs required to be tested by SR 3.6.1.3.8 from "each" to a "representative sample." The representative sample is approximately 20 percent of the reactor instrumentation line EFCVs such that each EFCV will be tested at least once every 10 years (nominal).

Date of issuance: February 14, 2019.

Effective date: As of the date of issuance and shall be implemented within 45 days of issuance.

Amendment No.: Unit 1 -235; Unit 2 - 221. A publicly-available version is in ADAMS under Accession No. ML19025A288; documents related to these amendments are listed in the Safety Evaluation enclosed with the amendments.

Renewed Facility Operating License Nos. NPF-11 and NPF-18: The amendments revised the Renewed Facility Operating Licenses and Technical Specifications.

Date of initial notice in *Federal Register*: April 10, 2018 (83 FR 15415).

The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated February 14, 2019.

No significant hazards consideration comments received: No.

FirstEnergy Nuclear Operating Company, Docket No. 50-440, Perry Nuclear Power Plant, Unit No. 1, Lake County, Ohio

Date of amendment request: March 7, 2018, as supplemented by letter dated October 26, 2018.

Brief description of amendment: The amendment revised Technical Specification 5.5.12 to replace the reference to Regulatory Guide 1.163, "Performance-Based Containment Leak-Test Program," with a reference to Nuclear Energy Institute (NEI) 94-01, Revision 3-A, "Industry Guideline for Implementing Performance-Based Option of 10 CFR Part 50, Appendix J," and the conditions and limitations specified in NEI 94-01, Revision 2-A, of the same name, and deleted two of the four listed exceptions to program guidelines in TS 5.5.12.

Date of issuance: February 25, 2019.

Effective date: As of the date of issuance and shall be implemented within 30 days of issuance.

Amendment No.: 185. A publicly-available version is in ADAMS under Accession No. ML19022A324; documents related to this amendment are listed in the Safety Evaluation enclosed with the amendment.

Facility Operating License No. NPF-58: Amendment revised the Facility Operating License and Technical Specifications.

Date of initial notice in *Federal Register*: June 19, 2018 (83 FR 28460). The supplemental letter dated October 26, 2018, provided additional information that clarified the application, did not expand the scope of the application as originally noticed, and did not change the staff's original proposed no significant hazards consideration determination as published in the *Federal Register*.

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated February 25, 2019.

No significant hazards consideration comments received: No.

Nebraska Public Power District, Docket No. 50-298, Cooper Nuclear Station (CNS), Nemaha County, Nebraska

Date of amendment request: June 11, 2018.

Brief description of amendment: The amendment revised CNS Technical Specification (TS) 3.8.3, "Diesel Fuel Oil, Lube Oil, and Starting Air," by removing the current stored diesel fuel oil volume and lube oil inventory numerical requirements and replacing them with duration-based diesel operating time requirements. The changes are consistent with the Technical Specifications Task Force (TSTF) Traveler TSTF-501, Revision 1, "Relocate Stored Fuel Oil and Lube Oil Volume Values to Licensee Control." The amendment also revised a surveillance requirement associated with TS 3.8.1, "AC

[Alternating Current] Sources - Operating,” by replacing the day tank numerical volume requirement with a duration-based diesel operating time requirement.

Date of issuance: February 21, 2019.

Effective date: As of the date of issuance and shall be implemented within 60 days from the date of issuance.

Amendment No.: 262. A publicly-available version is in ADAMS under Accession No. ML18348B103; documents related to this amendment are listed in the Safety Evaluation enclosed with the amendment.

Renewed Facility Operating License No. DPR-46: The amendment revised the Renewed Facility Operating License and Technical Specifications.

Date of initial notice in *Federal Register*: August 28, 2018 (83 FR 43905).

The Commission’s related evaluation of the amendment is contained in a Safety Evaluation dated February 21, 2019.

No significant hazards consideration comments received: No.

VI. Notice of Issuance of Amendments to Facility Operating Licenses and Combined Licenses and Final Determination of No Significant Hazards Consideration and Opportunity for a Hearing (Exigent Public Announcement or Emergency Circumstances)

During the period since publication of the last biweekly notice, the Commission has issued the following amendments. The Commission has determined for each of these amendments that the application for the amendment complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission’s rules and regulations. The Commission has made appropriate findings as required by the Act and the Commission’s rules and regulations in 10 CFR chapter I, which are set forth in the license amendment.

Because of exigent or emergency circumstances associated with the date the amendment was needed, there was not time for the Commission to publish, for public comment before issuance, its usual notice of consideration of issuance of amendment, proposed no significant hazards consideration determination, and opportunity for a hearing.

For exigent circumstances, the Commission has either issued a *Federal Register* notice providing opportunity for public comment or has used local media to provide notice to the public in the area surrounding a licensee's facility of the licensee's application and of the Commission's proposed determination of no significant hazards consideration. The Commission has provided a reasonable opportunity for the public to comment, using its best efforts to make available to the public means of communication for the public to respond quickly, and in the case of telephone comments, the comments have been recorded or transcribed as appropriate and the licensee has been informed of the public comments.

In circumstances where failure to act in a timely way would have resulted, for example, in derating or shutdown of a nuclear power plant or in prevention of either resumption of operation or of increase in power output up to the plant's licensed power level, the Commission may not have had an opportunity to provide for public comment on its no significant hazards consideration determination. In such case, the license amendment has been issued without opportunity for comment. If there has been some time for public comment but less than 30 days, the Commission may provide an opportunity for public comment. If comments have been requested, it is so stated. In either event, the State has been consulted by telephone whenever possible.

Under its regulations, the Commission may issue and make an amendment immediately effective, notwithstanding the pendency before it of a request for a hearing

from any person, in advance of the holding and completion of any required hearing, where it has determined that no significant hazards consideration is involved.

The Commission has applied the standards of 10 CFR 50.92 and has made a final determination that the amendment involves no significant hazards consideration. The basis for this determination is contained in the documents related to this action. Accordingly, the amendments have been issued and made effective as indicated.

Unless otherwise indicated, the Commission has determined that these amendments satisfy the criteria for categorical exclusion in accordance with 10 CFR 51.22. Therefore, pursuant to 10 CFR 51.22(b), no environmental impact statement or environmental assessment need be prepared for these amendments. If the Commission has prepared an environmental assessment under the special circumstances provision in 10 CFR 51.12(b) and has made a determination based on that assessment, it is so indicated.

For further details with respect to the action see (1) the application for amendment, (2) the amendment to Facility Operating License or Combined License, as applicable, and (3) the Commission's related letter, Safety Evaluation and/or Environmental Assessment, as indicated. All of these items can be accessed as described in the "Obtaining Information and Submitting Comments" section of this document.

A. Opportunity to Request a Hearing and Petition for Leave to Intervene

The Commission is also offering an opportunity for a hearing with respect to the issuance of the amendment. Within 60 days after the date of publication of this notice, any persons (petitioner) whose interest may be affected by this action may file a request for a hearing and petition for leave to intervene (petition) with respect to the action. Petitions shall be filed in accordance with the Commission's "Agency Rules of Practice and Procedure" in 10 CFR part 2. Interested persons should consult a current copy of

10 CFR 2.309. The NRC's regulations are accessible electronically from the NRC Library on the NRC's Web site at <http://www.nrc.gov/reading-rm/doc-collections/cfr/>. Alternatively, a copy of the regulations is available at the NRC's Public Document Room, located at One White Flint North, Room O1-F21, 11555 Rockville Pike (first floor), Rockville, Maryland 20852. If a petition is filed, the Commission or a presiding officer will rule on the petition and, if appropriate, a notice of a hearing will be issued.

As required by 10 CFR 2.309(d) the petition should specifically explain the reasons why intervention should be permitted with particular reference to the following general requirements for standing: (1) the name, address, and telephone number of the petitioner; (2) the nature of the petitioner's right under the Act to be made a party to the proceeding; (3) the nature and extent of the petitioner's property, financial, or other interest in the proceeding; and (4) the possible effect of any decision or order which may be entered in the proceeding on the petitioner's interest.

In accordance with 10 CFR 2.309(f), the petition must also set forth the specific contentions which the petitioner seeks to have litigated in the proceeding. Each contention must consist of a specific statement of the issue of law or fact to be raised or controverted. In addition, the petitioner must provide a brief explanation of the bases for the contention and a concise statement of the alleged facts or expert opinion which support the contention and on which the petitioner intends to rely in proving the contention at the hearing. The petitioner must also provide references to the specific sources and documents on which the petitioner intends to rely to support its position on the issue. The petition must include sufficient information to show that a genuine dispute exists with the applicant or licensee on a material issue of law or fact. Contentions must be limited to matters within the scope of the proceeding. The contention must be one which, if proven, would entitle the petitioner to relief. A petitioner who fails to satisfy the

requirements at 10 CFR 2.309(f) with respect to at least one contention will not be permitted to participate as a party.

Those permitted to intervene become parties to the proceeding, subject to any limitations in the order granting leave to intervene. Parties have the opportunity to participate fully in the conduct of the hearing with respect to resolution of that party's admitted contentions, including the opportunity to present evidence, consistent with the NRC's regulations, policies, and procedures.

Petitions must be filed no later than 60 days from the date of publication of this notice. Petitions and motions for leave to file new or amended contentions that are filed after the deadline will not be entertained absent a determination by the presiding officer that the filing demonstrates good cause by satisfying the three factors in 10 CFR 2.309(c)(1)(i) through (iii). The petition must be filed in accordance with the filing instructions in the "Electronic Submissions (E-Filing)" section of this document.

If a hearing is requested, and the Commission has not made a final determination on the issue of no significant hazards consideration, the Commission will make a final determination on the issue of no significant hazards consideration. The final determination will serve to establish when the hearing is held. If the final determination is that the amendment request involves no significant hazards consideration, the Commission may issue the amendment and make it immediately effective, notwithstanding the request for a hearing. Any hearing would take place after issuance of the amendment. If the final determination is that the amendment request involves a significant hazards consideration, then any hearing held would take place before the issuance of the amendment unless the Commission finds an imminent danger to the health or safety of the public, in which case it will issue an appropriate order or rule under 10 CFR part 2.

A State, local governmental body, Federally-recognized Indian Tribe, or agency thereof, may submit a petition to the Commission to participate as a party under 10 CFR 2.309(h)(1). The petition should state the nature and extent of the petitioner's interest in the proceeding. The petition should be submitted to the Commission no later than 60 days from the date of publication of this notice. The petition must be filed in accordance with the filing instructions in the "Electronic Submissions (E-Filing)" section of this document, and should meet the requirements for petitions set forth in this section, except that under 10 CFR 2.309(h)(2) a State, local governmental body, or Federally-recognized Indian Tribe, or agency thereof does not need to address the standing requirements in 10 CFR 2.309(d) if the facility is located within its boundaries. Alternatively, a State, local governmental body, Federally-recognized Indian Tribe, or agency thereof may participate as a non-party under 10 CFR 2.315(c).

If a hearing is granted, any person who is not a party to the proceeding and is not affiliated with or represented by a party may, at the discretion of the presiding officer, be permitted to make a limited appearance pursuant to the provisions of 10 CFR 2.315(a). A person making a limited appearance may make an oral or written statement of his or her position on the issues but may not otherwise participate in the proceeding. A limited appearance may be made at any session of the hearing or at any prehearing conference, subject to the limits and conditions as may be imposed by the presiding officer. Details regarding the opportunity to make a limited appearance will be provided by the presiding officer if such sessions are scheduled.

B. Electronic Submissions (E-Filing)

All documents filed in NRC adjudicatory proceedings, including a request for hearing and petition for leave to intervene (petition), any motion or other document filed in the proceeding prior to the submission of a request for hearing or petition to intervene, and documents filed by interested governmental entities that request to participate under

10 CFR 2.315(c), must be filed in accordance with the NRC's E-Filing rule (72 FR 49139; August 28, 2007, as amended at 77 FR 46562; August 3, 2012). The E-Filing process requires participants to submit and serve all adjudicatory documents over the internet, or in some cases to mail copies on electronic storage media. Detailed guidance on making electronic submissions may be found in the Guidance for Electronic Submissions to the NRC and on the NRC Web site at <http://www.nrc.gov/site-help/e-submittals.html>. Participants may not submit paper copies of their filings unless they seek an exemption in accordance with the procedures described below.

To comply with the procedural requirements of E-Filing, at least 10 days prior to the filing deadline, the participant should contact the Office of the Secretary by e-mail at hearing.docket@nrc.gov, or by telephone at 301-415-1677, to (1) request a digital identification (ID) certificate, which allows the participant (or its counsel or representative) to digitally sign submissions and access the E-Filing system for any proceeding in which it is participating; and (2) advise the Secretary that the participant will be submitting a petition or other adjudicatory document (even in instances in which the participant, or its counsel or representative, already holds an NRC-issued digital ID certificate). Based upon this information, the Secretary will establish an electronic docket for the hearing in this proceeding if the Secretary has not already established an electronic docket.

Information about applying for a digital ID certificate is available on the NRC's public Web site at <http://www.nrc.gov/site-help/e-submittals/getting-started.html>. Once a participant has obtained a digital ID certificate and a docket has been created, the participant can then submit adjudicatory documents. Submissions must be in Portable Document Format (PDF). Additional guidance on PDF submissions is available on the NRC's public Web site at <http://www.nrc.gov/site-help/electronic-sub-ref-mat.html>. A filing is considered complete at the time the document is submitted through the NRC's

E-Filing system. To be timely, an electronic filing must be submitted to the E-Filing system no later than 11:59 p.m. Eastern Time on the due date. Upon receipt of a transmission, the E-Filing system time-stamps the document and sends the submitter an e-mail notice confirming receipt of the document. The E-Filing system also distributes an e-mail notice that provides access to the document to the NRC's Office of the General Counsel and any others who have advised the Office of the Secretary that they wish to participate in the proceeding, so that the filer need not serve the document on those participants separately. Therefore, applicants and other participants (or their counsel or representative) must apply for and receive a digital ID certificate before adjudicatory documents are filed so that they can obtain access to the documents via the E-Filing system.

A person filing electronically using the NRC's adjudicatory E-Filing system may seek assistance by contacting the NRC's Electronic Filing Help Desk through the "Contact Us" link located on the NRC's public Web site at <http://www.nrc.gov/site-help/e-submittals.html>, by e-mail to MSHD.Resource@nrc.gov, or by a toll-free call at 1-866-672-7640. The NRC Electronic Filing Help Desk is available between 9 a.m. and 6 p.m., Eastern Time, Monday through Friday, excluding government holidays.

Participants who believe that they have a good cause for not submitting documents electronically must file an exemption request, in accordance with 10 CFR 2.302(g), with their initial paper filing stating why there is good cause for not filing electronically and requesting authorization to continue to submit documents in paper format. Such filings must be submitted by: (1) first class mail addressed to the Office of the Secretary of the Commission, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001, Attention: Rulemaking and Adjudications Staff; or (2) courier, express mail, or expedited delivery service to the Office of the Secretary, 11555 Rockville Pike, Rockville, Maryland 20852, Attention: Rulemaking and Adjudications Staff. Participants

filing adjudicatory documents in this manner are responsible for serving the document on all other participants. Filing is considered complete by first-class mail as of the time of deposit in the mail, or by courier, express mail, or expedited delivery service upon depositing the document with the provider of the service. A presiding officer, having granted an exemption request from using E-Filing, may require a participant or party to use E-Filing if the presiding officer subsequently determines that the reason for granting the exemption from use of E-Filing no longer exists.

Documents submitted in adjudicatory proceedings will appear in the NRC's electronic hearing docket which is available to the public at <https://adams.nrc.gov/ehd>, unless excluded pursuant to an order of the Commission or the presiding officer. If you do not have an NRC-issued digital ID certificate as described above, click "Cancel" when the link requests certificates and you will be automatically directed to the NRC's electronic hearing dockets where you will be able to access any publicly available documents in a particular hearing docket. Participants are requested not to include personal privacy information, such as social security numbers, home addresses, or personal phone numbers in their filings, unless an NRC regulation or other law requires submission of such information. For example, in some instances, individuals provide home addresses in order to demonstrate proximity to a facility or site. With respect to copyrighted works, except for limited excerpts that serve the purpose of the adjudicatory filings and would constitute a Fair Use application, participants are requested not to include copyrighted materials in their submission.

Northern States Power Company - Minnesota, Docket No. 50-306, Prairie Island Nuclear
Generating Plant, Unit 2, Goodhue County, Minnesota

Date of amendment request: January 29, 2019.

Description of amendment: The amendment revised Technical Specification 3.8.1, Condition E, to allow a one-time extension to the completion time for two diesel generators out of service. This notice supplements the notice published February 26, 2019 (84 FR 6182).

Date of issuance: January 29, 2019.

Effective date: January 29, 2019.

Amendment No: 213. A publicly-available version is in ADAMS under Accession No. ML19029A094; documents related to this amendment are listed in the Safety Evaluation enclosed with the amendment.

Renewed Facility Operating License No. DPR-60: The amendment revised the Renewed Facility Operating License and Technical Specifications.

Public comments requested as to proposed no significant hazards consideration (NSHC): No.

The Commission's related evaluation of the amendment, finding of emergency circumstances, state consultation, and final NSHC determination are contained in a Safety Evaluation dated January 29, 2019.

Attorney for licensee: Peter M. Glass, Assistant General Counsel, Xcel Energy Services, Inc., 414 Nicollet Mall, Minneapolis, MN 55401.

NRC Branch Chief: David J. Wrona.

Southern Nuclear Operating Company, Inc., Georgia Power Company, Oglethorpe Power Corporation, Municipal Electric Authority of Georgia, City of Dalton, Georgia, Docket Nos. 50-321 and 50-366, Edwin I. Hatch Nuclear Plant, Unit Nos. 1 and 2, Appling County, Georgia

Date of amendment request: February 19, 2019, as supplemented by letter dated February 20, 2019.

Brief description of amendments: The amendments revise the Unit No. 1 and Unit No. 2 Technical Specifications (TS) requirements of TS 3.8.1, "AC Sources - Operating," to change Surveillance Requirement 3.8.1.8 to increase the voltage limit for the emergency diesel generator full load rejection test for the Unit No. 2 diesel generators and the swing diesel generator.

Date of issuance: February 22, 2019.

Effective date: As of the date of issuance and shall be implemented within 30 days from the date of issuance.

Amendment Nos.: Unit 1 - 294, Unit 2 - 239. A publicly-available version is in ADAMS under Accession No. ML19053A093; documents related to these amendments are listed in the Safety Evaluation enclosed with the amendments.

Renewed Facility Operating License Nos. DPR-57 and NPF-5: Amendments revised the Renewed Facility Operating Licenses and Technical Specifications.

Public comments requested as to proposed no significant hazards consideration

(NSHC): No.

The Commission's related evaluation of the amendments, finding of emergency circumstances, state consultation, and final NSHC determination are contained in a Safety Evaluation dated February 22, 2019.

Attorney for licensee: Millicent Ronnlund, Vice President and General Counsel, Southern Nuclear Operating Co., Inc., P. O. Box 1295, Birmingham, AL 35201-1295,.

NRC Branch Chief: Michael T. Markley.

Dated at Rockville, Maryland, this 28th day of February 2019.

For the Nuclear Regulatory Commission.

/RA/

Kathryn M. Brock, Deputy Director,
Division of Operating Reactor Licensing,
Office of Nuclear Reactor Regulation.