



FEB 27 2019

L-2019-016  
10 CFR 50.36

U.S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, D. C. 20555-0001

Re: Turkey Point Units 3 and 4  
Docket Nos. 50-250 and 50-251  
2018 Annual Report of Reactor Coolant Specific Activity Limits

The 2018 Turkey Point Units 3 and 4 Annual Reactor Coolant System (RCS) Specific Activity Report is submitted herein pursuant to Turkey Point Technical Specification (TS) 6.9.1.2.

The reactor coolant specific activity limits of less than or equal to 0.25 microcuries per gram Dose Equivalent I-131 and less than or equal to 447.7 microcuries per gram of Dose Equivalent Xe-133 defined by Technical Specification 3.4.8.a and 3.4.8.b respectively were not exceeded for Turkey Point Units 3 and 4 during the year 2018.

Should there be any questions regarding this information, please contact Mr. Robert Hess, Licensing Manager, at (305) 246-4112.

Sincerely,

A handwritten signature in black ink, appearing to read 'B. Stamp', written over a horizontal line.

Brian Stamp  
Plant General Manager  
Turkey Point Nuclear Plant

SM

cc: Regional Administrator, Region II, USNRC  
Senior Resident Inspector, USNRC, Turkey Point Plant

TEH8  
NRR