



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

March 19, 2019

Mr. W. Anthony Nowinowski, Executive Director
PWR Owners Group, Program Management Office
Westinghouse Electric Company
1000 Westinghouse Drive, Suite 380
Cranberry Township, PA 16066

SUBJECT: DRAFT SAFETY EVALUATION FOR PRESSURIZED WATER REACTOR OWNERS GROUP TOPICAL REPORT PWROG-17011-NP, REVISION 1 REPORT, "UPDATE FOR SUBSEQUENT LICENSE RENEWAL: WCAP-14535A, 'TOPICAL REPORT ON REACTOR COOLANT PUMP FLYWHEEL INSPECTION ELIMINATION' AND WCAP-15666-A, 'EXTENSION OF REACTOR COOLANT PUMP MOTOR FLYWHEEL EXAMINATION'" (EPID: L-2018-TOP-0019)

Dear Mr. Nowinowski:

By letter dated May 15, 2018 (Agencywide Documents Access and Management System (ADAMS) Package Accession No. ML18143B465), the Pressurized Water Reactor Owners Group (PWROG) submitted Topical Report (TR) PWROG-17011-NP, Revision 1, "Update for Subsequent License Renewal: WCAP-14535A, "Topical Report on Reactor Coolant Pump Flywheel Inspection Elimination" (and WCAP-15666-A, "Extension of Reactor Coolant Pump Motor Flywheel Examination,") to the U.S. Nuclear Regulatory Commission (NRC) staff for review.

The NRC staff review determined that the information provided in the TR provides the technical and regulatory basis for continuing the 20-year in service inspection interval approved for reactor coolant pump motor flywheels for the period of extended operation (60 years) in WCAP-15666-A (ADAMS Accession No. ML18303A413), to the subsequent period of extended operation (80 years). The NRC staff has reviewed PWROG-17011-NP, Revision 1 and concludes that the subject report, as modified by the conditions and limitations summarized in Section 4.0 of the enclosed safety evaluation (SE), provides an acceptable methodology that can be used to support such a request.

Twenty working days are provided for you to comment on any factual errors or clarity concerns contained in the SE. The final SE will be issued and will be made publicly available after making any necessary changes. The NRC staff's disposition of your comments on the draft SE will be discussed in the final SE.

To facilitate the NRC staff's review of your comments, please provide a marked-up copy of the revised draft SE showing proposed changes and provide a summary table of the proposed changes.

If you have any questions, please contact Jason Drake at 301-415-8378.

Sincerely,

/RA

Dennis C. Morey, Chief
Licensing Processes Branch
Division of Licensing Projects
Office of Nuclear Reactor Regulation

Docket No. 99902037

Enclosure: Draft SE

SUBJECT: DRAFT SAFETY EVALUATION FOR PRESSURIZED WATER REACTOR OWNERS GROUP TOPICAL REPORT PWROG-17011-NP, REVISION 1 REPORT, "UPDATE FOR SUBSEQUENT LICENSE RENEWAL: WCAP-14535A, 'TOPICAL REPORT ON REACTOR COOLANT PUMP FLYWHEEL INSPECTION ELIMINATION' AND WCAP-15666-A, 'EXTENSION OF REACTOR COOLANT PUMP MOTOR FLYWHEEL EXAMINATION'"
DATE: MARCH 19, 2019

DISTRIBUTION:

PUBLIC

RidsResOd	RidsNrrDlp	RidsACRS_MailCTR	JDozier
RidsNrrLADHarrison	RidsOgcMailCenter	RidsNrrDlpPlpb	CSydnor
RidsNrrDmlr	DMorey, NRR	KHsueh	CFairbanks
RidsNroOd	DAalley, NRR	JDrake	

ADAMS Accession Nos:

PKG ML19072A095

Letter ML19072A103

Draft Enclosure ML19072A104

***concurrence via email**

NRR-106

OFFICE	NRR/PLPB: PM	NRR/PLPB: LA	NRR/DRA/ARCB: BC	NRR/DMLR/MVIB: BC	NRR/PLPB: BC
NAME	JDrake*	DHarrison*	KHsueh*	DAalley*	DMorey
DATE	3/15/2019	3/14/2019	3/18/2019	3/15/2019	3/19/2019

OFFICIAL RECORD COPY