



Global Nuclear Fuel

Brian R. Moore, Ph.D.

Global Nuclear Fuel – Americas, LLC
General Manager, Core & Fuel Engineering
P.O. Box 780, M/C A55
Wilmington, NC 28401 USA

T 910 232-2115

Brian.Moore@ge.com

M190056

March 18, 2019

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555-0001

Subject: Proposed Administrative Amendment 50 to NEDE-24011-P-A-27, General Electric Standard Application for Reactor Fuel (GESTAR II)

The enclosed changes to the US Supplement to GESTAR II are being proposed to remove an outdated reference to the compilation of improvements to the SAFER/GESTR-LOCA evaluation model. GNF tracks improvements to the SAFER/GESTR-LOCA evaluation model consistent with the reporting requirements of 10 CFR 50.46. The proposed revisions to the US Supplement and a basis discussion are included in Enclosure 1.

Sections S.2.2.3.2.1, S.2.2.3.2.2, and S.6 in the US Supplement to GESTAR II are affected by this amendment. All changes are shown in revision mode to ease the review.

If you have any questions about the information provided here, please contact me at (910) 819-6684 or Lisa Schichlein at (910) 819-4815.

Sincerely,

A handwritten signature in black ink that reads 'B R Moore'.

Brian R. Moore, Ph.D
General Manager, Core & Fuel Engineering
Global Nuclear Fuel – Americas, LLC

Project No. 712
Docket No. 99901376

Enclosure:

1. Proposed Amendment 50 to GESTAR II US Supplement – Non-Proprietary Information

M190056

Page 2 of 2

cc: J Golla, USNRC
MP Catts, GEH/Wilmington
KE Halac, GEH/Wilmington
LK Schichlein, GEH/Wilmington
PLM Specification 005N2310 R0

ENCLOSURE 1

M190056

Proposed Amendment 50 to GESTAR II US Supplement

Non-Proprietary Information

GESTAR II Bases Document

The following is a description of the basis for the change. Overall, the primary purpose of the revision is to remove an outdated document reference, S-33.

S-33 *Compilation of Improvements to GENE's SAFER ECCS-LOCA Evaluation Model*, NEDC-32950P, January 2000 as reviewed by letter from S. A. Richards (NRC) to J. F. Klapproth (GE), *General Electric Nuclear Energy (GENE) Topical Reports NEDC-32950P and NEDC-32084P Acceptability Review*, May 24, 2000.

NEDC-32950P is a summary of changes to the SAFER/GESTR-LOCA evaluation model and a repository of 10 CFR 50.46 Notification Letters up to that point in time that NEDC-32950P was issued. However, this document is not current and does not include more recent changes made to the SAFER/GESTR-LOCA evaluation model.

Ongoing changes to the SAFER/GESTR-LOCA evaluation model are tracked via the reporting of evaluation model changes to the NRC in accordance with the reporting requirements of 10 CFR 50.46(a)(3)(ii) and 10 CFR 50.46(a)(3)(iii).

Proposed revisions to the US Supplement to GESTAR II are shown on the following pages.

The first methodology, which was designated SAFE/REFLOOD has now been replaced by the SAFER/GESTR or SAFER/PRIME methodology in all U.S. plants utilizing GEH LOCA evaluation methodology. The content pertaining to SAFE/REFLOOD has been deleted and the sections renumbered such that the SAFER/GESTR or SAFER/PRIME methodology comes first. The SAFER/GESTR methodology, identified in Sections S.2.2.3.2.1 and S.2.2.3.2.2, utilizes improved ECCS evaluation models (References S-27 and S-28) along with a more realistic application approach (Reference S-29) to calculate a licensing PCT with margin substantiated by statistical considerations. Nominal values are used for most inputs, and Appendix K required inputs are utilized only for the limiting break in order to establish a licensing margin to 10CFR50.46 limits. This methodology was revised in Reference S-30 to extend the application to non-jet pump plants.

The SAFER/GESTR methodology has been updated to include the fuel and gap properties from the PRIME fuel performance methodology which was approved by the NRC (Reference S-31). This methodology is being designated as SAFER/PRIME. All other aspects of the SAFER/GESTR methodology which was reviewed and approved by the NRC remain unchanged.

In addition to the SAFER/PRIME methodology, a best-estimate plus uncertainties method is also available for ECCS performance evaluation. This methodology (Reference S-32), designated as TRACG-LOCA, is briefly described in Section S.2.2.3.2.4.

Either SAFER/PRIME or TRACG-LOCA methodology can be used for ECCS performance evaluation calculations for postulated LOCAs. The method used will be indicated in the FSAR for initial cores or the supplemental reload licensing report for each cycle (see Appendix A of country-specific supplement).

S.2.2.3.2.1 SAFER/GESTR LOCA Model Code Descriptions

The thermal-hydraulic model (SAFER) and fuel rod thermal-mechanical model (GESTR-LOCA) have been developed to provide more realistic calculations for LOCA analyses. The SAFER and GESTR-LOCA models are summarized below and discussed in detail in References S-27, S-28, S-30, ~~S-33 (as reviewed by the NRC in the letter specified in Reference S-33)~~ and S-34. The SAFER/GESTR methodology has been updated to include the fuel and gap properties from the PRIME fuel performance methodology which was approved by the NRC (Reference S-31). This methodology is designated as SAFER/PRIME. All other aspects of the SAFER/GESTR methodology which was reviewed and approved by the NRC remain unchanged.

SAFER/GESTR-LOCA and SAFER/PRIME are also applicable to prepressurized fuel. Non-prepressurized fuel calculations result in conservative limits with respect to prepressurized fuel. The MAPLHGR values calculated by the codes are applicable to both nonbarrier and barrier fuel.

S.2.2.3.2.1.1 Realistic Thermal-Hydraulics Model (SAFER)

The SAFER code employs a heatup model with a simplified radiation heat transfer correlation to calculate PCT and local maximum oxidation. The PCT and local maximum oxidation fraction from SAFER can be used directly.

S.2.2.3.2.1.2 Best Estimate Fuel Rod Thermal Mechanical Model

The GESTR-LOCA model has been developed to provide best-estimate predictions of the thermal performance of GE nuclear fuel rods experiencing variable power histories. For ECCS analyses, the GESTR-LOCA model is used to initialize the fuel stored energy and fuel rod fission gas inventory at the onset of a postulated LOCA. Details of the GESTR-LOCA models are provided in Reference S-27.

The fuel and gap properties have been updated based on the PRIME fuel performance methodology which was approved by the NRC (Reference S-31). This methodology is designated as SAFER/PRIME. All other aspects of the SAFER/GESTR methodology which was reviewed and approved by the NRC remain unchanged.

S.2.2.3.2.1.3 Transient Boiling Transition Model (TASC)

The TASC model is used to evaluate the short-term thermal-hydraulic response of the coolant in the core during a postulated loss-of-coolant accident. In particular, the convective heat transfer response in the thermally limiting fuel bundle is analyzed during the transient. For a detailed description of the model and a discussion regarding sources of input to the model, refer to Reference S-35.

S.2.2.3.2.2 SAFER/GESTR-LOCA Model Application Methodology

Using the SAFER/GESTR-LOCA or SAFER/PRIME models, the LOCA events are analyzed with nominal values of inputs and correlations. A calculation is performed in conformance to Appendix K and checked for consistency with generic statistical upper bound analyses that encompass modeling uncertainties in SAFER/GESTR-LOCA or SAFER/PRIME and uncertainties related to plant parameters.

The effects of power spiking due to in-reactor densification are considered negligible for SAFER/GESTR-LOCA or SAFER/PRIME analyses.

The details of the application methodology are summarized below and discussed in detail in References S-29, ~~S-33~~ and S-34.

S.2.2.3.2.2.1 Appendix K Conformance

The SAFER/GESTR-LOCA or SAFER/PRIME Appendix K conformance calculation will be performed only for the limiting break of a nominally calculated break spectrum with a range of break flow multipliers between 0.6 and 1.0. The licensing PCT is obtained as described in Reference S-29.

S.6 References

- S-1 *General Electric Standard Application for Reactor Fuel*, GESTAR II — Base Document (NEDE-24011-P-A, Revision 24, February 2017).
- S-2 *BWR Owners' Group Long-Term Stability Solutions Licensing Methodology*, NEDO-31960-A, November 1995, and NEDO-31960-A Supplement 1, November 1995.
- S-3 *Reactor Stability Long-Term Solution: Enhanced Option I-A*, NEDO-32339-A, Revision 1, April 1998.
- S-4 *General Electric Boiling Water Reactor Detect and Suppress Solution – Confirmation Density*, NEDC-33075P-A, Rev. 6, January 2008.
- S-5 *GE Hitachi Boiling Water Reactor Detect and Suppress Solution – Confirmation Density*, NEDC-33075P-A, Revision 8, November 2013.
- S-6 *BWR Owners' Group Guidelines for Stability Interim Corrective Action*, BWROG-94078, June 6, 1994.
- S-7 Letter from GE-NE to BWR Owners' Group, *Backup Stability Protection (BSP) for Inoperable Option III Solution*, OG-02-0119-260, July 17, 2002.
- S-8 *Standard Format and Content of Safety Analysis Reports for Nuclear Power Plants, LWR Edition*, Regulatory Guide 1.70, Revision 3, November 1978.
- S-9 *Determination of Limiting Cold Water Event*, NEDC-32538P-A, February 1996.
- S-10 *GESSAR II-238; BWR/6 Nuclear Island Design*, NRC Docket No. STN50-447.
- S-11 Letter from R. E. Engel (GE) to D. G. Eisenhut (NRC), *Fuel Assembly Loading Error*, June 1, 1977.
- S-12 Letter from R. E. Engel (GE) to D. G. Eisenhut (NRC), *Fuel Assembly Loading Error*, November 30, 1977.
- S-13 Letter from D. G. Eisenhut (NRC) to R. E. Engel (GE), MFN-200-78, May 8, 1978.
- S-14 Letter from Andrew A. Lingenfelter to Document Control Desk, *Transmittal of Updated Attachments Supporting GESTAR II Amendment 28 and Associated GESTAR II Sections* (TAC NO. MC3559), June 2, 2006.
- S-15 Letter from J. S. Charnley (GE) to C. O. Thomas (NRC), *Licensing Credit for Banked Position Withdrawal Sequences on Group Notch Plants*, May 10, 1985.
- S-16 Letter from T. Pickens (BWROG) to G. C. Lainas (NRC), *Amendment 17 to General Electric Licensing Topical Report NEDE-24011-P-A*, August 15, 1986.

- S-17 C. J. Paone, *Banked Position Withdrawal Sequence*, January 1977 (NEDO-21231) and Letter from OD Parr (USNRC) to GG Sherwood (GE), *Topical Report - NEDO-21231, "Banked Position Withdrawal Sequence,"* January 18, 1978.
- S-18 *Improved BPWS Control Rod Insertion Process*, NEDO-33091-A, Revision 2, July 2004.
- S-19 C. J. Paone and J. A. Woolley, *Rod Drop Accident Analysis for Large Boiling Water Reactors*, Licensing Topical Report, March 1972 (NEDO-10527).
- S-20 R. C. Stirn, C. J. Paone, and R. M. Young, *Rod Drop Accident Analysis for Large Boiling Water Reactors*, Licensing Topical Report, July 1972 (NEDO-10527, Supplement 1).
- S-21 R. C. Stirn, C. J. Paone, and J. M. Haun, *Rod Drop Accident Analysis for Large Boiling Water Reactors*, Addendum No. 2, Exposed Cores, Licensing Topical Report, January 1973 (NEDO-10527, Supplement 2).
- S-22 Letter from R. E. Engel (GE) to D. B. Vassallo (NRC), *Control Rod Drop Accident*, February 24, 1982, MFN-026-082.
- S-23 *Steady-State Nuclear Methods*, April 1985 (NEDE-30130-P-A and NEDO-30130-A).
- S-24 J. A. Woolley, *Three-Dimensional BWR Core Simulator*, January 1977 (NEDO-20953A).
- S-25 *Fuel Densification Effects on General Electric Boiling Water Reactor Fuel*, August 1973, (NEDM-10735, Supplement 6).
- S-26 *General Electric Fuel Bundle Designs*, NEDE-31152-P, Revision 8, April 2001.
- S-27 S. O. Akerlund et al, *The GESTR-LOCA and SAFER Models for the Evaluation of the Loss-of-Coolant Accident: Volume I — GESTR-LOCA — A Model for the Prediction of Fuel and Thermal Performance*, February 1985 (NEDE-23785-1-P-A and NEDO-23785-1-A).
- S-28 K. C. Chan et. al., *The GESTR-LOCA and SAFER Models for the Evaluation of the Loss-of-Coolant Accident: Volume II – SAFER –Long-Term Inventory Model for BWR Loss-of-Coolant Analysis*, February 1985 (NEDE-23785-1-P-A and NEDO-23785-1-A).
- S-29 B. S. Shiralkar et al, *The GESTR-LOCA and SAFER Models for the Evaluation of the Loss-of-Coolant Accident: Volume III – SAFER/GESTR Application Methodology*, February 1985 (NEDE-23785-1-P-A and NEDO-23785-1-A).
- S-30 *SAFER Model for Evaluation of Loss-of-Coolant Accidents for Jet Pump and Non-Jet Pump Plants*, Volumes I and II, NEDC-30996P-A, October 1987.

- S-31 GNF Licensing Topical Report, *The PRIME Model for Analysis of Fuel Rod Thermal – Mechanical Performance*, Technical Bases - NEDC-33256P-A, Qualification - NEDC-33257P-A, and Application Methodology - NEDC-33258P-A, September 2010.
- S-32 *TRACG Application for Emergency Core Cooling Systems / Loss-of-Coolant-Accident Analyses for BWR/2-6*, NEDE-33005P-A, Revision 2, May 2018.
- S-33 **(Not Used)** ~~*Compilation of Improvements to GENE's SAFER ECCS LOCA Evaluation Model*, NEDC-32950P, January 2000 as reviewed by letter from S. A. Richards (NRC) to J. F. Klapproth (GE), *General Electric Nuclear Energy (GENE) Topical Reports NEDC-32950P and NEDC-32084P Acceptability Review*, May 24, 2000.~~
- S-34 *GESTR-LOCA and SAFER Models for Evaluation of Loss-of-Coolant Accident Volume III, Supplement 1, Additional Information for Upper Bound PCT Calculation*, NEDE-23785P-A, Supplement 1, Revision 1, March 2002.
- S-35 *TASC-03A – A computer program for Transient Analysis of a Single Channel*, NEDC-32084P-A Rev. 2, July 2002.
- S-36 Letter from J. S. Charnley (GE) to M. W. Hodges (NRC), *Proposed Amendment 19 to GE LTR NEDE-24011-P-A (Power Distribution Limits)*, April 7, 1987.
- S-37 *Best-Estimate Calculations of Emergency Core Cooling System Performance*, U.S. NRC Regulatory Guide 1.157, May 1989.
- S-38 *Quantifying Reactor Safety Margins: Application for Code Scaling, Applicability, and Uncertainty Evaluation methodology to a Large-Break, Loss-of-Coolant Accident*, NUREG/CR-5249, December 1989.
- S-39 *Transient and Accidents Analysis Methods*, U.S. NRC Regulatory Guide 1.203, December 2005.
- S-40 Letter from J. F. Klapproth (GE) to R. C. Jones, Jr. (NRC), *Refueling Accident Analysis*, MFN 098-92, April 24, 1992.
- S-41 *GE12 Compliance With Amendment 22 of NEDE-24011-P-A (GESTAR II)*, NEDC-32417P, December 1994.
- S-42 *GE14 Compliance With Amendment 22 of NEDE-24011-P-A (GESTAR II)*, NEDE-32868P, Revision 6, March 2016.
- S-43 Letter from A. W. Dromerick (NRC) to J. J. Barton (GPUN), *Issuance of Amendment (TAC NO. 75536)*, March 6, 1991.
- S-44 Letter from D. S. Brinkman (NRC) to B. R. Sylvia (NMPC), *Issuance of Amendment (TAC NO. M89980)*, January 1995.

- S-45 Letter from R. C. Tedesco (NRC) to G. G. Sherwood (GE), *Acceptance for Referencing General Electric Licensing Topical Report NEDO-24154/NEDE-24154P*, February 4, 1981.
- S-46 Letter from Ivan F. Stuart (GE) to Victor Stello, Jr. (NRC), *Code Overpressure Protection Analysis — Sensitivity of Peak Vessel Pressures to Valve Operability*, December 23, 1975.
- S-47 *Qualification of the One-Dimensional Core Transient Model (ODYN) for BWR's*, NEDO-24154-A, Vol. 1 and 2: August 1986.
- S-48 *Qualification of the One-Dimensional Core Transient Model (ODYN) for BWR's*, NEDC-24154-P-A, Vol. 3: August 1986.
- S-49 *TRACG Application for Anticipated Operational Occurrences Transient Analyses*, NEDE-32906P-A, Revision 3, September 2006, *TRACG Application for Anticipated Transients without Scram Overpressure Transient Analyses*, NEDE-32906P, Supplement 1-A, November 2003, *TRACG Application for Anticipated Operational Occurrences Transient Analyses*, NEDE-32906P, Supplement 2-A, March 2006, and *Migration to TRACG04 / PANAC11 from TRACG02 / PANAC10 for TRACG AOO and ATWS Overpressure Transients*, NEDE-32906P, Supplement 3-A, Revision 1, April 2010.
- S-50 *Reactor Stability Detect and Suppress Solutions Licensing Basis Methodology for Reload Applications*, NEDO-32465-A, August 1996 and *Migration to TRACG04/PANAC11 from TRACG02/PANAC10 for Reactor Stability Detect and Suppress Solutions Licensing Basis Methodology for Reload Applications*, NEDE-32465, Supplement 1P-A, Revision 1, October 2014.
- S-51 GE-NE-0000-0031-6498-R0, *Plant-Specific Core-wide Mode DIVOM Procedure Guideline*, June 2, 2005.
- S-52 GE-NE-0000-0028-9714-R1, *Plant-Specific Regional Mode DIVOM Procedure Guideline*, June 2, 2005.
- S-53 *GEH Simplified Stability Solution (GS3)*, NEDE-33766P-A, Revision 1, March 2015.
- S-54 *ODYSY Application for Stability Licensing Calculations Including Option I-D and II Long Term Solutions*, NEDE-33213P-A, April 2009.
- S-55 *ODYSY Application for Stability Licensing Calculations*, NEDC-32992P-A, July 2001.
- S-56 *Reactor Stability Long-Term Solution: Enhanced Option I-A, ODYSY Application to EIA*, NEDC-32339P-A Supplement 1, December 1996.
- S-57 *Reactor Stability Long-Term Solution: Enhanced Option I-A, Solution Design*, NEDC-32339P-A Supplement 2, Revision 1, April 1998.

- S-58 *Reactor Stability Long-Term Solution: Enhanced Option I-A, Flow Mapping Methodology*, NEDO-32339-A Supplement 3, Revision 1, April 1998.
- S-59 *Reactor Stability Long-Term Solution: Enhanced Option I-A, Generic Technical Specifications*, NEDO-32339-A Supplement 4, Revision 1, April 1998.
- S-60 *Applicability of GE Methods to Expanded Operating Domains*, Licensing Topical Report, NEDC-33173P-A, Revision 4, Class III, November 2012.
- S-61 *Applicability of GE Methods to Expanded Operating Domains – Supplement for GNF2 Fuel*, NEDC-33173 Supplement 3P-A, Revision 1, July 2011.
- S-62 *Applicability of GE Methods to Expanded Operating Domains – Power Distribution Validation for Cofrentes Cycle 13*, NEDC-33173, Supplement 2, Part 1P-A, Revision 1, *Applicability of GE Methods to Expanded Operating Domains – Pin-by-Pin Gamma Scan at FitzPatrick October 2006*, NEDC-33173, Supplement 2, Part 2P-A, Revision 1, *Applicability of GE Methods to Expanded Operating Domains – Power Distribution Validation for Cofrentes Cycle 15*, NEDC-33173, Supplement 2, Part 3P-A, Revision 1, April 2012.
- S-63 *Implementation of PRIME Models and Data in Downstream Methods*, NEDO-33173 Supplement 4-A, Revision 1, November 2012.
- S-64 *BWROG In-Service Pressure Relief Technical Specification Revision Licensing Topical Report*, NEDC-31753P, February 1990.
- S-65 Letter from Ashok Thadani (USNRC) to Cynthia Tully (BWROG), *Acceptance for Referencing of Licensing Topical Report NEDC-31753P 'BWROG In-Service Pressure Relief Technical Specification Revision Licensing Topical Report' (TAC No. M79265)*, March 8, 1993.
- S-66 *General Electric Boiling Water Reactor, Maximum Extended Load Line Limit Analysis Plus*, NEDC-33006P-A, Revision 3, June 2009.
- S-67 *Generic Guidelines and Evaluations for General Electric Boiling Water Reactor Thermal Power Optimization*, NEDC-32938P-A, Revision 2, May 2003.
- S-68 *GNF2 Advantage Generic Compliance with NEDE-24011-P-A (GESTAR II)*, NEDC-33270P, Revision 9, December 2017.
- S-69 *The PRIME Model for Transient Analysis of Fuel Rod Thermal-Mechanical Performance*, NEDC-33840P-A, Revision 1, August 2017.