

**CALCULATION CHANGE NOTICE**

CCN NO. XX-E-013 - 004 - CN005  
 Base Calc No.      Rev No.      Sequence No.

**CALCULATION TITLE** - From **CALCULATION TITLE** field in EIS:  
 Post-Fire Safe Shutdown (PFSSD) Analysis

COMPUTER CODE:

VERSION:

Administrative?

☐ YES☒ NO

ASSOCIATED ENGINEERING CHANGE #:

020021

REGULATORY  
REVIEWS:☐ Attached

Evaluation # \_\_\_\_\_

☒ Attached to: CP 020021☐ Not Applicable N/A Only if  
Administrative

USAR STATEMENT:

☐ Requires a change to the USAR:☒ Does NOT require a change to the USARANY DOCUMENTS  
IMPACTED?☐ YES

If yes, enter: SWO #, or Condition Report #, if applicable.

☒ NO

Status:



COMMITTED



FINAL



VOID



SUPERSEDED

ORIG

DigsigOrg 2.8, 0.7

NA-Vendor Calculation

Printed Name

Date

NA

Signature

QUALIFICATION REQUIRED: ES9280479

ORIG

Printed Name

Date

Signature

QUALIFICATION REQUIRED: ES9280479

VERF

DigsigVer 2.8, 0.7

William M. Wilkins

Printed Name

10/2/2018

Date



Signature

QUALIFICATION REQUIRED: ES9280479

VERF

Printed Name

Date

Signature

QUALIFICATION REQUIRED: ES9280479

APP


DigsigApp 2.8, 0.7

Jeff Suter

Printed Name

10/02/2018

Date



Signature

APP

Printed Name

Date

Signature

DigsigCert 3.5 1.75

DigsigCert 3.5 1.75

Vendor supplied document – WCNOE PE Stamping is not  
 required per WCNOE-162 Rev. 05, Section 8.1.13.

**RPE Certification (For ASME Section III Stress Reports/Design Reports,  
 refer to AP 05D-001 for qualification requirements)**

**CALCULATION SUBJECT (Statement Of Problem)** - Enter this in **SUBJECT** field in EIS:

CP 020021 XNB01 replacement impact to revise relay designations for transformer protection features. Additionally, discussion of load tap changer feature of new transformer included with clarification it is not PFSSD.

<b>CALCULATION DATABASE INPUT</b>	Page 2		
	CCN NO.	XX-E-013	- 004 - CN005
	Base Calc No.	Rev No.	Sequence No.

Link new systems to the calculation/CCN in EIS.	
<b>Systems Affected:</b>	NB, MA
Develop relationships between interdependent calculations in EIS.	
<b>Additional Calculations Providing Input to this calculation:</b>	None
<b>Additional Calculations Impacted by this calculation:</b>	None
Develop relationships between the calculation/CCN and controlled reference documents in EIS.	
<b>Additional Controlled Documents Inputs to this calculation:</b>	None
<b>Additional Controlled Documents Impacted by this calculation:</b>	None
The reference documents listed below are those that cannot be linked to the calculation/CCN and shall be entered in the INDUSTRY REFERENCE field in EIS, e.g., ASME Codes, ANSI Standards, letters, etc.	
<b>Additional Other Reference Documents:</b>	CP 020021, Enercon Calc. WCN-025-CALC-010
Link new components to the calculation/CCN in EIS.	
<b>Additional Components:</b>	None





**REFER TO DESKTOP GUIDE FOR PROCESSING CALCULATIONS IN EIS**




**ATTACHMENT 1**

CCN NO.	XX-E-013	-	004	-	CN005
	Base Calc No.		Rev No.		Sequence No


Vendor calculation WCN-025-CALC-010, Rev 0


 <b>ENERCON</b> Excellence—Every project. Every day.		<b>CALCULATION COVER SHEET</b>		<b>CALC NO.</b> WCN-025-CALC-010	
				<b>REV.</b> 0	
				<b>PAGE NO.</b> 1 of 8	
<b>Title:</b>	UPDATE TO WCNOC CALCULATION XX-E-013, PFSSD ANALYSIS			<b>Client:</b> WCNOC	
				<b>Project Identifier:</b> WCN-025	
<b>Item</b>	<b>Cover Sheet Items</b>	<b>Yes</b>	<b>No</b>		
1	Does this calculation contain any open assumptions, including preliminary information, that require confirmation? (If YES, identify the assumptions.)	<input type="checkbox"/>	<input checked="" type="checkbox"/>		
2	Does this calculation serve as an "Alternate Calculation"? (If YES, identify the design verified calculation.) Design Verified Calculation No. _____	<input type="checkbox"/>	<input checked="" type="checkbox"/>		
3	Does this calculation supersede an existing Calculation? (If YES, identify the design verified calculation.) Superseded Calculation No. _____	<input type="checkbox"/>	<input checked="" type="checkbox"/>		
<b>Scope of Revision:</b> Initial Issue					
<b>Revision Impact on Results:</b> This calculation documents the changes for the replacement of transformer XNB01.					
Study Calculation <input type="checkbox"/> Final Calculation <input checked="" type="checkbox"/>					
Safety-Related <input type="checkbox"/> Non-Safety-Related <input checked="" type="checkbox"/>					
(Print Name and Sign)					
<b>Originator:</b> Robert N. Thomas 				<b>Date:</b> 09/20/2018	
<b>Design Verifier<sup>1</sup> (Reviewer if NSR):</b> Stacey Graybeal 				<b>Date:</b> 09/20/2018	
<b>Approver:</b> Austin Tran 				<b>Date:</b> 09/20/2018	

Note 1: For non-safety-related calculation, design verification can be substituted by review.




Digitally signed by  
 Austin Tran  
 DN: cn=Austin Tran,  
 o=Enercon Services, ou,  
 email=atran@enercon.c  
 om, c=US  
 Date: 2018.09.20  
 18:11:21 -05'00'

 <b>ENERCON</b> <i>Excellence—Every project. Every day.</i>	<b>CALCULATION REVISION STATUS SHEET</b>		CALC NO. WCN-025-CALC-010		
			REV.	0	
			PAGE NO.	2 of 8	
<b><u>CALCULATION REVISION STATUS</u></b>					
<b><u>REVISION</u></b> 0	<b><u>DATE</u></b> 09/20/2018	<b><u>DESCRIPTION</u></b> Initial Issue			
<b><u>PAGE REVISION STATUS</u></b>					
<b><u>PAGE NO.</u></b> ALL	<b><u>REVISION</u></b> 0	<b><u>PAGE NO.</u></b>	<b><u>REVISION</u></b>		
<b><u>APPENDIX/ATTACHMENT REVISION STATUS</u></b>					
<b><u>APPENDIX NO.</u></b> A	<b><u>NO. OF PAGES</u></b> 4	<b><u>REVISION NO.</u></b> 0	<b><u>ATTACHMENT NO.</u></b>	<b><u>NO. OF PAGES</u></b>	<b><u>REVISION NO.</u></b>

	TABLE OF CONTENTS	CALC NO. WCN-025-CALC-006
		REV. 0
		PAGE NO. 3 of 8

Section	Page No.
1.0 Purpose and Scope	4
2.0 Summary of Results and Conclusions	4
3.0 References	5
4.0 Assumptions	5
5.0 Design Inputs	5
6.0 Methodology	7
7.0 Calculations	8
8.0 Computer Software	8

List of Appendices	# of Pages
A - Markup Updates to XX-E-013	4

 <b>ENERCON</b> <i>Excellence—Every project. Every day.</i>	<b>UPDATE TO WCNO  CALCULATION XX-E-013,  PFSSD ANALYSIS</b>	<b>CALC NO.</b> <b>WCN-025-CALC-010</b>
		<b>REV.</b> <b>0</b>
		<b>PAGE NO.</b> <b>4 of 8</b>


## 1.0 Purpose and Scope

Wolf Creek is performing a systematic replacement of their large oil-filled transformers to address aging concerns and to implement design improvements in support of long term station operation. The first transformer to be replaced is ESF transformer XNB01.

DCP 020021 is replacing XNB01 and the new transformer will have a Load Tap Changer (LTC) to control the voltage supplied to 4.16kV bus NB01 even if the 13.8 kV input voltage level changes. The DCP is also replacing/deleting relays in the MA104F panel and the relays are addressed by XX-E-013. The purpose of this calculation is to document the impact on Wolf Creek calculation XX-E-013 due to these changes. This calculation is non-safety related per the ENERCON requirements. The Wolf Creek update will be considered "special scope" per the site requirements.

## 2.0 Summary of Results and Conclusions

Wolf Creek calculation XX-E-013 does not have any computations. It is a document used to identify the components required to support the Post Fire Safe Shutdown (PFSSD) functions. Based on the results of this calculation the addition of the LTC controls will not impact the PFSSD function of XNB01. Two overcurrent relays (287/T1 Phase B and Phase C) are removed from the calculation (287/T1 Phase A is replaced with one new relay to monitor all three phases). Also, components 263-1/T1, 263X-1/T1, 263-2/T1 and 263X-2/T1 are removed from the calculation. New fault pressure trip relays 263FP K4A and 263FP K4B are added because they provide a trip input for breaker NB00112 (XNB01 input breaker to NB01). Cable 15NBK16AA supplies 125VDC to the sudden pressure monitor that contains the two relays at XNB01. Failure of this cable does not cause the relays to

 <b>ENERCON</b> <i>Excellence—Every project. Every day.</i>	<b>UPDATE TO WCNO  CALCULATION XX-E-013,  PFSSD ANALYSIS</b>	CALC NO. <b>WCN-025-CALC-010</b>
		REV. <b>0</b>
		PAGE NO. <b>5 of 8</b>

change state and cause a loss of power to XNB01. Therefore, cable 15NBK16AA is not a PSFFD related cable. Drawing E-1F9425 impacted by this change and will be revised by DCP 020021 via WIP-E-1F9425-002-A-1. The proposed changes to XX-E-013 as a result of DCP 020021 are acceptable.


### 3.0 References

- 3.1 Wolf Creek Calculation XX-E-013, PFSSD Analysis, Rev. 4
- 3.2 E-074-00007, Outline (Tran-Sealed), Rev. W09
- 3.3 DCP 020021, XNB01 Replacement, Rev. 0
- 3.4 E-1F9425, Post Fire Safe Shutdown Logic Diagram Support Function – Electrical, NB001 Off-Site Power Availability, Rev. 2
- 3.5 E-1F9910, Post Fire Safe Shutdown Fire Area Analysis, Rev. 15
- 3.6 E-022-00029, Relay Panels and Fabrication Details, (related to MA104F), Rev. W12
- 3.7 E-022-00043, Transformer Feeder Wiring (related to XNB01), Rev. W09
- 3.8 E-15000, Electrical Cable and Raceway List, Rev. 67
- 3.9 E-1R4431, Raceway Plan Turbine Building Area-3 EL. 2033'-0", Rev. 2
- 3.10 E-1R4331, Raceway Plan Turbine Building Area-3 EL. 2000'-0", Rev. 1
- 3.11 E-1R4321, Raceway Plan Turbine Building Area-2 EL. 2000'-0", Rev. 2
- 3.12 E-1R4322, Exposed Conduit Turbine Building Area-2 EL. 2000'-0", Rev. 4
- 3.13 E-13NB10, Schematic Diagram 13.8kv XNB01 Breaker Rev. 3

### 4.0 Assumptions


There are no assumptions used in the calculation.

### 5.0 Design Inputs

 <b>ENERCON</b> <i>Excellence—Every project. Every day.</i>	<b>UPDATE TO WCNOC CALCULATION XX-E-013, PFSSD ANALYSIS</b>	<b>CALC NO.</b> <b>WCN-025-CALC-010</b>
		<b>REV.</b> <b>0</b>
		<b>PAGE NO.</b> <b>6 of 8</b>

Reviews of existing change notices against XX-E-013 were performed to determine if any of the documents impact the changes being performed by DCP 020021. Results are as follows:

- XX-E-013-004-CN001 – VOID
- XX-E-013-004-CN002 – FINAL – DCP 14209 removes the HMCP breakers from MCC cubicles NG03DBF6 and NG04DBF6, which were added as PFSSD components in CCN XX-E-013-002-CN014 per DCP 13800. These breaker cubicles provide power and control functions for Train A and B emergency diesel generator room supply fan motors DCGM01A and DCGM01B, respectively. Due to breaker coordination issues, DCP 14209 will modify the power supply to supply 480 VAC power to the diesel generator room supply fan motors DCGM01A and DCGM01B directly from new load center breakers NG0308 and NG0408, respectively. Breakers NG0308 and NG0408 will supply power to the fan control functions within NG03DBF6 and NG04DBF6, respectively. Therefore, MCC cubicles NG03DBF6 and NG04DBF6 will remain as PFSSD components. The changes per this update do not impact the evaluation performed by this calculation.
- XX-E-013-004-CN003 – COMMITTED – Change Package 14658 is replacing cable from EDGs speed signal generators to the EDGs speed switches. Appendices 1, 2 and 3 are updated to reflect these changes. The changes per this update do not impact the evaluation performed by this calculation.
- XX-E-013-004-CN004 – FINAL - CP 15070 is changing the 120VAC source from system NG to NN for the control room a/c unit inlet and exhaust dampers GKHZ0029A/B (Train A) & GKHZ0040A/B (Train B).

 <b>ENERCON</b> <i>Excellence—Every project. Every day.</i>	<b>UPDATE TO WCNOG CALCULATION XX-E-013, PFSSD ANALYSIS</b>	<b>CALC NO.</b> <b>WCN-025-CALC-010</b>
		<b>REV.</b> <b>0</b>
		<b>PAGE NO.</b> <b>7 of 8</b>

The changes per this update do not impact the evaluation performed by this calculation.

## 6.0 Methodology

This calculation is a tabulation of cables and components that are required to support the PFSSD power sources and functions. XNB01 is a power source that is required to support the PFSSD functions. The impact of the LTC controls on the PFSSD power supply function was reviewed and determined to not impact the PFSSD power supply function of XNB01. PFSSD components associated with XNB01 are listed in calculation XX-E-013. Some of the components are being removed by DCP 020021. The calculation was reviewed and components 287/T1(B) and 287/T1(C) are removed from the plant and will be removed from the calculation. Relay 287/T1(A) is changed to 287/T1(A,B,C) because the new digital relay monitors all three phases. Fault pressure monitors 263-1/T1 and 263-2/T1 are being removed from the plant and will be removed from the calculation. Auxiliary relays 263X-1/T1 and 263X-2/T1 are being disconnected/“abandoned-in-place” and will be removed from the calculation. A new sudden pressure monitor at XNB01 contains trip relays that are used to trip the NB00112 breaker on a fault pressure signal, 263FP relays K4A and K4B. These relays will be added to the calculation. The changes to the relays also impact drawing E-1F9425. This drawing update will be addressed in DCP 020021 via WIP-E-1F9425-002-A-1. PK4115 via cable 15NBK16AA supplies 125VDC to the sudden pressure monitor. Failure of this power source or cable does not cause the relays to change state and loss of XNB01. Therefore, PK4115 and cable 15NBK16AA are not required for PFSSD.

**APPENDIX 1**  
**PFSSD FUNCTION EVALUATIONS**  
**(PFSSD SUPPORT)**

CALCULATION NO. XX-E-013

REVISION NO. 4

Page 63

PA0210 is included in the PFSSD design because PA0210 control section provides control power for PA02. No PFSSD loads other than PA02 control power are supplied by PA0210.

Off-site power availability requires that off-site power cables and cables associated with XNB01 and XNB02 protective relays remain free of fire damage. The power cables are associated with the circuit breakers in the preceding table. Off-site protective relays and potential transformers required for PFSSD are identified in Appendix 4 and Appendix 3.

The above discussion addresses safety-related power required for post fire safe shutdown. A limited number of components derive their power from non-safety related busses (PA01 and PA02). The non-safety related power is normally supplied from the unit auxiliary transformer (XMR02). On a failure of XMR02 or the power to XMR02, a fast bus transfer to the start-up transformer (XMR01) occurs. The power path from XMR02 is not included in the PFSSD design because the XMR01 power path is in the PFSSD design. Other than 480V MCCs, there are no other non-safety related PFSSD loads powered from PA01 and PA02. Controls required for off-site and on-site power are identified in Appendix 3.

Forced cooling of ESF transformers XNB01 and XNB02 is not required for PFSSD. Each transformer has a self-cooled rating of 12 MVA and a forced air cooled rating of 16 MVA. The maximum design basis accident (DBA) load is approximately 6 MW which equates to 6 MVA assuming a power factor of 1 (actual power factor is between 0.8 and 1.0). Therefore, there is a 100% margin for the DBA loading for the self-cooled rating. PFSSD loading would be equal to or less than the DBA rating since some of the DBA loads are not credited for PFSSD (e.g. containment spray pumps and safety injection pumps). Therefore, there is adequate justification for not including ESF transformer cooling in the PFSSD analysis.

Lower medium voltage – 4.16KV components and relays required for PFSSD are identified in Appendix 4 and Appendix 3.

An evaluation of the potential for a fire-induced loss of off-site power is contained in Appendix 2. This evaluation identified the plant locations where a fire initiated loss of off-site power (loss of non-safety related power) could occur.

Low Voltage System – 480V

XNB01 has a Load Tap Changer (LTC) that is used to maintain a set voltage level on the NB01 bus even though voltage level changes on the 13.8kV switchyard supply voltage may occur. This function is local to the transformer. The power for the LTC controller is supplied from the 480VAC power supply to the transformer for auxiliary loads, such as fans. When operated in a "fixed tap" position (fixed tap setting by Operations) the transformer functions as a standard step down transformer and there are no new failure modes. When placed in the "automatic" mode of operation, the LTC controller monitors the 13.8 kV input and adjusts the tap changer position to maintain the NB01 voltage level at a set level. A failure of the main LTC controller would result in the LTC controls being shifted to the backup LTC controller and the Control Room being informed of the change via an alarm. A loss of 480VAC power to XNB01 will result in loss of power to the main and backup LTC controllers. This would keep the tap setting at a fixed position (the same as the "fixed tap" operation) and the transformer functions as a standard step down transformer. Therefore, a loss of power to the LTC controllers will not impact the PFSSD function of XNB01.

**APPENDIX 2  
LOSS OF OFF-SITE POWER  
EVALUATION**

CALCULATION NO. XX-E-013

REVISION NO. 4  
Page 7

TABLE A

## OFF-SITE POWER AND EMERGENCY DIESEL GENERATOR CABLES

CABLE	ASSOCIATED BUS / DIESEL GENERATOR				DESCRIPTION
	NB01	DG A	NB02	DG B	
14NEB02AH				X	Emergency Diesel Generator B
14NEB02AJ				X	Emergency Diesel Generator B
14NEB02AL				X	Emergency Diesel Generator B
14NEB02AM				X	Emergency Diesel Generator B
14NEB02AN				X	Emergency Diesel Generator B
14NEB02AP				X	Emergency Diesel Generator B
14NEB02AQ				X	Emergency Diesel Generator B
14NEB02AR				X	Emergency Diesel Generator B
14NEB02AS				X	Emergency Diesel Generator B
14NEB02AU				X	Emergency Diesel Generator B
14NEB02AV				X	Emergency Diesel Generator B
14NEB11AA				X	Emergency Diesel Generator B
14NEB11AB				X	Emergency Diesel Generator B
14NEB11AC				X	Emergency Diesel Generator B
14NEB11AD				X	Emergency Diesel Generator B
14NEB11AF				X	Emergency Diesel Generator B
14NEB11AG				X	Emergency Diesel Generator B
14NEB11AJ				X	Emergency Diesel Generator B
14NEK13AA				X	Emergency Diesel Generator B
14NEK13AD				X	Emergency Diesel Generator B
14NEK13AE				X	Emergency Diesel Generator B
14NEK13AH				X	Emergency Diesel Generator B
14NEK13AJ				X	Emergency Diesel Generator B
15MRK10AA			X		XMR01 fault pressure switch 463-1/T2 XMR01 fault pressure switch 463-2/T2 XMR01 fault pressure relay 463X-1/T2 XMR01 fault pressure relay 463X-2/T2
15MRK10AE			X		XMR01 Deluge Relay AR7
15MRK10AF			X		XMR01 Trip On PA0201 Phase Overcurrent
15MRM11AA	XNB01 Fault Pressure Trip Monitor relays 263FP K4A and K4B		X		XMR01 Transformer Cooling
15MRM11AC			X		XMR01 Lockout Relay Cooling and Oil Level Trips
15MRX01AG			X		XMR01 Phase Differential Relay 487/T1
15MRX01AL			X		XMR01 Neutral Ground Relay 251N-1/T1 XMR01 Neutral Ground Relay 251N-2/T1
15MRX01AN			X		XMR01 Feeder to PA0110
15NBA10AA	X				NB0112 Lockout Relay 286-1/T1 NB0212 Lockout Relay 286-2/T1
15NBA10AC	X				XNB01 Fault Pressure Switch 263-1/T1 XNB01 Fault Pressure Relay 263X-1/T1 XNB01 Fault Pressure Switch 263-2/T1 XNB01 Fault Pressure Relay 263X-2/T1

APPENDIX 4  
PFSSD RELAY LIST

(Sorted by Relay Location / Relay ID)

CALCULATION NO. XX-E-013

REVISION NO. 4

Page 4

Relay ID	S/G	Relay Name	Room	Fire Area	Relay Location	SSD Fun	Sprtd Fun	Hot Stdbly	Cold Shdwn	Normal Shdwn	Alt Shdwn	Schematic / One Line	Other Drawing	Power Feeder Breaker	Notes	Logic Diagram (E-1F)	R E V
TSR	4	Test Start Relay	5201	D-2	KJ122	S	R, M, H	X	X	X	X	E-13KJ03A	M-018-00105 M-018-00106	NK5414	—	9411B 9412B	0
286/T1	6	Lockout Relay						X	X	X	—				—	9426	0
486/T1	5	Lockout Relay						X	X	X	—	E-11MR01 E-13MR10 E-13NB11	—	PK6204 PK6106	—	9426	0
151N/T1	5	Ground Fault Current Relay	4401W	TURB	MA104F	S	R, M, H	X	X	X	—	E-13NB10	—	PK6108	—	9425	0
263X-1/T1	5	Fault Pressure Switch Relay	4401W	TURB	MA104F	S	R, M, H	X	X	X	—	E-13NB10	—	PK6108	—	9425	0
263X-2/T1	5	Fault Pressure Switch Relay	4401W	TURB	MA104F	S	R, M, H	X	X	X	—	E-13NB10	—	PK6108	—	9425	0
287/T1(A)	6	Phase A Differential Current Relay	4401W	TURB	MA104F	S	R, M, H	X	X	X	—	E-13NB10	—	PK6108	—	9425	0
287/T1(B)	6	Phase B Differential Current Relay	4401W	TURB	MA104F	S	R, M, H	X	X	X	—	E-13NB10	—	PK6108	—	9425	0
287/T1(C)	6	Phase C Differential Current Relay	4401W	TURB	MA104F	S	R, M, H	X	X	X	—	E-13NB10	—	PK6108	—	9425	0
94-1/T	6	Switchyard Trip Relay	4401W	TURB	MA104F	S	R, M, H	X	X	X	—	E-13NB10	—	PK6108	—	9425	0
127-1/DG	1	NB01 Undervoltage Relay	3301	C-9	NB0101	S	R, M, H	X	X	X	—	E-12NF01 E-13NB01 E-13NF01	—	NB0101	—	9411A 9412A	0
152 STA	1	AC Circuit Breaker Stationary Contact	3301	C-9	NB0104	S	R, M, H	X	X	X	—	E-13EG01A	—	NK4101	—	9401A 9401B	0
152 STA	1	287/T1 (A,B,C) Phase A,B,C Differential Current Relay	3301	C-9	NB0108	S	R, M, H	X	X	X	—	E-13EG01A E-13EG01B	—	NK4101	—	9401A 9401B	0
186/M	1	Lockout Relay	3301	C-9	NB0107	S	R, M, H	X	X	X	—	E-13EG01A	—	NK4101	—	9401A	0
152 STA	1	AC Circuit Breaker Stationary Contact	3301	C-9	NB0108	S	R, M, H	X	X	X	—	E-13EG01A E-13EG01B	—	NK4101	—	9401A 9401B	0
186/M	1	Lockout Relay	3301	C-9	NB0108	S	R, M, H	X	X	X	—	E-13EG01B	—	NK4101	—	9401A	0
125/F	1	Synchronizing Check Relay	3301	C-9	NB0109	S	R, M, H	X	X	X	—	E-13NB02 E-13NB13	—	NK4101	—	9425	0
152 STA	1	AC Circuit Breaker Stationary Contact	3301	C-9	NB0109	S	R, M, H	X	X	X	—	E-13NE10	—	NK4101	—	9423	0
186/F	1	Lockout Relay	3301	C-9	NB0109	S	R, M, H	X	X	X	—	E-13NB13 E-13NE10	—	NK4101	—	9423 9425	0
286-2/T2	1	Lockout Relay	3301	C-9	NB0109	S	R, M, H	X	X	X	—	E-13NB13	—	NK4101	—	9425	0

These two relays are no longer inservice and can be removed.

These two relays are removed from the plant.

**APPENDIX 4**  
**PFSSD RELAY LIST**

CALCULATION NO. XX-E-013

REVISION NO. 4

Page 24

(Sorted by Relay Location / Relay ID)

Relay ID	S/G	Relay Name	Room	Fire Area	Relay Location	SSD Fun	Sprtd Fun	Hot Stdbby	Cold Shdwn	Normal Shdwn	Alt Shdwn	Schematic / One Line	Other Drawing	Power Feeder Breaker	Notes	Logic Diagram (E-1F)	R E V
K526	4	Safety Injection Master Relay	3605	C-27	SB032D	S	R, M, H	X	X	X	—	—	M-767-00374 M-767-00350	NK4416 NN0412	—	9432	0
K713	4	Pressurizer High Pressure Relay	3601	C-27	SB032D	M	—	X	X	X	—	E-13BB40 E-13SB05	M-767-00186 M-767-00189	NK4421 NN0412 NK4416	BBPCV0456A opens if K713 is energized. XX-E-013-002-CN002	9301	3
K726	4	Low-Low T <sub>AVG</sub> or ABHS0064 in 'OFF/RESET' Relay	3605	C-27	SB032D	R, H	—	X	—	X	—	E-13AB08	M-767-00188	NK4416 NN0412	—	9103	0
K727	4	Low-Low T <sub>AVG</sub> or ABHS0064 in 'OFF/RESET' Relay	3605	C-27	SB032D	R, H	—	X	—	X	—	E-13AB11A E-13AB11B E-13AB11C	M-767-00188	NK4416 NN0412	—	9103	0
K728	4	Low-Low T <sub>AVG</sub> or ABHS0064 in 'OFF/RESET' Relay	3605	C-27	SB032D	R, H	—	X	—	X	—	E-13AB11C	M-767-00188	NK4416 NN0412	—	9103	0
K734	4	High-1 RCS Pressure Relay	3605	C-27	SB032D	H	—	—	X	—	—	E-13BB12A E-13BB12B	M-767-00186 M-767-00189	NG02BCF2 NG02BBF3 NN0412 NK4416	—	9205	0
K740	4	Safety Injection Signal Relay	3605	C-27	SB032D	H	—	—	X	—	—	E-13EJ06B E-13SB05	M-767-00189	NG02BEF2 NN0412 NK4416	—	9205	0
K741	4	RWST Low-Low 1 Level Relay	3605	C-27	SB032D	H	—	—	X	—	—	E-13EJ06B E-13SB05	M-767-00189	NG02BEF2 NN0412 NK4416	—	9205	0
K811	4	Block Test Relay	3605	C-27	SB033A	M	—	X	X	X	X	E-13BB40	—	NK4421	—	9301	0
263-1/T1	5	Fault Pressure Switch Relay	Yard	—	XNB01	S	R, M, H	X	X	X	—	E-13NB10	—	PK6108	—	9425	0
263-2/T1	5	Fault Pressure Switch Relay	Yard	—	XNB01	S	R, M, H	X	X	X	—	E-13NB10	—	PK6108	—	9425	0
263-1/T2	6	Fault Pressure Switch Relay	Yard	—	XNB02	S	R, M, H	X	X	X	—	E-13NB11 E-13PA14	—	PK6204	—	9426	0
263-2/T2	6	Fault Pressure Switch Relay	Yard	—	XNB02	S	R, M, H	X	X	X	—	E-13NB11 E-13PA14	—	PK6204	—	9426	0

263FP (K4A)

PK4115

263FP (K4B)

PK4115 is connected to cable 15NBK16AA. This supplies power to the monitor that houses relays at XNB01. PK4115 and associated cable 15NBK16AA are not required for PFSSD. Loss of power or cable failure will not cause a loss of XNB01.

<b>WCNOC</b>	<b>OWNER'S ACCEPTANCE REVIEW CHECKLIST FOR EXTERNAL CALCULATIONS AND SPECIFICATIONS</b>		<b>PAGE 1 OF 5</b>
	Title: Post Fire Safe Shutdown (PFSSD) Analysis		
	Wolf Creek document #: XX-E-013-004-CN005	Revision #: N/A	
ECDE: Enercon			

INITIATING DOCUMENT and revision: (e.g., PO, CR, SWO)	CP 020021 R/0
--	---------------

CHANGE TYPE:

☒

Calculation

☐

Specification

SAFETY CLASS:

☐



SR

☒

SS

☐

NSR

WCNOC Reviewer signature:	DigsigVer 5, 0.45  	Date:	09/26/18
WCNOC Approver:	DigsigVer 5, 0.45  	Date:	10/02/2018

Prepared By:	Init / Date
William M. Wilkins	WMW 9/26/18

<b>WCNOC</b>	<b>OWNER'S ACCEPTANCE REVIEW CHECKLIST FOR EXTERNAL CALCULATIONS AND SPECIFICATIONS</b>		<b>PAGE 2 OF 5</b>
	Title: Post Fire Safe Shutdown (PFSSD) Analysis		
	Wolf Creek document #: XX-E-013-004-CN005	Revision #: N/A	
ECDE: Enercon			

No.	Question	Instructions and Guidance	YES	NO	N/A
1	Do assumptions have sufficient documented rationale?	<p>All Assumptions should be stated in clear terms with enough justification to confirm that the assumption is conservative:</p> <p>For example, 1) the exact value of a particular parameter may not be known or that parameter may be known to vary over the range of conditions covered by the Calculation. It is appropriate to represent or bound the parameter with an assumed value. 2) The predicted performance of a specific piece of equipment in lieu of actual test data. It is appropriate to use the documented opinion/position of a recognized expert on that equipment to represent predicted equipment performance.</p> <p>Consideration should also be given as to any qualification testing that may be needed to validate the Assumptions. Ask yourself, would you provide more justification if you were performing this analysis? If yes, the rationale is likely incomplete.</p>			X
2	Are assumptions compatible with the way the plant is operated and with the licensing basis?	<p>Ensure the documentation for source and rationale for the assumption supports the way the plant is currently or will be operated post change and they are not in conflict with any design parameters. If the Analysis purpose is to establish a new licensing basis, this question can be answered yes, if the assumption supports that new basis.</p>			X

<b>WCNOC</b>	<b>OWNER'S ACCEPTANCE REVIEW CHECKLIST FOR EXTERNAL CALCULATIONS AND SPECIFICATIONS</b>		<b>PAGE 3 OF 5</b>
	Title: Post Fire Safe Shutdown (PFSSD) Analysis		
	Wolf Creek document #: XX-E-013-004-CN005	Revision #: N/A	
ECDE: Enercon			

No.	Question	Instructions and Guidance	YES	NO	N/A
3	Do all unverified assumptions have a tracking and closure mechanism in place?	If there are unverified assumptions without a tracking mechanism indicated, then create the tracking item either through an ATI or a work order attached to the implementing WO. Due dates for these actions need to support verification prior to the analysis becoming operational or the resultant plant change being op authorized.			X
4	Do the design inputs have sufficient rationale?	The origin of the input, or the source should be identified and be readily retrievable within WCNOC's documentation system. If not, then the source should be attached to the analysis. Ask yourself, would you provide more justification if you were performing this analysis? If yes, the rationale is likely incomplete.	X		
5	Are design inputs correct and reasonable with critical parameters identified, if appropriate?	The expectation is that an WCNOC Engineer should be able to clearly understand which input parameters are critical to the outcome of the analysis. That is, what is the impact of a change in the parameter to the results of the analysis? If the impact is large, then that parameter is critical.	X		
6	Are design inputs compatible with the way the plant is operated and with the licensing basis?	Ensure the documentation for source and rationale for the inputs supports the way the plant is currently or will be operated post change and they are not in conflict with any design parameters.	X		
7	Are Engineering Judgments clearly documented and justified?	Ask yourself, would you provide more justification if you were performing this analysis? If yes, the rationale is likely incomplete.			X

<b>WCNOC</b>	<b>OWNER'S ACCEPTANCE REVIEW CHECKLIST FOR EXTERNAL CALCULATIONS AND SPECIFICATIONS</b>		<b>PAGE 4 OF 5</b>
	Title: Post Fire Safe Shutdown (PFSSD) Analysis		
	Wolf Creek document #: XX-E-013-004-CN005	Revision #: N/A	
ECDE: Enercon			

No.	Question	Instructions and Guidance	YES	NO	N/A
8	Are Engineering Judgments compatible with the way the plant is operated and with the licensing basis?	Ensure the justification for the engineering judgment supports the way the plant is currently or will be operated post change and is not in conflict with any design parameters. If the Analysis purpose is to establish a new licensing basis, then this question can be answered yes, if the judgment supports that new basis.			X
9	Do the results and conclusions satisfy the purpose and objective of the Design Analysis?	Why was the analysis being performed? Does the stated purpose match the expectation from WCNOC on the proposed application of the results? If yes, then the analysis meets the needs of the contract.	X		
10	Are the results and conclusions compatible with the way the plant is operated and with the licensing basis?	Make sure that the results support the USAR defined system design and operating conditions, or they support a proposed change to those conditions. If the analysis supports a change, are all of the other changing documents included on the cover sheet as impacted documents?	X		
11	Have any limitations on the use of the results been identified and transmitted to the appropriate organizations?	Does the analysis support a temporary condition or procedure change? Make sure that any other documents needing to be updated are included and clearly delineated in the design analysis. Make sure that the cover sheet includes the other documents where the results of this analysis provide the input.			X
12	Have margin impacts been identified and documented appropriately for any negative impacts.	Make sure that the impacts to margin are clearly shown within the body of the analysis. If the analysis results in reduced margins ensure that this has been appropriately dispositioned in the EC being used to issue the analysis.			X

<b>WCNOC</b>	<b>OWNER'S ACCEPTANCE REVIEW CHECKLIST FOR EXTERNAL CALCULATIONS AND SPECIFICATIONS</b>		<b>PAGE 5 OF 5</b>
	Title: Post Fire Safe Shutdown (PFSSD) Analysis		
	Wolf Creek document #: XX-E-013-004-CN005	Revision #: N/A	
ECDE: Enercon			

No.	Question	Instructions and Guidance	YES	NO	N/A
13	Does the Design Analysis include the applicable design basis documentation?	Are there sufficient documents included to support the sources of input, and other reference material that is not readily retrievable in WCNOC controlled Documents?			X
14	Have all affected design analyses been documented on the Affected Documents List (ADL) for the associated ConfiQuration Change?	Determine if sufficient searches have been performed to identify any related analyses that need to be revised along with the base analysis. It may be necessary to perform some basic searches to validate this.			X
15	Do the sources of inputs and analysis methodology used meet committed technical and regulatory requirements?	Compare any referenced codes and standards to the current design basis and ensure that any differences are reconciled. If the input sources or analysis methodology are based on an out-of-date methodology or code, additional reconciliation may be required if the site has since committed to a more recent code			X
16	Have vendor supporting technical documents and references (including GE DRFs) been reviewed when necessary?	Based on the risk assessment performed during the pre-job brief for the analysis, ensure that sufficient reviews of any supporting documents not provided with the final analysis are performed.			X
17	Does the design include any digital assets? If so, does it adequately address digital and cyber security requirements?	Ensure the design addresses and meets digital and cyber security requirements. Refer to AP 15D-008 and contact the Cyber Security Group to perform additional reviews prior to approval. The CSAT is required to review modifications impacting Cyber Security.	X		

- END -