VIRGINIA ELECTRIC AND POWER COMPANY Richmond, Virginia 23261

March 13, 1975

Stor Same A. 272

Office of Plans and Schedules Division of Reactor Licensing United States Nuclear Regulatory Commission Washington, D. C. 20555 Serial No. 432/021974 PO&M/JTB:clw

Docket Nos. 50-280 50-281 License Nos. DPR-32 DPR-37

Dear Sir:

Pursuant to Mr. L. Manning Muntzing's directive of February 19, 1974 requiring that certain operating information be forwarded to you on a monthly basis, the Virginia Electric and Power Company submits the information enclosed herewith for the month of February 1975.

Very truly yours,

7. Stallings

C. M. Stallings Vice President-Power Supply and Production Operations

Attachments

cc: Mr. Norman C. Moseley, Director Region II

DOCKET NO. <u>50-280</u>

UNIT Surry Unit No. 1

DATE 3-3-75

COMPLETED BY W. C. Earl

AVERAGE DAILY UNIT POWER LEVEL

MONT	HFEBRUARY		
DAY	AVERAGE DAILY POWER LEVEL (MWe-net)	DAY	AVERAGE DAILY POWER LEVEL (MWe-net)
1	0	17	762.3
2	3.9	18	764.0
3	237.6	19	766.8
4	272.2	20 ⁻	767.5
5	638.0	21	767.6
6	764.5	22	756.9
7	768.4	23	709.1
8	773.4	24	753.1
9	295.8	25	624.7
10	649.6	26	97.2
11	766.2	27	764.3
12	764.5	28	714.6
13	765.5	29	
14	736.7	. 30	
15	760.5	31	
16	742.4		•
			-

DAILY UNIT POWER LEVEL FORM INSTRUCTIONS

On this form, list the average daily unit power level in MWe-net for each day in the reporting month. Compute to the nearest whole megawatt.

These figures will be used to plot a graph for each reporting month. Note that by using maximum dependable capacity for the net electrical rating of the unit, there may be occasions when the daily average power level exceeds the 100% line (or the restricted power level line). In such cases, the average daily unit power output sheet should be footnoted to explain the apparent anomaly.

Surry Unit No.]
3-3-75
W. C. Earl
50-280

OPERATING STATUS

1.	REPORTING PERIOD:	0001	750201	THROUGH	2400	750228	
	HOURS IN REPORTING	PERIOD:	672				

2. CURRENTLY AUTHORIZED POWER LEVEL (MWth) 2441 MAX. DEPENDABLE CAPACITY (MWe-NET) 788

3. LOWEST POWER LEVEL TO WHICH SPECIFICALLY RESTRICTED (IF ANY) (MWe-NET):

4. REASONS FOR RESTRICTION (IF ANY):

		THIS		CUMULATIVE
		REPORTING PERIOD	YR TO DATE	TO DATE
		665.3	707 5	11 621 0
5.	HOURS REACTOR WAS CRITICAL		707.5	11,431.9
6.	REACTOR RESERVE SHUTDOWN HOURS		0	0
7.	HOURS GENERATOR ON LINE	590.7	<u> 590.7 </u>	<u>11,008.2</u>
8.	UNIT RESERVE SHUTDOWN HOURS	. 0	0	0
9.	GROSS THERMAL ENERGY	•		
	GENERATED (MWH)	<u>1,329,659</u>	<u>1,330,27</u> 0	<u>23,386,29</u> 1
10.	GROSS ELECTRICAL ENERGY			
	GENERATED (MWH)		434,615	<u>7,762,378</u>
11.	NET ELECTRICAL ENERGY GENERATED	412,497	412,497	7,342,850
	(MWH)	· · · · · · · · · · · · · · · · · · ·		
12.	REACTOR AVAILABILITY FACTOR (1)		50.0	59.6
13.	UNIT AVAILABILITY FACTOR (2)	87.9	41.7	57.4
14.	UNIT CAPACITY FACTOR (3)	77.9	37.0	48.6
15.	UNIT FORCED OUTAGE RATE (4)	1.0	1.0	29.2

16. SHUTDOWNS SCHEDULED TO BEGIN IN NEXT 6 MONTHS (STATE TYPE, DATE, AND DURATION OF EACH):

17. IF SHUT DOWN AT END OF REPORT PERIOD, ESTIMATED DATE OF STARTUP: ____

18. UNITS IN TEST STATUS (PRIOR TO COMMERCIAL OPERATION) REPORT THE FOLLOWING:

				DATE LAST FORECAST	DATE ACHIEVED
			INITIAL CRITICALITY		<u></u>
			INITIAL ELECTRICAL POWER GENERATION		•
	• .		COMMERCIAL OPERATION	<u> </u>	<u></u> ·
			·		
(1)	REACTOR AVAILABILITY FACTOR	=	HOURS REACTOR WAS CRITICAL HOURS IN REPORTING PERIOD		
(2)	UNIT AVAILABILITY FACTOR	=	HOURS GENERATOR ON LINE HOURS IN REPORTING PERIOD X 100		
. (3)	UNIT CAPACITY FACTOR	8	NET ELECTRICAL POWER GENERATED MAX. DEPENDABLE CAPACITY (MWe-NET) X H	OURS IN REPOR	RTING PERIOD
(4)	UNIT FORCED OUTAGE RATE	H	FORCED OUTAGE HOURS HOURS GENERATOR ON LINE + FORCED OUTA	GE HOURS X	100

.

UNIT SHUTDOWNS

DOCKET NO. <u>50-280</u>

UNIT NAME Surry Unit No. 1

DATE <u>3-3-75</u>

COMPLETED BY W. C. Earl

REPORT MONTH _____FEBRUARY____

NO.	DATE	TYPE F-FORCED S-SCHEDULED	DURATION (HOURS)	REASON (1)	METHOD OF SHUTTING DOWN THE REACTOR (2)	CORRECTIVE ACTIONS/COMMENTS
74-21	102474	S	31.8	С	3.	Unit was down for refueling
75-1	020275	F	1.5	Н	3	Error in wiring caused feed reg. valve t fail open.
75-2	020275	F	0.7	G	3	Low steam generator level and steam flow F.W. flow mismatch.
75-3	020275	F	1.0	G ·	3	Same as above.
75-4	020275		0.6	G	3	Same as above.
7.5-5	020375	F F	0.6	G	3	Same as above.
75-6	020975	S	0.6	В	1	PT-1.4 100 per cent load reject.
75-7	020975	F	0.9	G	3	Operator error.
75-8	022575	F	0.8	G	3	High steam generator level and steam flow/f.f. mismatch.
		۱ ۱ ۱ ۱ ۱ ۱				 (1) REASON (2) METHOD AEQUIPMENT FAILURE (EXPLAIN) B-MAINT. OR TEST 2-MANUAL CREFUELING D-REGULATORY RESTRICTION E-OPERATOR TRAINING AND LICENSE EXAMINATION F-ADMINISTRATIVE G-OPERATIONAL ERROR (EXPLAIN) H-OTHER (EXPLAIN)

SUMMARY:

DOCKET NO. <u>50-281</u>

UNIT Surry Unit No. 2

DATE <u>3-3-75</u>

COMPLETED BY W. C. Earl

AVERAGE DAILY UNIT POWER LEVEL

MONTI	HFEBRUARY		
DAY	AVERAGE DAILY POWER LEVEL (MWe-net)	DAY	AVERAGE DAILY POWER LEVEL (MWe-net)
1	757.2	17	741.2
2	287.2	18	767.4
3	372.3	19	762.8
4	715.0	20	763.0
5	744.7	21	763.0
6	752.2.	22	752.5
7	748.4	23	733.2
8	677.1	24	764.2
9	746.4	25	761.3
10	749.1	26	729.5
11	751.6	27	760.2
12	758.3	28	761.4
13	758.7	29	
14	762.4	30	<u></u>
15	. 761.1	31	
16	621.4		•

DAILY UNIT POWER LEVEL FORM INSTRUCTIONS

On this form, list the average daily unit power level in MWe-net for each day in the reporting month. Compute to the nearest whole megawatt.

These figures will be used to plot a graph for each reporting month. Note that by using maximum dependable capacity for the net electrical rating of the unit, there may be occasions when the daily average power level exceeds the 100% line (or the restricted power level line). In such cases, the average daily unit power output sheet should be footnoted to explain the apparent anomaly.

UNIT .	Surry	Unit	No.	_2
DATE	3-3-7	5		
COMPLETED BY				-
DOCKET NO.				
DOCKET NO.				-

OPERATING STATUS

1.	REPORTING PERIOD:	0001	750201	~	_ THROUGH	2400	750228	
	HOURS IN REPORTING	PERIOD:	672	0112				<u></u>

2. CURRENTLY AUTHORIZED POWER LEVEL (MWth) 2441 MAX. DEPENDABLE CAPACITY (MWe-NET) 788

3. LOWEST POWER LEVEL TO WHICH SPECIFICALLY RESTRICTED (IF ANY) (MWe-NET):____

4. REASONS FOR RESTRICTION (IF ANY):

		THIS REPORTING PERIOD	YR TO DATE	CUMULATIVE TO DATE
		KEFOR HING FERIOD	INTODAIL	TODATE
5.	HOURS REACTOR WAS CRITICAL.	655.9	1,319.2	9,828.2
6.	REACTOR RESERVE SHUTDOWN HOURS		0	304.3
7.	HOURS GENERATOR ON LINE	653.7	1,295.1	9.679.3
8.	UNIT RESERVE SHUTDOWN HOURS	0	0	0
9.	GROSS THERMAL ENERGY			
	GENERATED (MWH)	<u>1,539,183</u>	2,910,646	<u>21,135,43</u> 5
10.	GROSS ELECTRICAL ENERGY			
	GENERATED (MWH)	505,670	953,485	<u>6,975,95</u> 2
11.	NET ELECTRICAL ENERGY GENERATED		001 656	
	(MWH)	480,554	904,656	<u>6,603,95</u> 5
12.	REACTOR AVAILABILITY FACTOR (1)		93.2	61.2
13.	UNIT AVAILABILITY FACTOR (2)	97_3	91.5	<u> 60,3 </u>
14.	UNIT CAPACITY FACTOR (3)		<u> </u>	
15.	UNIT FORCED OUTAGE RATE (4)	2.4	8.4	26.7

16. SHUTDOWNS SCHEDULED TO BEGIN IN NEXT 6 MONTHS (STATE TYPE, DATE, AND DURATION OF EACH): Refueling scheduled April 25, 1975; approximately 6 weeks

17. IF SHUT DOWN AT END OF REPORT PERIOD, ESTIMATED DATE OF STARTUP: ____

18. UNITS IN TEST STATUS (PRIOR TO COMMERCIAL OPERATION) REPORT THE FOLLOWING:

				DATE LAST FORECAST	DATE ACHIEVED
	· ·		INITIAL CRITICALITY	<u></u>	
			INITIAL ELECTRICAL POWER GENERATION		
	•		COMMERCIAL OPERATION	<u> </u>	
(1)	REACTOR AVAILABILITY FACTOR	=	HOURS REACTOR WAS CRITICAL HOURS IN REPORTING PERIOD X 100		
(2)	UNIT AVAILABILITY FACTOR	=	HOURS GENERATOR ON LINE HOURS IN REPORTING PERIOD X 100	, ,	
(3)	UNIT CAPACITY FACTOR	=	NET ELECTRICAL POWER GENERATED MAX. DEPENDABLE CAPACITY (MWe-NET) X H	OURS IN REPOF	TING PERIOD
(4)	UNIT FORCED OUTAGE RATE	=	FORCED OUTAGE HOURS HOURS GENERATOR ON LINE + FORCED OUTAG	GE HOURS X	100

UNIT SHUTDOWNS

DOCKET NO. <u>50-281</u>

UNIT NAME Surry Unit No. 2

DATE <u>3-3-75</u>

COMPLETED BY W. C. Earl

REPORT MONTH _____FEBRUARY

NO.	DATE	TYPE F-FORCED S-SCHEDULED	DURATION (HOURS)	REASON (1)	METHOD OF SHUTTING DOWN THE REACTOR (2)	CORRECTIVE ACTIONS/COMMENTS
5-3	020275	F	0.6	G	3	Operator closed 2-FW-78 isolating feed to "C" steam generator in error.
54	020275	F	15.6	G	3	Steam generator low level with steam flow/feed flow mismatch.
			· · ·			
		· · ·				
						(1) REASON(2) METHODAEQUIPMENT FAILURE (EXPLAIN)1-MANUALB-MAINT. OR TEST2-MANUAL
		1				CREFUELING SCRAM D-REGULATORY RESTRICTION 3-AUTOMATI E-OPERATOR TRAINING AND SCRAM
						LICENSE EXAMINATION F-ADMINISTRATIVE
						G-OPERATIONAL ERROR (EXPLAIN) H-OTHER (EXPLAIN)
						;
JMMA						