

VIRGINIA ELECTRIC AND POWER COMPANY  
RICHMOND, VIRGINIA 23261

June 13, 1978

REGISTRATION  
SERVICES UNIT

1978 JUN 15 AM 10 46

REGISTRATION  
SERVICES UNIT

Mr. R. A. Hartfield, Acting Director  
Office of Management Information and  
Program Control  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Serial No. 339  
PO&M/DLB:das  
Docket Nos. 50-280  
50-281  
License Nos. DPR-32  
DPR-37

Dear Mr. Hartfield:

Enclosed are the following reports for Surry Power Station Unit Nos. 1 and 2.

- Attachment 1: Refueling and Spent Fuel Storage Information, Surry Unit No. 1
- Attachment 2: Refueling and Spent Fuel Storage Information, Surry Unit No. 2
- Attachment 3: Monthly Operating Report, Surry Power Station, Unit Nos. 1 and 2; for May 1978.

Very truly yours,

*C. M. Stallings*

C. M. Stallings  
Vice President - Power Supply  
and Production Operations

Enclosures (3 copies)

cc: Dr. Ernst Volgenau, Director (10 copies)  
Office of Inspection and Enforcement

Mr. James P. O'Reilly, Director (1 copy)  
Office of Inspection and Enforcement

781660041

REGULATORY DOCKET FILE COPY

1003  
2/13

ATTACHMENT 1

1. Name: SURRY UNIT NO. 1
2. Next scheduled date for refueling shutdown: 11/1/79
3. Scheduled date for restart following refueling: 5/1/80 (refueling outage extended for steam generator replacement).
4. Technical Specifications Changes: No changes are foreseen due to the reload core design. (The review by both the station and system safety committees will take place prior to submittal of the reload license to NRC.)
5. Scheduled date for reload licensing submittal: 2/1/80
6. Important licensing considerations: None
7. Number of fuel assemblies (as of 6/1/78):
  - a. In the core: 157
  - b. In the spent fuel storage pool:\* 436
8. Licensed spent fuel pool storage capacity:\*
  - a. Current: 1044
9. Projected date of last refueling that can be discharged to the spent fuel storage pool assuming currently licensed capacity: October, 1984.

\*Surry Units No. 1 and 2 share a common spent fuel storage pool.

ATTACHMENT 2

1. Name: SURRY UNIT NO. 2
2. Next scheduled date for refueling shutdown: 10/8/78
3. Scheduled date for restart following refueling: 4/15/79 (refueling outage extended for steam generator replacement)
4. Technical Specifications Changes: No changes are foreseen due to the reload core design (The review by both the station and system safety committees will take place prior to submittal of the reload license to the NRC).
5. Scheduled date for reload licensing submittal: 1/1/79
6. Important licensing considerations: None
7. Number of fuel assemblies (as of 6/1/78)
  - a. In the core: 157
  - b. In the spent fuel storage pool:\* 436
8. Licensed spent fuel pool storage capacity:\*
  - a. Current: 1044
9. Projected date of last refueling that can be discharged to the spent fuel storage pool assuming currently licensed capacity: April, 1985.

---

\*Surry Units No. 1 and 2 share a common spent fuel storage pool.


VIRGINIA ELECTRIC AND POWER COMPANY

SURRY POWER STATION


MONTHLY OPERATING REPORT

REPORT NO. 78-05

MAY, 1978

  
\_\_\_\_\_  
Superintendent - Station Operations

APPROVED:

  
\_\_\_\_\_  
for MANAGER

CONTENTS

<u>Section</u>	<u>Page</u>
Operating Data Report - Unit #1	1
Operating Data Report - Unit #2	2
Unit Shutdowns and Power Reductions - Unit #1	3
Unit Shutdowns and Power Reductions - Unit #2	4
Load Reductions Due to Environmental Restrictions - Unit #1	5
Load Reductions Due to Environmental Restrictions - Unit #2	6
Average Daily Unit Power Level - Unit #1	7
Average Daily Unit Power Level - Unit #2	8
Summary of Operating Experience	9
Amendments to Facility License or Technical Specifications	11
Facility Changes Requiring NRC Approval	12
Facility Changes That Did Not Require NRC Approval	12
Tests and Experiments Requiring NRC Approval	15
Tests and Experiments That Did Not Require NRC Approval	15
Other Changes, Test and Experiments	16
Chemistry Report	17
Description of All Instances Where Thermal Discharge Limits Were Exceeded	18
Fuel Handling	19
Procedure Revisions That Changed the Operating Mode Described in the FSAR	22
Description of Periodic Tests Which Were Not Completed Within The Time Limits Specified in Technical Specifications	23
Inservice Inspection	24
Reportable Occurrences Pertaining to Any Outage or Power Reductions	26
Monthly Operating Supplement Sheet - Mechanical Maint. Unit #1	27
Maintenance of Safety Related Systems During Outage or Reduced Power Periods Unit #1	28

<u>Section</u>	<u>Page</u>
Monthly Operating Supplement Sheet - Mechanical Maint. Unit# 2	31
Maintenance of Safety Related Systems During Outage or Reduced Power Periods - Unit #2	32
Monthly Operating Supplement Sheet - Electrical Dept. Unit #1	33
Maintenance of Safety Related Systems During Outage or Reduced Power Periods - Unit #1	34
Monthly Operating Supplement Sheet - Electrical Maint. Unit #2	36
Maintenance of Safety Related Systems During Outage or Reduced Power Periods - Unit #2	37
Monthly Operating Supplement Sheet Instrument Maint.- Unit #1	38
Maintenance of Safety Related Systems During Outage or Reduced Power Period - Unit 1	39
Monthly Operating Supplement Sheet - Instrument Maint. Unit #2	40
Health Physics	41
Report Of Radioactive Effluents	42
Sensitivity Data	45
Procedure Deviations Reviewed by Station Nuclear Safety and and Operating Committee After Time Limit Specified in T.S.	46

OPERATING DATA REPORT

DOCKET NO. 50-280  
 DATE 6-1-78  
 COMPLETED BY O.J. Costello  
 TELEPHONE 804-357-3184

OPERATING STATUS

1. Unit Name: Surry 1
2. Reporting Period: 0001 780501 - 2400 780531
3. Licensed Thermal Power (MWt): 2441
4. Nameplate Rating (Gross MWe): 847.5
5. Design Electrical Rating (Net MWe): 822
6. Maximum Dependable Capacity (Gross MWe): 811
7. Maximum Dependable Capacity (Net MWe): 775
8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reasons:  
N/A

Notes

9. Power Level To Which Restricted, If Any (Net MWe): N/A
10. Reasons For Restrictions, If Any: N/A

	This Month	Yr.-to-Date	Cumulative
11. Hours In Reporting Period	<u>744</u>	<u>3,623</u>	<u>47,687</u>
12. Number Of Hours Reactor Was Critical	<u>0</u>	<u>2,667</u>	<u>31983.9</u>
13. Reactor Reserve Shutdown Hours	<u>0</u>	<u>0</u>	<u>0</u>
14. Hours Generator On-Line	<u>0</u>	<u>2666.5</u>	<u>31231.7</u>
15. Unit Reserve Shutdown Hours	<u>0</u>	<u>0</u>	<u>0</u>
16. Gross Thermal Energy Generated (MWH)	<u>0</u>	<u>6,486,752</u>	<u>71,627,748</u>
17. Gross Electrical Energy Generated (MWH)	<u>0</u>	<u>2,160,910</u>	<u>23,520,753</u>
18. Net Electrical Energy Generated (MWH)	<u>0</u>	<u>2,057,327</u>	<u>22,324,891</u>
19. Unit Service Factor	<u>0</u>	<u>73.6%</u>	<u>65.5%</u>
20. Unit Availability Factor	<u>0</u>	<u>73.6%</u>	<u>65.5%</u>
21. Unit Capacity Factor (Using MDC Net)	<u>0</u>	<u>73.3%</u>	<u>60.4%</u>
22. Unit Capacity Factor (Using DER Net)	<u>0</u>	<u>69.1%</u>	<u>57%</u>
23. Unit Forced Outage Rate	<u>0</u>	<u>0</u>	<u>16.8%</u>

24. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each):  
None

25. If Shut Down At End Of Report Period, Estimated Date of Startup: 6/30/78

26. Units In Test Status (Prior to Commercial Operation):	Forecast	Achieved
INITIAL CRITICALITY	<u>      </u>	<u>      </u>
INITIAL ELECTRICITY	<u>      </u>	<u>      </u>
COMMERCIAL OPERATION	<u>      </u>	<u>      </u>

OPERATING DATA REPORT

DOCKET NO. 50-281  
 DATE 6-1-78  
 COMPLETED BY O.J. Costello  
 TELEPHONE 804-357-3184

OPERATING STATUS

1. Unit Name: Surry 2
2. Reporting Period: 0001 780501 - 2400 780531
3. Licensed Thermal Power (MWt): 2441
4. Nameplate Rating (Gross MWe): 847.5
5. Design Electrical Rating (Net MWe): 822
6. Maximum Dependable Capacity (Gross MWe): 811
7. Maximum Dependable Capacity (Net MWe): 775
8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reasons:  
N/A

Notes

9. Power Level To Which Restricted, If Any (Net MWe): N/A
10. Reasons For Restrictions, If Any: N/A

	This Month	Yr.-to-Date	Cumulative
11. Hours In Reporting Period	<u>744</u>	<u>3,623</u>	<u>44,567</u>
12. Number Of Hours Reactor Was Critical	<u>616.9</u>	<u>2,993.8</u>	<u>29,406.6</u>
13. Reactor Reserve Shutdown Hours	<u>0</u>	<u>0</u>	<u>0</u>
14. Hours Generator On-Line	<u>614.9</u>	<u>2,988.2</u>	<u>28,917.1</u>
15. Unit Reserve Shutdown Hours	<u>0</u>	<u>0</u>	<u>0</u>
16. Gross Thermal Energy Generated (MWH)	<u>1,493,577</u>	<u>7,267,966</u>	<u>66,978,200</u>
17. Gross Electrical Energy Generated (MWH)	<u>482,750</u>	<u>2,371,315</u>	<u>21,938,709</u>
18. Net Electrical Energy Generated (MWH)	<u>459,395</u>	<u>2,253,597</u>	<u>20,806,714</u>
19. Unit Service Factor	<u>82.6%</u>	<u>82.5%</u>	<u>64.9%</u>
20. Unit Availability Factor	<u>82.6%</u>	<u>82.5%</u>	<u>64.9%</u>
21. Unit Capacity Factor (Using MDC Net)	<u>79.7%</u>	<u>80.3%</u>	<u>60.2%</u>
22. Unit Capacity Factor (Using DER Net)	<u>75.1%</u>	<u>75.7%</u>	<u>56.8%</u>
23. Unit Forced Outage Rate	<u>17.4%</u>	<u>4.1%</u>	<u>23.8%</u>

24. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each):  
Refueling and Steam Generator Inspection - Oct. 15, 1978, 5 weeks.

25. If Shut Down At End Of Report Period, Estimated Date of Startup: N/A

26. Units In Test Status (Prior to Commercial Operation):	Forecast	Achieved
INITIAL CRITICALITY	<u>      </u>	<u>      </u>
INITIAL ELECTRICITY	<u>      </u>	<u>      </u>
COMMERCIAL OPERATION	<u>      </u>	<u>      </u>



**UNIT SHUTDOWNS AND POWER REDUCTIONS**

REPORT MONTH May, 1978

DOCKET NO. 50-280  
 UNIT NAME Surry  
 DATE 6-1-78  
 COMPLETED BY G. Kane  
 TELEPHONE 804-357-3184

No.	Date	Type <sup>1</sup>	Duration (Hours)	Reason <sup>2</sup>	Method of Shutting Down Reactor <sup>3</sup>	Licensee Event Report #	System Code <sup>4</sup>	Component Code <sup>5</sup>	Cause & Corrective Action to Prevent Recurrence
78-1	780501	S	744	C	1				Unit shutdown for the entire month. Refueling completed, turbine repairs in progress, steam generator maintenance in progress.

<sup>1</sup>  
 F: Forced  
 S: Scheduled

<sup>2</sup>  
 Reason:  
 A-Equipment Failure (Explain)  
 B-Maintenance of Test  
 C-Refueling  
 D-Regulatory Restriction  
 E-Operator Training & License Examination  
 F-Administrative  
 G-Operational Error (Explain)  
 H-Other (Explain)

<sup>3</sup>  
 Method:  
 1-Manual  
 2-Manual Scram.  
 3-Automatic Scram.  
 4-Other (Explain)

<sup>4</sup>  
 Exhibit G - Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NUREG-0161)

<sup>5</sup>  
 Exhibit I - Same Source

(9/77)

# UNIT SHUTDOWNS AND POWER REDUCTIONS

REPORT MONTH May, 1978

DOCKET NO. 50-281  
 UNIT NAME Surry 2  
 DATE 6-1-78  
 COMPLETED BY G. Kane  
 TELEPHONE 804-357-3184

No.	Date	Type <sup>1</sup>	Duration (Hours)	Reason <sup>2</sup>	Method of Shutting Down Reactor <sup>3</sup>	Licensee Event Report #	System Code <sup>4</sup>	Component Code <sup>5</sup>	Cause & Corrective Action to Prevent Recurrence
78-2	780524	F	129.1	H	1	LER 78-019/03L-0	ZZ	Suport	Snubber Inspection

<sup>1</sup>  
**F: Forced**  
**S: Scheduled**

<sup>2</sup>  
**Reason:**  
**A-Equipment Failure (Explain)**  
**B-Maintenance of Test**  
**C-Refueling**  
**D-Regulatory Restriction**  
**E-Operator Training & License Examination**  
**F-Administrative**  
**G-Operational Error (Explain)**  
**H-Other (Explain)**

<sup>3</sup>  
**Method:**  
**1-Manual**  
**2-Manual Scram.**  
**3-Automatic Scram.**  
**4-Other (Explain)**

<sup>4</sup>  
**Exhibit G - Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NUREG-0161)**

<sup>5</sup>  
**Exhibit I - Same Source**

(9/77)

LOAD REDUCTIONS DUE TO ENVIRONMENTAL RESTRICTIONS

UNIT NO. 1

MONTH: MAY, 1978

<u>DATE</u>	<u>TIME</u>	<u>HOURS</u>	<u>LOAD, MW</u>	<u>REDUCTIONS, MW</u>	<u>MWH</u>	<u>REASON</u>
				(None during this reporting period).		
MONTHLY TOTAL					0	



DOCKET NO. 50-280

UNIT I

DATE May, 1978

COMPLETED BY O.J. Costello

**AVERAGE DAILY UNIT POWER LEVEL**

MONTH May, 1978

DAY	AVERAGE DAILY POWER LEVEL (MWe-net)	DAY	AVERAGE DAILY POWER LEVEL (MWe-net)
1	<u>0</u>	17	<u>0</u>
2	<u>0</u>	18	<u>0</u>
3	<u>0</u>	19	<u>0</u>
4	<u>0</u>	20	<u>0</u>
5	<u>0</u>	21	<u>0</u>
6	<u>0</u>	22	<u>0</u>
7	<u>0</u>	23	<u>0</u>
8	<u>0</u>	24	<u>0</u>
9	<u>0</u>	25	<u>0</u>
10	<u>0</u>	26	<u>0</u>
11	<u>0</u>	27	<u>0</u>
12	<u>0</u>	28	<u>0</u>
13	<u>0</u>	29	<u>0</u>
14	<u>0</u>	30	<u>0</u>
15	<u>0</u>	31	<u>0</u>
16	<u>0</u>		

**DAILY UNIT POWER LEVEL FORM INSTRUCTIONS**

On this form, list the average daily unit power level in MWe-net for each day in the reporting month. Compute to the nearest whole megawatt.

These figures will be used to plot a graph for each reporting month. Note that by using maximum dependable capacity for the net electrical rating of the unit, there may be occasions when the daily average power level exceeds the 100% line (or the restricted power level line). In such cases, the average daily unit power output sheet should be footnoted to explain the apparent anomaly.

DOCKET NO. 50-281

UNIT II

DATE May, 1978

COMPLETED BY O.J. Costello

AVERAGE DAILY UNIT POWER LEVEL

MONTH May, 1978

DAY	AVERAGE DAILY POWER LEVEL (MWe-net)	DAY	AVERAGE DAILY POWER LEVEL (MWe-net)
1	<u>756.0</u>	17	<u>753.9</u>
2	<u>756.8</u>	18	<u>753.3</u>
3	<u>752.3</u>	19	<u>753.3</u>
4	<u>751.6</u>	20	<u>753.5</u>
5	<u>748.8</u>	21	<u>753.8</u>
6	<u>750.0</u>	22	<u>752.3</u>
7	<u>750.1</u>	23	<u>751.5</u>
8	<u>749.8</u>	24	<u>452.5</u>
9	<u>745.6</u>	25	<u>0</u>
10	<u>753.1</u>	26	<u>0</u>
11	<u>752.3</u>	27	<u>0</u>
12	<u>752.0</u>	28	<u>0</u>
13	<u>758.1</u>	29	<u>0</u>
14	<u>757.1</u>	30	<u>624.7</u>
15	<u>757.9</u>	31	<u>748.0</u>
16	<u>753.1</u>		

DAILY UNIT POWER LEVEL FORM INSTRUCTIONS

On this form, list the average daily unit power level in MWe-net for each day in the reporting month. Compute to the nearest whole megawatt.

These figures will be used to plot a graph for each reporting month. Note that by using maximum dependable capacity for the net electrical rating of the unit, there may be occasions when the daily average power level exceeds the 100% line (or the restricted power level line). In such cases, the average daily unit power output sheet should be footnoted to explain the apparent anomaly.

SUMMARY OF OPERATING EXPERIENCE

MAY, 1978

Listed below in chronological sequence by unit is a summary of operating experiences for this month which required load reductions or resulted in significant non-load related incidents.

UNIT 1

- May 1 - This report begins with the unit in a refueling outage with head bolt detensioning in progress.
- May 2 - Part length control rod unlatching operation completed at 1830.
- May 3 - Lifted reactor vessel head at 1030. Full length control rod unlatching operation completed at 1500. Commenced fuel movement at 2340.
- May 4 - Fuel movement stopped due to high airborne activity in the containment.
- May 6 - Fuel movement restarted at 1538.
- May 12 - Fuel movement completed at 1105. Surveillance capsule W was removed for evaluation.
- May 13 - Full length control rod latching operation completed at 1000.
- May 15 - Lower reactor vessel head in place at 1055. Part length control rod latching operation completed at 2200.
- May 31 - This report ends with the unit still in a maintenance outage with the reactor vessel head bolts tensioned. There is still primary maintenance underway and major turbine maintenance underway.

UNIT 2

- May 1 - This report begins with the unit at 100% power.
- May 5 - At 0910 load was reduced to 94% to clear a delta-T runback alarm. At 1100 the unit was returned to 100%.
- May 9 - At 1540 load was reduced to 96% to allow removal of both Lo Pressure Drain Pumps for cooling line maintenance. At 1927 the unit was returned to 100% power.
- May 24 - At 1200 a rampdown was started for snubber inspection. At 1645 the generator output breakers were opened, the turbine tripped, and the reactor manually shutdown. A unit cooldown was commenced. At 2330 the unit was <350°F/450 PSIG. The plant temperature was to be maintained at approximately 340°F. The snubber inspection was begun.
- May 29 - At 1430 the RCS was heated up to >350°F/450 PSIG as per normal plant recovery. The snubber inspection & repair having been completed. At 2350 the reactor was taken critical and at 2400 was at  $2 \times 10^{-5}$  amps in the intermediate range of nuclear instrumentation.

SUMMARY OF OPERATING EXPERIENCE

(CONTINUED)

UNIT 2

- May 30 - At 0149 the turbine was synchronized to the system and a load increase begun. At 0700 the unit reached 100% power.
- May 31 - This report ends with the unit at 100% power.



AMENDMENTS TO FACILITY LICENSE OR TECHNICAL SPECIFICATIONS

MAY, 1978

On May 10, 1978, the Nuclear Regulatory Commission issued Amendment Nos. 41 and 40 to the Operating License for the Surry Power Station Unit Nos. 1 and 2, respectively, which are designated as Technical Specification Change No. 53. This change is the result of an NRC request to add surveillance requirements for the emergency diesel batteries. Of significance are the following changes:

1. Addition of limiting condition for operation of emergency diesel batteries.
2. Addition of tests, test frequencies and acceptance criteria for emergency diesel batteries.

The Nuclear Regulatory Commission issued an order April 28, 1978, which modifies Surry Unit No. 2 Operating License. The order results from the NRC Staff's review of an error in the Westinghouse Electric Corporation LOCA-ECCS analysis. The error discovered was in the fuel rod heat balance equation involving the incorrect use of only half of the volumetric heat generation due to metal-water reaction in calculating the cladding temperature. Of significance, the order has the following provisions:

1. As soon as possible, the licensee shall submit a re-evaluation of ECCS cooling performance calculated in accordance with the Westinghouse Evaluation Model, approved by the NRC Staff and corrected for the errors described herein.
2. Until further authorization by the Commission, the Technical Specification limit for total nuclear peaking factor ( $F_Q$ ) for the Surry Power Station, Unit No. 2 shall be limited to 1.81 for a steam generator tube plugging level of 20.8% or less and 1.79 for a steam generator tube plugging level of greater than 20.8% but less than 25%.
3. Until further authorization by the Commission, the licensee shall conduct the operating surveillance program described in its letter of April 17, 1978 where APDM surveillance will be performed above 85% for Unit No. 2.

FACILITY CHANGES REQUIRING  
NRC APPROVAL

There were none during this reporting period.

FACILITY CHANGES THAT  
DID NOT REQUIRE NRC APPROVAL

MAY, 1978

The following facility changes were implemented during the month of May. None of the changes constituted an unreviewed safety question per 10CFR50.59.

Design Change

Unit

1. DC-76-29 - Flow Shutoff of Low Pressure Heater Drain Pump Miniflow  
Description - This design change incorporates the addition of a solenoid valve in the recirculation line which will eliminate cavitation through the miniflow line when flow through the pump is greater than 400 gpm. 1

Summary of Safety Evaluation

This system is not addressed in either the FSAR or Technical Specifications since it is not safety related and does not affect any safety related system.

Conclusion

There are no safety implications for this design change which effect the health and safety of the public.

2. DC-76-36 - Manipulator Crane Load Cell Readout  
Description - This modification is to mount an auxiliary readout for the Manipulator Crane load cell to enable the crane operator to monitor the load and evaluation continuously. 1

Summary of Safety Evaluation

The probability of occurrence or the consequence of an accident or malfunction of equipment important to safety and previously evaluated in the safety analysis report is not increased because no protective circuits will be altered. A possibility for an accident or malfunction of a different type than any evaluated in the safety analysis report is not created because the proposed Design Change does not alter the function of the original equipment. The margin of safety as defined in the basis for any Technical Specification is not reduced because no protective functions have been altered.

Conclusion

This Design Change does not constitute an unreviewed safety question or change the basis of any Technical Specification.

FACILITY CHANGES THAT  
DID NOT REQUIRE NRC APPROVAL  
(CONTINUED)

Design Change

Unit

3. DC-77-02 - Manipulator Crane Improvements 1  
Description - Modifications have been initiated to eliminate the possibility of dropping a fuel assembly. A control circuit was inserted to prevent lifting a hung up assembly and the designed gripper guidepins were installed.

Summary of Safety Evaluation

The possibility of an occurrence or the consequence of an accident or malfunction of equipment important to safety and previously evaluated in the Safety Analysis Report is not increased because the addition of the interlock circuit does not bypass any existing safety interlock circuits and the installation of the new guidepins will not alter their function or performance of the gripper. A possibility for an accident or malfunction of a different type than any previously evaluated in the Safety Analysis Report is not created because the failure of the new interlock system will either render the system to its original configuration or prevent the withdrawal of a fuel assembly. This will not create a possibility for a different type of accident. The new guide pins will function as the previous ones have and thus will not create a possibility for a different type of accident. The margin of safety as defined in the basis for any Technical Specification is not reduced because the proposed Design Change will add two safety features which will increase the margin of safety as discussed in Section 3.10.

Conclusion

This design change does not constitute an unreviewed safety question or change the basis of any Technical Specification.

4. DC-77-07 - Manipulator Crane Gripper Modification 1  
Description - Modify the manipulator crane gripper to provide power assistance with the engage stroke. Previous configuration included power stroke only while disengaging.

Summary of Safety Evaluation

The probability of occurrence or the consequences of an accident or malfunction of equipment important to safety and previously evaluated in the Safety Analysis Report is not increased because this change does not modify any existing safety features or interlocks. A possibility for an accident or malfunction of a different type than any evaluated previously, in the Safety Analysis Report is not created because the gripper and its interlocks will function as they were designed. The margin of safety as defined in the basis for any Technical Specification is not reduced because no margin of safety for the manipulator crane is addressed in Technical Specification.

-14-  
FACILITY CHANGES THAT  
DID NOT REQUIRE NRC APPROVAL  
(CONTINUED)

4. DC-77-07 - Manipulator Crane Gripper Modification

Conclusion

The design change neither constitutes an unreviewed safety question nor changes the basis for any Technical Specification.

5. DC-77-18 - Modification to Manipulator Crane Gripper Fingers Unit  
Description - Due to redesigned fuel assemblies from Westinghouse, 1  
the interface of the gripper fingers and fuel assemblies must be modified to provide proper latching. This was accomplished by machining the fingers to provide more secure latching.

Summary of Safety Evaluation

The probability of occurrence or the consequences of an accident or malfunction of equipment important to safety and previously evaluated in the safety analysis is decreased because, after the elimination of the point of interference, the reliability of the gripper will be assured, and, also the handling tools used in the fuel handling operation are conservatively designed initially, and operate on a fail-safe basis. A possibility for an accident or malfunction of a different type than any evaluated previously in the Safety Analysis Report is not created because the removed metal will be on the thickest part of the finger and will not compromise the strength of the thinner part of the finger where no relief is required. Also, the thinner part of the finger, where the surface is vertical, is where the maximum static movement stresses are located. The margin of safety as defined in the basis for any Technical Specification is not reduced because no margin of safety for the Manipulator Crane Gripper Fingers is addressed in the Technical Specifications.

Conclusion

This design change does not constitute an unreviewed Safety Question per 10CFR50.59 or change the basis for any Technical Specification.

6. DC-78-02 - Chemistry Hot Lab Gas Bottle Storage 1,2  
Description - The storage and piping configuration for bottled gasses used in the Hot Lab presented potential safety hazards, which were eliminated with the relocation of the storage area outside the building adjacent to the other bottled gases (N<sub>2</sub>, H<sub>2</sub>).

Summary of Safety Evaluation

This design change does not modify safety related equipment, involve any postulation addressed in the FSAR, or reflect on any margin of safety defined in Technical Specification.

Conclusion

This design change presents no implications which should effect the health and safety of the public.

-15-  
TEST AND EXPERIMENTS REQUIRING  
NRC APPROVAL

MAY, 1978

There were none during this reporting period.

TESTS AND EXPERIMENTS THAT  
DID NOT REQUIRE NRC APPROVAL

MAY, 1978

<u>ST-54</u>	<u>Terminal Block Verification</u>	<u>Unit</u>
	This test was conducted May 11, 1978, to obtain information to formulate a response to IE Bulletin 78-02. Results of the test will be reported in a specific response letter.	1
<u>ST-56</u>	<u>Limit Switch Verification</u>	
	This test was conducted May 11, 1978, to obtain information to formulate a response to IE Bulletin 78-04. Results of the test will be reported in a specific response letter.	1

OTHER CHANGES, TESTS AND EXPERIMENTS

MAY, 1978

There were none during this reporting period.

SURRY POWER STATION

CHEMISTRY REPORT

MAY , 1978

T.S.6.6.A.11

PRIMARY COOLANT ANALYSIS	UNIT NO. 1			UNIT NO. 2		
	MAXIMUM	MINIMUM	AVERAGE	MAXIMUM	MINIMUM	AVERAGE
Gross Radioact., $\mu\text{Ci/ml}$	1.19E-2	1.02E-3	4.18E-3	1.52E-1	2.38E-3	8.67E-2
Suspended Solids, ppm	2.0	0.2	0.7	0.7	0.0	0.3
Gross Tritium, $\mu\text{Ci/ml}$	3.56E-2	2.07E-2	2.40E-2	2.14E-1	8.09E-2	1.60E-1
Iodine-131, $\mu\text{Ci/ml}$	2.45E-3	1.17E-4	5.68E-4	5.69E-4	1.37E-4	3.46E-4
I-131/I-133	*	*	*	.2527	.0643	.1142
Hydrogen, cc/kg	0.0	0.0	0.0	44.7	29.4	36.2
Lithium, ppm	0.35	0.00	0.15	1.95	0.96	1.57
Boron-10, ppm +	538.6	445.7	499.0	233.8	82.7	111.7
Oxygen-16, ppm	6.0	0.6	1.5	0.000	0.000	0.000
Chloride, ppm	0.07	0.05	0.05	0.07	0.05	0.05
pH @ 25°C	5.38	4.56	4.97	7.06	6.39	6.88

+ Boron-10 = Total Boron x 0.196

NON-RADIOACTIVE CHEMICAL  
RELEASES, POUNDS  
T.S. 4.13.A.8

Phosphate	<u>19</u>	Boron	<u>754</u>
Sulfate	<u>580</u>	Chromate	<u>5.0</u>
50% NaOH	<u>702</u>	Chlorine	<u>0.0</u>

Remarks: \* Unit #1 Refueling shutdown during entire month.

Unit #2 Shutdown 5-24-78 to 5-30-78

DESCRIPTION OF ALL INSTANCES WHERE  
THERMAL DISCHARGE LIMITS WERE EXCEEDED

MAY, 1978

On May 30, 1978, a thermal excursion was experienced during startup of Unit II with maintenance in progress on circulating water fish screens and condenser waterboxes. The excursion was reported in accordance with Technical Specification 4.14.C.1.

May 30, 1978 - Exceeded 3°F/Hr Rate of change

There were no reported instances of significant adverse environmental impact.



FUEL HANDLING

MAY, 1978

During this month Unit 1 was refueled. There were 64 new fuel assemblies inserted into Unit 1 and 64 discharged to the spent fuel pool. No new fuel was received or spent fuel shipped.





PROCEDURE REVISIONS THAT CHANGED THE  
OPERATING MODE DESCRIBED IN THE FSAR

MAY, 1978

There were none during this reporting period.

DESCRIPTION OF PERIODIC TESTS WHICH WERE NOT  
COMPLETED WITHIN THE TIME LIMITS  
SPECIFIED IN TECHNICAL SPECIFICATIONS

MAY, 1978

There were none during this reporting period.

INSERVICE INSPECTION

MAY, 1978

An eddy current, gaging inspection was performed in Unit #1 A,B and C Steam Generators in accordance with VEPCO NDT Procedure 14.1. The Reg. Guide 1.83 inspection revealed 2 tubes in "A" S/G having defects >40%. "B" S/G had no tubes with >40% defect. "C" S/G had 6 tubes with >40% defect. Greater than 12% of the tubes were inspected in all three S/G's in accordance with Reg. Guide 1.83. The number of tubes scheduled to be plugged are as follows:

	<u>A</u>	<u>B</u>	<u>C</u>
Gaging	18	31	40
Reg. Guide	2	-	6

Approved W Procedures were used in the repair of the 10 leaking plugs in "A" Steam Generator.

Westinghouse performed inservice inspections on the Unit #1 applicable safety related items detailed in Technical Specifications, Section 4.2-1 through 4.2-35.

This inspection included a visual on the reactor vessel interior surfaces, ultrasonic testing of the reactor coolant pump flywheel, visual and liquid penetrant on sensitized piping. The detailed inspection program along with results will be published by Westinghouse and transferred to the site for records purposes. The rough data is available on site for review.

No reportable indications were found in the above mentioned inspections.

Ultrasonic inspection was conducted on 20 welds in the low points of the C.S. and R.S. Systems in accordance with VEPCO letter serial number 345/112476, dated January 11, 1977.

No reportable indications were found in this inspection.

DEPT=NDT

2 JUN 78 \* 11:23 AM PAGE 7

UNIT 1-MAY 1978  
 (MAINTENANCE OF SAFETY RELATED SYSTEMS DURING OUTAGE OR REDUCED POWER PERIODS)

REFSEVDT	SYS	COMP	MARK	SUMMARY	WKPREF	U	SK	TOTDWTM
05/14/78	RC	RX VESS		PERFORM NDT ON RX VESS COMPONENTS	INSPECTION SATISFACTORY	1	804201057	358
05/16/78	RC	PIPING	1.5-RC-105	INVESTIGATE SURFACE GRIND INDICAT	INDICATION CLEARED	1	805151024	27
05/16/78	RC	PIPING	1.5-RC-101	INVESTIGATE SURFACE GRIND INDICAT	INDICATIONS CLEARED	1	805151025	5
05/17/78	SI	PIPING	6-SI-153	GRIND WELD FLUSH RE EXAM IT	RT ACCEPTABLE	1	805151023	48
05/17/78	WH	PIPING	10-RC-18-602	INVESTIGATE SURFACE GRIND INDICAT	INDICATIONS BUFFED OUT RE PT'D	1	805151026	48
05/18/78	RC	PIPING	6-RC-19	INVESTIGATE SURFACE GRIND INDICAT	INDICATIONS BUFFED OUT RE PT'D	1	805161420	43
05/18/78	RC	PIPING	6-RC-18	INVESTIGATE SURFACE GRIND INDICAT	INDICATIONS BUFFED OUT RE PT'D	1	805161425	43
05/18/78	CH	PIPING	2-CH-9	INVESTIGATE SURFACE GRIND INDICAT	INDICATIONS BUFFED OUT RE PT'D	1	805161436	43
05/20/78	CH	PIPING	3-CH-61	PUFF OUT INDICATION RC PT	INDICATION BUFFED OUT RE PT'D	1	805191000	22
05/20/78	CH	PIPING	3-CH-1	PUFF OUT INDICATION RE PT	INDICATION BUFFED OUT PT'D OK	1	805191001	22
05/20/78	SI	PIPING	2-SI-74	PUFF OUT INDICATION RE PT	INDICATIONS BUFFED OUT RE PT'D	1	805191002	22
05/20/78	SI	PIPING	2-SI-71	PUFF OUT INDICATION RE PT	INDICATION BUFFED OUT PT'D OK	1	805191003	22
05/20/78	SI	PIPING	6-SI-50	GRIND OUT INDICATIONS RE PT	INDICATIONS BUFFED OUT PT'D OK	1	805191004	22
05/23/78	RC	PRP MTR	1-RC-P-1A	UT/VT FLYWHEEL	NDT COMPLETE SATISFACTORY	1	804201058	636
05/23/78	RC	PRP MTR	1-RC-P-1B	UT/VT FLYWHEEL	NDT COMPLETE SATISFACTORY	1	804201059	636
05/23/78	RC	PRP MTR	1-RC-P-1C	UT/VT FLYWHEEL	NDT COMPLETED SATISFACTORY	1	804201100	636
05/26/78	RC	PIPING		UT RS+CS WELDS	UT 10 WELDS ON RS AND CS SYS EACH	1	804201101	715
05/30/78	RC	PZR		PERFORM NDT ON PZR COMPONENTS	NDT COMPLETE SATISFACTORY	1	804201056	864
05/31/78	RC	PIPING		PERFORM NDT ON PRIMARY PIPING SYSTEM	NDT COMPLETE SATISFACTORY	1	804201055	888

DEPT TOTAL

5100

REPORTABLE OCCURRENCES PERTAINING TO  
ANY OUTAGE OR POWER REDUCTIONS

MAY, 1978

Unit #2 Outage occurred on May 24-30, 1978 because of a requirement for re-inspection of hydraulic seismic supports (snubbers). The details of this inspection and results are contained in LER 78-09/03-L-0 (050-0281).



MAY, 1978

MONTHLY OPERATING SUPPLEMENT SHEET  
MECHANICAL MAINTENANCE

UNIT 1

- |    |   |            |
|----|---|------------|
| 1. | MAINTENANCE ORDERS COMPLETED SAFETY RELATED ITEMS   | <u>114</u> |
| 2. | DESIGN CHANGES BEING WORKED <u>DC-76-29, 76-36; 77-02, 77-07, 77-18, 77-29, 78-01,</u><br><u>76-30, 77-08, 78-10, 76-14, 77-19, 75-55</u> |            |
| 3. | PERIODIC TESTS PERFORMED  | <u>6</u>   |
|    | PT-39   |            |
|    | PT-12   |            |
|    | PT-22.4A  |            |
|    | PT-22.4C  |            |
|    | PT-46   |            |
|    | PT-16.4   |            |

## UNIT 1-MAY 1978

## (MAINTENANCE OF SAFETY RELATED SYSTEMS DURING OUTAGE OR REDUCED POWER PERIODS)

REFERENCE	SYS	CONF	MARKNO	SUMMARY	WREKRF	U	GR	TOTDTRFM
05/02/78	SI	NOV	NOV-1866B	PACKING LEAK	ADJUSTED PACKING	1	10185370	2
05/02/78	SI	NOV	NOV-1866C	PACKING LEAK	ADJUSTED PACKING	1	10185380	2
05/02/78	SI	NOV	NOV-1866D	PACKING LEAK	ADJUSTED PACKING	1	10185350	2
05/02/78	SI	NOV	NOV-1866E	PACKING LEAK	ADJUSTED PACKING	1	10185360	2
05/02/78	SI	NOV	NOV-1866F	PACKING LEAK	ADJUSTED PACKING	1	10185370	2
05/02/78	SI	NOV	NOV-1866A	PACKING LEAK	ADJUSTED PACKING	1	10185380	2
05/02/78	CH	VALVE	1-CH-100	LEAKS BY	STOPPED LEAK	1	803360400	4
05/03/78	DG	VALVE	1-DG-50	REPLACE DIAPHRAM	REPLACED DIAPHRAGM	1	10184530	7
05/03/78	DG	VALVE	1-DG-49	REPLACE DIAPHRAM	REPLACED DIAPHRAGM	1	10184640	7
05/03/78	RH	NOV	NOV1701	INSPECT PACKING GLAND STUDS AND	INSPECTED GLAND STUDS-SAT	1	801250829	4
05/03/78	RH	NOV	NOV-1700	INSPECT PACKING GLAND STUDS AND	WILL REPLACE BAD STUDS DURING REPACK	1	801250830	4
05/03/78	EE	VALVE	TK-4	REFLEX VALVE ON AIR TANK 4 NEEDS	INSTALLED NEW VALVE	1	804181540	9
05/03/78	RC	SG	1-RC-E-1A	INSPECT 6 IN HAND HOLES	COMPLETED	1	804260937	45
05/03/78	RC	SG	1-RC-E-1B	INSPECT 6 IN HAND HOLES	COMPLETED	1	804260938	144
05/03/78	RC	SG	1-RC-E-1C	INSPECT 6 IN HAND HOLES	COMPLETED	1	804260939	199
05/04/78	CH	VALVE	1-CH-210	DIAPHRAM LEAKS	REPLACED DIAPHRAGM	1	10186220	12
05/04/78	SSS	SHRUBBER		PT 39	COMPLETED PT 39 SAT	1	804240825	113
05/05/78	CS	PUMP	1-CS-P-2D	BEARING NOISE	NOISE IN CK VLV NOT PUMP	1	10186700	1
05/05/78	SI	PIPING	PE1943	FLANGES LEAK BORIC ACID	REPLACED GASKETS	1	804361928	27
05/06/78	CH	VALVE	1-CH-392	REPLACE DIAPHRAMS (GRINNELL)	REPLACED DIAPHRAGM	1	10181400	5
05/06/78	CH	VALVE	1-CH-168	REPLACE DIAPHRAM (GRINNELL)	REPLACED DIAPHRAGM	1	10181570	5
05/06/78	CH	VALVE	1-CH-171	REPLACE DIAPHRAM (GRINNELL)	REPLACED DIAPHRAGM	1	10181580	5
05/06/78	IA	PIPING	PI-1A-104	REINSTALL AIR LINE TO LEAK OFF POT	INSTALLED AIR LINE	1	804221606	33
05/06/78	CH	VALVE	1-CH-96	REPLACE DIAPHRAGM	CHANGED DIAPHRAGM	1	805021352	7
05/06/78	CH	VALVE	1-CH-106	REPLACE DIAPHRAGM	CHANGED DIAPHRAGM	1	805021356	5
05/06/78	CH	VALVE	1-CH-107	REPLACE DIAPHRAGM	CHANGED DIAPHRAGM	1	805021358	5
05/08/78	CH	VALVE	1-CH-208	DIAPHRAM LEAKS	VOID	1	10186210	0
05/08/78	SI	NOV	NOV1890A	NO MANUAL ENGAGE LEVER-INSTALL	VOID	1	804240830	0
05/08/78	CH	PUMP	1-CH-P-2D	BROKEN COUPLING	MADE NEW SHAFT SLEEVE+PHF SIDE CPLIN	1	805052330	61
05/09/78	SI	NOV	NOV-1865A	BODY TO BONNET LEAK	COMPLETED	1	804261307	10
05/09/78	BR	VALVE	1-BR-1	REPLACE DIAPHRAGM	CHANGED DIAPHRAGM	1	805061045	4
05/09/78	BR	VALVE	1-BR-234	REPLACE DIAPHRAGM	REPLACED DIAPHRAGM	1	805062100	2
05/10/78	CS	VALVE	1-CS-77	REPLACE DIAPHRAGM	REPLACED DIAPHRAGM	1	805061105	8
05/10/78	CS	VALVE	1-CS-76	REPLACE DIAPHRAGM	REPLACED DIAPHRAGM	1	805061106	8
05/10/78	CS	VALVE	1-CS-73	REPLACE DIAPHRAGM	REPLACED DIAPHRAGM	1	805061107	8
05/10/78	CS	VALVE	1-CS-72	REPLACE DIAPHRAGM	REPLACED DIAPHRAGM	1	805061108	8
05/11/78	RS	HX	1-RS-E-1C	REMOVE SW SUPPLY ELBOW FOR HX INSP	INSPECTED SW SIDE	1	802171110	188
05/11/78	BR	VALVE	1-BR-2	DIAPHRAM LEAK (LEAKS OUT OF STEM)	VOID	1	803100510	0
05/11/78	RC	SG	1-RC-E-1C	REMOVE/INSTALL SEC MANWAYS	COMPLETED	1	804260936	302
05/11/78	CR	CRANE	1-CR-1	CHECK OUT POLAR CRANE	COMPLETED NOT WORK	1	804261305	336
05/11/78	RH	NOV	NOV1700	BODY TO BONNET LEAK REPAIR FOR PT16.	REPLACED BONNET GASKET	1	804221604	120
05/11/78	CS	NOV	NOV-CS-101C	EXCESSIVE LEAKAGE ON PT 16.4(VLV PTT	REPAIRED VALVE	1	805070915	190
05/11/78	CS	NOV	NOV-CS-101D	EXCESSIVE LEAKAGE ON PT 16.4(VLV PTT	REPAIRED VALVE	1	805070916	222
05/11/78	CS	NOV	NOV-CS-101A	EXCESSIVE LEAKAGE ON PT 16.4(VLV PTT	REPAIRED VALVE	1	805070920	198
05/11/78	CS	NOV	NOV-CS-101B	EXCESSIVE LEAKAGE ON PT 16.4(VLV PTT	REPAIRED VALVE	1	805070921	199
05/11/78	BR	VALVE	1-BR-2	REPLACE DIAPHRAGM	CHANGED DIAPHRAGM	1	805061046	54
05/11/78	CS	VALVE	1-CS-48	REPLACE DIAPHRAGM	REPLACED DIAPHRAGM	1	805061109	6

UNIT 1--MAY 1978  
 (MAINTENANCE OF SAFETY RELATED SYSTEMS DURING OUTAGE OR REDUCED POWER PERIODS)

RETRCDVDT	SYS	COMP	MARKNO	SUMMARY	WKPFRF	U	LR	TOTDWTG
05/11/78	CS	VALVE	1-CS-47	REPLACE DIAPHRAGM	CHANGED DIAPHRAGM	1	8050.1110	21
05/11/78	CS	VALVE	1-CS-46	REPLACE DIAPHRAGM	CHANGED DIAPHRAGM	1	8050.1111	21
05/12/78	SI	VALVE	1-SI-17 <sup>u</sup>	EXCESSIVE LEAKAGE ON PT 16.4	REPLACED VALVE	1	804201151	27
05/12/78	CV	VALVE	1CV-CV-100	EXCESSIVE LEAKAGE ON PT 16.4	SHIFED BALL DTSC SEAL	1	8050.05925	49
05/12/78	CS	VALVE	1-CS-36	REPLACE DIAPHRAGM	REPLACED DIAPHRAGM	1	8050.1112	27
05/12/78	CS	VALVE	1-CS-35	REPLACE DIAPHRAGM	REPLACED DIAPHRAGM	1	8050.1113	27
05/12/78	CS	VALVE	1-CS-33	REPLACE DIAPHRAGM	REPLACED DIAPHRAGM	1	8050.1114	2
05/12/78	CS	VALVE	1-CS-28	REPLACE DIAPHRAGM	REPLACED DIAPHRAGM	1	8050.1116	66
05/12/78	CS	VALVE	1-CS-19	REPLACE DIAPHRAGM	REPLACED DIAPHRAGM	1	8050.1118	6
05/12/78	CS	VALVE	1-CS-30	REPLACE DIAPHRAGM	REPLACED DIAPHRAGM	1	8050.1121	2
05/12/78	CS	VALVE	1-CS-31	REPLACE DIAPHRAGM	REPLACED DIAPHRAGM	1	8050.1125	66
05/12/78	CS	VALVE	1-CS-18	REPLACE DIAPHRAGM	REPLACED DIAPHRAGM	1	8050.1126	16
05/13/78	RS	HX	1-RS-E-1B	INSTALL BLANKS ON RS INLET+OUTLETS	INSTALLED BLANKS*REMOVED BLANKS	1	802171101	484
05/13/78	RS	HX	1-RS-E-1A	INSTALL BLANKS ON RS INLET+OUTLETS	INSTALLED BLANKS*REMOVED BLANKS	1	802171104	484
05/14/78	HSS	SMUDBER	1-SHP-HSS-9+	REPLACE SEALS	REPLACED SEALS	1	804200820	272
05/14/78	RH	VALVE	NOV1700	REPACK AND REPLACE GLAND STUDS	REPACKED*REPLACED STUFFING BOX	1	805111430	20
05/15/78	KS	PIPING	1-KS-E-1D	REMOVE SW SUPPLY ELBOW FOR HX INSP	VOID	1	802171113	0
05/15/78	SI	TANK	1-SI-TK-2	REMOVE COUPLINGS FOR INSPECTION+	REMOVED COUPLINGS	1	805001300	149
05/15/78	CH	VALVE	1-CH-309	BODY TO BONNET LEAK 16.4	LAPPED VALVE*REPLACED GASKET	1	805111015	30
05/15/78	CH	VALVE	1-CH-309	EXCESSIVE LEAKAGE ON PT 16.4	VOID	1	805110831	0
05/16/78	SI	VALVE	1-SI-86	PACKING LEAK	COMPLETED	1	802001446	305
05/16/78	SI	VALVE	1-SI-87	PACKING LEAK	REPACKED VALVE	1	802001447	305
05/16/78	IC	THIMBLES		RETRACT/INSERT FLUX MAPPING THIMBLES	RETRACTED/REINSERTED FLUX MAP THIMBL	1	804201301	528
05/16/78	RC	VALVE	PCV-1456	LEAKS THRU BADLY	LAPPED SEATS	1	804211427	129
05/16/78	RC	VALVE	PCV-1455C	LEAKS THRU BADLY	REPAIRED LEAK	1	804211428	20
05/16/78	RC	VALVE		PERFORM PT 12 ON PZR RELIEF VALVES	TEST SATISFACTORY	1	805110233	104
05/17/78	RS	PIPING	NOV-RS-155	INSTALL*REMOVE TEST FLANGES(PT16.4)	INSTALLED BLANKS*REMOVED BLANKS	1	8011705	571
05/17/78	SI	REL VLV	1-SI-RV-1893	VALVE LEAKS THROUGH	REPLACED DTSC*SPRING	1	101.3310	0
05/17/78	BR	VALVE	PCV-BR-131	STEM AND BODY LEAKS	REPACKED VALVE	1	8030.0200	30
05/17/78	SI	NOV	NOV1069B	EXCESSIVE LEAKAGE ON PT 16.4	VALVE BEYOND REPAIR	1	804200859	556
05/17/78	SI	PIPING		REMOVE OLD NOV1062 GLAND LEAKOFF	REMOVED PIPE	1	805110830	19
05/17/78	CH	PIPING	CH-81-1503	DISCHARGE FLANGE LEAK	NOT LEAKING	1	805111516	5
05/18/78	RC	VALVE	1-KC-79	PACKING LEAK C LOOP	VOID	1	101.5390	0
05/18/78	KS	PIPING	1-KS-E-1B	REMOVE SW SUPPLY ELBOW FOR HX INSP	VOID	1	802171111	0
05/18/78	KS	PIPING	1-KS-E-1A	REMOVE SW SUPPLY ELBOW FOR INSP	VOID	1	802171112	0
05/18/78	BR	VALVE	1-BR-3	REPLACE DIAPHRAGM	REPLACED DIAPHRAGM	1	805001047	212
05/18/78	BR	VALVE	1-BR-4	REPLACE DIAPHRAGM	REPLACED DIAPHRAGM	1	8050.1048	212
05/18/78	CS	VALVE	1-CS-79	BODY BOLT MISSING	REPLACED MISSING BOLT	1	8050.1546	23
05/18/78	CH	PUMP	1-CH-P-2B	PUMP COUPLING LOOSE	MADE NEW SLEEVE FOR SHAFT*INSTALLED	1	805170145	6
05/19/78	RC	VALVE	1-KC-102	REPACK	COMPLETED	1	101.5520	6
05/19/78	CS	PUMP	1-CS-P-3	LUBE OIL SEAL+PUMP SEAL LEAKS	REPLACED MECHANICAL SEAL	1	805100820	6
05/19/78	CH	NOV	NOV-1287B	PACKING LEAK	ADJUSTED PACKING	1	805170603	1
05/20/78	RS			WORK HX CAVITY SEALS FOR REFUELING	COMPLETED	1	804201250	0
05/20/78	KS	VALVE	1-KS-17	PACKING LEAK	REPACKED	1	8050.0055	394
05/20/78	VG	VALVE	TV-VG-109B	EXCESSIVE LEAKAGE ON PT 16.4	REPAIRED LEAK	1	805100800	37
05/20/78	VG	VALVE	TV-VG-109A	EXCESSIVE LEAKAGE ON PT 16.4	REPAIRED LEAK	1	805100800	37
05/20/78	SS	VALVE	TV-SS-103	EXCESSIVE LEAKAGE ON PT 16.4	REPAIRED VALVE	1	805100861	76

UNIT 1-MAY 1978  
 MAINTENANCE OF SAFETY RELATED SYSTEMS DURING OUTAGE OR REDUCED POWER PERIODS

DATE/TIME	SYS	COMP	MARKNO	SUMMARY	WKFERE	U	SR	TOTDRTN
05/20/78	CH	PIPING	1-CH-375	REMOVE FLEX AND PUT FLANGE BACK ON	REPLACED FLEX GASKET	1	805130730	33
05/21/78	SI	VALVE	1-SI-234	EXCESSIVE LEAKAGE PT 16.4		1	805130861	0
05/22/78	CH	PUMP	1-CH-P-1B	VARIOUS LUBE OIL LEAKS-BEARING CAP	TIGHTENED BEARING CAP	1	10115110	624
05/22/78	SI	MOV	NOV1890C	PACKING LEAK REPAIR FOR PT 16.4	CLEAR PACKING GLAND + ADJUSTED	1	804221601	175
05/22/78	SI	MOV	NOV1862B	LEAKS THRU	ADJUSTED PLUG VALVE	1	804221602	166
05/22/78	SI	MOV	NOV1862A	LEAKS THRU	ADJUSTED PLUG VALVE	1	804221603	168
05/22/78	SI	MOV	NOV1885C	BAD PACKING LEAK	ADJUSTED PACKING	1	804221605	210
05/22/78	SI	MOV	NOV1864A	BODY TO BONNET LEAK+PACKING LEAK	ADJUSTED PACKING+TIGHTENED PACKING	1	804221600	166
05/22/78	SI	MOV	NOV-1864B	VALVE HAS BODY TO BONNET +PACKING	ADJUSTED PACKING +TIGHTENED PIPING	1	805041361	166
05/23/78	RC	KX VESS		REMOVE/REINSTALL VESS HD FOR REFUEL	VESSEL HEAD REMOVE+REINSTALLED	1	804191455	690
05/23/78	SI	MOV	NOV1860B	BODY TO BONNET AND PACKING LEAK	REPAIRED VALVE	1	805051608	161
05/23/78	CH	VALVE	1-CH-365	PACKING LEAK	REPACKED VALVE	1	805211440	24
05/24/78	HK	VALVE	SOV-HK-101C	VENTS CONTINUOUSLY	REBUILT VALVE	1	663160511	201
05/24/78	CH	VALVE	HCV-1310A	PACKING LEAK	REPACKED	1	805211441	36
05/26/78	RC	VALVE	1-RC-21	PACKING LEAK A LOOP	MADE NEW SPLIT RINGS+REPACKED	1	10135410	249
05/26/78	HD	SNOBBER	1-HD-HSS-03	FUNCTIONAL TEST	REPLACED SNOBBER	1	805250805	24
05/30/78	VS	MOV	NOV-VS-100	INSTALL TESTING FLANGES FOR PT 16.4	INSTALLED/REMOVED BLANK FLANGE	1	803160423	888
05/30/78	RC	VALVE	FCV-1455C	LEAK AROUND EDGE OF DIAPHRAM	REPLACED DIAPHRAM	1	805151355	3
05/30/78	SS	VALVE	TV-SS-103	LEAKS THRU-UNSAT FOR PT 16.4	VOID	1	805221446	0
05/31/78	RC	SG	1-RC-E-1A	REMOVE/REPLACE 6 IN. HAND HOLE	REMOVED/REPLACED HANDHOLE COVERS	1	805251345	127

DEPT TOTAL

\*\*\*\*\*

MAY, 1978

MONTHLY OPERATING SUPPLEMENT SHEET  
MECHANICAL MAINTENANCE

UNIT 2

1.	MAINTENANCE ORDERS COMPLETED SAFETY RELATED ITEMS	<u>10</u>
2.	DESIGN CHANGES BEING WORKED <u>DC-77-19, 74-44, 78-10, 76-30, 77-29.</u>	
<hr/>		
3.	PERIODIC TESTS PERFORMED	<u>2</u>
	PT-39	
	PT-39.1	

UNIT 2-MAY 1978  
(MAINTENANCE OF SAFETY RELATED SYSTEMS DURING OUTAGE OR REDUCED POWER PERIODS)

REF	SYD	COMP	MARKNO	SUMMARY	MARKNO	QTY	UNIT	DATE	DESCRIPTION	QTY	UNIT	DATE	DESCRIPTION
	CH	VALVE	HCV-2310A	PACKING LEAK (ADJUST)		2		05/20/78	TIGHTENED PACKING	2		05/20/1350	
	CH	VALVE	2-CH-316	PACKING LEAK (ADJUST)		2		05/26/78	TIGHTENED PACKING	2		05/21/1460	
	HC	VALVE	2-KC-S1	ADJUST PACKING		2		05/26/78	TIGHTENED PACKING	2		05/21/1461	
	HC	VALVE	2-KC-45	ADJUST PACKING		2		05/26/78	TIGHTENED PACKING	2		05/21/1405	
	HS	VALVE	NOV-HS-256B	INSPECT-INSTALL SPHERICAL FLANGE		2		05/21/78	INSPECTED VALVE	2		05/20/1546	
	CS	NOV	NOV-CS-201B	BLANK FOR PT 16.4 TEST		2		05/29/78	INSTALL/REMOVED BLANK FLANGES	2		05/25/1306	
	CS	NOV	NOV-CS-201A	DESN+INSPECT		2		05/29/78	CLEANED/LAVERD SEALS	2		05/21/1025	
	CS	NOV	NOV-CS-201A	INSTALL BLANK FLANGE FOR 16.4 TEST		2		05/29/78	INSTALL/REMOVED BLANK FLANGES	2		05/21/1026	
	CS	NOV	NOV-CS-201B	INSPECT (4350F 450 LBS)		2		05/29/78	CLEANED/LAVERD SEALS	2		05/20/1004	
DEPT TOTAL													

UNIT 1

MONTHLY OPERATING SUPPLEMENT SHEET  
ELECTRICAL MAINTENANCE

MAY, 1978

1. MAINTENANCE ORDERS COMPLETED SAFETY RELATED ITEMS

70

2. DESIGN CHANGES BEING WORKED DC-77-08, DC-76-14A, DC-76-36, DC-77-02, DC-78-01, DC-74-73, DC-76-29,  
DC-76-30.

3. PERIODIC TEST PERFORMED

24

PT-34 (5)  
PT-23.1A (5)  
PT-23.6 (5)  
PT-24.4B  
PT-23.3  
PT-31.3  
PT-24.6  
PT-31.2  
PT-27  
PT-23.1  
PT-23.2  
PT-24.5A

UNIT 1-MAY 1978  
 (MAINTENANCE OF SAFETY RELATED SYSTEMS DURING OUTAGE OR REDUCED POWER PERIODS)

RTSRVDT	SYS	COMP	MARKNO	SUPPLY	JAPERF	U	MR	TOTLJMTS
05/01/78	VS	FAN MTR	1-VS-F-60A	INSPECT MOTOR	TESTED+INSPECTED	1	804171203	216
05/01/78	VS	FAN MTR	1-VS-F-60D	INSPECT MOTOR	TESTED+INSPECTED	1	804171205	216
05/02/78	VS	FAN MTR	1-VS-F-1B	INSPECT MOTOR	CHECKED	1	804171201	155
05/02/78	VS	FAN MTR	1-VS-F-1C	INSPECT MOTOR	CHECKED SAT	1	804171202	131
05/02/78	EH	MANIP CR		INSPECT MANIP CRANE+TRANSFER SYS	ASSISTED TECH RGP	1	804170812	166
05/02/78	GV	RECOINB	B	PMS	CLEANED+CHECKED UNIT	1	804170812	104
05/02/78	GV	RECOINB	A	PMS	CLEANED+CHECKED	1	804170813	106
05/05/78	SI	HT	PHLUCKT2	LOW TEMP ALARM	REPLACED HEAT TAPE	1	805050455	15
05/01/78	BR	MOV	MOV-BR-100A	CLEAN+INSPECT	CLEANED+INSPECTED	1	805050810	9
05/01/78	CH	HT	PHLUCKT26	CHECK OUT ALARM THERMOSTAT	REPLACED THERMOSTAT	1	805071130	6
05/04/78	EPCH	BREAKER		PMS	CLEANED+INSPECTED	1	804170816	362
05/04/78	EPCH	BREAKER		PMS	CLEANED INSPECTED+TESTED	1	804170817	362
05/04/78	EPCH	BREAKER		PMS	CLEANED INSPECTED+TESTED	1	804170818	362
05/04/78	EPCH	BREAKER		PMS	CLEANED+INSPECTED	1	804170819	362
05/04/78	CH	MOV	MOV-1286A	DISCONNECT POWER SUPPLY FOR MECHANIC	VOID	1	805051310	0
05/04/78	CH	MOV	MOV-1287A	DISCONNECT POWER SUPPLY FOR MECHANIC	VOID	1	805051315	0
05/04/78	CH	MOV	MOV1381	WILL NOT SHUT ELECTRICALLY-NEED	REPLACED TORQUE SWITCH	1	805071760	7
05/09/78	RS	MOV	MOV-RS-101C	CLEAN + INSPECT	CLEANED+INSPECTED	1	804260731	312
05/09/78	RS	MOV	MOV-RS-156B	DOES NOT OPERATE ELECTRICALLY	INSPECTED-REFERRED TO MECHS	1	805051545	5
05/10/78	VS	FAN MTR	1-VS-F-3A	FAN 3A OVERLOAD WILL NOT RESET	REPLACED MOTOR+FAN	1	803051950	1464
05/10/78	CH	MOV	MOV-1289A	CLEAN+INSPECT	CLEANED INSPECTED+TESTED	1	805040838	20
05/10/78	RP	RELAY	XB1590	REPLACE RELAY RK TRIP BREAKER	REPLACED RELAY	1	8050651200	24
05/11/78	VS	FAN MTR	1-VS-F-3B	PMS	CHECKED SAT	1	804170807	18
05/11/78	CS	MOV	MOV-CS-101B	CLEAN+INSPECT	CHECKED	1	805040820	35
05/11/78	CS	MOV	MOV-CS-101A	CLEAN+INSPECT	CHECKED	1	805040821	35
05/12/78	VS	FAN MTR	1-VS-F-3A	PMS	VOID	1	804170868	0
05/13/78	RS	MOV	RS-156B	CLEAN+INSPECT	CLEANED AND INSPECTED SET LIMITS	1	805051026	33
05/15/78	CS	MOV	MOV-CS-102B	CLEAN+INSPECT	INSPECTED+TESTED	1	805040817	190
05/15/78	CS	MOV	MOV-CS-102A	CLEAN+INSPECT	TESTED+INSPECTED	1	805040810	190
05/15/78	CS	MOV	MOV-CS-101C	ADJUST LIMIT TORQUE	NO PROBLEM FOUND	1	805050737	240
05/16/78	EPCH	CRDM		DISC PL RODS+TAKE RESISTANCE READING	TOOK RESISTANCE READINGS	1	804170807	577
05/16/78	GI	EMP MTR	1-GI-F-1B	TRSP+CHANGE OIL	PERFORMED EMP-P-LU-28	1	804170822	148
05/18/78	SS	VALVE	TV-SS-104A	DOES NOT OPERATE FROM CONTROL ROOM	CHECKED VALVE SATISFACTORY	1	805151411	23
05/20/78	RC	PER MTR		PMS	CLEANED+INSPECTED SAT	1	804170811	72
05/22/78	VS	FAN MTR	1-VS-F-60C	INSPECT MOTOR	REPLACED BEARINGS-CONNECTED-TESTED	1	804171204	718
05/22/78	VS	FAN MTR	1-VS-F-60F	INSPECT MOTOR	REPLACED BEARINGS-CONNECTED-TESTED	1	804171206	718
05/22/78	HS			EMER HATCH LIMIT SW BROKE	FOUND NO PROBLEM	1	804251539	216
05/22/78	CS	MOV	MOV-CS-101D	CLEAN+INSPECT	CLEANED+INSPECTED+SET TORQUE SW	1	805040819	300
05/22/78	CS	MOV	MOV-CS-101C	CLEAN+INSPECT	CLEANED+INSPECTED+SET TORQUE SW	1	805040824	300
05/22/78	EPH	BREAKER	1-CH-P-2D	REPLACE SOLDER JOBS IN BREAKER	VOID	1	805151636	0
05/24/78	EPCH	CRDM RPT		DISC RECONNECT READ OUT	DISCONNECTED-RECONNECTED+TESTED	1	804170868	720
05/25/78	CH	MOV	MOV-1286A	CLEAN+INSPECT	DISCONNECTED-RECONNECTED+TESTED	1	805040832	456
05/26/78	CH	MOV	MOV-1275A	CLEAN+INSPECT	CLEANED-INSPECTED+TESTED	1	805040829	389
05/26/78	CH	MOV	MOV-1275C	CLEAN+INSPECT	CLEANED-INSPECTED+TESTED	1	805040831	389
05/27/78	EW	MOV	MOV-EW-151E	CLEAN+INSPECT	DISCONNECTED RECONNECTED+TESTED	1	805011123	576
05/27/78	EW	MOV	MOV-EW-151C	CLEAN+INSPECT	DISCONNECTED-RECONNECTED+TESTED	1	805011125	576
05/27/78	EW	MOV	MOV-EW-151B	CLEAN+INSPECT	DISCONNECTED RECONNECTED+TESTED	1	805011126	576



UNIT 1-MAY 1978  
 (MAINTENANCE OF SAFETY RELATED SYSTEMS DURING OUTAGE OR REDUCED POWER PERIODS)

DATE/SHIFT	SYS	COMP	MARKNO	SUMMARY	W/PERK	U	HR	TOTD/WTN
05/27/78	CH	MOV	MOV-1270A	CLEAN+INSPECT	CLEARED+INSPECTED	1	805040812	476
05/27/78	CH	MOV	MOV-1269B	CLEAN+INSPECT	CLEARED+INSPECTED	1	805040813	476
05/27/78	CH	MOV	MOV-1269A	CLEAN+INSPECT	CLEARED+INSPECTED	1	805040814	476
05/27/78	CH	MOV	MOV-1267B	CLEAN+INSPECT	CLEARED INSPECTED+TESTED	1	805040815	432
05/27/78	CH	MOV	MOV-1267A	CLEAN+INSPECT	CLEARED INSPECTED+TESTED	1	805040816	432
05/27/78	CH	MOV	MOV-1270B	CLEAN+INSPECT	CLEARED-TESTED+INSPECTED	1	805040828	413
05/27/78	CH	MOV	MOV-1286C	CLEAN+INSPECT	CLEARED TESTED+INSPECTED	1	805040834	413
05/27/78	CH	MOV	MOV-1287B	CLEAN+INSPECT	CLEARED INSPECTED+TESTED	1	805040836	413
05/27/78	CH	MOV	MOV-1289B	CLEAN+INSPECT	CLEARED+TESTED	1	805040839	413
05/27/78	SI	MOV	1860B	CLEAN+INSPECT	DISCONNECTED+CONNECTED+INSPECTED	1	805091014	240
05/28/78	SI	MOV	1890C	CLEAN+INSPECT	CLEARED INSPECTED+TESTED	1	805091065	11
05/29/78	SI	MOV	1869B	CLEAN+INSPECT	PERFORMED ENP-P-NOV-45	1	805091011	135
05/29/78	RS	MOV	MOV-RS-156B	SET LIMIT SWITCH	SET LIMITS	1	805041466	68
05/30/78	RC	MOV	MOV-1536	CLEAN+INSPECT	CLEARED INSPECTED+TESTED	1	805011115	384
05/30/78	VS	MOV	VS-101	CLEAN+INSPECT	CLEARED INSPECTED+TESTED	1	805091002	59
05/30/78	SI	MOV	1890B	CLEAN+INSPECT	CLEARED INSPECTED+TESTED	1	805091007	59
05/30/78	SI	MOV	1885C	CLEAN+INSPECT	CLEARED INSPECTED+TESTED	1	805091008	59
05/30/78	SI	MOV	1869A	CLEAN+INSPECT	CLEARED INSPECTED+TESTED	1	805091012	48
05/30/78	SI	MOV	1885B	CLEAN+INSPECT	CLEARED INSPECTED+TESTED	1	805091300	59
05/31/78	CH	MOV	MOV-LCV-1115	CLEAN+INSPECT	CLEARED INSPECTED+TESTED	1	805091030	77
05/31/78	CH	MOV	MOV-LCV-1115	CLEAN+INSPECT	CLEARED INSPECTED+TESTED	1	805091031	77
05/31/78	CH	MOV	MOV-LCV-1115	CLEAN+INSPECT	CLEARED INSPECTED+TESTED	1	805091032	77
05/31/78	CH	MOV	MOV-LCV-1115	CLEAN+INSPECT	CLEARED INSPECTED+TESTED	1	805091415	77

DEPT TOTAL

\*\*\*\*\*

UNIT 2

MONTHLY OPERATING SUPPLEMENT SHEET  
ELECTRICAL MAINTENANCE

MAY, 1978

1. MAINTENANCE ORDERS COMPLETED SAFETY RELATED ITEMS

5

---

2. DESIGN CHANGES BEING WORKED DC-76-30

---

3. PERIODIC TEST PERFORMED

6

---

PT-34 (4)  
PT-23.1  
PT-27

UNIT 2-BAY 1978  
(MAINTENANCE OF SAFETY RELATED SYSTEMS DURING OUTAGE OR REDUCED POWER PERIODS)

DATE	RS/SERVDT	SYS	COMP	MARKNO	SUMMARY	WRPERF	D	HR	TOTDRTM
05/26/78	EPH	BREAKER		25H4	SET AGASTAT TO 50+10 <sup>-6</sup> SECONDS	TESTED*ADJUSTED	2	8050:1005	14
05/26/78	EPH	BREAKER		25J4	SET AGASTAT TO 50 + 10 <sup>-6</sup> SECONDS	TESTED*ADJUSTED	2	8050:1006	14
05/27/78	RS	MOV		NOV-RS-256B	CHANGE OPERATOR TO LIMIT CLOSED	REMOVED JUMPER FROM LSB	2	8650:0920	24
05/29/78	BD	VALVE		TV-BD-200A	VALVE WONT OPEN-LIMIT SWITCH PROBLEM	ADJUSTED LIMIT SWITCH	2	8650:0906	71
05/29/78	CS	MOV		NOV-CS-201B	RESET LIMITS AFTER INSPECTION	SET LIMIT SWITCHES*CYCLED	2	8650:1005	49
DEPT TOTAL									172

UNIT 1

MONTHLY OPERATING SUPPLEMENT SHEET  
INSTRUMENT MAINTENANCE

MAY, 1978

1. MAINTENANCE ORDERS COMPLETED SAFETY RELATED ITEMS

7

2. DESIGN CHANGES BEING WORKED DC-77-08

3. PERIODIC TEST PERFORMED

34

DELT=INST

2 JUN 78 \* 11:23 AM PAGE 3

UNIT 1-MAY 1978  
 MAINTENANCE OF SAFETY RELATED SYSTEMS DURING OUTAGE OR REDUCED POWER PERIODS)

DATE-SRVDT	SYS	COMP	MARKNO	SUMMARY	WKPERS	U	HR	TOTL/RTM
05/04/78	CV	INST	PI-CV-101B(2	NEEDS CALIBRATING POSSIBLE FAILURE	REFUELING CAL COMPLETED	1	804210930	272
05/09/78	BECK	CONT		RODS STEP OUT BEFORE NECESSARY WITH	REALIGNED SYSTEM	1	804210645	248
05/09/78	RM	ROTO-MTR	RI-GM-101/10	ROTO METER BROKEN	REBUILT ROTOMETER	1	804270746	193
05/09/78	GM	INST	RC-GM-101	FLOW METER BROKE	REBUILT ROTOMETER	1	804361536	190
05/09/78	SK	CONT	L-1-BK-104A	FAILED HIGH	REPLACED LT-BK-104A	1	805072245	9
05/09/78	SR	CONT	PCV-AS-110A	FAILS OPEN SLOWLY	REPAIRED OPEN INPUT TO CONTROLLER	1	805072330	9
05/11/78	SS	VALVE	DC78-01	REPLACE TRIP VALVES-SEE LIST	REPLACED SOLENOID VALVES+TUBED UP	1	804170854	1146
DELT TOTAL								2675



HEALTH PHYSICS

MAY, 1978

There was no single release of radioactivity specifically associated with an outage that accounted for more than 10% of the allowable annual values in 10CFR20.

There were 3 individuals who received single radiation exposures specifically associated with Unit #1 Steam Generator work which accounted for more than 10% of the allowable annual values in 10CFR20.101.

REPORT OF RADIOACTIVE EFFLUENTS

PAGE 1

Facility: Surry Power Station

DOCKET: 50-280 and 50-281

YEAR, 1970

I. LIQUID RELEASES

		UNITS	JANUARY	FEBRUARY	MARCH	APRIL	MAY		
1.	Gross Radioactivity (By)								
	(a) Total Release	Curies	6.12E-1	5.14E-2	4.70E-2	1.63E-1	8.38E-2		
	(b) Avg. Concentration Released	µCi/ml	2.34E-9	2.41E-10	2.17E-10	6.86E-10	4.96E-10		
	(c) Maximum Concentration Released	µCi/ml	5.14E-9	3.47E-10	2.71E-10	5.67E-10	4.92E-10		
2.	Tritium								
	(a) Total Released	Curies	9.27E+1	2.35E+1	1.11E+2	8.13E+1	2.71E+1		
	(b) Avg. Concentration Released	µCi/ml	3.54E-7	1.10E-7	5.12E-7	3.43E-7	1.61E-7		
3.	Dissolved Noble Gases								
	(a) Total Release	Curies	2.38E-1	1.18E+0	3.67E-1	9.97E-1	1.06E-1		
	(b) Avg. Concentration Released	µCi/ml	9.08E-10	5.55E-9	1.69E-9	4.21E-9	6.25E-10		
4.	Gross Alpha Radioactivity								
	(a) Total Released	Curies	1.16E-5	3.70E-7	1.86E-6	1.92E-5	1.62E-5		
	(b) Avg. Concentration Released	µCi/ml	4.43E-14	1.74E-15	8.58E-15	8.10E-14	9.60E-14		
5.	Vol. of Liquid to Disch. Canal	Liters	3.37E+7	7.17E+7	3.39E+7	2.83E+7	5.01E+7		
6.	Vol. of Dilution Water	Liters	2.62E+11	2.13E+11	2.17E+11	2.37E+11	1.69E+11		
7.	Isotopes Released MPC µCi/ml	Curies							
	I-131 $3 \times 10^{-7}$		1.42E-2	8.96E-3	1.02E-2	2.08E-2	4.52E-3		
	I-132 $8 \times 10^{-6}$		1.71E-4	8.96E-4	4.20E-2	5.49E-4	1.88E-4		
	I-133 $1 \times 10^{-6}$		3.72E-4	6.06E-4	4.39E-2	5.07E-3	*		
	I-134 $2 \times 10^{-5}$		5.15E-4	5.33E-4	4.20E-2	*	*		
	I-135 $4 \times 10^{-6}$		1.38E-4	6.70E-4	5.19E-2	5.16E-4	*		
	Cs-134 $9 \times 10^{-6}$		1.73E-2	2.22E-2	1.76E-2	1.14E-2	8.47E-3		
	Cs-136 $6 \times 10^{-5}$		*	1.35E-3	9.27E-5	*	*		
	Cs-137 $2 \times 10^{-5}$		3.39E-2	4.65E-2	3.82E-2	2.14E-2	2.90E-2		
	Cs-138 -		2.22E-4	*	1.86E-2	*	*		
	Co-57 $4 \times 10^{-4}$		1.54E-4	1.56E-4	1.64E-3	1.33E-4	7.60E-4		
	Co-58 $9 \times 10^{-5}$		1.14E-1	2.54E-2	1.03E-1	1.40E-1	3.00E-1		
	Co-60 $3 \times 10^{-5}$		1.03E-1	6.06E-2	8.13E-2	9.19E-2	2.33E-1		
	Mn-54 $1 \times 10^{-4}$		6.94E-3	2.43E-3	5.21E-3	9.51E-3	2.69E-2		
	Na-24 $3 \times 10^{-5}$		1.59E-2	2.54E-2	5.51E-1	4.70E-4	9.47E-5		
	Cr-51 $2 \times 10^{-3}$		3.60E-2	6.16E-3	3.32E-2	3.97E-2	1.99E-1		
	Fe-59 $5 \times 10^{-5}$		9.09E-4	1.51E-4	1.06E-4	*	7.51E-4		
	Nb-95 $1 \times 10^{-4}$		3.51E-3	8.34E-4	3.01E-3	3.33E-3	1.42E-2		
	Ba-1a-140 $2 \times 10^{-5}$		1.81E-3	7.83E-4	9.25E-5	*	2.48E-5		
	Rb-88 -		*	1.36E-3	2.10E-3	*	*		



FACILITY: Curry Power Station

REPORT OF RADIOACTIVE EFFLUENTS

PAGE 2

DOCKET: 50-280 and 50-281

YEAR: 1978

I. LIQUID RELEASES (CON'T)

UNITS		JANUARY	FEBRUARY	MARCH	APRIL	MAY	TOTAL	± Error
7.	Isotopes Released $\mu\text{MPC Ci/ml}$	Curies						
	Ce-141 $9 \times 10^{-6}$	*	2.37E-4	1.97E-5	*	1.53E-4		
	Ce-144 $1 \times 10^{-6}$	*	*	*	*	5.36E-4		
	Xe-133 $3 \times 10^{-6}$	2.01E-1	1.00E-1	3.08E-1	9.49E-1	2.28E-2		
	Xe-135 $3 \times 10^{-6}$	3.62E-2	2.05E-2	3.24E-2	2.91E-2	1.66E-3		
	Ar-41 $3 \times 10^{-6}$	3.81E-5	9.31E-6	*	*	3.59E-4		
	Sr-89 $3 \times 10^{-6}$							
	Sr-90 $3 \times 10^{-7}$							
	C-14 $8 \times 10^{-4}$							
8.	Percent of 10CFR20	Percent	5.19E-2	3.71E-2	1.10E-1	1.72E-1	2.22E-2	
II. AIRBORNE RELEASES								
1.	Total Noble Gases	Curies	9.47E+1	4.80E+2	1.95E+2	1.24E+3	9.61E+1	
2.	Total Halogens	Curies	1.23E-4	2.90E-5	1.36E-4	5.34E-3	5.37E-2	
3.	Total Particulate Gross Radioactivity (By)	Curies	1.93E-5	1.47E-6	1.61E-5	7.13E-5	1.29E-4	
4.	Total Tritium	Curies	4.46E+0	4.33E+0	1.23E+2	6.79E+0	3.64E+0	
5.	Total Particulate Gross Alpha Radioactivity	Curies	1.04E-6	7.69E-7	5.62E-7	1.57E-6	1.11E-5	
6.	Maximum Noble Gas Release Rate	$\mu\text{Ci/sec}$	6.37E+2	9.40E+2	1.50E+3	1.44E+4	6.51E+2	
7.	Percent of Applicable Limit for Technical Specifications							
	(a) Noble Gases	Percent	5.90E-2	3.46E-1	1.27E-1	8.21E-1	5.98E-2	
	(b) Halogens	Percent	8.29E-5	3.38E-4	1.51E-3	5.65E-2	6.02E-1	
	(c) Particulates	Percent	1.19E-3	2.30E-4	3.01E-4	9.96E-4	1.68E-3	
8.	Isotopes Released:	Curies						
	(a) Particulates							
	Cs-134		2.04E-5	9.54E-7	7.20E-9	*	2.27E-6	
	Cs-135		*	*	*	*	*	
	Cs-137		1.53E-8	1.42E-6	2.14E-6	1.37E-6	7.41E-6	
	Cs-138		*	2.17E-3	3.26E-3	*	*	
	Co-58		3.05E-5	2.60E-6	1.33E-5	7.97E-5	4.72E-5	
	Co-60		5.21E-5	1.36E-5	1.14E-5	4.87E-6	9.05E-5	
	Hu-54		3.34E-6	5.75E-9	*	*	2.49E-6	
	Fe-59		*	*	*	*	*	
	Rb-88		8.11E-5	1.27E-5	1.57E-4	*	*	

1-3

REPORT OF RADIOACTIVE EFFLUENTS

FACILITY: Curry Power Station

DOCKET: 50-280 and 50-281

YEAR: 8

II. AIRBORNE RELEASES (CON'T)

		UNITS	JANUARY	FEBRUARY	MARCH	APRIL	MAY
8.	Isotopes Released (con't)	Curies					
(b)	Halogens						
	I-131		7.39E-6	2.72E-5	1.34E-4	4.88E-3	5.13E-2
	I-132		1.04E-6	*	*	2.93E-4	2.64E-7
	I-133		2.75E-6	1.81E-6	1.34E-7	1.68E-4	9.06E-9
	I-134		*	*	*	*	*
	I-135		*	*	1.78E-7	*	*
(c)	Gases						
	Xe-133		9.43E+1	4.67E+2	1.90E+2	1.20E+3	7.02E+1
	Xe-133m		*	4.76E-1	7.38E-1	1.18E+1	7.30E-2
	Xe-135		3.94E-1	1.13E+1	2.46E+0	2.16E+1	6.06E-3
	Kr-85m		2.41E-4	4.27E-3	3.42E-2	*	*
	Kr-85		*	7.07E-1	*	*	2.59E+1
	Kr-87		*	*	3.95E-2	*	*
	Kr-88		*	5.42E-3	6.67E-2	*	*
	Ar-41		*	9.87E-3	6.40E-1	*	*
III.	SOLID RADIOACTIVE WASTE DISPOSAL						
1.	(a) Total Amount Solid Waste Packaged	ft <sup>3</sup>	60 ft. <sup>3</sup>	7.76E+2	7.21E+2	2.12E+3	3.89E+3
	(b) Estimated Total Activity	Curies	1.625	1.12E+1	9.20E+1	1.32E+2	65.5
	(c) Date of Shipment and Disposition		Barnwell, S.C.	Barnwell, S.C.	Barnwell, S.C.	Barnwell, S.C.	Barnwell, S.C.

01-23-78

2-2-78

3-1-78

04-10-78

05-02-78

2-21-78

3-10-78

04-12-78

05-03-78

2-22-78

3-10-78

04-26-78

05-05-78

3-31-78

04-27-78

05-10-78

05-11-78

05-16-78

05-17-78

05-18-78

05-19-78

05-24-78

05-25-78

\* SENSITIVITY DATA

1. Minimum Detectable Activity

- a. Gross Alpha; 5.27E-9  $\mu$ Ci/ml
- b. Tritium; 4.0E-6  $\mu$ Ci/ml
- c. Strontium-89; less than 3.0E+1 pCi per total filter composite.
- d. Strontium-90; less than 2.0E+0 pCi per total filter composite.
- e. CO<sub>2</sub>-14; less than 7.0E-10  $\mu$ Ci/ml.
- f. Strontium-89; less than 9.0E-9  $\mu$ Ci/ml.
- g. Strontium-90; less than 8.0E-10  $\mu$ Ci/ml.

2. Multichannel Analyzer - GeLi

a. Liquid and/or Radiogases - 100cc

Ba-La-140	2.0E-7
I-131	5.1E-8
Xe-133	5.4E-8
Xe-135	2.9E-8
Cs-137	9.2E-8
Cs-134	7.2E-8
Co-60	1.5E-7
Co-58	9.8E-8
Cr-51	3.8E-7
Mn-54	1.0E-7
Fe-59	2.4E-7
Ar-41	1.6E-7
I-134	1.1E-7
I-132	1.0E-7
Na-24	1.7E-7
I-133	6.9E-8
I-135	4.5E-7
Kr-85	1.36E-5
Kr-88	5.5E-8
Kr-87	5.3E-8
Kr-85m	2.3E-7
Xe-138	4.7E-9
Xe-135m	5.8E-8
Xe-133m	1.7E-7
Rb-88	8.5E-7

b. Radioiodines

I-131	2.3E-6
I-133	3.1E-6
I-132	4.7E-6
I-134	4.8E-6
I-135	2.0E-5

PROCEDURE DEVIATIONS REVIEWED BY STATION NUCLEAR  
SAFETY AND OPERATING COMMITTEE AFTER TIME LIMIT  
SPECIFIED IN TECHNICAL SPECIFICATIONS

MAY, 1978

<u>Number</u>	<u>Unit</u>	<u>Title</u>	<u>Deviation</u>
PT-26.4	1	Radiation Monitoring Equipment Test During Fuel Handling Operations	Step 5.2.4-Unable to verify alarm 1G1. Step 5.2.5-Unable to verify alarm 1G9. Step 5.3.4-Unable to verify alarm 1G1. Step 5.3.5-Unable to verify alarm 1G9. Step 5.4.4-Unable to verify alarm 1G1. Step 5.4.5-Unable to verify alarm 1G9.

This procedure was deviated 05-01-78 and reviewed by the Station Nuclear Safety and Operating Committee 05-18-78.

PT-24.1	1	Fire Protection Water Pump	Steps 5.12 through 5.17 and 6.1.2, not performed.
---------	---	-------------------------------	--

This procedure was deviated 05-09-78 and reviewed by the Station Nuclear Safety and Operating Committee 05-24-78.