



April 2, 2019

Docket No. 52-048

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
One White Flint North
11555 Rockville Pike
Rockville, MD 20852-2738

SUBJECT: NuScale Power, LLC Submittal of Presentation Materials Entitled "ACRS Full Committee Presentation: NuScale Chapter 9, Auxiliary Systems," PM-0319-64807, Revision 0

The purpose of this submittal is to provide presentation materials to the NRC for use during the upcoming Advisory Committee on Reactor Safeguards (ACRS) NuScale Full Committee meeting on April 4, 2019. The materials support NuScale's presentation of Chapter 9, "Auxiliary Systems" of the NuScale design certification application.

The enclosure to this letter is the nonproprietary version of the presentation entitled "ACRS Full Committee Presentation: NuScale Chapter 9, Auxiliary Systems," PM-0319-64807, Revision 0.

This letter makes no regulatory commitments and no revisions to any existing regulatory commitments.

If you have any questions, please contact Carrie Fosaaen at 541-452-7126 or at cfosaaen@nuscalepower.com.

Sincerely,

Zackary W. Rad
Director, Regulatory Affairs
NuScale Power, LLC

Distribution: Robert Taylor, NRC, OWFN-8H12
Michael Snodderly, NRC, TWFN-2E26
Samuel Lee, NRC, OWFN-8H12
Gregory Cranston, NRC, OWFN-8H12
Getachew Tesfaye, NRC, OWFN-8H12


Enclosure: "ACRS Full Committee Presentation: NuScale Chapter 9, Auxiliary Systems," PM-0319-64807, Revision 0

D111
NRD



Enclosure:

"ACRS Full Committee Presentation: NuScale Chapter 9, Auxiliary Systems," PM-0319-64807, Revision 0



ACRS Full Committee Presentation: NuScale Chapter 9, Auxiliary Systems

Presentation Team

Scott Harris

Supervisor, Mechanical Systems

Corrie Nichol, Ph.D.

Refueling and Remote Handling

Zackary Rad

Director, Regulatory Affairs

Zach Houghton

Manager, Mechanical Design

Reactor Building Crane

- RBC Design
 - Designed to ASME NOG-1 Type 1 (Meets NUREG-0554 requirements)
 - Designed to be Seismic Category 1 (Required to withstand earthquake stress and retain load.)
 - Movement uses redundant position control system interlocks
- Risk Significant
 - RBC has augmented Quality Control per Part III of the QAPD (because of Risk Significance)
 - Augmented requirements conform to regulatory requirements. (SRP 9.1.5, NUREG-0554, NUREG-0612, and RG 1.13)
- Non-Safety
 - The RBC doesn't perform any functions that meet the regulatory definition of safety-related.

RBC Control System

- Redundant limit switches
 - Hoist overtravel (upper limit switches, lower limit switches)
 - Hoist overload
- Interlocks
 - Slack rope and Hoist drum rope mis-spooling
 - Hoist overspeed
 - Unbalanced load
 - Reactor building crane-fuel handling machine (FHM) interlock
 - Bridge and trolley overtravel limits
- Safe Load Paths
 - Restricted handling path and speed (30 ft/min traverse, 2 ft/min hoist)
 - Operator monitored

RBC Control System

- E-stop system
 - Physical relay controlled – no software
 - Cuts power to motors and brakes (stops motors, sets brakes)
 - Independent of any controls used for normal operation
- Redundant Physical Load Control Systems
 - Redundant gearboxes, cables, brakes on main hoist
 - Redundant elements are all capable of performing their function individually at full load

RBC Control System

- In the event of failure of load lift control system:
 - Redundant upper travel limit switches
 - Two-blocking capable (Hard upper limit doesn't damage RBC)
 - Raise to top of travel – fuel still covered, shielding maintained, reactor module base is 29 feet above the floor
- In the event of a failure of travel control system:
 - Traverse speed limited, operator monitors motion, speed is slow enough to enable operator to protect from impacts (30 ft/min)
 - Energy absorbing hard stops, designed to protect in event of redundant limit switch failure (at end of travel for bridge and trolley)

Digital I&C Design and Development

- Design and development of any RBC software-based components follows a rigorous quality assurance program to ensure high quality and reliable operation based on the safety and risk significance.
- RBC Software Integrity Level (SIL)
 - RBC is nonsafety-related, risk-significant which invokes SIL 3
 - Independent verification and validation is required for SIL 3 and SIL 4 digital I&C.
- NuScale Digital I&C Software Quality Assurance Program described in DCA Section 7.2.1, and complies with ASME NQA-1-2008 and NQA-1a-2009

Initial Testing Program

ASME NOG-1 and Other Required Controls Testing (from DCA Table 14.2-52 and 14.2-52a)

- E-stop functionality
- Functional testing of controls and components
- Full load test
- Test limit switches
- Test speed limit at full load
- Two-blocking
- Brake function (redundant brakes for hoist and travel)
- Lowering speed limit and lowering brake test

Initial Testing Program

Prerequisites

- Site Acceptance Testing
- Rated Load Test – ASME NOG-1 – Hoists (Main, Aux and Wet)
- Rated Load Test – ANSI N14.6 – MLA and NPM lift fixture
- Instrument Calibrations completed

Component Testing

- Controls – interlocks and limits on RBC motion tested
- Loss of Control/Power or Seismic event – Results in no movement of bridge trolley, all hoists and brakes are set

Initial Testing Program

Component Testing (continued)

- Load Path Verification includes:
 - speeds - max limits enforced
 - bridge/trolley movement - toggles from full speed to microspeed when in proximity to reference locations – other NPMs or load path boundary
 - Main hoist movement – elevation enforced and proximity
 - Main hoist rotation
 - Full seating of NPM in reactor bay receiver

ITAAC

ITAAC 03.10.01

- ASME NOG-1 Inspection of main hoist machinery – redundant and non-redundant structural components – bridge, trolley, wire rope drum, hook, drive train, two-blocking and overload

ITAAC 03.10.02 and 03.10.03

- ASME NOG-1 Inspection of aux and wet hoist machinery – same scope as ITAAC 03.10.01

ITAAC 03.10.04

- ASME NOG-1 main hoist Full Load (100%) and Rated Load (125%) testing

ITAAC 03.10.05 and 03.10.06

- ASME NOG-1 aux and wet hoists Full Load and Rated Load testing

ITAAC

ITAAC 03.10.07

- ASME NOG-1 NDE of RBC as-built welds

ITAAC 03.10.08

- ASME NOG-1 NDE of wet hoist as-built welds

ITAAC 03.10.09


- ANSI N14.6 MLA single load path tested to 300% of Manufacturer's rating
- ANSI N14.6 MLA dual load path tested to 150% of Manufacturer's rating
- ANSI N14.6 MLA load bearing welds undergo NDE testing

ITAAC 03.10.10

- ANSI N14.6 MLA inspection of lifting arms and pinned clevis

Pool Liner

- Liner Functions:
 - Protect concrete from the borated pool water.
 - Collect pool leakage and direct to sumps.
- Seismic Category I
- High sump level alarms in control room




Pool Liner

- RXB floor slab is 10 feet of reinforced concrete
- RXB floor slab is capable of withstanding a module drop from maximum hook height without damaging the concrete in such a way as to cause significant damage to RXB concrete
- Pool liner rupture would result in negligible loss from UHS inventory
 - Flooding would fill gaps and channels between liner and RXB concrete

Reactor Pool Mixing

- Spent Fuel Pool Cooling System
 - 2x 1250 gpm pump & heat exchanger trains
- Reactor Pool Cooling System
 - 3x 1250 gpm pump & heat exchanger trains
- Combined minimum operating flow (1 SFPCS / 1 RPCS)
 - 3.6 Million gallons / day (~7 Million gallon pool)
- Sample points on discharge of RPCS, SFPCS, and PCUS
- Conductivity monitors on outlet of RPCS, SFPCS, and PCUS
 - Conductivity mismatch between systems could indicate a difference in boron concentration between pools

Reactor Pool Mixing



Reactor Pool Mixing

- Shutdown Margin verified by TS 3.1.1
 - SR 3.1.1.1 (will use samples from RPCS to verify pool boron concentration)
 - Every 24 hours
- UHS boron concentration verified by TS 3.5.3
 - SR 3.5.3.3
 - Every 31 Days
 - And within 6 hours after each solution volume increase of $\geq 15,000$ gal

Acronyms

- **ANSI – American National Standards Institute**
- **ASME – American Society of Mechanical Engineers**
- **aux – Auxiliary**
- **CNV – Containment Vessel**
- **DCA – Design Certification Application**
- **E-Stop – Emergency Stop**
- **FHM – Fuel Handling Machine**
- **ft – feet**
- **gpm – gallons per minute**
- **I&C – Instrument and Control**
- **ITAAC - Inspections, Tests, Analyses, and Acceptance Criteria**
- **MCS – Module Control System**
- **min – minute**
- **MLA – Module Lifting Adapter**
- **NDE – Nondestructive Examination**
- **NPM – NuScale Power Module**
- **PCS – Plant Control System**
- **QAPD – Quality Assurance Program Description**
- **PCUS – Pool Cleanup System**
- **RBC – Reactor Building Crane**
- **RFT – Refueling Tool**
- **RG – Regulatory Guide**
- **RPCS – Reactor Pool Cooling System**
- **RPV – Reactor Pressure Vessel**
- **RXB – Reactor Building**
- **SFPCS – Spent Fuel Pool Cooling System**
- **SIL – Software Integrity Level**
- **SR – Surveillance Requirement**
- **SRP – Standard Review Plan**
- **TS – Technical Specification**
- **UHS – Ultimate Heat Sink**

Portland Office

6650 SW Redwood Lane,
Suite 210
Portland, OR 97224
971.371.1592

Corvallis Office

1100 NE Circle Blvd., Suite 200
Corvallis, OR 97330
541.360.0500

Rockville Office

11333 Woodglen Ave., Suite 205
Rockville, MD 20852
301.770.0472

Charlotte Office

2815 Coliseum Centre Drive,
Suite 230
Charlotte, NC 28217
980.349.4804

Richland Office


1933 Jadwin Ave., Suite 130
Richland, WA 99354
541.360.0500

Arlington Office

2300 Clarendon Blvd., Suite 1110
Arlington, VA 22201

London Office

1st Floor Portland House
Bressenden Place
London SW1E 5BH
United Kingdom
+44 (0) 2079 321700



<http://www.nuscalepower.com>

Twitter: @NuScale_Power

