

MAR 19 2019



U.S. Nuclear Regulatory Commission  
Attention: Document Control Desk  
Washington, DC 20555

Serial No. 19-092  
NSSL/MLC R0  
Docket No. 50-423  
License No. NPF-49

**DOMINION ENERGY NUCLEAR CONNECTICUT, INC.**  
**MILLSTONE POWER STATION UNIT 3**  
**INSERVICE INSPECTION PROGRAM INTERVAL CHANGE**

The purpose of this letter is to inform the NRC staff of a change to the end date for the Millstone Power Station Unit 3 (MPS3) third 10-year Inservice Inspection (ISI) interval. This change is being made in accordance with Section XI of the American Society of Mechanical Engineers (ASME) Boiler and Pressure Vessel Code, 2004 Edition (no Addenda) pursuant to 10 CFR 50.55a(g). As specified within ASME IWA-2430 paragraph (d), "Each inspection interval may be reduced or extended by as much as one year. Adjustments shall not cause successive intervals to be altered by more than one year from the original pattern of intervals."

MPS3's third 10-year ISI interval, which began on April 23, 2009, is scheduled to end on April 22, 2019. Since this end date will occur prior to the end of the upcoming spring 2019 refueling outage, the end date for the third 10-year ISI interval is being extended to June 22, 2019. This adjustment will allow the interval to extend through the end of the spring 2019 refueling outage and allow for continued use of the currently approved third 10-year ISI interval relief requests.


The fourth 10-year ISI interval for MPS3 began on February 23, 2019 and is scheduled to end on February 22, 2029. The code of record for MPS3's fourth 10-year ISI interval is the 2013 Edition (no Addenda) of ASME Section XI. This interval will overlap the third 10-year ISI interval by four months.

During the spring 2019 refueling outage, MPS3 will complete work for the third 10-year ISI interval concurrent with inspections required to be performed during the fourth 10-year interval as allowed by ASME Section XI IWA-2430.

This adjustment does not cause successive intervals to be altered by more than one year from the original pattern of intervals.

If you have any questions or require additional information, please contact Mr. Jeffrey A. Langan at 860-444-5544.

Sincerely,

 For JRD

J. R. Daugherty  
Site Vice President - Millstone

A047  
NRR

Attachments: None

Commitments made in this letter: None.

cc: U.S. Nuclear Regulatory Commission  
Region I  
2100 Renaissance Blvd, Suite 100  
King of Prussia, PA 19406-2713

Richard V. Guzman  
Senior Project Manager  
U.S. Nuclear Regulatory Commission  
One White Flint North, Mail Stop 08 C2  
11555 Rockville Pike  
Rockville, MD 20852-2738

NRC Senior Resident Inspector  
Millstone Power Station