



APR 12 2019

TS 6.9.1.5.b

LR-N19-0048

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555-0001

Hope Creek Generating Station
Renewed Facility Operating License No. NPF-57
NRC Docket No. 50-354

Subject: 2018 Annual Report of SRV Challenges

This report is being submitted in accordance with Hope Creek Technical Specification 6.9.1.5.b, which requires the documentation of all challenges to main steam line safety / relief valves (SRVs) be provided on an annual basis.

For 2018, the SRVs were not challenged by any over pressurization events or transients that would have required the valves to respond automatically.

There are no regulatory commitments contained in this letter.

Should you have any questions or require any additional information regarding this submittal, please contact Ms. Kirsten Stokes, at (856) 339-2834.

Sincerely,

A handwritten signature in black ink, appearing to read "E. T. Casulli".

Edward T. Casulli
Plant Manager, Hope Creek Generating Station

Page 2
LR-N19-0048

cc: Administrator, Region I, NRC
NRC Project Manager, Hope Creek
NRC Senior Resident Inspector, Hope Creek
Manager, NJBNE
Corporate Commitment Tracking Coordinator
Hope Creek Commitment Tracking Coordinator