

REGULATORY DOCUMENT COPY

VIRGINIA ELECTRIC AND POWER COMPANY
RICHMOND, VIRGINIA 23261



September 21, 1977

Mr. James P. O'Reilly, Director
Office of Inspection and Enforcement
U. S. Nuclear Regulatory Commission
Region II - Suite 818
230 Peachtree Street, Northwest
Atlanta, Georgia 30303

Serial No. 419
PO&M/TAP;dgt
Docket No. 50-281
License No. DPR-37

Dear Mr. O'Reilly:

Pursuant to Surry Power Station Technical Specification 6.6.2, the Virginia Electric and Power Company hereby submits a copy of Reportable Occurrence No. RO-S2-77-08.

The substance of this report has been reviewed by the Station Nuclear Safety and Operating Committee and will be placed on the agenda for the next meeting of the System Nuclear Safety and Operating Committee.

Very truly yours,

A handwritten signature in cursive script that reads "G. M. Stallings".

G. M. Stallings
Vice President-Power Supply
and Production Operations

Enclosures

40 copies RO-S2-77-08

cc: Mr. Robert W. Reid, Chief
Operating Reactors Branch 4

772660152

EVENT DESCRIPTION (CONTINUED)

concentration was 17.6 percent. (RO-S2-77- 08)

CAUSE DESCRIPTION (CONTINUED)

Westinghouse letter dated 8-25-77 indicated the original procedure was defective because the calculations were in terms of volume instead of mass or weight. Recalculating the concentration of sodium hydroxide in the samples taken prior to Sept. 1975 indicated one Technical Specification violation as previously noted.

RECEIVED DOCUMENT
PROCESSING UNIT

1977 SEP 23 PM 1 54