

Central File
50-281

AO-S2-76-4

Vepco

VIRGINIA ELECTRIC AND POWER COMPANY
Surry Power Station
P.O. Box 315
Surry, Virginia 23883

June 7, 1976

Director of Regulatory Operations
Region II
230 Peachtree Street, N.W.
Suite 818
Atlanta, Georgia 30303

This is to inform you by telecopy of a Reportable Occurrence that was noted on June 6, 1976, at Surry Nuclear Power Station. Surry Unit 2 was taken critical without all heat tracing circuits being operable as required by the Technical Specifications. At no time while the reactor was critical were any low temperatures experienced in the boric acid systems.

E. M. Sweeney, Jr.
E. M. Sweeney, Jr.
Manager