

Central File
50-281

Vepco

RD-52-76-2

VIRGINIA ELECTRIC AND POWER COMPANY
Surry Power Station
P.O. Box 315
Surry, Virginia 23888

May 11, 1976

Director of Regulatory Operations
230 Peachtree Street, N.W.
Suite 818
Atlanta, Georgia 30303

This is to inform you by telecopy of a Reportable Occurrence that was noted on May 11, 1976 at Surry Nuclear Power Station. During refueling shutdown on Unit 2 the seventh (top) support plate in "A" steam generator was observed to have areas of distortion and cracking.

E. M. Sweeney, Jr.
E.M. Sweeney, Jr.
Manager