

NRC DISTRIBUTION FOR PART 50 DOCKET MATERIAL

TO: Mr Rusche		FROM: VEPCO Richmond, Va C M Stallings		DATE OF DOCUMENT 8-26-76
1 76				DATE RECEIVED 8-31-76
<input checked="" type="checkbox"/> LETTER	<input type="checkbox"/> NOTORIZED	PROP	INPUT FORM	NUMBER OF COPIES RECEIVED one signed
<input checked="" type="checkbox"/> ORIGINAL	<input checked="" type="checkbox"/> UNCLASSIFIED			
<input type="checkbox"/> COPY				

DESCRIPTION

Let re Westinghouse to VEPCO ltr dtd 8-5-76  
.....trans the following:

PLANT NAME: Surry 1 & 2


ENCLOSURE

Info concerning unreviewed safety issues with regard to ECCS & DNBR.....

SAFETY		FOR ACTION/INFORMATION		ENVIRO	8-31-76	ehf
ASSIGNED AD:		ASSIGNED AD:				
BRANCH CHIEF:	Reid (5)	BRANCH CHIEF:				
PROJECT MANAGER:	Fairfile	PROJECT MANAGER:				
LIC. ASST.:	Ingram	LIC. ASST.:				


INTERNAL DISTRIBUTION			
<input checked="" type="checkbox"/> REG FILE	SYSTEMS SAFETY	PLANT SYSTEMS	SITE SAFETY &
<input checked="" type="checkbox"/> NRC PDR	HEINEMAN	TEDESCO	ENVIRO ANALYSIS
<input checked="" type="checkbox"/> I & E (2)	SCHROEDER	BENAROYA	DENTON & MULLER
<input checked="" type="checkbox"/> OELD		LAINAS	
<input checked="" type="checkbox"/> GOSSICK & STAFF	ENGINEERING	IPPOLITO	ENVIRO TECH.
MIPC	MACCARRY	KIRKWOOD	ERNST
CASE	KNIGHT		BALLARD
HANAUER	SIHWEIL	OPERATING REACTORS	SPANGLER
HARLESS	PAWLICKI	STELLO	
			SITE TECH.
PROJECT MANAGEMENT	REACTOR SAFETY	OPERATING TECH.	GAMMILL
BOYD	ROSS	EISENHUT	STEPP
P. COLLINS	NOVAK	SHAO	HULMAN
HOUSTON	ROSZTOCZY	BAER	
PETERSON	CHECK	BUTLER	SITE ANALYSIS
MELTZ		GRIMES	VOLLNER
HEITEMES	AT & I		BUNCH
SKOVHOLT	SALTZMAN		J. COLLINS
	RUTBERG		KREGER

EXTERNAL DISTRIBUTION			CONTROL NUMBER
LPR: Williamsburg, Va	NAT LAB:	BROOKHAVEN NAT LAB	8848
TIC:	REG. VIE	ULRIKSON (ORNL)	
NSIC:	LA PDR		
ASLB:	CONSULTANTS		
ACRS / 6 CYS HOLDING / SENT	To LA Ingram		



VIRGINIA ELECTRIC AND POWER COMPANY  
RICHMOND, VIRGINIA 23261

August 26, 1976



Mr. Benard C. Rusche, Director  
Office of Nuclear Reactor Regulation  
Attn: Mr. Robert W. Reid, Chief  
Operating Reactors Branch No. 4  
Division of Operating Reactors  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Serial No. 211  
FR/JTR:agg

Docket Nos. 50-280  
50-281

Dear Mr. Rusche:


On August 5, 1976, the Virginia Electric and Power Company (Vepco) was informed by the Westinghouse Electric Corporation of two unreviewed safety questions with potential impact on the operation of Surry Units 1 and 2. These unreviewed questions are concerned with the impact of higher upper head fluid temperatures on the Loss of Coolant Accident ECCS Analysis and a greater than anticipated effect on DNBR of fuel rod bowing in thimble cells. An evaluation of these concerns and their potential impact on the operation of Surry Units 1 and 2 was conducted by Vepco, and on August 6, 1976, voluntary reductions in all hot channel peaking factor limits were put into effect. Notification of these actions was then provided to the U. S. Nuclear Regulatory Commission (NRC).

On August 13, 1976, additional guidance on an interim mechanism for conservatively accommodating any potential impact from the above concerns was informally received from the NRC Staff. Evaluations were then performed to determine the appropriate limits on the operation of Surry Units 1 and 2 consistent with the guidance received from the Staff. These evaluations and associated operating limits were reviewed with the Staff on August 16, 1976, and were formally submitted, as required, on August 18, 1976, in our letter Serial No. 194.

On August 24, 1976, the Staff informed us that our evaluation and associated limits for the impact of higher upper head fluid temperature on the Surry LOCA/ECCS were not acceptable. During further discussions on August 25, 1976, the Staff informed us that the reason the evaluation was unacceptable was that it did not contain sufficient information to confirm that the most conservative value of the discharge coefficient ( $C_d$ ) was used, notwithstanding our specific discussion on this point on August 16, 1976, and the fact that we addressed and justified our position on this point directly in our August 18, 1976, submittal. The Staff further indicated that until confirmatory analyses could be submitted, reviewed, and approved, an additional penalty of 0.05 on the FQ limits contained in our August 18, 1976, submittal would be required.

Our position on this matter is that our evaluations and associated limits contained in our August 18, 1976, submittal are technically correct and complete; however, we will accept the Staff's position until confirmatory analyses can be approved. Accordingly, we have revised the operating limits contained in our August 18, 1976, submittal. These limits are contained in Attachment 1 to this letter.

Very truly yours,



C. M. Stallings  
Vice President-Power Supply  
and Production Operations

Attachment

cc: Mr. Norman C. Moseley, Director  
Office of Inspection and Enforcement  
Region II

The limiting values of the following power distribution parameters shall be changed:

- a. heat flux hot channel factor,  $F_Q(Z)$
- b. enthalpy rise hot channel factor,  $F_{\Delta H}^N$ , and
- c. quadrant power tilt ratio.

- The heat flux hot channel factor,  $F_Q(Z)$  shall be limited to the following values:

For Unit 1

$$F_Q(Z) \leq (1.80/P) \times K(Z) \text{ for } P > 0.5$$

$$F_Q(Z) \leq (3.60) \times K(Z) \text{ for } P \leq 0.5$$

For Unit 2

$$F_Q(Z) \leq (1.82/P) \times K(Z) \text{ for } P > 0.5$$

$$F_Q(Z) \leq (3.64) \times K(Z) \text{ for } P \leq 0.5$$

where  $P$  is the fraction of rated power at which the core is operating,  $K(Z)$  is the function given in Figure 1, and  $Z$  is the core height location of  $F_Q(Z)$ . Additionally, the limiting behavior of  $F_Q(Z)$  for nominal transient operation of each unit shall be periodically evaluated. If this evaluation shows that  $F_Q(Z)$  could potentially violate its limiting values either:

- a. reactor thermal power shall be reduced appropriately in order to accommodate this potential violation, or
  - b. APDMS type surveillance shall be performed to directly monitor  $F_Q(Z)$ .
- The enthalpy rise hot channel factor,  $F_{\Delta H}^N$ , shall be limited to the following values:

$$F_{\Delta H}^N = 1.55 \{ 1 + 0.2(1-P) \} \times T(\text{BU})$$

where  $P$  is the fraction of rated power at which the core is operating and  $T(\text{BU})$  is the thimble cell penalty on  $F_{\Delta H}^N$ , which is given in Figure 2.

- The quadrant power tilt ratio shall be limited to values  $< 1.02$ .


ATTACHMENT 1

CHANGES TO LIMITING VALUES OF POWER  
DISTRIBUTION PARAMETERS FOR CYCLE 3 OPERATION OF  
SURRY UNITS NO. 1 AND 2 AS THE RESULT OF HIGHER UPPER HEAD  
FLUID TEMPERATURES AND THIMBLE CELL ROD BOW EFFECT

Figure 1

HOT CHANNEL FACTOR NORMALIZED  
OPERATING ENVELOPE

SURRY POWER STATION  
UNITS NO. 1 AND 2



46 1510

10 X 10 TO THE CENTIMETER  
KEUFFEL & ESSER CO. MADE IN USA

K·E




FIGURE 2