

Official Transcript of Proceedings

NUCLEAR REGULATORY COMMISSION

Title: 660th Meeting, Advisory Committee
on Reactor Safeguards (ACRS),
Open Session

Docket Number: N/A

Location: Rockville, Maryland

Date: February 6, 2019

Work Order No.: NRC-0127

Pages 1-294

NEAL R. GROSS AND CO., INC.
Court Reporters and Transcribers
1323 Rhode Island Avenue, N.W.
Washington, D.C. 20005
(202) 234-4433

DISCLAIMER

UNITED STATES NUCLEAR REGULATORY COMMISSION'S
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

The contents of this transcript of the proceeding of the United States Nuclear Regulatory Commission Advisory Committee on Reactor Safeguards, as reported herein, is a record of the discussions recorded at the meeting.

This transcript has not been reviewed, corrected, and edited, and it may contain inaccuracies.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

+ + + + +

660TH MEETING

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS
(ACRS)

+ + + + +

WEDNESDAY

FEBRUARY 6, 2019

+ + + + +

ROCKVILLE, MARYLAND

+ + + + +

The Advisory Committee met at the Nuclear
Regulatory Commission, Two White Flint North, T3D50,
11545 Rockville Pike, at 8:30 a.m., Peter Riccardella,
Chairman, presiding.

COMMITTEE MEMBERS:

PETER RICCARDELLA, Chairman

MATTHEW W. SUNSERI, Vice Chairman

JOY L. REMPE, Member-at-Large

RONALD G. BALLINGER, Member

DENNIS C. BLEY, Member

CHARLES H. BROWN, JR. Member

MICHAEL L. CORRADINI, Member

1 VESNA B. DIMITRIJEVIC, Member
2 WALTER L. KIRCHNER, Member
3 JOSE MARCH-LEUBA, Member
4 HAROLD B. RAY, Member
5 GORDON R. SKILLMAN, Member
6

7 DESIGNATED FEDERAL OFFICIALS:

8 DEREK WIDMAYER
9 QUYNH NGUYEN
10 MIKE SNODDERLY
11 ZENA ABDULLAHI
12
13
14
15
16
17
18
19
20
21
22
23
24
25

T-A-B-L-E O-F C-O-N-T-E-N-T-S

	<u>Page</u>
Opening Remarks by the ACRS Chairman	4
Technology-Inclusive, Risk-Informed, Performance-Based Approach for Approving Non-Light-Water Reactors Remarks by the Subcommittee Chairman	7
Discussion	13
Non-Production & Utilization Facilities Rulemaking	95
Interim Letter: Chapters 2 and 17 of the NRC Staff's Safety Evaluation Reports With Open Items Related to the Certification of the NuScale Small Modular Reactor	131
Adjourned	217

P-R-O-C-E-E-D-I-N-G-S

(8:31 a.m.)

CHAIRMAN RICCARDELLA: Good morning. The meeting will come to order. This is the first day of the 660th meeting of the Advisory Committee on Reactor Safeguards.

During today's meeting the Committee will consider the following. Technology-inclusive, risk-informed, performance-based approach for approving non-light water reactors, non-power production and utilization facilities rulemaking, Interim Letter Chapters 2 and 17 of the NRC Staff's safety evaluation reports, with open items related to the certification of the NuScale small module reactor.

Number 4, review of AURORA-B for LOCA scenarios and preparation of ACRS reports. The ACRS was established by statute and is governed by the Federal Advisory Committee Act, FACA.

As such, this meeting is being conducted in accordance with the provisions of FACA. That means that the Committee can only speak through its published letter reports.

We hold meetings to gather information, to support our deliberations. Interested parties who wish to provide comments can contact our office

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

(202) 234-4433

1 requesting time after the federal register notice
2 describing a meeting is published.

3 With that said, we also set aside ten
4 minutes for spur of the moment comments for members of
5 the public attending or listening to our meetings.
6 Written comments are also welcome.

7 Mr. Derek Widmayer is the designated
8 federal officer for the initial portion of this
9 meeting.

10 Portions of the sessions, on Interim
11 Letter Chapters 2 and 17 of the NRC Staff safety
12 evaluation reports with open items may be closed in
13 order to discuss and protect information designated as
14 proprietary.

15 The AURORA-B for LOCA scenario meeting
16 will be closed in its entirety in order to discuss
17 protected proprietary information.

18 The ACRS section of the U.S. NRC public
19 website provides our charter, bylaws, letter of
20 reports and full transcripts of all full and
21 subcommittee meetings. Including all slides presented
22 at the meetings.

23 We have received no written comments or
24 requests to make oral statements from members of the
25 public regarding today's sessions.

1 There will be a phone bridge line, but to
2 preclude interruption of the meeting, the phone will
3 be placed in a listen only mode during the
4 presentations and Committee discussion.

5 A transcript of portions of this meeting
6 is being kept. And it is requested that speakers use
7 one of the microphones, identify themselves and speak
8 with sufficient clarity and volume so that they can be
9 readily heard.

10 As an item of current interests, I would
11 like to welcome to new management and analysts to our
12 support staff, Paula Dorm and Makeeka Compton.

13 MEMBER CORRADINI: They should stand.
14 Stand up.

15 MS. DORM: Hi, I'm Paula.

16 CHAIRMAN RICCARDELLA: That's Makeeka.
17 Hi. With that said, I'll turn the meeting over to
18 Derek Widmayer.

19 MEMBER BLEY: Well, speaking on Derek's
20 behalf, this is --

21 (Laughter.)

22 MEMBER BLEY: I'd like to welcome
23 everybody to our December meeting to look at the
24 Staff's proposed SECY and guidance documents on the,
25 what we were calling the licensee modernization

1 project and is now called the Technology-Inclusive,
2 Risk-Informed and Performance-Based Approach, to
3 inform the content of applications for licensees'
4 licenses.

5 At this point, Bill, am I going to turn it
6 over to you or John?

7 MR. SEGALA: Yes.

8 MEMBER BLEY: John Segala, please
9 introduce this for us.

10 MR. SEGALA: Thank you, Dr. Bley. I'm
11 John Segala, I'm the Chief of the Advance Reactor and
12 Policy Branch in the Office of New Reactors, and I'm
13 appreciative of the ACRS inviting us here today.

14 We had previously briefed the Subcommittee
15 back in October and we were scheduled to brief the
16 Full Committee in early December, but due to President
17 Bush's funeral and the Government closure at that
18 time, we got rescheduled. So I appreciate you
19 accommodating us today.

20 We have, as you said, we're moving forward
21 with commission paper. We're also developing an
22 associated draft regulatory guide.

23 We were scheduling to try to get the draft
24 guide out the end of December. Due to the Government,
25 the Federal Register has been closed for us. But we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 also ran into some internal concurrence issues.

2 So we're still working to get that draft
3 guide out as soon as possible, but I just wanted to
4 update you on where we were with that.

5 MEMBER BLEY: Thank you. We look forward
6 to seeing that.

7 MR. SEGALA: Okay. So I also wanted to
8 sort of step back based on some things that have
9 happened since we last met.

10 First of all, as you know, when you look
11 at some of the designers out there that might be
12 considered early movers, ones that would be coming in
13 with an application using the current regulations.

14 We see the licensee modernization project
15 in our draft guide as very important for helping to
16 establish, as you said, a technology-inclusive, risk-
17 informed, performance-based approach for establishing
18 the licensing basis and the content of the
19 application.

20 In addition, recently, the Nuclear Energy
21 Innovation and Modernization Act was signed into law.
22 That's requiring the NRC to develop a technology-
23 inclusive, risk-informed, performance-based regulation
24 for advance reactors. We call this Part 53, although
25 it's not officially a Part 53.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 But we see, we don't know the exact scope
2 of what this is going to be, but we see the licensing
3 modernization project as forming the foundation for
4 this future rulemaking that we have to do by 2027.

5 So I just wanted to sort of set the stage
6 for that. We're looking for the ACRS today to provide
7 feedback on our commission paper and to provide us a
8 letter on the commission paper.

9 So that's our goal for today. And we're
10 looking forward to having discussions.

11 MEMBER BLEY: Thanks for that. What's the
12 status of the paper now, I thought you were, you were
13 hoping to get it out already?

14 MR. SEGALA: Yes. And we're still working
15 on getting that out as well.

16 MEMBER BLEY: Okay.

17 MR. SEGALA: It's in final concurrences
18 now.

19 MEMBER CORRADINI: So, just to clarify one
20 thing. So, the intent is the technical basis we're
21 going to be talking about today would probably be what
22 you would point to in satisfaction of this new
23 congressional action?

24 MR. SEGALA: It will help form the base
25 foundation for that new rule.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER CORRADINI: Okay, thank you.

2 MR. SEGALA: So I just wanted to put that
3 in perspective for you that this is where, we had
4 always, when we had developed our vision and strategy
5 document and our implementation action plans, we had
6 always included in the mid-term and the long-term
7 implementation action plans, a plan to look at whether
8 or not we should be doing a new rule for advance
9 reactors.

10 Now, with this law, we were being told to
11 just do it. So, we had always thought that LMP would
12 eventually help form the basis if we end up, in the
13 future, ever did a new rule. But now that that's
14 become a reality, we're moving forward with that in
15 mind.

16 MEMBER BLEY: Well, it's nice to be a
17 little ahead.

18 MR. SEGALA: Yes. For once.

19 MEMBER REMPE: John? You mentioned that
20 you were hearing some of the design developers
21 expressing interest in using what is in the NEI
22 document and this approach, can you characterize a
23 little bit more about how strong that interest is and
24 the schedule when you'd anticipate them to actually
25 trying to apply it?

1 MR. SEGALA: Well, I guess it depends on
2 who you talk to. There has been, we've generally
3 heard favorable responses from designers on using it.
4 We're not quite sure if everybody is going to use it.

5 There have been, as we mentioned in a
6 Subcommittee meeting, there's been a number of
7 tabletops or --

8 MEMBER REMPE: Right.

9 MR. SEGALA: -- pilots of LMP. X-energy
10 has done it, Oklo has done it.

11 We're looking to, I believe Kairos is
12 planning to do it. Westinghouse, for the eVinci, is
13 planning to do a tabletop.

14 And so, we're hearing a lot of interests
15 in using it. I think the one area that we're not
16 quite sure, that we haven't heard as much, has maybe
17 been in more the molten salt reactors.

18 MEMBER REMPE: So, okay, let's pick on X-
19 energy. Have they said, hey, we're going to use it,
20 we're going to be here within the next year to come,
21 or how strong is that is interest?

22 Or is there anyone who said, I'm going to
23 be here in the next year?

24 MR. SEGALA: I can't really talk about
25 that because that information is proprietary.

1 MEMBER REMPE: Okay. But without
2 characterizing anyone, you can't tell me if anyone has
3 said they're going to be here in the next year, the
4 next two years, next five years?

5 MR. SEGALA: We are currently expecting an
6 application within the next year or so.

7 MEMBER REMPE: Okay.

8 CHAIRMAN RICCARDELLA: Excuse me, we need
9 to pause the meeting for a second so that we can open
10 the phone for outside. And it's going to be a little
11 noisy.

12 (Off record comments.)

13 CHAIRMAN RICCARDELLA: Okay, you can
14 continue.

15 MR. SEGALA: So that's all I had in terms
16 of --

17 CHAIRMAN RICCARDELLA: Thanks.

18 (Laughter.)

19 MEMBER CORRADINI: I'm sure the people on
20 the line enjoyed that conversation. But that was the
21 introduction, that's all you had.

22 MR. SEGALA: We're done.

23 (Laughter.)

24 MR. SEGALA: You can write the letter
25 right now.

1 CHAIRMAN RICCARDELLA: Correctly.

2 MR. SEGALA: Do you want Bill to swear on
3 a Bible since he's in the court of law here?

4 MR. RECKLEY: No, thank you. Okay, so,
5 again, I'm Bill Reckley and I'm going to walk through
6 some of the background, the guidance.

7 We still call it licensing modernization
8 project as well, but the official document is a draft
9 of NEI 18-04 and a draft regulatory guide which
10 provides the background into elements of how we would
11 approach licensing of non-light water reactors. It's
12 not the total story but it's been, these areas are the
13 cornerstones, if you will, of a licensing approaches.
14 And then that feeds into the draft commission papers.

15 As John said, when we came in October, we
16 were really kind of looking for a letter on both the
17 guidance, so, down in the details, as well we the
18 higher level, that would be addressed in the
19 commission paper. Although things haven't really
20 panned out as we thought.

21 We thought the draft guide would be out by
22 now and so, but we're going to stick to the plan that
23 the draft guide will be going out for comment and
24 we'll return to the ACRS for the final guide. And
25 that's the details, both in the NEI guidance document

1 and the draft guide.

2 MEMBER BLEY: Bill?

3 MR. RECKLEY: Yes.

4 MEMBER BLEY: At that time, will there be
5 any additional tabletop work completed? And if so,
6 can we include some of that in the --

7 MR. RECKLEY: Yes. Yes. Anything that is
8 done and any actual insights, even from the two
9 tabletops that have been done.

10 At the Subcommittee meeting we talked
11 about the PRISM tabletop, but the report wasn't out.

12 MEMBER BLEY: We did get it, yesterday, I
13 think.

14 (Laughter.)

15 MR. RECKLEY: Yes. We've provided it. I
16 know. We'll, we only got it Friday, so it wasn't as
17 --

18 MEMBER BLEY: Okay, fair enough.

19 MR. RECKLEY: -- if we were holding it.
20 But now that the report is out that would be perhaps
21 another topic, as well as any other tabletops that are
22 done, as John mentioned, on any of the other
23 technologies.

24 And any insights that we get from the
25 commission, from the paper, ACRS, discussions at this

1 and any additional meetings that we have, and then the
2 public comment itself. And then at the same time, the
3 industry, all of the developers, or many of the
4 developers, are looking at it in real time.

5 And they might provide comments, both to
6 us and to the, to NEI, for incorporation into the
7 final NEI document. So it's still a little bit of a
8 fluid process, but nothing to date has been identified
9 that really changes things dramatically.

10 MEMBER BLEY: If I can --

11 MR. RECKLEY: Sure.

12 MEMBER BLEY: -- with one. I'd like to
13 hear from, at that time, from both you and folks from
14 the industry, in the tabletops that will have been
15 done by that point.

16 I'm interested in, are there any aspects
17 of the NEI document and your guide that have not been
18 tested.

19 MR. RECKLEY: Okay.

20 MEMBER REMPE: While we're talking about
21 those tabletops, this is the first time I heard that
22 something like an Oklo's reactor that is more of,
23 really a departure from the established PRISM and the
24 pebble bed that we've heard about for a long time.

25 Are you familiar with what occurred in

1 that tabletop? Is there a document, were you there?

2 Something that doesn't maybe have a PRA
3 for example, how did that work?

4 MR. RECKLEY: We'll provide the report,
5 the public version of the report today's ACRS.
6 Actually, we --

7 MEMBER REMPE: Is it done?

8 MR. RECKLEY: There is a public version
9 available now.

10 MR. SEGALA: There is one, I'm not sure
11 it's been made public yet.

12 MR. RECKLEY: Okay.

13 MR. SEGALA: We went through the process
14 --

15 MR. RECKLEY: All right.

16 MR. SEGALA: -- of getting a redacted
17 version of that.

18 MR. RECKLEY: So, when it is public, we
19 will provide it.

20 MEMBER REMPE: Can you give us a heads up,
21 how did it go or anything, or you just got to wait
22 till it becomes public to talk in a public meeting
23 about it?

24 MR. RECKLEY: It would be better if we
25 waited.

1 One of the lessons that we really look to
2 get out of, not only Oklo but then probably some of
3 the other micro-reactors, is, within this methodology,
4 which has its roots going all the back into the '80's
5 for a different technology, whether the micros do fit,
6 whether the guidance needs to be tweaked because the
7 micros are different enough from the MHTGRs and the
8 PRISMs, that size, that medium size, whether the
9 guidance needs to be tweaked, whether additional
10 guidance might be developed for micros.

11 So that is one of the things we're looking
12 to get out of some of the recent and planned
13 tabletops.

14 MEMBER REMPE: And did you see that the
15 guidance needs to be tweaked or you can't, you're
16 still trying to decide?

17 MR. RECKLEY: I'm not sure that we saw
18 that. It may be that the language here or there needs
19 to be clarified.

20 But, again, I think because we're
21 addressing these key elements, the identification of
22 events, the classification of the SSCs and an
23 assessment of defense-in-depth, those are things that
24 any size reactor, even non-reactors, need to address
25 that.

1 And so, I don't think there will be any
2 fundamental shifts, but there may be areas where
3 they're different enough, the behaviors and their
4 reliance on inherent features for intrinsic
5 characteristics, whatever the key phrase is there,
6 might need to get reflected a little more in the
7 guidance.

8 MEMBER REMPE: Okay, thank you.

9 MR. RECKLEY: So, as John mentioned,
10 although it didn't pan out, we still expect to issue
11 the draft guide and wouldn't really be able at this
12 point, hopefully. It's near enough in the future that
13 we wouldn't be able to take into account ACRS comments
14 on the draft, but we'll come back for the final.

15 On the commission paper, it's changed in
16 that we would now expect to wait for your letter
17 before sending up the commission paper. So, as
18 opposed to telling the commission in the paper, the
19 little couple of sentences, you'll get a letter from
20 ACRS, it will be, you've gotten a letter from ACRS.

21 MEMBER BLEY: We're hopeful in that.

22 (Laughter.)

23 MR. RECKLEY: Well, again, yes. We can
24 always change it back.

25 So, just, in terms of the background and

1 kind of higher-level activity, I won't spend a lot of
2 time because we have gone over this numerous times
3 between Subcommittees and Full Committees, the non-
4 light water reactor program, or advance reactor
5 program, we've defined through a number of strategies
6 and then activities within strategies.

7 Trying to increase the skills and
8 capability of the staff is Strategy 1. That's
9 training and so forth.

10 Strategy 2 is trying to make sure we have
11 the analytical tools, the computer codes, simulation
12 models.

13 Strategy 3 is licensing processes. And
14 that's largely what we're going to be talking about
15 today, the licensing modernization project or NEI 18-
16 04.

17 Strategy 4 is consensus codes and
18 standards. The major activity there is ASME Section
19 3, Division 5 for high temperature materials.

20 Strategy 5 is policy issues. And I will
21 make a mention that the checkmark on functional
22 containment, we not only sent the paper up last year,
23 SECY-18-96, but we got the commission decision and the
24 Staff's requirements memorandum dated December 4th,
25 saying that we could proceed with that approach, the

1 functional containment.

2 MEMBER BLEY: Bill, I don't think we've
3 seen the SRM.

4 MR. RECKLEY: Okay. It will be --

5 MEMBER BLEY: I guess it's public?

6 MR. RECKLEY: Yes.

7 MEMBER BLEY: Yes, we can get it.

8 MR. RECKLEY: Okay. It was --

9 MEMBER BLEY: Didn't know it was out. And
10 while I say that --

11 MR. RECKLEY: Sure.

12 MEMBER BLEY: -- are you going to talk
13 about EP for us in a moment? What's the status there?

14 MR. RECKLEY: That's currently before the
15 commission and we're still waiting for a commission
16 decision on that proposed rulemaking. So the next
17 step is expected to be the issuance of a proposed rule
18 for public comment on how to consider potential
19 reductions in emergency planning zones for advance
20 reactors and other new technologies, which includes
21 not only non-light water reactors but small light
22 water reactors, such as the NuScale SRM. And then
23 also, medical isotope production facilities.

24 And, yes, we can get you that but it's
25 available on the commission's site.

1 MEMBER BLEY: Yes.

2 MR. RECKLEY: It's a clean SRM, so --

3 MEMBER BLEY: Oh.

4 MR. RECKLEY: -- I mean, it basically said
5 what we addressed in the SECY paper and what the ACRS
6 recommended in the letter, we could proceed with that
7 approach.

8 MR. SEGALA: I'd just like to also add on
9 EP, that based on your letter and our response to your
10 letter, we have added, we're in the process of adding
11 some wording to the draft guide for that on source
12 term and PRA. There's a little bit that we've added.
13 And we're going to share that with you when we send
14 that out.

15 MEMBER BLEY: Okay, thanks.

16 MR. RECKLEY: The two boxes at the bottom
17 here are just, as we're doing this infrastructure
18 work, if you will, we're trying to keep an eye on
19 potential first movers and then things like micro-
20 reactors and the request for information that's been
21 issued, both by the Department of Energy and the
22 Department of Defense.

23 And so we're trying to keep an eye on
24 those activities, to Dr. Rempe's point, just to try to
25 make sure that we're not caught by surprise by an

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 applicant coming in sooner than what we're prepared
2 for.

3 So, as things firm up, again, keeping an
4 eye on largely the DOE and DoD activities, if we see
5 something starting to move, we would shift and try to
6 make sure that we have preparations underway for that
7 application, should it come in.

8 Okay. I'm going to go through a couple
9 nightmare figures here for the next couple slides.

10 So the first is, I've used this in
11 previous presentations to the ACRS, it's a kind of a
12 generic risk assessment, risk communication tool
13 called a bowtie diagram. And it goes through a
14 process of looking at barriers and measures to prevent
15 a top-level event and measures that one might take to
16 mitigate or recover from a top-level event.

17 So, in light water space the top-level
18 event is usually discussed as being core damage
19 accidents in our space since we're trying to make this
20 technology-inclusive. We just kind of use the
21 unplanned movement of radioactive materials from one
22 place, where they're supposed to be, to another place
23 where they're not supposed to be.

24 And that way we can address molten salts
25 or whatever technology might be presented to us.

1 So, within those barriers you can see some
2 of the activities that we have already underway. For
3 example, we're looking at emergency planning and
4 whether emergency planning zones might be revised as
5 a result of the technology.

6 That's usually the last line of defense to
7 protect public health and safety. So that's that last
8 box there in the figure.

9 We are looking at citing. Whether the
10 same citing guidance and regulations, established for
11 large light water reactors dating back from the,
12 largely from the '50s and '60s, would still be
13 necessary or appropriate for advance reactor designs.

14 I mentioned the functional containment in
15 that box on that safety arm.

16 In the socioeconomic arm we're looking at
17 Price-Anderson and we owe a report to Congress in 2021
18 that will say, is Price-Anderson good enough as it
19 stands, is it too restrictive, is it not restrictive
20 enough. Whatever the conclusion would be by that time
21 frame.

22 We have to look at environment, and that
23 is another activity we have underway to say, is the
24 way we approach environmental reviews for large light
25 water reactors, can it be right sized or revised to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 address the smaller non-light water reactor designs.

2 So the box in the yellow there is, what is
3 the LMP or what is in NEI 18-04 and the draft guide.
4 It covers how we're going to identify and address
5 both, from the plant standpoint, the prevention and
6 mitigation of the identified events. Both internal
7 and external.

8 MEMBER CORRADINI: So, I have a question
9 about the one thing you didn't talk about, SECY-18-
10 0076.

11 MR. RECKLEY: Okay.

12 MEMBER CORRADINI: So, how does one map
13 that onto a frequency consequence analysis to make
14 sure that you're not bound, well, to at least
15 understand where it sits relative to consequences
16 versus consequences from --

17 MR. RECKLEY: The way --

18 MEMBER CORRADINI: -- other initiating
19 events?

20 MR. RECKLEY: Right. It may not get
21 plotted on a frequency consequence because the
22 frequency part is sometimes hard to get people to
23 estimate for security events.

24 But what we're talking about under SECY-
25 18-0076 is more of a consequence-based approach. And

1 the arrow there is pointing to that part of the
2 security program that goes to intervening if there is
3 an assault on the facility.

4 So, current requirements are that
5 operating plants have ten, minimum of ten armed
6 responders standing by waiting to respond to an
7 assault.

8 MEMBER CORRADINI: So, it's taking the
9 current approach and applying it to --

10 MR. RECKLEY: Right. The notion is,
11 looking at that particular thing, the number of armed
12 responders.

13 If one can address through the consequence
14 assessment that even if the armed responders, even if
15 the armed assault was successful, in terms of what
16 they were able to damage under the design basis
17 threat, that the consequences, in terms of public
18 health and safety are below a threshold, then you can
19 say, you can potentially relax that requirement for
20 ten armed responders.

21 And in terms of the operating reactors,
22 ten armed responders is \$5 million a year. So that is
23 the reason that the industry picked that particular
24 activity out.

25 As we look at micro-reactors in some other

1 areas for advance reactors, it may be possible that
2 additional security requirements get looked at.

3 MEMBER CORRADINI: Okay.

4 MR. RECKLEY: But for right now, we've
5 narrowed it down to just a couple things that we're
6 going to look at to say, could relief be justified
7 through a consequence assessment.

8 MEMBER CORRADINI: I got it. Thank you
9 very much.

10 MR. RECKLEY: Okay. So this is the second
11 nightmare figure. As John mentioned, one of the
12 things that we're trying to do is to kind of go back
13 to basics because we're starting from a technology-
14 inclusive. All sizes, all reactor types.

15 So, how can we kind of develop an approach
16 that is so generic that it can address that wide
17 range. So, part of the reason, or part of the way
18 we'll do that, and this goes to, I think the ACRS
19 comments when we were talking to you about emergency
20 planning, is to focus on the source terms.

21 So, at the top of this figure is a generic
22 mechanistic source term representation. Inventory
23 times a series of release fractions. And then you
24 enter that into a computer code, like MACCS, for how
25 it gets distributed once it goes off site. And you

1 can do a consequence assessment.

2 And so, by and large, what we're looking
3 at for each technology, and each design ultimately is,
4 how are you controlling the release fractions across
5 the series of barriers. And from a design standpoint
6 you have flexibility.

7 For gas cooled reactors, the thrust of the
8 argument to date has been, we want to control the
9 first one, and maybe the first two. We want to try to
10 keep the radionuclides within the TRISO particle. If
11 it manages to get out of the TRISO particle we want to
12 try to keep it in the matrix, to some degree, for
13 other particular transients.

14 You also go as far as the reactor, the
15 primary system, the helium circuit and a reactor
16 building. But by and large, the thrust has been
17 trying to keep it within the TRISO particle.

18 Another molten salt reactor design may
19 have a different strategy altogether. And they may
20 emphasize trying to keep certain radionuclide groups
21 within the salt, but for other radionuclides a
22 physical barrier. The last leap path factor.

23 So they might put the emphasis on salts,
24 chemistry and then physical structures, like a
25 building. Something closer to maybe a containment.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Although the lower energy may not be a challenge in
2 terms of needing to survive 60 pounds per square inch,
3 or something like that.

4 So, each design, each technology will look
5 and they'll come up with a strategy for, in the end,
6 trying to keep the radioactive material from escaping
7 from the facility. So --

8 MEMBER CORRADINI: So, can I take, I like
9 the diagram. Has Staff thought it through for these
10 generic concepts and kind of estimated the hours for
11 the decontamination as I move from left to right and
12 the methods used for heat removal from going from left
13 to right?

14 In other words, I'm sure that the
15 particular industry or vendor will come up with
16 calculations, et cetera, et cetera, but it seems to me
17 one can rough out how this might look for the various
18 three types.

19 MR. RECKLEY: We have. And I'm hoping
20 that we'll have a report within a few months. We
21 asked Sandia to look, and to use this model, and to go
22 back historically. So they're not doing analysis --

23 MEMBER CORRADINI: Sure.

24 MR. RECKLEY: -- they're doing historical
25 looks at PRAs and consequence assessments from each

1 technology.

2 MEMBER BLEY: And experiments?

3 MR. RECKLEY: Wherever they can get data.

4 MEMBER BLEY: Wherever they can get
5 information.

6 MR. RECKLEY: Wherever they can get data.
7 And where they don't have data they're going to use
8 their best guess.

9 Just to give us this idea, and in part,
10 the reason we ask them to do that is, as we look for
11 the technologies as to where we should be putting our
12 planning and resources, it should match up to where
13 they, that technology is going to be trying to credit
14 which release fraction they're going to put the
15 emphasis on.

16 MEMBER BLEY: Okay.

17 MR. RECKLEY: And so, to date, nothing
18 really all that surprising has come out of it. But
19 we'll have a little better tool and we'll have the
20 calculations. And as soon as they report is issued,
21 we'll make it available to you.

22 MEMBER BLEY: We look forward to that.
23 Are they looking at different reactor types as well?

24 MR. RECKLEY: Because of the constraints

25 --

1 MEMBER BLEY: Yes.

2 MR. RECKLEY: -- in terms of how much
3 money we gave them, they picked three designs, one for
4 each technology group. Then they picked several event
5 sequences.

6 Because each, the release fractions is a
7 function of the transient. Each specific transient.

8 MEMBER BLEY: Of course.

9 (Off microphone comment.)

10 MR. RECKLEY: What?

11 MEMBER KIRCHNER: And the design. They're
12 separating fuel and fission products. You're in a
13 different place on this diagram to start the incident.

14 MR. RECKLEY: Right. So they're looking,
15 again, they've picked a couple models.

16 MEMBER KIRCHNER: Yes.

17 MR. RECKLEY: Specific transients,
18 specific reactor designs. And then they're going to
19 scale things like power level and so forth.

20 So, as soon as that report is available,
21 we'll make it available to you.

22 MEMBER BLEY: Because, as part of their
23 assignment, given the three generic reactor types
24 they're looking at, is part of their assignment to
25 identify the areas or additional research or

1 experimentation would be useful for each type?

2 MR. RECKLEY: In part, that is what will
3 come out. That wasn't the primary mission but when we
4 get the report and they say, we had to make major
5 assumptions here, here and here, but over here the
6 data was pretty good, we'll be able to get that out of
7 the report.

8 MEMBER BLEY: Okay.

9 MR. RECKLEY: So, what can affect the
10 release fractions? I mean, this is what the designers
11 are going to have to identify.

12 So, things like in the first case, how
13 does the radionuclides go from the fuel to the matrix,
14 that's going to be functions of a radiation or burn
15 off, it's going to be functions of temperature.

16 Temperature is expected to remain a major
17 driver for the release fractions for all the
18 technologies. And so, the bottom part of the figure
19 is just a simple representation of the other two
20 fundamental safety functions of heat generation and
21 heat removal and how that might look and how that
22 might get assessed.

23 This one shows an expected passive kind of
24 design. And so, the emphasis is on the heat going
25 from the core, basically out to the environment

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 through a series of passive mechanisms.

2 So, the reason to put this up here is,
3 again, sort of like the bowtie. That we're trying to
4 look at this from the simple, and then it gets more
5 complex.

6 One of the things that the Sandia report
7 does, for example, is they have a matrix. So it
8 starts off really simple but then you say, what is the
9 variables that go into making that release fraction,
10 how you can estimate it. And it just multiples very
11 quickly until it becomes a huge matrix.

12 And so, as we go into the next discussion
13 on the events and so forth, we're just, from the
14 Staff's point of view, tying all of this, trying to
15 tie it together. The mechanistic source term, the
16 event selection.

17 And then ultimately, even classification,
18 SSCs, they come back. Where are you putting your
19 emphasis. And so that will come back into the, which
20 ones are safety related, which ones may be warranting
21 special treatment and which ones might be backup that
22 you're satisfied with the commercial, commercial grade
23 equipment.

24 MEMBER CORRADINI: Just one thing, just to
25 understand, Bill. The analysis that Sandia is doing,

1 that is all for non-light water --

2 MR. RECKLEY: Yes.

3 MEMBER CORRADINI: -- options?

4 MR. RECKLEY: Yes.

5 MEMBER CORRADINI: Okay, thank you.

6 MR. RECKLEY: So, all of that is kind of
7 background. Getting into the specifics of what is in
8 the guidance document, what's in, at a higher level,
9 what's in the commission paper.

10 Again, the elements that we're looking at
11 is, how do you use the behavior of the non-light water
12 reactors, considering all of those things I just
13 talked about, and come in and do things like, identify
14 and assess licensing basis events using both
15 probabilistic approaches, risk-informed approaches and
16 using deterministic approaches and engineering
17 judgment.

18 How do you classify the equipment, how do
19 you define performance requirements?

20 One question that often comes up is, for
21 non-light water reactors, the operating history is not
22 as populated as light water reactors, how do you make
23 up for those uncertainties in having less operational
24 data?

25 So, that becomes important because as you

1 do the PRA and make your best assumptions on
2 frequencies of the availability or the failure of
3 equipment, along with that, you're going to define the
4 performance requirements in order to make sure that
5 down the road the assumptions you made are reasonable.
6 And that the events that you analyzed and the
7 acceptance criteria that you used are still valid.

8 And then lastly, the defense-in-depth
9 assessment that's including in the methodology, to
10 make sure that, again, largely to make sure that
11 uncertainties are addressed, that you don't overly
12 rely on one element, one barrier, and to bring in that
13 engineering judgment through the integrated decision-
14 making process to make sure that you're making
15 conscious choices on how to address the safety for
16 that particular design.

17 MEMBER REMPE: Bill? If I were thinking
18 back on what I thought was important in 18-04, I would
19 have identified those three bullets, but I also would
20 have identified identifying key safety functions for
21 that particular design.

22 MR. RECKLEY: Right.

23 MEMBER REMPE: Did you think about
24 highlighting that as a bullet, and why did you not?

25 MR. RECKLEY: I guess the sub-bullet under

1 SSC classification function and risk considerations,
2 that was my attempt. But I agree with you that the
3 way the methodology lays out that in order to identify
4 the equipment, you first identify the functions.

5 MEMBER REMPE: Key safety functions.

6 MR. RECKLEY: And then from the functions
7 comes the performance requirements for individual
8 SSCs.

9 MEMBER REMPE: And for defense-in-depth,
10 I think you need to know that too.

11 MR. RECKLEY: Right.

12 MEMBER REMPE: And I just was thinking
13 about it, if I were doing it.

14 MR. RECKLEY: And I don't disagree with
15 you.

16 MEMBER REMPE: Okay.

17 MR. RECKLEY: One item that we like to
18 address, and this was highlighted in, not the October
19 meeting, but the subcommittee meeting we had before
20 then. Although the topics that are addressed in NEI
21 18-04 and the draft guide are important, they're not
22 100 percent of the requirements that will be imposed
23 on these reactors.

24 And so, it is necessary to keep in mind,
25 the regulatory context is broad. This is a very

1 important part but it's not 100 percent.

2 And so I broke it down at the subcommittee
3 meeting into those requirements that are associated
4 with LMP. And for example, the maintenance rule and
5 quality assurance programs, they're built in to how
6 programmatic controls are used within the LMP process
7 to provide the reliability and ensure equipment has
8 the capabilities to do the functions of, that they're
9 assigned to do.

10 The LMP then also interfaces with other
11 requirements. And this was back on the bowtie
12 diagram. The LMP itself doesn't get into citing,
13 doesn't get into emergency planning or environment
14 reviews.

15 But as shown on the diagram, you're doing
16 events assessments ultimately to determine things like
17 emergency planning and whether they can be relaxed.
18 And so, it's a natural outgrowth of the guidance in
19 NEI 18-04 and the draft guide that, as you're
20 analyzing events, you're going to use those
21 consequence assessments as part of the rational for
22 whether you can reduce emergency planning zones.

23 MEMBER CORRADINI: So, maybe you, I think
24 I can guess the answer but, so if I, you said they're
25 disconnected, but in some sense the source term used

1 to construct the FC curve so that you can do an
2 analysis, has got to decide where you stop on
3 frequency, below what you don't consider on frequency,
4 to understand the consequences that you apply to
5 emergency planning --

6 MR. RECKLEY: Right.

7 MEMBER CORRADINI: -- at the site?

8 MR. RECKLEY: Yes. And that's why said --

9 MEMBER CORRADINI: Is there guidance in
10 the considered version of 1353 that verbalizes that or
11 is it just implied?

12 In other words, how do I know when I stop
13 the AP and citing?

14 MR. RECKLEY: Yes, we'll get into that.

15 MEMBER CORRADINI: Okay, fine. Sorry.

16 MR. RECKLEY: No, that's fine. But,
17 that's why it's called an interface. It's really a
18 hand off. It is part of the same decision-making
19 process --

20 MEMBER CORRADINI: Okay.

21 MR. RECKLEY: -- it's just that you don't
22 see in NEI 18-04, here's the additional work that you
23 need to do in order to do the emergency planning. But
24 1353 references 1350 and 1350, the reg guide for the
25 EPC, references back to 1353. So, it's recognized

1 that the two things work together.

2 MEMBER CORRADINI: Okay. I'm smiling
3 because I just don't want to create an infinite loop
4 that doesn't --

5 (Laughter.)

6 MEMBER CORRADINI: The way you said it, it
7 sounds like I'm --

8 MR. RECKLEY: Hopefully not.

9 MEMBER CORRADINI: Okay.

10 MR. SEGALA: There are some things that
11 would need to be considered, in LMP it's like a 30 day
12 dose and EP they're looking at a 96 hour dose.

13 MEMBER CORRADINI: Right.

14 MR. SEGALA: So, if you're less than one
15 rem for 30 days, they're going to be less than one rem
16 for the 96 hours.

17 MR. RECKLEY: And then lastly on the
18 slide, there are requirements, such as routine
19 effluents, worker protections and elements of security
20 that aren't addressed within LMP.

21 So, getting to the event selection and
22 much of the focus of the discussions often comes down
23 to looking at the frequency target. Frequency
24 consequence target figure.

25 So, at the highest level for the

1 commission paper, we're basically just saying what the
2 categories are and how we're using the figure and the
3 emphasis, as its stated at the top, that the targets
4 are not intended to be interpreted as being actual
5 acceptance criteria.

6 One of the things I did to this figure was
7 went ahead and added the two orders of magnitude zone
8 that's used in the defense-in-depth assessment as risk
9 significant licensing basis events.

10 Just to be clear that you're not looking
11 at the solid bright blue line but you're looking at,
12 where does the event map onto the frequency
13 consequence, what's keeping it from going up or down
14 and the general message of, the closer you are to the
15 line the more attention you should pay as to what's
16 limiting the consequences.

17 So, I think that was basically all for the
18 SECY paper, was the level of detail we were providing
19 to the commission. The note off to the side, there
20 is, and maintains, a deterministic approach. The
21 traditional Chapter 15 approach.

22 That is the design basis accident category
23 that are events that are taken from the mid-range, the
24 design basis event category, and then analyzed with
25 more traditional approaches of using only safety

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 related equipment in the assumptions.

2 And then what's not shown on the figure,
3 but one also needs to keep in mind, is in addition to
4 the plotting of the event sequences and looking at
5 each sequence in terms of what is keeping it at an
6 appropriate place on the frequency consequence.

7 Target, in terms of the availability and
8 reliability of equipment and the capability of that
9 equipment to prevent a release.

10 You're also looking holistically at the
11 design and comparing it to aggregate goals, like the
12 commission's safety goals.

13 MEMBER MARCH-LEUBA: Okay, before you
14 move. All of these results are based on you knowing
15 the frequency. The y-axis in this figure.

16 So what degree of certainty do you require
17 from an applicant, to believe the frequencies he tells
18 you?

19 MR. RECKLEY: Well, yes. One of the
20 things that the methodology includes is you're not
21 only plotting the mean frequency as your best guess of
22 what the frequency is, but you're plotting the
23 uncertainty bands.

24 And so, as you look at the uncertainties,
25 it might be very possible that those uncertainty bands

1 will be much wider than people are accustom to seeing
2 on, maybe for light water PRAs.

3 MEMBER MARCH-LEUBA: But those are --

4 MR. RECKLEY: But --

5 MEMBER MARCH-LEUBA: Those are the
6 estimates from the applicant, which has a bias
7 towards, per this position, where he decides his PRA.

8 Where I would like to see some emphasis is
9 on requiring from the Staff, when they review those
10 PRA, that there be an aggressive, thorough and
11 complete review. Not just, let's review what the
12 applicant said and check their math.

13 If you're going to build a reactor like
14 this, Five Mile is upwind from my house, I want you to
15 raise your right hand and tell me, I know these
16 frequencies, I dually agree with them, not just a
17 cursory review of the math of the applicant. Because
18 the applicant has a bias when they develop their PRA.

19 And we have some examples when some people
20 go and tells us the probability of failure of this
21 system is ten to the minus 11. That does nothing.

22 MR. RECKLEY: I guess all I can say is I
23 think the staff always does that.

24 MEMBER MARCH-LEUBA: Well, they're not
25 doing it in this case.

1 MR. RECKLEY: Okay. That you might want
2 to take up --

3 MEMBER MARCH-LEUBA: I would like to see,
4 on the guidance and on the --

5 MR. RECKLEY: Right.

6 MEMBER MARCH-LEUBA: -- procedures, some
7 emphasis that the Staff will do an aggressive review
8 of what's missing on the PRA and what's bias.

9 MR. RECKLEY: Okay. Again, I won't attest
10 to any particular ongoing or past review, but I would
11 say that's the goal of the NRC Staff for any review.

12 And certainly we'll be coming before the
13 ACRS and you can challenge not only the applicant but
14 the Staff on the thoroughness.

15 MEMBER MARCH-LEUBA: I've done a lot of
16 reviews for the Staff and we tend to check the math of
17 the applicant more than looking --

18 MR. RECKLEY: Okay.

19 MEMBER MARCH-LEUBA: When the consequences
20 of you being wrong are so large, I mean, when we're
21 talking about, are you violating CHF or not in a small
22 reactor that has no consequence for safety, I mean,
23 you can be a little more forgiving. But when the
24 consequence of you being wrong are so large --

25 MR. RECKLEY: No. And that, to me, that's

1 one of the nice features of the frequency consequence
2 target figure is, you're not only looking at the
3 uncertainties associated with the frequencies, which
4 move you up and down, but your uncertainties in terms
5 of the consequences.

6 And there may be events in which the
7 uncertainties and frequencies are very large, but the
8 consequence uncertainties remain very close to the
9 area where you would have no concern.

10 The closer you are in either, to the
11 target area, the risk significant LBE region, the more
12 attention you're going to pay to the uncertainties
13 associated with, not only the consequences, but also
14 the availability of the equipment.

15 MEMBER MARCH-LEUBA: Yes, I just wanted to
16 put you on the record.

17 MR. RECKLEY: Yes. Nope.

18 MEMBER MARCH-LEUBA: There's an issue of
19 availability of resources at the time to review. We
20 have to do it in 18 months or we have to do it in 12
21 months now. We don't have time to do a thorough
22 check. And that should be emphasized.

23 MR. RECKLEY: Okay.

24 MEMBER MARCH-LEUBA: That everything is
25 based on, we know the y-axis.

1 MR. RECKLEY: Okay.

2 MEMBER REMPE: So, with this figure, if
3 you have a micro-reactor that doesn't have a PRA, do
4 you just assume that the accident happens or do they
5 have some sort of hazard assessment where they had
6 higher frequency hazards and lower frequency hazards?

7 I mean, how far did this tabletop go? I
8 mean, they don't have a detail PRA, they don't have
9 data for qualifying a lot of their new designs.

10 MR. RECKLEY: Well, again, to me that just
11 is reflected in the uncertainty events. When you say
12 they don't have a PRA you --

13 MEMBER REMPE: Do they have some sort of
14 hazard assessments, so there was some sort of --

15 MR. RECKLEY: Yes.

16 MEMBER REMPE: -- simplified PRA?

17 MR. RECKLEY: Right.

18 MEMBER REMPE: So no one came in without
19 a PRA is what you're telling me in the tabletops?

20 MR. RECKLEY: Right.

21 MEMBER REMPE: Okay. I don't know whether
22 these designs are.

23 MR. RECKLEY: Right.

24 MEMBER REMPE: So they do need to have a
25 PRA of some sort --

1 MR. RECKLEY: Right. And NEI 18-04
2 discusses that since this is related to the design
3 process, and ultimately to the licensing process, it's
4 an iterative process.

5 And so you start off with maybe more
6 traditional hazards. Maybe failure modes and effects
7 analysis or process hazards with less focus on the
8 frequencies but just identifying what can go wrong.

9 Then as you progress through the design
10 process you start to ask the question, not only what
11 can go wrong but how likely is it, such that you can
12 put it on the frequency consequence curve.

13 But, by the time the design is submitted
14 for a licensing application, the expectation is that
15 they will have, not only what can go wrong but how
16 likely it is.

17 I'll say, one potential caveat is, if
18 there is a reactor design, and I'll stress the if,
19 that you could model maybe as, on the non-reactor side
20 there's processes to assess unmitigated releases,
21 right? Just, you've got a source term, just let it
22 go, what happens?

23 Well, if it ever was that the design, the
24 inventory was small enough or the design so straight
25 forward that you could kind of do an unmitigated

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 release and show that it was a minimal consequence,
2 then maybe you wouldn't bother with doing this more --

3 MEMBER REMPE: In our discussions over the
4 last, I don't know how many months, you mentioned that
5 earlier and I wasn't sure where these tabletops were
6 going, and I wondered if they did come in with --

7 MR. RECKLEY: We haven't seen one go that
8 route yet.

9 MEMBER REMPE: Okay.

10 MR. SEGALA: Yes, all of them so far have
11 used a PRA.

12 MEMBER MARCH-LEUBA: Let me reemphasize my
13 point. Can you go back a couple slides before on the
14 specification of SSCs. I think it's like --

15 MR. RECKLEY: The next slide.

16 MEMBER MARCH-LEUBA: -- 6 or 5. Go
17 backward. There. Okay.

18 Those SSCs classified as a non-safety
19 related with a special treatment. The example we saw
20 during the Subcommittee was, the way I read it, and
21 I'm oversimplifying, is an SSC that the PRA said you
22 didn't have to worry about. And then the committee
23 said, you're crazy, you have to worry about it.

24 Isn't that what that classification is?
25 Non-safety related with a special treatment. Why did

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 you add it?

2 MR. RECKLEY: The non-safety related with
3 special treatment is a category of equipment that does
4 have some risk importance. Some safety functions.

5 It's not needed necessarily for the design
6 basis accident, but it's needed to control where you
7 are on the frequency consequence target.

8 MEMBER MARCH-LEUBA: And it's decided by
9 this committee that reviews at the end? The defense-
10 in-depth committee I believe it's called.

11 MR. RECKLEY: The integrative decision-
12 making panel will play a role in that, yes.

13 MEMBER MARCH-LEUBA: All right. So, isn't
14 that an example where the PRAs have told you, you
15 needed to make it safety related, and you didn't?

16 MEMBER BLEY: No.

17 MR. RECKLEY: No.

18 MEMBER BLEY: No. They set out, you might
19 want to talk about this, specific definitions of what
20 is safety related in the future --

21 MR. RECKLEY: Right.

22 MEMBER BLEY: -- under this program.
23 These would be cases that don't meet those rules but
24 need a risk criteria.

25 MEMBER MARCH-LEUBA: I don't know if we

1 can talk about the particular example we talked during
2 the subcommittee, it's an open session. But it
3 involved some sodium water reactor.

4 And in my opinion, it nearly pointed to
5 the fact that the PRA was deficient, and they decided
6 to go this route instead of --

7 MR. RECKLEY: Okay.

8 MEMBER MARCH-LEUBA: But that's my
9 opinion.

10 MR. RECKLEY: All right. So, as Dennis
11 said, the second element within the methodology is
12 really the establishment of safety classes and
13 performance criteria for the equipment.

14 For safety related equipment it's defined
15 there in the bullet. For non-safety related, as we
16 were just mentioning, it is those SSCs that are
17 playing a role. And then non-safety related with no
18 special treatment are all other SSCs.

19 I would go as far as to say you got to be
20 careful because even equipment that's not safety
21 related with no special treatment does not mean that
22 it serves no purposes in controlling, in contributing
23 to either a risk or lack thereof within a facility,
24 it's just an SSC that you don't need to put particular
25 performance measures or address through other than

1 commercial procurement.

2 CHAIRMAN RICCARDELLA: Bill, go on back to
3 that frequency consequence curve. Could you briefly
4 describe the rationale for why there is that step
5 change at one rem?

6 MR. RECKLEY: There's a number of ways to
7 construct a frequency consequence target. And the
8 closer you try to get to marrying it to a regulatory
9 limit, the actual more steps you have. If you go
10 back, for example, and look at NUREG-1860, it had like
11 ten steps, because as you go through the various
12 regulations.

13 So, the reason for the step in this
14 particular figure that we accepted from the industry
15 is, the top line for the higher frequency events,
16 you're really trying to derive the dose considerations
17 from Part 20, something close to normal effluence.

18 The bottom point, in terms of the dose and
19 frequency, is largely derived from the safety goal, at
20 the lower end. And the LMP decided to connect a value
21 at E-2 and one rem, based on traditional event
22 assessment criteria, with the safety goal kind of
23 number down at E-7.

24 And you end up with this break in the
25 curve. It has no particular significance to us, you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 could have drawn a straight line.

2 In general, there's a preference in risk
3 evaluations to have a slope greater than one, kind of
4 to make it a little more risk-adverse, so that you're
5 addressing the bottom end a little more conservatively
6 than you would, that's largely because of
7 uncertainties and so forth.

8 So, all of that is in there.

9 MEMBER CORRADINI: But, I mean, I think
10 Pete's asking the question is, or my way of thinking
11 about it is, once you get close to this knuckle, you
12 start looking closely. Whether I look -- right?

13 MR. RECKLEY: Yes.

14 MEMBER CORRADINI: That's how I view it --

15 MR. RECKLEY: Right.

16 MEMBER CORRADINI: -- is that, when I get
17 to this little stair-step, if I'm starting to get near
18 it, I have to ask, in terms of uncertainty and
19 frequency and uncertainty and consequence --

20 MR. RECKLEY: Right.

21 MEMBER CORRADINI: -- to make sure I'm
22 below your buffer, whatever, your dark yellow versus
23 your light yellow or whatever it is.

24 MR. RECKLEY: Right.

25 MEMBER CORRADINI: Okay.

1 MEMBER MARCH-LEUBA: Short question on this
2 topic. In previous presentations, you've been very
3 careful to tell us that NRC was not sponsoring these
4 numbers, not even accepting them. Are we now to a
5 point in which NRC approves them or accepts them? Or
6 where are we?

7 MR. RECKLEY: We're going to accept, or
8 propose to accept, that this frequency consequence
9 target for the identification of events, for defense-
10 in-depth assessments, and everything that's within the
11 methodology that we talk about.

12 The caution has always been, we just don't
13 want the line to be interpreted as acceptance
14 criteria. That will remain, to include the possible
15 use of engineering judgment --

16 MEMBER KIRCHNER: Well, 10 CFR 50.34 is
17 very explicit that this is not a goal, 25 rem.

18 MR. RECKLEY: Right.

19 MEMBER KIRCHNER: It's expected that the
20 applicant will demonstrate well margin below that.

21 MR. RECKLEY: And even the 25 rem number,
22 we've historically had troubling saying what frequency
23 is it associated with? And so, that's why, although
24 this is plotted at 25 and E-4, we're saying, don't
25 interpret our regulations to be E-14 and 25 rem.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER BLEY: To Jose's point, I think back
2 in October, when you were with us, you had told us
3 that you guys were still considering whether this is
4 the right target or you ought to have something
5 different.

6 MR. RECKLEY: Well, definitely during the
7 briefings on the functional containment paper, we
8 said, don't focus on the numbers, we're --

9 MEMBER BLEY: Oh, yes.

10 MR. RECKLEY: -- just trying to get the
11 concept. But at the Subcommittee meeting, what we
12 intended to say was, this is the figure --

13 MEMBER BLEY: Okay.

14 MR. RECKLEY: -- that we're saying is
15 acceptable for use, within the limitations we talk
16 about.

17 MEMBER BLEY: I have my meetings mixed up,
18 perhaps.

19 MEMBER MARCH-LEUBA: Then, would it be
20 appropriate to -- are you expecting an evaluation of
21 that from ACRS in our letter, I mean, in our
22 recommendation, of that line? The wisdom of using
23 such a line?

24 MR. RECKLEY: We propose in the Commission
25 paper that the way events will be selected,

1 categorized, and analyzed, and the way SSCs will be
2 classified and performance measures established, and
3 the way defense-in-depth assessments will be done,
4 will use this figure.

5 MEMBER MARCH-LEUBA: Okay.

6 MR. RECKLEY: And so, yes.

7 MEMBER MARCH-LEUBA: So, the answer is yes?

8 You --

9 MR. RECKLEY: Yes.

10 MEMBER MARCH-LEUBA: -- would expect us to,
11 at least in the discussion, mention it?

12 MR. RECKLEY: Right. And I'll get into
13 that in a second, when we get into the paper.

14 MEMBER KIRCHNER: Bill, may I just throw
15 out a caution? This figure is really derivative from
16 the LWR experience. And implied in this is an
17 unfolding of an accident scenario and time. And
18 without making a pejorative statement, let me see how
19 I can explain my point.

20 There can be events in other non-LWR
21 designs that could lead to large, instantaneous large
22 inventory release, which is different than how we
23 anticipate, shall I say, an LWR event proceeding.

24 And where I'm going with this is, for
25 example, time becomes of essence, because the PAG of

1 one rem could be exceeded before you could even sound
2 a general alert or respond, depending on where the
3 location is of the EAB and the local workforce and
4 population.

5 So, I just throw that at that, as I think
6 about this, the implicit here is, we have an unfolding
7 over time, which allows ample time to make decisions
8 about protective action, et cetera, that may not be
9 the case for alternate designs, that might have --

10 MEMBER BLEY: Let's have a little --

11 MEMBER KIRCHNER: -- a large inventory.

12 MEMBER BLEY: -- among the many discussions
13 on this one. I don't quite see that, Walt.

14 MEMBER KIRCHNER: Okay.

15 MEMBER BLEY: Because the one you're
16 suggesting, although it happens fast, there's no time
17 on here, but it would fall outside of this curve on
18 consequences. At least, that's what I think you're
19 getting at.

20 So, when it's all done, you plot the point
21 on here where you end up and if it's outside of that
22 line, it's unacceptable, whether it happens very
23 quickly --

24 MEMBER KIRCHNER: No.

25 MEMBER BLEY: -- or not at all. And that

1 --

2 MEMBER KIRCHNER: No, I agree with you.

3 MEMBER BLEY: -- includes modeling carrying
4 out protective actions as well.

5 MEMBER KIRCHNER: Okay.

6 MEMBER BLEY: So, you just couldn't do it

7 --

8 MEMBER KIRCHNER: Or the EAB may be --

9 MEMBER BLEY: -- in that case, yes.

10 MEMBER KIRCHNER: -- a significant
11 distance.

12 MEMBER CORRADINI: Right.

13 MEMBER BLEY: Yes.

14 MEMBER CORRADINI: You would have to change
15 the distance --

16 MEMBER KIRCHNER: You'd go back to the --

17 MEMBER CORRADINI: -- you evaluate.

18 MEMBER KIRCHNER: -- design and change the
19 EAB. Anyway, that's -- thank you.

20 MR. RECKLEY: The -- yes, I would go as far
21 as to say, I agree with you that time is a key
22 variable and it's a key variable in a number of ways.
23 In some reactor designs, you might have a puff and
24 you'd have to control that --

25 MEMBER KIRCHNER: Right.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. RECKLEY: -- and that will be a quicker
2 release than maybe large light-water reactors.

3 The other way it comes into play in this
4 mechanistic source term assessment is, there may be
5 designs in which particular radionuclide groups
6 migrate through, and that time needs to be assessed,
7 such that, by the time that you get to the leak path
8 factor for the building, it might be the release, and
9 some of the stuff that we're seeing is, sometimes the
10 releases from non-light-water reactors can be many
11 days. So, the releases can be longer.

12 MEMBER KIRCHNER: Yes.

13 MR. RECKLEY: So, both of those will have
14 to get looked at and assessed within, as Dennis
15 mentioned, a 30-day dose on the figure.

16 So, lastly, within the methodology, or
17 next to last, I guess, is the assessment within the
18 process for defense-in-depth, which looks at, again,
19 the risk-informed assessment techniques, PRAs, and
20 before PRAs in the design process. Again, maybe
21 you're using failure modes and effects, a process
22 hazard kind of assessment tools.

23 But ultimately, by the time it's licensed,
24 you would be looking also at the question of how
25 likely are failures and what reliability requirements

1 would be needed for SSCs, down under the programmatic
2 controls? So, all of those things to support the PRA.

3 You're also looking at deterministic
4 criteria, through both the Chapter 15 analysis and
5 also, the defense-in-depth assessment being done
6 through the Integrated Decision-Making Panel is
7 looking at deterministic or engineering judgment kind
8 of criteria.

9 So, again, for the purpose of the SECY
10 paper, the notion that the defense-in-depth
11 assessments are being done is about the level that
12 we're talking about and that it includes both plant-
13 level hardware-oriented measures, as well as
14 programmatic measures.

15 MEMBER BLEY: Bill, a couple things about
16 this. One, it's in the flavor of the Integrated
17 Decision-Making Process that's in 1174.

18 MR. RECKLEY: Yes.

19 MEMBER BLEY: But now, we've tagged a panel
20 with carrying that out, which you always needed in
21 some form.

22 The only way we'll really see if that
23 panel is doing a good job is careful dissection of the
24 tabletop exercise reports, I think. And I wonder how
25 much you guys have thought about that.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 The other is, the panel is described under
2 the defense-in-depth section, but it seems they have
3 a role in the SSCs and in the selection of licensing
4 basis events, which is kind of saying did the PRA
5 leave anything out that we ought to be looking for?

6 MR. RECKLEY: Yes, I --

7 MEMBER BLEY: Will you talk about that
8 ensemble of things I've put together?

9 MR. RECKLEY: Yes. I think what you just
10 said is true, it's an Integrated Decision-Making Panel
11 and the integrated includes how all of those pieces
12 fit together.

13 And so, thinking of it from a design
14 perspective, the designer, and in this particular
15 case, the process or the panel, has all those things
16 in play, because they're trying to make design
17 decisions.

18 What equipment do I want to make safety-
19 related? What equipment might warrant being
20 additional special treatment requirements?

21 Going back, that panel will contribute to
22 -- maybe going back and saying, maybe we should make
23 a design change to actually affect the event
24 selection. So, yes, it only works if all of those
25 things are in play.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER BLEY: Now, somewhere in the things
2 I've read for this meeting, you talk about how, or
3 someone talks about how the panel is originally set up
4 by the designer and eventually, this role moves over
5 to the licensee, as the design comes to completion and
6 the machine moves over to an owner.

7 Can you say anything about the
8 requirements of what kinds of people need to be on
9 this panel? Including if you need a facilitator of
10 some sort who really understand the whole process?

11 MR. RECKLEY: Yes. The panel, as it's
12 discussed within the guidance, points over to the
13 50.69-related guidance, in terms of how to set up a
14 multi-disciplinary or Integrated Decision-Making
15 Panel.

16 Those models are basically the same,
17 whether we look at what we did for the Maintenance
18 Rule or what the industry did for the Maintenance
19 Rule, what it's done for 50.69, what it's done for
20 risk-informed tech spec initiatives.

21 The notion of an Integrated Decision-
22 Making Panel or multi-disciplinary panel is basically
23 the same, or at least very similar, between all of
24 those and it's going to require people from the risk
25 arena, the PRA arena, operations, design, some

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 mechanical, civil, structural, depending on the
2 elements.

3 So, I'm not personally an expert in that,
4 other than to just say, it's really borrowing from the
5 use of that particular tool, multi-disciplinary or
6 Integrated Decision-Making Panels, from all of that
7 experience. Again, the tech specs, the Maintenance
8 Rule, and more lately, the 50.69.

9 On the next slide, I do address --

10 MEMBER CORRADINI: But just to make sure I
11 understand your answer to Dennis, you're looking at
12 this decision-making panel, is not the final judgment,
13 but I'll call it the final decision-making
14 recommendation to this is safety-related or not
15 safety-related? This is an appropriate defense-in-
16 depth or not? This is essentially the LBEs that ought
17 to be the DBAs? Is that my understanding?

18 MR. RECKLEY: Well, I can say, from the
19 staff's point of view, we have the luxury of only
20 looking at the outcomes of all those decisions that
21 have been made.

22 MEMBER CORRADINI: But if we went to the
23 example, tabletops, that's what you would be expecting
24 this to be the answer, is that decision-making panel
25 examined each of these features and said, yes, well,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 we understand the PRA, but we were concerned,
2 therefore, just to be sure, this will become safety-
3 related, or this will be an additional defense-in-
4 depth necessary?

5 MR. RECKLEY: Right. And the rationale
6 that they laid out for why that was added and why it
7 was enough. Again, from our standpoint, we're
8 focusing on what the outcome of that process is, more
9 so than actually the mechanics --

10 MEMBER CORRADINI: Understood.

11 MR. RECKLEY: -- of it. Which goes to the
12 first bullet here, and again, I think --

13 MEMBER RAY: Bill, can I interrupt you for
14 a second?

15 MR. RECKLEY: Sure.

16 MEMBER RAY: Dennis, you referred to the
17 licensee. And of course, now, our thinking is in
18 terms of certification applicant, for example, which
19 may or may not be what you meant by licensee, because
20 there's another step, it's a process that involves
21 both a licensee of a plant that they own, as well as
22 potentially in this process, a certification applicant
23 that doesn't own a plant, is only producing something
24 that they're marketing.

25 MEMBER BLEY: I was referring to something

1 I read, and I don't remember exactly where it was, but
2 it, at least to me, it implied that this process ought
3 to continue from early in the design into operations
4 of a facility.

5 MEMBER RAY: Well, and I guess --

6 MEMBER BLEY: Which would be a real
7 licensee.

8 MEMBER RAY: I just want to make a note
9 that the step between somebody who may be seeking a
10 certification that they then want to market, to
11 somebody who ultimately, maybe a long time down the
12 road --

13 MEMBER REMPE: So, Harold?

14 MEMBER RAY: -- is a purchaser of that
15 certification, I don't imagine it as a continuity that
16 seems to be implicit in the question.

17 MEMBER REMPE: Harold?

18 MEMBER RAY: Yes?

19 MEMBER REMPE: I'd argue that it has to be,
20 because they have to have site characteristics to
21 fully apply this.

22 Once they finally have a licensee that
23 owns it, they will have to go through the process
24 again and assume, in order to get the dose and the
25 consequences, the actual characteristics of the site,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 they may make some tweaks in the design-basis events
2 and the classification of the equipment, right?

3 MEMBER RAY: Well, I'm just asking to
4 clarify. You're talking about, basically, some
5 assumptions that may be made in certification that
6 then have to be --

7 MEMBER REMPE: Right.

8 MEMBER RAY: -- reassessed by a COL
9 applicant --

10 MEMBER REMPE: Right.

11 MEMBER RAY: -- if it's a Part 52. And I
12 don't know whether it is or not. But the point is, I
13 was just trying to understand what Dennis was
14 referring to.

15 MR. SEGALA: I think you should keep in
16 mind, too, that -- this is John Segala from the staff
17 -- that for non-light-water reactors, we're looking at
18 all possible licensing process.

19 They could come in under Part 50 with a
20 construction permit operating license. They can come
21 in under 52 with a design cert, and then, switch over
22 to a COL. They could come right into a COL, with a
23 full design siting review all at once.

24 So, there's a wide variety of situations
25 that we're going to be having to prepare for. And

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 this will be an iterative process.

2 MEMBER RAY: I understand that to be the
3 case, what you just said, which is maybe why I asked
4 the question to begin with.

5 I think we need to keep that in mind as
6 we're going through and talking about this and asking
7 questions and so on, are the answers different
8 depending on which process somebody comes in with?

9 Joy just explained that, well, presumably,
10 if one does seek a certification, you make assumptions
11 about the site conditions, those then have to be
12 validated by the COL holder and modified as necessary
13 later on.

14 But that process may affect what we're
15 talking about here. It's not as easy as just saying,
16 well, if I'm just a certification applicant, I'll make
17 some assumptions and then, anybody who purchases that
18 certified design has to validate those assumptions
19 that I've made or change them, whatever the case may
20 be. That's enough, then, thank you.

21 MR. RECKLEY: Okay.

22 MR. SEGALA: And we do that under the
23 current reviews, the design certs have a bounds for
24 the site characteristics and then, we have to validate
25 to make sure that there's no exceedances at the site

1 when it's selected.

2 MEMBER RAY: That's what we're striving to
3 do, I'm not sure we've done it yet. But that's part
4 of the dialogue that's going on, is assumptions made
5 in a certification, how do you know what they were and
6 how do you validate them when you go to use the
7 certified design? So, okay.

8 MR. RECKLEY: So, related to the same
9 topic, out of the Subcommittee meeting, Dr. Rempe had
10 asked what our experience was with Integrated
11 Decision-Making Panels or the process.

12 And so, we did go back and look. And I
13 took the question, do we have something that actually
14 watched and then, said, we like the way it's working,
15 how the interchange between the experts or the panel
16 members works, is there best practices in maybe how to
17 set that up?

18 And unfortunately, I guess, my reply is,
19 no. To the degree we've watched, we've not
20 documented. Again, all those processes I mentioned
21 that have included these, we've looked at outcomes,
22 but we've not really documented, per se, how the panel
23 worked within that process and maybe what best
24 practices was.

25 And so, I'll just leave that as has been

1 talked about, that that will be a key focus area for
2 us as we go forward, and also for the developers, that
3 they'll have to look during the process, because the
4 importance of the Integrated Decision-Making Panel
5 members is to address the uncertainties.

6 And we will be looking and asking the same
7 questions that they should be asking of themselves.
8 But the short answer is, no, we couldn't find a
9 document that actually looked at the performance of a
10 panel.

11 Another question -- I guess I can go back
12 to -- I was hoping we would find something, but we
13 didn't.

14 MEMBER REMPE: Thank you for looking into
15 it.

16 MR. RECKLEY: Okay. The second question,
17 or another question to come out of the Subcommittee
18 was on the reliability of passive heat removal and the
19 need to look, not only at the design, but then, also
20 degradation mechanisms and challenges to those.

21 And we acknowledge that. I passed along
22 some references from Argonne in regards to the reactor
23 cavity cooling system, but that's an example, that's
24 not an exhaustive set of references.

25 But for the purpose of the SECY paper,

1 this is maybe one level of detail down. As we go back
2 and look at the draft Guide and the NEI document,
3 we'll revisit whether we need to include some
4 discussion of making sure the degradation mechanisms
5 and so forth.

6 That was the intent, we'll just go back
7 and make sure it clearly states that that needs to get
8 looked at.

9 MEMBER BLEY: In the Reg Guide or --

10 MR. RECKLEY: Both NEI 18-04 and the draft
11 Guide.

12 MEMBER BLEY: Okay, I think that would be
13 great.

14 MR. RECKLEY: Okay. Then, we talked about
15 tabletop exercises, the ADAMS accession numbers for
16 the two that we have. Then, additional ones are
17 planned or underway, and we've talked about that.

18 And then, John also mentioned the Nuclear
19 Energy Innovation and Modernization Act. I'll just
20 mention that the Act includes a couple of requirements
21 for the NRC.

22 One is, within the current construct, to
23 come up with a technology-inclusive, risk-informed,
24 that's this activity. So, when we report back to
25 Congress and say, what are we doing under the current

1 requirements?, that's this.

2 As John mentioned, the Act also says, do
3 the Part 53 or do a rulemaking to develop a framework.
4 We're hopeful that this is also establishing the
5 groundwork for doing that. But we're just at the
6 beginning stages of talking about that rulemaking.

7 MEMBER REMPE: Bill, just for the record,
8 the PRISM application does not go into an Integrated
9 Decision-Making Panel for defense-in-depth assessment,
10 is that true?

11 MR. RECKLEY: They're on --

12 MEMBER BLEY: I did a quick look and saw
13 that they do talk about the Integrated Decision-Making
14 Panel, but I didn't get a chance to read it --

15 MEMBER REMPE: I don't think --

16 MEMBER BLEY: -- in detail. Maybe --

17 MEMBER REMPE: -- they did. From my quick
18 look, they didn't go into defense-in-depth evaluations
19 yet. So, that part of the process hasn't been
20 evaluated in a tabletop, unless this new one for Oklo
21 did, I don't know. But I just wanted -- can you
22 clarify that part --

23 MR. RECKLEY: Do you recall?

24 MR. SEGALA: Yes, I think they were limited
25 in what they did in that.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER CORRADINI: Yes, I think they -- I
2 seem to remember you asked that question of the PRISM
3 people at the Subcommittee and I thought, at that
4 point, they had not.

5 MEMBER REMPE: That's what the report also
6 indicated, and I just wanted to make sure. And then,
7 I'm just trying to understand how far the process has
8 been explored in tabletops, is why I'm asking the
9 question on the record.

10 MR. RECKLEY: Okay.

11 MEMBER BLEY: Bill, just a comment. I'm
12 surprised you couldn't find anything. The -- this is
13 really like an expert elicitation process --

14 MR. RECKLEY: Yes.

15 MEMBER BLEY: -- like you do in PIRT, like
16 you do in technical expert elicitations, a whole
17 variety of areas. There's a vast literature about how
18 that works and how it fails.

19 And a key piece in the places where it's
20 worked well is defining the role of the facilitator
21 very well and how to protect against biases. That's
22 missing in most of our guidance documents for this
23 sort of panel. But it's available.

24 MR. RECKLEY: And maybe I just need to be
25 clear, I didn't find it an NRC assessment and

1 definition.

2 MEMBER BLEY: I agree with you.

3 MR. RECKLEY: Okay.

4 (Laughter.)

5 MR. RECKLEY: There are -- yes, if you
6 Google multi-disciplinary or expert panels --

7 MEMBER BLEY: You're buried for months.

8 MR. RECKLEY: -- yes, you can find a lot of
9 references on how to do it. But I just didn't find an
10 NRC assessment of one of those.

11 MEMBER REMPE: I didn't have a lot of time
12 to look at the PRISM report, but I liked that, just
13 because I'm not so familiar with the design, there
14 were a lot of differences in the selection of the
15 licensing basis events. It provided a more documented
16 approach on why they selected it, so if they changed,
17 I think that's nice.

18 There were a lot of recommendations on how
19 to improve the process on educating the members and
20 things like that. So, I really wanted to emphasize
21 that I think these tabletops are very useful.

22 MR. RECKLEY: And it helped having the
23 PRISM design, which has a well basis, it had people
24 available at GEH that were familiar with the design,
25 familiar with licensing, who became familiar with this

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 process. And so, yes, we agree, it was --

2 MEMBER REMPE: And DOE had funded a new
3 PRA, so a lot of other people had gotten involved.
4 So, it was a nice time to do that work.

5 MEMBER BLEY: Just another comment, since
6 we're on this train. Often, when looking at Reg
7 Guides and this sort of thing, we've pushed the staff
8 to include examples.

9 But it seems to me, because this is such
10 a large integrated process, that having a series of
11 tabletop reports will look less like a cookbook and
12 more like the kind of thing that will be helpful in
13 the future, showing people various ways to go at this
14 problem.

15 MR. RECKLEY: Thank you. Well, and I
16 really should thank the industry, the industry is
17 doing the tabletops and coordinating those.

18 So, I'll spend the next few minutes going
19 through the paper, because, again, it is the paper
20 that we're expecting to be addressed in the letter and
21 we'll come back for a letter on the draft Guide.

22 Anyway, that's the way we had kind of left
23 it, it's obviously up to the Committee to decide how
24 to do this. But we are asking the Commission to make
25 some decisions and I'm sure that they would value the

1 ACRS input on the proposal.

2 So, the paper is just organized -- and by
3 the way, it hasn't changed. Neither has the draft
4 Guide changed as we've really gone through the
5 process, more than some clarifications and editorial
6 changes.

7 So, it's organized by the paper itself.
8 An enclosure with background that goes into the
9 previous activities, going back into the 1990s and
10 then, up to current day.

11 And then, Enclosure 2, which talks about
12 the process, which is a higher level summary of the
13 discussions in NEI 18-04 and DG-1353.

14 So, in terms of background, I'm not going
15 to go into a lot. There were a couple key papers
16 brought before the Commission.

17 One, SECY-93-092, back in the early 1990s.
18 This was coming out of the initial PRISM review,
19 considerations of the modular high-temperature gas
20 reactor, and some other designs.

21 There was a lapse for a while, in terms of
22 the scale of our activities, we came back in the early
23 2000s. And a key paper for this current discussion is
24 SECY-03-0047, Policy Issues Related to Licensing Non-
25 Light-Water Reactor Designs. And I'll come to that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 one in particular.

2 And then, also, building off of all the
3 other risk-informed activities. The time frame for a
4 lot of the non-light-water reactor work was
5 overlapping with other risk-informed, performance-
6 based activities, leading to things like NUREG-1860
7 proposals and advanced notice of proposed rulemaking
8 and some of those things that, as projects kind of
9 lost their momentum, got set aside.

10 But there was progress made. And as I
11 mentioned, one of the key ones was putting before the
12 Commission proposals and having them make actual
13 decisions on a couple key policy issues.

14 And so, in SECY-003-0047, the staff asked
15 the Commission to approve the use of a probabilistic
16 approach for the identification of events, a
17 probabilistic approach to safety classification of
18 SSCs, and a relaxation or a change to the design
19 process to move from single failure criteria over to
20 a broad assessment of events across a wider range of
21 frequencies and to replace the single failure
22 criterion with a probabilistic or reliability-based
23 approach. So, the Commission approved those in an SRM
24 related to that SECY paper.

25 And so, for the current paper, we go

1 through the major elements that are addressed in the
2 draft Guide, again, at a higher level, and we try to
3 point out the key areas where we think they are
4 consistent with the previous Commission decisions,
5 where it might be a new decision or a logical
6 extension of past decisions.

7 And then, also, to ask the Commission,
8 finally, you're going to get to see a picture of how
9 the pieces fit together. We want to make sure that
10 this is in line with what you think is appropriate.

11 So, the biggest decision out of the paper
12 is how the pieces fit together and then, there are a
13 couple areas where the Commission has not made a
14 specific decision and we are going to ask them to make
15 sure that they're okay with the direction we're going.

16 MEMBER MARCH-LEUBA: Very quickly, because
17 the time is getting there, have you given any thought
18 of how this will be implemented? Say, for example,
19 NuScale, NuScale could have used this, they didn't,
20 but they could have, for the design certification.

21 MEMBER CORRADINI: I don't think they
22 could, they're not a non-light-water reactor. They'd
23 have to --

24 MEMBER MARCH-LEUBA: It's a small -- it's
25 an SMR, right? Well, what -- okay. Somebody that

1 wants to do a design certification, and they choose
2 the events early in the process.

3 Is there a way, whether you tie it -- when
4 you're finally done and you have a COL and all those
5 150 ITAACs get resolved, that this gets reanalyzed and
6 verified that all the events -- that you didn't miss
7 one?

8 Because I can guarantee you what's going
9 to happen, they're going to choose some events out of
10 whatever draft PRA they got, and then, they are going
11 to change them.

12 MR. RECKLEY: The gist of the process is
13 that you don't really get to choose your events. You
14 have a design and you're going to assume failures of
15 all of the various combinations of SSCs that you have.
16 What you get to estimate, perhaps, and what will get
17 a lot of attention --

18 MEMBER MARCH-LEUBA: They do it based on a
19 draft conceptual PRA, incomplete always.

20 MR. RECKLEY: Yes. Yes, as they go
21 through, again, it's iterative. And so, what they
22 start out estimating through the process hazard or the
23 failure modes and effects, and then, ultimately,
24 through the PRA. By the time it's submitted to us, it
25 will be complete and it will be supported by the PRA

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 they're providing to us.

2 MEMBER MARCH-LEUBA: Yes, but then,
3 eventually, there's going to be -- there's a lot of
4 ITAACs and COL items that get pushed back. Is there
5 a thought that, whenever you want to build a plant,
6 you have to redo this -- the final PRA is not done
7 until two days before you load fuel, right?

8 MR. RECKLEY: Right.

9 MEMBER MARCH-LEUBA: And that --

10 MR. RECKLEY: Well, it's some period --

11 MEMBER MARCH-LEUBA: Okay. A --

12 MR. RECKLEY: -- six months or --

13 MEMBER MARCH-LEUBA: -- couple of weeks.

14 MR. RECKLEY: Yes.

15 MEMBER MARCH-LEUBA: But --

16 (Laughter.)

17 MEMBER CORRADINI: I was going to say, I
18 think there's a definable time period.

19 MR. RECKLEY: Right.

20 MEMBER CORRADINI: I can't remember if it's
21 a year --

22 MEMBER MARCH-LEUBA: I'm exaggerating with
23 a couple of weeks, but very late in the process. Is
24 there a thought that the events have to be rethought,
25 verified that you didn't miss something, when you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 actually have the real PRA?

2 MR. RECKLEY: Or that the PRA has to verify

3 --

4 MEMBER MARCH-LEUBA: Yes.

5 MR. RECKLEY: -- what you've modeled and
6 how you've laid it out, yes.

7 MEMBER MARCH-LEUBA: But that should be, I
8 wouldn't call it codified, but it should be understood
9 that that's -- there is a process that would have to
10 be followed.

11 Because we're pushing a lot of things to
12 the construction side and something will be forgotten.
13 And not just forgotten, once you have your design-
14 basis events specified, it's going to be very hard to
15 change them, even if the PRA changes.

16 MR. RECKLEY: Okay. So, just going through
17 the highlighted area of what we're asking the
18 Commission, we just basically describe what we've
19 already described here, in terms of the event
20 selection.

21 From the Commission's point of view, or
22 the staff's point of view, we're saying the use of the
23 probabilistic approach to the identification of events
24 is consistent with our previous SECY paper and
25 Commission decision in 2003.

1 The use of frequency consequence targets
2 to support the capabilities and reliabilities is
3 consistent. And the replacement of the -- or not
4 including the assumption of single failure within the
5 design process, based on a probabilistic and
6 establishing performance criteria for SSCs is
7 consistent.

8 The one thing the Commission didn't
9 specifically address in those previous decisions, and
10 I think it's something Dr. Corradini brought up
11 earlier, was the notion of having a cutoff below which
12 you're saying there is some residual risk of this
13 facility, and it's not address specifically within the
14 LBEs and the measures taken to prevent or mitigate
15 those LBEs.

16 And so, we want to point out to the
17 Commission that we think that that is a logical
18 outgrowth of using the probabilistic approach. There
19 has to be, at some point, where you say, we're not
20 going to address that. That's within the current
21 processes, it'll be within the process going forward.

22 We think it's just -- the process going
23 forward actually has more thought given to what you're
24 not going to address than what the current one does.

25 But also, within the discussion, the fact

1 that this isn't, or shouldn't be viewed as a hard
2 line, such that 5E-7 is some magic number and if I'm
3 able to show that I'm at 4E-7, I'm just free to just
4 dismiss that.

5 You have to address the uncertainties,
6 where the defense-in-depth assessment, the
7 consideration of cliff edge effects, all of those
8 things that we've learned that we need to do is built
9 into the process, such that you're making a logical
10 decision for what you do not need to address within
11 the licensing basis events.

12 The safety classification and performance
13 criteria element within the paper is, again, generally
14 consistent with the discussions that were going on in
15 the 2003 time frame, and so, consistent with the
16 Commission decision in 2003, to use a probabilistic
17 approach for safety classification.

18 Assessing defense-in-depth, again, the
19 paper just outlines, and we've gone through this, so
20 I won't repeat.

21 It includes things like the Integrated
22 Decision-Making Panel that we've incorporated into
23 50.69 and 50.65, the Maintenance Rule, our
24 consideration of risk-informed tech specs. So, this
25 is, again, generally consistent with other actions

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that the Agency has taken.

2 One thing we point out in the paper is
3 that there was a time frame and a decision made
4 related to SECY-15-0168, was the risk management
5 regulatory framework proposal.

6 And in that paper, the question was posed
7 to the Commission, should the Agency define defense-
8 in-depth? Should we define a specific policy
9 statement, where we're very clear on what it means?
10 And the Commission said, no.

11 And so, what we point out in the
12 Commission paper is, this process does include a
13 defense-in-depth assessment as part of the process.
14 We are not planning to impose this on anybody else,
15 but if you're using this process, an assessment of
16 defense-in-depth is an integral part of the process.

17 So, we just want to make sure that the
18 Commission's comfortable, for this particular case,
19 for non-light-water reactors using this methodology,
20 that it does include an assessment of adequacy of
21 defense-in-depth.

22 MEMBER MARCH-LEUBA: Yes. Bullet 3 there,
23 it kind of -- it's very interesting. It kind of
24 provides how you do the defense-in-depth, right? You
25 make sure that if one fails, the other one works. Is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 this a fancy way of saying, single failure criteria?

2 MR. RECKLEY: I wouldn't say -- it has some
3 similarities to it, but in large degree, the single
4 failure criterion, I'll simplify, led to two trains.
5 Often, two redundant trains, not necessarily two
6 diverse trains.

7 This will say, I'm not putting all my eggs
8 in one basket, but it probably would lead to more
9 diversity versus --

10 MEMBER MARCH-LEUBA: But you --

11 MR. RECKLEY: -- simple redundancy.

12 MEMBER MARCH-LEUBA: But you did use
13 independent, you didn't use diversity.

14 MR. RECKLEY: Right.

15 MEMBER MARCH-LEUBA: On purpose, I assume.

16 MR. RECKLEY: But that would come, really,
17 out of the risk assessments. And it's an expected
18 outcome, but not necessarily a required outcome.

19 MEMBER MARCH-LEUBA: So, when they're doing
20 this verification in Bullet 3, they should at least
21 consider diversity or common-cause failures of the two
22 systems?

23 MR. RECKLEY: Yes.

24 MEMBER MARCH-LEUBA: Because if you put two
25 check valves next to each other, they get broken by

1 the same seismic event?

2 MR. RECKLEY: That's right.

3 MEMBER MARCH-LEUBA: Okay, thank you.

4 MR. RECKLEY: Then, lastly, within the
5 paper, we bring up that we're really looking to take
6 this as a stepping stone to providing additional
7 guidance on the content to applications.

8 To try to make sure that the developers,
9 ultimately the applicants, are able to provide us the
10 most directed, concise application that they can bring
11 us, addressing the measures that assure the safety of
12 that particular design.

13 We think this approach feeds that
14 capability pretty well, because the design process,
15 the licensing process, as it's defined here, is all
16 trying to focus in on what's the most important, and
17 from our point of view, therefore, what should be the
18 focus of the application?

19 What areas do you need to provide the most
20 information? What areas might you be able to provide
21 less information? And possibly, what areas don't you
22 need to include any information?

23 And so, although the Commission has
24 previously told us many times, in different papers and
25 different initiatives, to include risk-informed,

1 performance-based approaches in our reviews, it's not
2 quite been as emphasized that it should also be used
3 in actually deciding what's put in an application.

4 So, we want to put before the Commission,
5 we want to take this, expand upon it, and actually use
6 this approach to define what needs to be in an
7 application.

8 MEMBER REMPE: So, Bill, now, the NEI
9 document acknowledges that not all the regulations
10 will be met.

11 MR. RECKLEY: Right.

12 MEMBER REMPE: Are you saying, then, in
13 light of the fact that not all regulations will be met
14 using this approach, it's just for selecting licensing
15 basis events and --

16 MR. RECKLEY: Right.

17 MEMBER REMPE: -- et cetera, classifying
18 equipment, are you saying the applications don't have
19 to include anything else about the design to meet the
20 other regulations?

21 MR. RECKLEY: No. No, but if you look at
22 an application -- they will still have to address all
23 the other regulatory criteria and how they are meeting
24 that and what aspects of the design.

25 But to be fair, when you look at what

1 drives the level of information on particular systems,
2 structures, and components, and the bulk of an FSAR,
3 that is this big, it really is the events and the
4 safety classification, and to some degree, the
5 defense-in-depth assessments, not so much for current
6 applications.

7 But what you need to do for those other
8 rules tends to be much more direct. Here's the rule,
9 here's what we're doing to address it. That will
10 still need to be there.

11 MEMBER REMPE: Okay, thank you.

12 MEMBER CORRADINI: So, this is an optional
13 path for non-light-water reactors. So, if they choose
14 not to go this path, they must meet current
15 regulations and take exemptions to the general design
16 criteria, et cetera, et cetera?

17 In other words, I'm trying to understand
18 -- and the reason I'm asking the question like this
19 is, although defined, and I typically think it's quite
20 a good approach, it could create a conversation for
21 the first few of these that could be viewed as
22 interminable.

23 So, the other option path is to
24 essentially follow the current regulations and then,
25 take exemptions? I mean, that's how --

1 MR. RECKLEY: Yes.

2 MEMBER CORRADINI: -- the gas-cooled
3 reactor did it, that's how --

4 MR. RECKLEY: You could do that approach.
5 You can come forward with principal design criteria,
6 your barriers.

7 You could take the standard ANS 51.1,
8 52.1, for light-water reactors and try to say, here's
9 our events, based on functions like decreases in heat
10 removal, decreases in inventory, reactivity
11 transients, and here's how we're going to address
12 those within our designs. One could construct that --

13 MEMBER CORRADINI: I understand.

14 MR. RECKLEY: Yes, you could take a shot.
15 We're going to end up asking you many of the questions
16 that would have been answered through this process.

17 MEMBER CORRADINI: I figured that.

18 MR. RECKLEY: I mean, so --

19 MS. CUBBAGE: This is Amy Cubbage. I just
20 wanted to clarify something. Under both approaches,
21 they both have to propose PDCs. And in either case,
22 would they need an exemption to do so, because the
23 GDCs don't apply.

24 So, in both cases, if you use LMP or an
25 alternative approach, you have to propose PDCs. And

1 both approaches would be under the current regulations
2 and both approaches would likely have some level of
3 exemptions. The use of LMP wouldn't necessarily
4 obviate the need for exemptions or otherwise.

5 MEMBER CORRADINI: Okay. So, your point,
6 though, is that it would, in theory, streamline the
7 choosing of what LBES go into DBAs, et cetera, et
8 cetera --

9 MS. CUBBAGE: Which is one way of
10 fulfilling the current regulations. Another way of
11 fulfilling the current regulations is to use, as Bill
12 said, more of the standards and traditional
13 engineering judgment and deterministic thoughts to
14 determine what the events are.

15 MEMBER CORRADINI: Okay.

16 MR. RECKLEY: Right.

17 MEMBER CORRADINI: Thank you.

18 MR. RECKLEY: But then we would go from,
19 for example, in the area of non-safety-related with
20 special treatment, you would go, and if you're going
21 to say, well, we'll going to try to use something much
22 closer to what we do now, then you would go over to
23 regulatory treatment of non-safety systems or RTNSS.

24 And the criteria that are defined are
25 sometimes hard to follow and sometimes, they're light-

1 water reactor specific, as to how they were derived.
2 You would have to propose something in that arena to
3 say, here's how we're going to go.

4 My personal opinion is, it's going to come
5 out looking a lot like, well, we're going to have an
6 Integrated Decision-Making Process to try to help us
7 assess what needs additional regulatory treatment.

8 MEMBER CORRADINI: So, okay. I want to
9 just test the other pathway. The other part of this,
10 though, that I wanted to make sure I understood is,
11 you're not necessarily looking for a detailed PRA, but
12 you're looking for a comprehensive look at the system,
13 so that I might be able to make, I'll use the word
14 conservative or bounding estimates on frequency or
15 consequence.

16 As long as it's complete, as complete as
17 you can get it, it doesn't have to be highly detailed.
18 Because some of these systems are such that, to get a
19 highly detailed one would be a challenge.

20 MR. RECKLEY: I think that's true.

21 MEMBER MARCH-LEUBA: How can it be complete
22 and not detailed?

23 MEMBER CORRADINI: Because you can make
24 bounding assumptions. In some --

25 MEMBER MARCH-LEUBA: Okay.

1 MEMBER CORRADINI: -- other applications,
2 that we shouldn't --

3 MEMBER MARCH-LEUBA: You mean conservative?

4 MEMBER CORRADINI: -- talk about in public,
5 they've had relatively conservative assumptions on
6 what the accidents are and what the responses to those
7 accidents are. And that made it complete, but it was
8 not very detailed.

9 MR. RECKLEY: Time will tell. The thought
10 is, many of these designs would have more
11 straightforward or simpler PRAs, just reflecting the
12 simpler designs, right?

13 If I have an active component that then
14 relies on active cooling and AC power and all of those
15 dependencies, that is what drives the complexity. And
16 sometimes, as you mentioned, I make assumptions on
17 those supporting things or how far down I go.

18 In the passive arena, hopefully, they're
19 less complex simply because they're less complex.

20 MEMBER CORRADINI: Right. But I --

21 MEMBER BLEY: Often, this -- not going at
22 the detail, making what appear to be conservative
23 assumptions, are conservative for what you're thinking
24 about, but may be optimistic for other scenarios.

25 So, your consideration of scenarios better

1 be pretty thorough, to make sure if you do make
2 bounding assumptions, that they're really bounding for
3 everything.

4 MR. RECKLEY: Or you make different
5 assumptions for different scenarios.

6 MEMBER BLEY: Which is the right way to do
7 it.

8 MR. RECKLEY: Yes.

9 MEMBER CORRADINI: Okay. All right,
10 thanks.

11 MEMBER MARCH-LEUBA: As we are getting to
12 the closing arguments, I wanted to reemphasize what I
13 said before, that the staff is always going to be
14 reinventing, retransforming, reengineering, pick the
15 name, which means, have less money available to the
16 reviews.

17 This type of PRA is not the place to save
18 money, doing the review. Because the consequences of
19 being wrong on those frequencies, having missed a
20 sequence, are very large. So, whenever we retransform
21 again, don't save money on this PRA review.

22 MR. RECKLEY: Okay. And we hope, I didn't
23 mention it here, we mention it within the draft Guide
24 and it's mentioned in NEI 18-04, we look, hopefully to
25 help in that arena, the ASME/ANS non-light-water

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 reactor PRA standard, that will call -- provide
2 guidance for how to do that or include peer reviews
3 and so forth, to help make sure that the PRA is good
4 enough to support this activity.

5 MEMBER BLEY: You're all done? I think
6 it's time to see if any of the members have further
7 questions. And then, we'll go for public comment.

8 MEMBER KIRCHNER: May I ask?

9 MEMBER BLEY: Sure.

10 MEMBER KIRCHNER: Bill, I just want to test
11 the last lines of 19. So, do you see -- this
12 approach, I think should inform where the NRC puts a
13 great deal of its attention, but how substantively is
14 that going to change the scope and level of detail in
15 the application?

16 MR. RECKLEY: That will be design-specific.
17 As an example that I've used in the past is, the
18 current requirements to describe within the
19 essentially complete design is to describe the power
20 conversion systems in some detail.

21 And for light-water reactors, that makes
22 sense, because power conversion, upsets on the
23 secondary translate very quickly to upsets on the
24 primary, and you're dependent on heat removal and so
25 forth. And so, secondary plant systems are described

1 in some detail for light-water reactors.

2 If a design can show that their heat
3 removal is not through the secondary, and a secondary
4 plant upset doesn't cause a transient, a fast-acting
5 transient on the primary, because the heat's being
6 absorbed by the graphite or the heat capacity of the
7 sodium or whatever the argument would be, then that
8 argument would be, they don't need to describe the
9 secondary plant as much as the light-water reactor has
10 done.

11 That would be an example. But they would
12 have to show that an upset on the secondary doesn't --

13 MEMBER KIRCHNER: They would have to show
14 enough to demonstrate to you that it doesn't have an
15 impact?

16 MR. RECKLEY: Right. But having shown
17 that, they then wouldn't need to describe the
18 secondary as much.

19 MEMBER BLEY: Anything else from the
20 members? Charlie?

21 MEMBER BROWN: Yes, a little bit on, since
22 I haven't said anything about the I&C world. But when
23 you -- level of detail of information to be included,
24 following up on Walt's comment, where when I first got
25 here, ten years ago plus change, ESBWR was coming

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 through for an application.

2 And the level of detail provided for the
3 I&C systems were sparse, to say the least. Little
4 information on how they achieved independence and just
5 words that says, in the application, we'll follow the
6 rules and the rule for IEEE 603, et cetera, and the
7 various Reg Guides.

8 It was -- you just had no idea how they
9 were going to accomplish this with the software-based
10 systems. Has -- now, I understand that for event
11 selection, that's a different issue.

12 But here, are reactor protection and
13 reactor trip or safeguards actuation type functions,
14 where there's a fairly standardized approach, and have
15 there been any discussion on whether those would be,
16 quote, under the risk assessments, say, we don't need
17 them at all?

18 MR. RECKLEY: I haven't seen --

19 MEMBER BROWN: Because these plants are so
20 safe?

21 MR. RECKLEY: I haven't seen any go as far
22 as, we don't need them at all. The -- you do have, in
23 the non-light-waters, again, the additional thermal
24 capacities or the longer time constants can reduce the
25 importance of how fast your reactivity control systems

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 work.

2 Which then can show up in simpler
3 reactivity control systems and simpler instrumentation
4 to drive it, because I don't need the instrumentation
5 and the control rods to respond in two seconds, I
6 might have a much longer time period.

7 And so, those physical things can get
8 reflected in the descriptions and in the application,
9 but it's because you've shown that they're less
10 important, not a priori, I'm not going to describe
11 them.

12 Once you show they're less important, then
13 you might be able to describe them in less detail or
14 have less complex systems.

15 MEMBER BROWN: That's fairly mushy.

16 MR. RECKLEY: Yes.

17 MEMBER BROWN: Okay.

18 MR. RECKLEY: Because we won't know until
19 we see a design and how they craft the safety
20 arguments that they're trying to craft.

21 MEMBER BROWN: Well, time response is one
22 issue. I mean, a few seconds versus 250 milliseconds
23 or 500 milliseconds.

24 There's -- I mean, we've got some
25 scenarios that are seconds in response today, yet our

1 systems fundamentally reflect fairly responsive and
2 parallel independent systems, to make sure something
3 happens --

4 MR. RECKLEY: Right.

5 MEMBER BROWN: -- regardless of whether you
6 have ten or 15 minutes to do something.

7 MR. RECKLEY: Right. But again, one of the
8 fundamental or primary safety functions, the
9 generation of heat or reactivity control, will
10 continue, I think, personal opinion, to always require
11 you have those protection systems, and they'll have to
12 be described as to how they work.

13 There will just be a little more
14 discussion for the non-lights, I think, as to how that
15 also pairs with intrinsic reactivity feedback
16 mechanisms and other things that come into play, maybe
17 more than light-water reactors have. But we'll see.
18 I don't --

19 MEMBER BROWN: Thank you.

20 MEMBER BLEY: Okay. And I think at this
21 point, we'll go to public comments. If we can get the
22 phone line open?

23 While we're waiting for the phone line, if
24 anyone in the audience would like to make a comment,
25 please come up to the podium right behind me, state

1 your name and your organization, and give us your
2 comment.

3 Is there anyone on the phone line who
4 would make a comment? Who would like to make a
5 comment? It's really open? Okay. I don't hear
6 anything.

7 Okay. I think we're finished. Mr.
8 Chairman, back to you.

9 CHAIRMAN RICCARDELLA: Thank you.

10 MEMBER BLEY: Exactly on time.

11 CHAIRMAN RICCARDELLA: Very well done,
12 we're exactly on time at 10:30. And it shows that we
13 have a 15-minute break. We will reconvene at 10:45 to
14 discuss Non-Production and Utilization Facilities
15 Rulemaking. Thank you.

16 (Whereupon, the above-entitled matter went
17 off the record at 10:30 a.m. and resumed at 10:47
18 a.m.)

19 CHAIRMAN RICCARDELLA: Okay. I think we
20 have a quorum.

21 We will now move to NPUF, non-production
22 and utilization facilities rulemaking. And I will
23 turn the meeting over to Subcommittee Chairman, Matt
24 Sunseri.

25 MEMBER SUNSERI: Thank you, Mr. Chairman.

1 This discussion on the non-production and utilization
2 facilities rulemaking is a continuation of a process
3 that we've been going through for a couple of years
4 now.

5 There was a previous subcommittee and a
6 letter written in 2016. And we recently had a
7 subcommittee meeting in January. And this will be the
8 briefing from that meeting. And we intend to roll
9 into letter preparation, letter report preparation
10 following this presentation today.

11 So, with no further ado, I'd like to turn
12 it over to Ms. Lund for introductions here.

13 MS. LUND: Thank you very much. Good
14 morning. I'm Louise Lund. And I'm the Director of
15 the Division of Licensing Projects --

16 MEMBER SUNSERI: Can I just -- hold on for
17 a second. So the acoustics in this room are pretty
18 challenged here. So what I ask you to do is just to
19 make sure that the microphone is clearly aligned with
20 your voice, because I couldn't hear what you were
21 saying.

22 MS. LUND: Okay. Does this work?

23 MEMBER SUNSERI: That --

24 MS. LUND: Okay. Great. Thank you. Good
25 morning. I'm Louise Lund. And I'm the Director of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the Division of Licensing Projects in the Office of
2 Nuclear Reactor Regulation.

3 The NRC is here today to provide an
4 overview of the draft final non-power production or
5 utilization facility rulemaking, which we call the
6 NPUF rulemaking.

7 Seated at the table over there to the side
8 are Bob Beall, the Rulemaking Project Manager from the
9 Office of Nuclear Material Safety and Safeguards, and
10 I am sure that you're aware that rulemaking moved over
11 as a group to NMSS, and Duane Hardesty, Senior Project
12 Manager, and Al Adams, Senior Project Manager. And
13 they're both from the Research and Test Reactor
14 Licensing Branch in the Office of Nuclear Reactor
15 Regulation.

16 And I think we mentioned probably at the
17 subcommittee meeting that Al Adams is now in phased
18 retirement. But he's still in the group helping us
19 out with a number of projects. So that's really good
20 for us.

21 So we also have working group members and
22 management from the offices of NRR, Office of General
23 Counsel, Office of Research, NMSS, and the Office of
24 New Reactors.

25 Key staff members include Duke Kennedy,

1 who is the Acting Branch Chief in the RTR Licensing
2 Branch, Rich Clement, Michael Smith, Kevin Folk, and
3 Kos Lois from NRR, Tony Gomez from NMSS, Howard
4 Benowitz from OGC, and Michael Eudy from research to
5 assist in answering any questions that come from the
6 committee.

7 And to support this rulemaking, the staff
8 has developed a draft final rulemaking package which
9 consists of a Commission Paper, Federal Register
10 Notice and a new regulatory guide, Reg Guide 2.7,
11 preparation of updated final safety analysis reports
12 for non-power production or utilization facilities,
13 and I'll tell you a little bit more how that factors
14 in, and other supporting documents that provide the
15 details of the proposed regulatory changes and the
16 benefits to the licensees and NRC staff.

17 There are nine regulatory actions which
18 are changes included in the draft final rule. Okay.

19 The most transformative action is
20 elimination of fixed license terms for research
21 reactors, which is consistent with the requirement of
22 the Atomic Energy Act to impose minimum regulation on
23 these licensees and reduces the burden on licensees
24 and the NRC staff, and most importantly, maintains
25 adequate protection of public health and safety of the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

(202) 234-4433

1 environment. And there'll be more discussion as to
2 how that works.

3 We look forward to an informative
4 interaction with the ACRS today. And I want to thank
5 the ACRS for its review, its comments, and feedback to
6 the staff on this very important rulemaking.

7 To start today's presentation, Bob Beall
8 will provide an overview of the NPUF rulemaking. And
9 Duane and Al will then provide a detailed discussion
10 of the nine recommended regulatory changes. Thank you
11 very much.

12 MR. BEALL: Okay. Thank you, Louise. So
13 the draft final rule here that's before you and I'm
14 here to discuss implements the direction the staff got
15 from the Commission to streamline the license renewal
16 process for non-power reactors in NPUF type
17 facilities.

18 And they wanted us to create a more
19 efficient and effective regulatory framework for these
20 facilities.

21 And during the process over the past
22 couple years the staff has used their own knowledge
23 and also comments from the public to come up with
24 innovative and transformative approaches, which you'll
25 see in a few minutes that we've come up with some

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 interesting ideas on how to accomplish this for these
2 non-power licensees.

3 And those ideas are all contained in the
4 nine rulemaking objectives that Al and Duane will be
5 going over in a few minutes.

6 For the proposed rule, we issued a
7 proposed rule on March of 2017 that was out for a 75-
8 day comment period. And we also held a public meeting
9 on May of that year to assist the public in
10 formulating their questions. They came in and we were
11 available, the staff was available to answer any
12 questions or comments they may have about the proposed
13 rule.

14 And at the end of the comment period, we
15 received 16 comment submissions. And in general, all
16 the comments were supportive of the rulemaking process
17 that we were proposing.

18 As Matt mentioned, we were here just a
19 couple weeks ago in January to present to the
20 subcommittee. And during that meeting, the TRTR
21 chairman stated that he felt that the draft final NPUF
22 rule was a win/win for both the NRC and the NPR
23 community. So that was a very nice endorsement he
24 gave us.

25 So, with that, I'd like to turn it over to

1 Duane and Al. And they will go through the nine
2 regulatory changes that the staff is proposing to
3 make.

4 MR. HARDESTY: Good morning. I would like
5 to start by showing this slide, this graphic here,
6 which is a generalization of the types of facilities
7 that are affected by this rulemaking.

8 Section 101 of the Atomic Energy Act
9 provides the authority to license production and
10 utilization facilities. And the types of non-power
11 production or utilization facilities or NPUFs are
12 given in both Section 103 and 104 of the Act.

13 Currently, the NRC regulate 36 NPUFs,
14 which includes 30 research reactors, 1 testing
15 facility, 1 of which is dual licensed as a medical
16 therapy facility under 104(a), and then the 5
17 remaining facilities are 2 medical isotope production
18 facilities which have construction permits, and 3
19 class 103, I'm sorry, 3 104(c) facilities that are in
20 decommissioning.

21 As we go through the slides, you're going
22 to see this graphic each time. And it will be grayed
23 in and out to show the effectivity of the particular
24 objective that I'm talking about.

25 You're also going to see some red text on

1 those slides. And that denotes changes between what
2 was in the proposed rule and what's in the draft final
3 rule.

4 So the first objective of the rule is to
5 address inconsistencies in definitions and terminology
6 that were in our regulations. The draft final rule
7 creates a definition for non-power production and
8 utilization facilities which is flexible enough to
9 capture all of the non-power facilities licensed under
10 Part 50, including the medical isotope facilities.

11 The NPUF definition was modified in the
12 draft final rule because the staff realized that the
13 definition was too broad.

14 The definition in the proposed rule
15 excluded fuel cycle facilities, or I'm sorry, fuel
16 reprocessing facilities. But we determined we also
17 needed to exclude production facilities that were
18 designed for the formation of plutonium or uranium-233
19 or designed for the separation of plutonium, both
20 which are captured in Part 1 and 2 of the definition
21 of production facility in 50.2.

22 The staff also received a public comment
23 on the definition of testing facility and research
24 reactor, which I will talk about next.

25 So the National Institutes of Standard and

1 Technology submitted a comment recommending a more
2 risk-informed definition for testing facility and for
3 research reactor and recommended the use of the one
4 rem accident dose criteria that we established for
5 research reactors as being the demarcation threshold
6 between them. Next slide. Okay.

7 The NRC agreed that use of the postulated
8 accident dose is a more risk-informed, performance-
9 based approach to distinguish between NPUF facility
10 types and modified the definitions of testing facility
11 and research reactor to be based on that accident dose
12 criteria.

13 The staff also made conforming changes to
14 the definition of non-power reactor and standardized
15 the use of terminology throughout the NRC regulations.
16 Next slide.

17 MR. ADAMS: Good morning. I'd like to
18 talk about the second objective, which entails
19 eliminating license terms for certain NPUFs.

20 The Atomic Energy Act does not establish
21 a license term for class 104(a) or 104(c) facilities.
22 The term is limited only by 10 CFR 50.51(a) to 40
23 years or less. The staff currently licenses NPUFs for
24 20-year terms for both renewals and initial licenses.

25 The staff's analysis of license terms did

1 consider terms that were longer than 20 years other
2 than indefinite, but determined that with the addition
3 of regular FSAR updates there's no significant nexus
4 between safety and the license renewal process.

5 The regulations allow 40-year licenses.
6 And several licenses with 40-year terms were issued in
7 the late 1950s and early 1960s.

8 The staff determined that 40 years was too
9 long of a time to go without an SAR update and adopted
10 the practice of 20-year terms after a decision was
11 made in the 1970s that license renewal was no longer
12 a simple administrative action.

13 The staff's experience with renewals show
14 that even going 20 years without a formal process to
15 update the licensee basis documentation contributed to
16 a loss of licensing basis and contributed to the last
17 backlog of license renewals. Thus, the staff
18 concluded that longer license terms would further
19 aggravate the difficulties that were experienced.

20 During the proposed rule phase, it was
21 suggested that we both extend the terms of licenses
22 and require FSAR updates. However, feedback from
23 public meetings showed that the RTR license community
24 would not support a proposal that included both FSAR
25 updates and license renewal for research reactors.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 The staff agreed that both were not needed
2 to protect public health and safety. The staff's view
3 is that the non-expiring license is consistent with
4 the Atomic Energy Act Section 104(a)(2), quote, impose
5 only such minimum amount of regulation under this Act
6 to promote the common defense and security and to
7 protect public health and safety.

8 The next two slides discuss how health and
9 safety of the public is maintained with a non-expiring
10 license. Next slide.

11 This slide provides technical reasons
12 based on design and operational characteristics of
13 class 104 NPUFs for discontinuing license renewal for
14 NPUF licensees due to their low risk.

15 This discussion is applicable to the
16 medical therapy and research reactors. It is not
17 related to testing facilities or commercial and
18 medical ISO facilities who will still be subject to
19 license renewal.

20 While commercial facilities may have some
21 of the attributes of non-commercial facilities,
22 potential pace and scope of commercial activities
23 justifies the additional scrutiny of class 103
24 licensing process.

25 Under this rule, class 104 NPUFs other

1 than testing facilities will have a maximum accident
2 dose criteria of one rem TEDE. These facilities
3 operate at low power levels, have a small inventory of
4 fission products, and operate at low temperatures and
5 pressures preventing a low potential radiological risk
6 to the environment and the public.

7 These facilities are also simple in their
8 design and operation. And, therefore, the scope of
9 aging-related concerns is limited. The staff has
10 found no significant aging issues because NRC
11 currently imposes aging-related surveillance
12 requirements on NPUFs via their technical
13 specifications.

14 In addition, the design basis of these
15 facilities evolves slowly over time. The NRC receives
16 approximately five license amendment requests each
17 year from all the licensees combined. Further, on
18 average, each of these facilities reports only five 10
19 CFR 50.59 evaluations per year. Next slide, please.

20 MEMBER KIRCHNER: Al, before you go on,
21 just as a footnote, could you just specify where that
22 dose is measured?

23 MR. ADAMS: So the dose is to the
24 maximally exposed person, wherever that person might
25 happen to be.

1 MEMBER KIRCHNER: So there's no distance
2 implied, just the maximally --

3 MR. ADAMS: Right.

4 MEMBER KIRCHNER: -- exposed person?

5 MR. ADAMS: Right.

6 MEMBER KIRCHNER: Okay.

7 MR. ADAMS: Sometimes the distance is to
8 the fence or to the -- you know, the boundary of the
9 restricted area of research reactors is very small.
10 It could sometimes be the, you know, the room in the
11 engineering building.

12 MEMBER KIRCHNER: Yes. All right.

13 MR. ADAMS: So we considered the nexus
14 between license renewal and safety. When the first
15 power reactors are facing license renewal, research
16 reactor license renewal is already an established
17 process.

18 We looked at the framework that was being
19 developed for power reactor license renewal and
20 focused on aging of structures, systems, and
21 components important to continued safety.

22 We did not include research reactors in
23 the power reactor framework for Part 54 because we
24 already had an established license renewal process.
25 Also, we could not envision what license renewal would

1 encompass if limited to aging issues for research
2 reactors.

3 So the question is, without notable aging
4 issues, what does taking a snapshot of a research
5 reactor only once every 20 or 40 years contribute to
6 safety. We came to the conclusion that there was
7 nothing of safety importance.

8 There are other processes in place that
9 ensure safety on a continuing basis. And the actions
10 we have taken or are proposing to take contribute more
11 than continuing safety than performing a license
12 renewal every 20 years.

13 NUREG 1537 is our format and content
14 guidance for licensees and the standard review plan
15 for the staff for NPUF licensing actions. It was
16 issued in 1996 with two interim staff guidance
17 documents issued later. There was no comprehensive
18 guidance for research and test reactors before 1996.

19 As an entrance criteria to being ordered
20 into a non-expiring license, all of the facilities
21 will undergo a license renewal review using the
22 guidance of NUREG 1537. This ensures a comprehensive
23 and consistent licensing basis using established
24 guidance for the licensees.

25 For the staff, we have a licensing basis

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that was reviewed and documented in the safety
2 evaluation report using the standard review plan. So
3 we will have the solid, documented basis of the safety
4 of the facilities entering into the non-expiring
5 license process.

6 The oversight and inspection program is a
7 comprehensive look at all aspects of facility
8 operation. Inspectors are on site up to several times
9 a year. Any deterioration in licensing performance
10 will be discovered, documented, and corrected.

11 Inspection results are reviewed for
12 adverse trends that could indicate new aging issues.
13 Licensees also report maintenance, which includes
14 component issues, in their annual reports, which would
15 allow the NRC to identify new aging issues if they
16 were to occur.

17 As such, the staff believes that the
18 regulatory oversight and requirement for FSAR updates
19 by the final rule will provide the safety benefits
20 currently afforded by the license renewal process.

21 I'll turn it back over to Duane at this
22 point.

23 MR. HARDESTY: All right. So, moving on
24 to the third objective under the draft final rule, the
25 staff wished to consolidate the license renewal

1 requirements for current and future NPUF licensees
2 licensed under 10 CFR 50.22 and all testing
3 facilities.

4 There are no new requirements under 51.35.
5 However, we did make minor modifications to the draft
6 final rule to make the renewed license effective
7 immediately. It used to be effective in 30 days.
8 That was to add flexibility for implementation of the
9 staff and the licensee working together to give
10 flexibility.

11 Then we also removed some text which
12 unnecessarily limited a renewed NPUF license to less
13 than 40 years. A 40-year term is allowed by the
14 Atomic Energy Act. And so that was an error that we
15 corrected. Next slide, please.

16 For the fourth objective, the staff has
17 extended the requirements for updates of final safety
18 analysis reports under 50.71(e) of the Code of Federal
19 Regulations to be applicable to all NPUFs.

20 This is kind of the key part of our entire
21 package in that we are relying on the FSAR updates to
22 be the basis, to maintain the licensing basis for our
23 licensing, or licensees.

24 These updates were not required
25 previously. And history has shown that licensees were

1 having difficulty providing documentation to fully
2 describe the details of their licensing basis.

3 Under the draft final rule, NPUFs will be
4 required to provide five-year updates to the FSAR
5 ensuring more timely documentation of changes to the
6 facility. The updated FSAR is important for the NRC's
7 inspection program and for effective license operator
8 training at the facility.

9 The five-year periodicity that we chose
10 reflects the more slowly evolving basis that AI just
11 mentioned for NPUFs. But it's also frequent enough to
12 maintain the licensing basis given the staff's
13 findings for typical number of facility changes and
14 the staff turnover at the facilities.

15 We also generated a Reg Guide, Reg Guide
16 2.7, which provides guidance to the licensees on
17 preparing and submitting FSAR updates.

18 MEMBER SKILLMAN: Duane, what inspection
19 requirements changed when the five-year updates became
20 required? Did --

21 MR. HARDESTY: When will they be required?

22 MEMBER SKILLMAN: No. You have a licensee
23 who has now agreed to have an unexpired, an unexpiring
24 license. And for that privilege, you require a five-
25 year update on the FSAR, right?

1 MR. HARDESTY: Actually, all NPUFs, even
2 the ones that undergo license renewal, have to do the
3 updates.

4 MEMBER SKILLMAN: Okay. So what
5 inspection requirements did you change? Did you
6 institute a thicker magnifying glass for that FSAR
7 update so that you really, really know those licensees
8 are toeing the line?

9 MR. HARDESTY: Not per se. There is part
10 of the inspection program where they look at the
11 facility as changed, whether it be via amendment,
12 which the licensing branch would look at, as well as
13 whether it would be under 50.59 without prior
14 notification to the NRC or prior approval of the NRC.

15 And that is documented by the licensee in
16 an annual report to us. So we see those changes much
17 more frequently. And additionally, our project
18 managers interface with the facilities to understand
19 the changes to the facility.

20 So we see that, any changes that come in
21 both from the inspections program where they go out
22 and look at the facilities from these annual reports.
23 And then we'll see a consolidation of that into the
24 five-year updates, which the staff will review as part
25 of the new licensing or the regulatory requirement.

1 MR. ADAMS: Can I just add something? So,
2 when these updates come in to NRC, they're not
3 licensing actions. But the project managers will sit
4 down, review the FSARs. And, you know, they already
5 know what they expect to see in it because they've
6 been involved in issuing the license amendments.
7 They've been involved in looking at 50.59 reviews.

8 So, if they don't see what they expect to
9 see, then they can, then through the inspectors they
10 can feed back through the inspection program a process
11 where the inspectors would discuss this with the
12 licensees when they're on site.

13 MR. HARDESTY: Right. And even now
14 without this, when the project manager and the
15 inspector want to discuss the facility, they'll
16 schedule something prior to the inspector going out
17 for a routine inspection. And the project manager has
18 the opportunity to have the inspector ask any
19 additional questions or look at any additional records
20 that might be reasonable for understanding what is
21 under, what changes are being made at the facility.

22 MEMBER SKILLMAN: Thank you.

23 MR. HARDESTY: So the fifth objective is
24 to amend the timely renewal provision under 10 CFR
25 2.109 for the class 103 NPUFs and for all testing

1 facilities, which are the two types of facilities that
2 will continue to undergo license renewal.

3 The change is to make the requirement such
4 that they have to submit an application two years
5 prior to the expiration of the license. Current
6 regulations allow that NPUF licensees can submit as
7 soon as 30 days or as late as 30 days prior to the
8 expiration of the license.

9 Again, historically that 30 days has
10 proven to be insufficient time for the NRC staff to
11 make a determination of the acceptability of the
12 application and to adequately assess, I mean, to ask
13 for the licensee to supplement the application.

14 So what we've done in the past is we've
15 basically accepted the application as is, which is,
16 which increased the burden to both the NRC staff and
17 the licensees because all of those deficiencies had to
18 then be addressed through other means such as the
19 request for additional information process.

20 The proposed rule also would have
21 eliminated the requirement for also class, all class
22 104 NPUFs because they didn't have license renewal
23 anymore, so we didn't need them to be in 2.109.

24 However, during the draft final rule
25 discussions, we realized that there's a timing

1 situation in which at least one facility will be
2 subject and getting ready to go through license
3 renewal, which is one of our entrance criteria under
4 NUREG 1537, after the final rule goes into effect.

5 So we basically would have put them into
6 a box where they didn't have a timely renewal
7 provision because they couldn't meet the two-year
8 window because they were less than that.

9 So we modified the language slightly so
10 that it didn't go away for anybody that might be doing
11 license renewal that's an NPUF. But it also changed
12 it to two years for those that we intend to have
13 future license renewal, which would be the class 104
14 test, 4(c) testing facilities and all 50.22
15 facilities. Next slide, please.

16 So this is the objective for the accident
17 dose criterion that we alluded to a couple of times
18 already. So we created a new accident dose criterion
19 for all NPUFs other than testing facilities in 10 CFR
20 50.34.

21 So, prior to this, the staff didn't have
22 an accident dose criteria in the regulations. So the
23 licensees were asked to meet the Part 20, 10 CFR Part
24 20 requirements for accident dose criteria.

25 In May 1972, the NRC Atomic Safety and

1 Licensing Appeals Board suggested that the standards
2 in Part 20 were unduly restricted as accident dose
3 criteria for research reactors.

4 In 1991, the NRC amended Part 20 and
5 lowered that public dose from .5 down to .rem. Still
6 at that time the staff was using the Part 20
7 requirements for NPUFs other than testing facilities
8 as the accident dose criteria for demonstrating worst-
9 case accidents to a member of the public for the
10 maximum hypothetical accident.

11 MEMBER REMPE: So --

12 MR. HARDESTY: However, in 1992, the
13 Environmental Protection Agency published protective
14 action guidelines. And in January 2017, the EPA
15 published an update to the PAGs and the PAG manual
16 that had dose guidelines that supported their decision
17 to protective actions such as staying indoors,
18 evacuation or evacuation to protect the public during
19 a radiological incident.

20 In the early phase of radiological
21 incidents, the trigger for the protective action of
22 sheltering in place or evacuation of the public range
23 is from one to five rem. So the EPA PAG manual does
24 not provide a protective action recommendation for the
25 public when the projected dose to an individual from

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 an incident is less than one rem.

2 So, putting that all together, the staff
3 realized that we were unnecessarily limiting the
4 accident dose criteria or we were severely limiting
5 the accident dose criteria for our research reactors
6 and, indeed, also our testing facility. And they were
7 able to meet that.

8 However, not having that accident dose
9 criteria and the fact that the trend is that Part 20
10 continues to go down in dose limits, we wanted to
11 provide an accident dose criteria that was
12 specifically applicable to those non-power production
13 and utilization facilities other than testing
14 facilities, which were governed under Part 100.

15 The staff believes that that one rem
16 criteria aligns well with the PAG guidelines, being as
17 if there is no protective action guidelines
18 recommendations under one rem. And the staff has
19 determined that there is a benefit to the licensees
20 without undue risk to the public by establishing this
21 actual accident dose criteria.

22 The staff did make a small change in the
23 final rule. It was an administrative change of where
24 it was located in 50.34. Where we had put it
25 inadvertently placed it under power reactor criterion.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 And we moved it out there to be where all of the other
2 facilities would be other than power reactors. Next
3 --

4 MEMBER SUNSERI: Duane, let me ask you a
5 question. Joy, did you have a question? Did you want
6 to ask him?

7 MEMBER REMPE: It's not on this point. It
8 was actually an earlier one. But --

9 (Simultaneous speaking.)

10 MEMBER SUNSERI: Okay.

11 MEMBER REMPE: Well, I'll ask it later
12 when --

13 MEMBER SUNSERI: Okay. Go ahead.

14 MEMBER REMPE: Oh, okay. Well, since
15 we've interrupted and you're not -- I thought you had
16 a question on item 6.

17 MEMBER SUNSERI: No, no, I was --

18 MEMBER REMPE: Okay.

19 MEMBER SUNSERI: I was stopping him so,
20 because I thought you had a question.

21 MEMBER REMPE: I did. It was on 5 I
22 believe where you talked about there are a couple of
23 facilities that you left the 30-day timely renewal
24 provision in there. I've forgotten now if this was in
25 the original review when we did the letter a while

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 ago.

2 But if it's only a couple of facilities
3 and in light that it's hard for the staff to turn
4 things around in 30 days, is it wise to leave that as
5 a, to leave it in? I mean, it was a couple of
6 exceptions is what I think I heard you say. And
7 should -- the two years is really where you want to
8 go, right?

9 MR. HARDESTY: So the specific issue is
10 that the new regulation would, as it was written in
11 the proposed rule would have established a two-year
12 timeframe.

13 MEMBER REMPE: Right.

14 MR. HARDESTY: The one particular facility
15 will be within about a year of timely, needing to
16 submit their application. They won't be eligible for
17 timely renewal because it's less than two years the
18 way it was written.

19 So, basically the flow of 2.109 the way
20 it's written is, unless you're this or this or this,
21 it falls out to 30 days.

22 So we left that waterfall in so that when
23 this particular facility looks at that regulation for
24 applicability it automatically goes down to 30 days.
25 That's to protect them from being in violation of the

1 regulations when they do come for license renewal.

2 MEMBER REMPE: And no other facility will
3 ever fall into that category in the future is what I'm
4 trying to get to. It was just this one.

5 MR. HARDESTY: Correct.

6 MEMBER REMPE: And I just wanted to make
7 sure I understood that.

8 MR. HARDESTY: Yeah.

9 MEMBER REMPE: Thank you. Sorry --

10 MEMBER SUNSERI: No, no, it was a good
11 question. So they built in the transition period into
12 the regulation so that you didn't have to deal with an
13 exception afterwards or something, right?

14 MR. ADAMS: That's correct, because right
15 now, you know, when the rule would become effective
16 they would already be within two years of submitting
17 an application.

18 MEMBER SUNSERI: Right.

19 MR. ADAMS: So --

20 MEMBER SUNSERI: Thank you.

21 MR. HARDESTY: Okay. The seventh
22 objective is to extend the applicability of 10 CFR
23 50.59 to NPUFs that have had their fuel removed from
24 their site in preparation for decommissioning.

25 50.59(b) did not apply 50.59 to NPUFs

1 whose license were amended to reflect permanent
2 cessation of operations and that no longer had fuel on
3 site because these facilities have returned their fuel
4 to the Department of Energy.

5 The former language stated that 50.59
6 applied to licensees whose license has been amended to
7 allow possession of nuclear fuel but not operation of
8 the facility.

9 So what the staff had to do when we
10 reached that situation was we would essentially write
11 a license condition to give them the same 50.59
12 allowance that the regulations would normally do. So
13 this is just simply an administrative change to the
14 wording to prevent that and make 50.59 applicable to
15 all facilities regardless of their status for the
16 fuel. Next slide.

17 Objective 8 clarifies the existing
18 environmental reporting requirements. The NRC is
19 required to prepare either an environmental impact
20 statement or an environmental assessment as
21 appropriate for all licensing actions pursuant to 10
22 CFR Part 51 unless a categorical exclusion applies.

23 For most types of license, Part 51
24 specifies that an applicant must submit environmental
25 documentation in the form of an environmental report

1 or a supplement to a previously provided environmental
2 report to assist the NRC in preparing the National
3 Environmental Policy Act documentation.

4 A new section was added to 10 CFR Part 51
5 to clarify the NPUF environmental reporting
6 requirements. 51.56 clarifies that an applicant's
7 existing requirement for meeting the provisions of
8 51.45.

9 Again, the change is not a new
10 requirement. It's just for regulatory certainty we
11 wanted to provide clarity such that it was clear in
12 the new requirements that environmental report
13 submissions were required from the applicants for
14 licensing actions. Next slide.

15 And finally, the ninth objective is to
16 eliminate NPUF financial qualification information
17 requirements. Before this final rule, 50.33(f) of the
18 Code of Federal Regulations required NPUF licensees
19 that requested license renewal to submit the same
20 financial information that was required in an
21 application for an initial license.

22 In 2004, there was rulemaking where the
23 NRC discontinued financial qualification reviews for
24 power reactors at the license renewal stage except in
25 very limited circumstances. The Commission at that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 time stated that the NRC had not found a consistent
2 correlation between licensees' poor financial health
3 and poor safety performance.

4 So, if the licensee postpones inspection
5 repairs that are subject to NRC oversight, the NRC has
6 the authority to shut down the reactor and take
7 appropriate action if there is a safety issue. So
8 that's independent of any financial information or
9 qualifications.

10 So, on a similar reasoning, we determined
11 that it was valid for NPUF licensees seeking license
12 renewal to also be excluded from this NPUF, or rather
13 this financial qualification requirement.

14 At the NPUF sites, the NRC's inspection
15 enforcement programs serve as an important tool for
16 evaluating licensee performance and assuring the safe
17 operation. And the inspection program examines all
18 aspects of facility operation to ensure they're safe.

19 The NRC is similarly not aware of any
20 connection between an NPUF's financial qualifications
21 at license renewal and the safe operation of the
22 facility.

23 The NRC found that the financial
24 qualification information did not meaningfully
25 contribute to the NRC's determination for the license

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 renewal application.

2 And so the elimination of NPUF license
3 renewal financial qualification requirements is
4 recommended for, or is listed as part of the draft
5 final rule to reduce the burden associated with
6 license renewal applications while still enabling the
7 NRC to obtain the information necessary to conduct its
8 review for license renewal. Next slide.

9 MR. ADAMS: Next slide. So the staff made
10 changes in the draft rule to arrive at the final rule.
11 And that was as a result of public comments and work
12 group considerations. So this slide summarizes the
13 more significant changes.

14 So we revised the proposed definition of
15 non-power production and utilization facility to
16 exclude a production facility designed or used
17 primarily for the formation of plutonium or uranium-
18 233 or designed or used for the separation of the
19 isotopes of plutonium.

20 Based on a comment from this, we revised
21 the existing definition of non-power reactor, research
22 reactor, and testing facility to base the definitions
23 on radiological risk rather than reactor power level.
24 This is the most significant change made from the
25 proposed rule.

1 Where appropriate, we made conforming
2 changes to the terms and definitions throughout 10 CFR
3 Chapter 1 to add, correct, or standardize the
4 terminology and definitions.

5 The proposed 10 CFR 50.135 was revised so
6 that renewed licenses will be effective immediately.
7 Time for the licensee to implement the renewed license
8 would be determined on a case-by-case basis instead of
9 by rule to allow more licensee flexibility in
10 operation.

11 We also clarified the proposed 10 CFR 135
12 to maintain up to a 40-year term for renewed licenses.
13 The wording of the draft regulation inadvertently
14 could limit license terms to 30 years.

15 We also maintained the 30-day timely
16 renewal provision for facilities licensed under
17 Section 104(a) and (c) of the Atomic Energy Act that
18 still needed to undergo license renewal to be subject
19 to a non-expiring license.

20 Finally, we revised the location within 10
21 CFR 50.34 of the accident dose criterion. We realized
22 that we could place the criterion in the section of
23 50.34 that would allow greater clarity for the
24 application. Next slide.

25 So this is our final slide. This slide

1 summarizes the nine final --

2 MEMBER KIRCHNER: Al, just a minor point,
3 why did you stick with testing facility? Testing
4 facility to me is rather vague. Why didn't you call
5 it reactor testing facility or test reactor or
6 something?

7 Is there some historical legal basis for
8 that or -- I mean, testing facility, there are a lot
9 of reactor-related testing facilities that don't have
10 radioactive sources or don't use a test reactor.

11 MR. ADAMS: Yeah, no, we didn't. And,
12 indeed, you know, I completely understand what you're
13 saying, because in the past we did look at a petition
14 for rulemaking to change the terminology.

15 All I can tell you is that in the
16 regulations there was testing facility, testing
17 reactor. They call themselves test reactor. For no
18 good reason, we left it alone.

19 MEMBER KIRCHNER: Okay. That's it. Thank
20 you.

21 MEMBER REMPE: So, while you're, again,
22 interrupted. Let's talk about what you did in the
23 past when they had to submit their financial
24 qualification updates.

25 Did they -- it costs a lot to D&D a

1 facility. Did they used to say, yeah, we had this
2 money when we got it licensed and we know that prices
3 have increased, so they included the increase in
4 price?

5 MR. ADAMS: So the financial requirements
6 for decommissioning are in 50.75 and decommissioning
7 is in 50.82. Those aren't changing. Those
8 requirements aren't changing. The financial --

9 MEMBER REMPE: Oh, okay.

10 MR. ADAMS: The financial requirements
11 we're talking about is that as part of the license
12 application you would have to tell us normally for the
13 first five years of the renewed license where you were
14 getting your money from, how you were spending your
15 money.

16 MEMBER REMPE: Okay.

17 MR. ADAMS: So it was basically a pro
18 forma financial statement.

19 MEMBER REMPE: Okay. So they still have
20 to show they can --

21 MR. ADAMS: They still have to show
22 capability to fund decommissioning in accordance with
23 the regulations. And there's a requirement to keep
24 that cost estimate up-to-date.

25 MEMBER REMPE: Good. Thank you.

1 MR. ADAMS: That's not changing.

2 So this is our final slide. It summarizes
3 the nine final rule change areas of the NPUF rule
4 showing the facilities each of the changes are
5 applicable to.

6 Along with Louise, I'd like to recognize
7 the work of the working group. They put in many long
8 hours, lots of discussion and very thoughtful
9 discussion to address the comments that were made from
10 the public and also to go through the proposed rule
11 and make sure it was the best rule we can create.

12 With that, I'll turn the presentation back
13 to Bob to discuss moving forward.

14 MR. BEALL: Okay. Thank you, Al. So
15 where are we with the final rule? Currently, the
16 draft final rule is in formal concurrence. At the,
17 towards the end of February, the staff will get
18 comments from the division level and NRC management.

19 We also plan on having another public
20 meeting towards the end of February. And this public
21 meeting is to get last minute feedback on the proposed
22 implementation schedule of the draft final rule from
23 the public.

24 And we can, we will then consider those if
25 they want any changes to that and the package as it

1 goes towards the Commission. And speaking of the
2 Commission, the package is due by June of this year to
3 them. And right now we're on schedule to meet that
4 date.

5 With that, the three of us will be happy
6 to take any further questions from the Committee.

7 MEMBER SUNSERI: Members, any additional
8 questions for the group? None? All right.

9 So let's open the phone lines. And while
10 we're doing that, we'll call for any comments from the
11 audience. Members of the public in the audience,
12 please come to the podium and state your name.
13 Nobody? Oh, here comes one.

14 MR. NEWTON: I'm Tom Newton from the
15 Center for Neutron Research. I just kind of wanted to
16 reiterate my comments that I did with the subcommittee
17 a couple weeks ago, is if this rule is properly
18 implemented, the TRTR community, both the research
19 reactor community and others, feel like this is a
20 win/win. It will reduce burden for both of us without
21 having any really safety consequence.

22 MEMBER SUNSERI: Thank you. Any other
23 comments from the audience?

24 Okay. We'll turn to the phone line now.
25 Is there anybody on the phone line that would like to

1 make public comments? Please state your name and make
2 your comment.

3 Is anybody on the phone line that can hear
4 this, please just speak up because it was my
5 understanding that there was somebody that wanted to
6 make a public comment.

7 Thank you. All right. One last chance.
8 Any member of the public on the phone line that would
9 like to make a comment, please do so at this time.
10 All right. Well, that's it. We'll close the phone
11 line.

12 With no further questions, we'll turn it
13 back to you, Mr. Chairman.

14 CHAIRMAN RICCARDELLA: Okay. Thank you,
15 Matt. We have about a half an hour. And I understand
16 that we have a letter ready to meet on this topic.

17 MEMBER SUNSERI: That's correct. We have
18 a draft letter. We can --

19 CHAIRMAN RICCARDELLA: Okay. We're no
20 longer on the record.

21 (Whereupon, the above-entitled matter went
22 off the record at 11:28 a.m. and resumed at 1:02 p.m.)

23 CHAIRMAN RICCARDELLA: Okay, the meeting
24 will convene. The topic is --

25 MEMBER CORRADINI: Okay, shall we get

1 started?

2 CHAIRMAN RICCARDELLA: Yes, Mike.

3 MEMBER CORRADINI: Okay, we're in a
4 session that is going to be talking about NuScale
5 Chapter 2 and 17. This is our containing Phase 3
6 review of NuScale With Open Items.

7 And, what I'll do is I'll turn it over to
8 NRO, Dr. Chowdhury will lead us through at least the
9 first part of it.

10 And then, we have staff to support him if
11 we have detailed questions.

12 Dr. Chowdhury?

13 DR. CHOWDHURY: Yes, good afternoon. My
14 name is Prosanta Chowdhury. I'm the Project Manager
15 for Chapter 2 of the NuScale Design Certification
16 Application review.

17 I have been with the NRC about 14 years
18 and my background is, I'm in -- I have a nuclear
19 engineering degree, Master's degree, and also on -- in
20 electrical engineering.

21 Prior to joining the NRC, I worked for the
22 State of Louisiana in the radiation protection area
23 for 18 and a half years.

24 At the NRC, I joined the Project
25 Management Group in 2008, so I have been there for ten

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 years now.

2 What I plan to do today is to go over the
3 high level of findings that the staff presented at the
4 ACRS Subcommittee meeting on Chapter 2 on December 18,
5 2018.

6 And so, and then, if there are any
7 specific questions the members may have, then we have
8 the staff present in the audience to answer those
9 questions.

10 Okay, this is slide number two. On
11 December 18, 2018, the staff presented to the ACRS
12 Subcommittee Chapter 2, the following topics.

13 The topics are geography and demography,
14 which is Section 2.1 of the Standard Review Plan;
15 Nearby Industrial, Transportation and Military
16 Facilities, Section 2.2; Meteorology Section 2.3;
17 Hydrology Engineering is Section 2.4; and Geology,
18 Seismology and Geotechnical Engineering is Section 2.5
19 of the SRP.

20 I want to make a note here that the staff
21 review that was presented on December 18, 2018 was
22 based on Design Certification Application Revision 1
23 submitted by NuScale on March 15, 2018.

24 We also received later Revision 2 of the
25 Design Certification Application, but the staff,

1 because of the scheduling and timing, the staff did
2 not review that part to influence the SE. So, that
3 will come later. At this point, our focus is on
4 Revision 1.

5 Topics and conclusions for SRP Section 2.1
6 at Geography and Demography and also SRP Section 2.2,
7 Nearby Industrial, Transportation and Military
8 Facilities, COL items provided in the Design
9 Certification Application have been found to be
10 acceptable.

11 The COL Applicant referencing the NuScale
12 power plant design clarification should describe and
13 address site specific geographic and demographic
14 statistics as part of COL item 2.1-1.

15 Nearby Industrial, Transportation and
16 Military Facilities to demonstrate that the design is
17 acceptable for each potential accident or provide site
18 specific design alternatives as part of COL item 2.2-
19 1.

20 Site specific information in a COL
21 application should be bounded by the design
22 parameters.

23 MEMBER REMPE: Excuse me for a minute, I
24 missed the Subcommittee meeting. But I was curious
25 from the transcript which I read after the

1 Subcommittee meeting where the staff said they
2 evaluated six sites and only one of the six sites were
3 bounded by the site parameters that are based on the
4 EPRI users or utility requirements document.

5 Correct, that's what --

6 DR. CHOWDHURY: That's in Section 2.3 I
7 believe. And Mike Mazaika is present in the audience.

8 MEMBER CORRADINI: I think that was
9 strictly for the LPZ and EAB calculations. The staff
10 did an audit on six.

11 DR. CHOWDHURY: Yes, that's in Section
12 2.3.

13 MEMBER REMPE: Right. Okay, so I'd note
14 that in --

15 MEMBER CORRADINI: But not on these.

16 MEMBER REMPE: Okay. So, I should wait
17 until -- okay. Heads up, go ahead.

18 DR. CHOWDHURY: Okay.

19 So, now we are talking about 2.3,
20 Meteorology. And, for -- there are five subsections
21 there, 2.3.1, 2.3.2., 2.3.3, 2.3.4 and 2.3.5.

22 So, each of them climatology, 2.3.1;
23 precipitation, winds, rain, snow and ambient dry and
24 wet-bulb temperatures are generally representative of
25 a reasonable number of potential plant site locations.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 However, because design may be deployed in
2 remote locations or at sites subject to harsh weather
3 conditions, some postulative parameter values may be
4 challenged.

5 And, these were discussed in detail at the
6 Subcommittee meetings.

7 Local meteorology and onsite
8 meteorological measurements are the COL Applicant's
9 responsibility and they'll be responded or provided by
10 the COL Applicant.

11 So, would you like to bring up your
12 question at this point?

13 MEMBER REMPE: Okay, so, again, the staff
14 did an audit and only one out of six sites were found
15 to be bounded by what was in the EPRI utility
16 requirements document.

17 DR. CHOWDHURY: The staff did a
18 calculation by themselves. So, I would request Mike
19 Mazaika to come forward please to the microphone or
20 Jason White, one of them.

21 MEMBER REMPE: So, just to give the whole
22 extent of my question, Chapter 19 did their analysis
23 for the risk assessment using Surry parameters.

24 So, I'm just curious in the one out of six
25 or the six ones you did with the audit, did you

1 include Surry?

2 MR. WHITE: One moment.

3 MEMBER CORRADINI: If I just want to
4 clarify to get precisely to -- so, what the staff did
5 was on the accident releases. They chose the
6 specified NuScale short distance and then chose six
7 sites and one of the six passed at that short
8 distance.

9 MEMBER REMPE: Right. But didn't they
10 assume -- did they look -- I'm not sure what they did
11 in the audit. But did they look at the X/Qs for all
12 six sites and said, hey, only one out of six sites are
13 bounded by what's in the EPRI document?

14 MR. WHITE: Yes, that's correct.

15 MEMBER REMPE: Okay, of the six sites, did
16 you include Surry?

17 MR. WHITE: That's what I'm checking, one
18 moment, please.

19 MEMBER REMPE: And then, at some point,
20 I'd like to hear from NuScale, are there any -- we've
21 only looked at a few of the chapters and we're going
22 to see a third set of site parameters in the DCD or
23 was it just limited to Surry and the EPRI recommended
24 values?

25 MR. SHAVER: This is Mark Shaver from

1 NuScale Power.

2 MEMBER CORRADINI: You're going to have
3 speak up, please, Mark.

4 MR. SHAVER: Sorry, is this better?

5 MEMBER CORRADINI: Yes.

6 MR. SHAVER: All right. So, what NuScale
7 did was took meteorological data from airports all
8 over the U.S. and picked the value between the 80th
9 and 90th percentile, the meteorological data was the
10 80th to 90th percentile and did --

11 MEMBER REMPE: I'm having trouble hearing
12 you.

13 MEMBER CORRADINI: You're going to have to
14 speak a little more clearly and a little slower or
15 else, we can't understand you.

16 MR. SHAVER: All right. So, what NuScale
17 did to develop the X/Qs for accident doses is looked
18 at meteorological data all over the United States from
19 airports.

20 And, we took the 80th to 90th percentile
21 site which ended up being Sacramento.

22 And then, we took that meteorological data
23 to develop X/Qs for the accident scenarios.

24 MEMBER REMPE: So, is this for Chapter 2
25 what you did? Because in Chapter 2, I thought you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 attributed it to the EPRI URD.

2 But now, you're telling me you
3 independently looked at all of these sites?

4 MR. SHAVER: Yes, we independently looked
5 at sites. And this was at Chapter 2 X/Qs that were
6 used in Chapter 15 analysis.

7 And we did that because of our shorter
8 site boundary distance. We used the ARCON96 code
9 modified to do the X/Qs.

10 MEMBER REMPE: So, I'm having a little
11 trouble still hearing you, so you're tell me on
12 Chapter 2 and Chapter 15, you did your own assessment
13 and picked the 85th or something percentile values of
14 the existing sites in the U.S. today, is that what you
15 said?

16 MR. SHAVER: The meteorological data, that
17 is correct. And then, we used that meteorological
18 data in the ARCON code to develop X/Qs for our shorter
19 site boundary.

20 MEMBER REMPE: Okay. So, then, again, I'm
21 just repeating what I read in Chapter 19 in the open
22 version, it says you used Surry.

23 So, how does this 85th percentile compare
24 with Surry?

25 MR. SHAVER: I'm not sure, I haven't done

1 that comparison.

2 MEMBER DIMITRIJEVIC: Joy, as I pointed in
3 the email, the Surry data was for some of the
4 population by 2060 and also economical effects.

5 I didn't find reference to Surry data in
6 anything else in Chapter 19.

7 MEMBER REMPE: I thought they did it when
8 they actually evaluated the does to get the
9 consequences.

10 MEMBER CORRADINI: I don't -- so, two
11 things. One, NuScale, if we start getting into areas
12 that are in proprietary, you have to stop us and we'll
13 save for closed session. That's point one.

14 Point two is, I think what Vesna says is
15 correct to the extent that it's open information.

16 MEMBER REMPE: Okay, so, one --

17 MEMBER CORRADINI: What they did by the
18 number of sites, the number of sites as Matt said,
19 80th to 90th percentile and then staff came back with
20 an audit at six reactor sites and found at a short
21 distance only one out of six passed using that tool
22 and that meteorological data from those six sites.

23 So, two different totally different
24 analyses approaches.

25 MEMBER REMPE: So, I guess I'd like --

1 MEMBER DIMITRIJEVIC: But also Chapter 19
2 has the meteorological data for the tornados, you
3 know, for external events. And they're not for
4 meters, you know, they're not -- the ones I tracked
5 are not are equivalent to Chapter 2.

6 So, I'm not -- and plus, I don't remember,
7 did you look in the separate document to see does EPRI
8 document gives the all the data that they provide in
9 Chapter 2 table?

10 MEMBER REMPE: Okay, so again, I'm really
11 getting confused because they did their own
12 assessment. I did see attributes in the staff
13 documents to what NuScale did saying that it was the
14 EPRI.

15 I thought it was actually in the NuScale
16 document, too, they'd used the EPRI UFRDX. But, they
17 did not, is -- I was confused on that totally. They
18 did not ever use the EPRI document?

19 MR. WHITE: So, from the staff's
20 perspective, I'm not sure what NuScale used for their
21 calculations.

22 We did not do a direct comparison to the
23 Surry data set. We used six data sets that we had in
24 house and we did an independent calculation using the
25 ARCON96 methodology with those six meteorological data

1 sets and we compared our numbers to the numbers that
2 they provided as their site parameters.

3 MEMBER REMPE: So, I guess where I'm
4 coming from and I'm not quite sure I fully understand
5 what you're saying, Vesna. But, to me, at some point,
6 the COL Applicant has to come in and compare their
7 particular site with all the assumptions that were
8 made by NuScale.

9 And, where I'm trying to go with this is,
10 are there two sets of assumptions for -- or two
11 different type of site evaluations for parameters?

12 Or, is that list going to be very
13 convoluted to compare with for different analyses they
14 need to compare different things?

15 MR. WHITE: Well, I'm not quite sure for
16 the Chapter 19 analysis that you mentioned. But, for
17 Chapter 2, we're only comparing their results to the
18 site parameters that they provided for Chapter 2.

19 MEMBER REMPE: Okay. So, I'm not quite --
20 I had trouble hearing what you're saying. Yes, could
21 you --

22 MEMBER CORRADINI: You have to speak
23 closer to the mic.

24 MEMBER REMPE: Yes, it's --

25 MEMBER CORRADINI: It's mushy in here.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. WHITE: Okay. Sorry about that.

2 We're only looking at the site parameters
3 that they provided for Chapter 2. So, when we did our
4 independent verification, we were looking at our
5 results versus the values that they provided for
6 Chapter 2.

7 I'm not quite sure what they provided for
8 Chapter 19.

9 MEMBER REMPE: Okay. So, that's the point
10 I'm going to is that I want to know what exactly was
11 used in Chapter 19 so it's clear to everybody that the
12 -- what needs to be considered for the different
13 analyses.

14 And I guess I -- maybe this has happened
15 in other GCs where they used two different site
16 parameters type things?

17 MEMBER CORRADINI: So, if I might try, I
18 mean, I don't want to read from the SER because it is
19 a proprietary SER, but I think as the staff member
20 noted, it was essentially, and as NuScale noted, they
21 essentially used the 80th, 90th percentile from a
22 number of sites.

23 They did not consider Surry. They did not
24 consider anything in Chapter 19.

25 And staff independently had six

1 calculations at a short distance. The distance
2 matters because you change the methodology relative
3 close to buildings versus far away as the diffusion
4 and the spread of the thing.

5 So, I think that's the open item that's
6 left out there to be considered.

7 MEMBER REMPE: It is, but then, what's
8 considered for Chapter 2 may be different than Chapter
9 19 is the point I'm trying to emphasize.

10 CHAIRMAN RICCARDELLA: But in Chapter 19,
11 wouldn't the COL Applicant have to do his own PRA and
12 consider the specific --

13 MEMBER CORRADINI: Yes.

14 MEMBER REMPE: Right.

15 CHAIRMAN RICCARDELLA: -- parameters --
16 site parameters that are applicable to their site?

17 MEMBER DIMITRIJEVIC: Right, because --

18 MEMBER REMPE: But they won't ever --

19 CHAIRMAN RICCARDELLA: They just used
20 Surry as an example.

21 MEMBER REMPE: They won't ever say, well,
22 it's bounded because -- and they'll -- by what's in
23 Surry here versus what's in the 80th percentile?

24 MEMBER CORRADINI: I guess my -- again, I
25 don't want to speak for the staff, but my sense is, in

1 a sense, this is a red herring.

2 They have a calculation. The calculation
3 is an open item because, at these close distances, it
4 does not meet the EAB and the LPZ proposed.

5 So, they either have to go back and --
6 NuScale's got to go back and redo the analysis and to
7 staff's approval or change the distance and show that
8 at some distance you then meet the site parameters.

9 But, I think that's it. I don't think
10 looking at Chapter 19 at this point is going to
11 benefit us at all.

12 MEMBER REMPE: I just, again, I'll
13 probably bring it up again in Chapter 19 space, but it
14 seems like there's different assumptions used for
15 different places. And I just am wondering about that.
16 Okay?

17 CHAIRMAN RICCARDELLA: But we reviewed the
18 PRA a few months ago.

19 MEMBER REMPE: Preliminary review, yes.

20 CHAIRMAN RICCARDELLA: Preliminary review.
21 It was the preliminary PRA but it was just an example
22 of -- it wasn't in the PRA.

23 MEMBER DIMITRIJEVIC: Well, the PRA, like
24 everything else, has to be conforming the qualified,
25 you know, phase and all the assumptions on the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 locations and the thing will have to be confirmed.

2 I don't see any contradiction actually, at
3 least what I checked with what you're saying. Because
4 the only problem will be if you have a contradictory
5 assumption which are important from my point.

6 But since they all were used in -- and I
7 didn't see this other Surry application. So, the
8 Surry data, it was used in some but is not used in
9 Chapter 2.

10 Well, my point is, I don't think we need
11 to be concerned because all of those assumptions still
12 have to be confirmed in the qualified.

13 MEMBER REMPE: I agree with you that
14 they'll have to be confirmed, but I don't -- I'm
15 trying to emphasize the point, there's two different
16 sets of assumptions is all I'm trying to emphasize.

17 MEMBER DIMITRIJEVIC: But they --

18 MEMBER REMPE: And I was curious, are
19 there going to be a third set? I mean, how many
20 different site parameters -- or do they pick for
21 different chapters is where I'm kind of going.

22 MEMBER CORRADINI: Again, I'll just
23 repeat, I think, to focus just on Chapter 2, staff has
24 left it an open item in terms of the source term
25 itself and the methodology used for short distances.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 And, until NuScale comes back and confirms
2 that they've sorted out the methodology or show that
3 they meet the method -- they use the methodology as
4 stated at a longer distance, it remains an open item.

5 MEMBER REMPE: Okay.

6 MEMBER CORRADINI: I think -- I'm looking
7 at you -- I think I've said it --

8 MR. WHITE: Yes, that's accurate.

9 MEMBER REMPE: Okay.

10 MEMBER CORRADINI: Okay.

11 MEMBER REMPE: Thank you.

12 DR. CHOWDHURY: So, the open item, I'm on
13 slide number five.

14 On slide five, we mention just talked
15 about the open item, it's Open Item 02.03.04-1. And,
16 again, we are currently evaluating X/Qs in meteorology
17 to determine if the methodology is acceptable for
18 calculating design assess and offsite X/Q values in
19 parameters at EAB and LPZ in relation to NuScale
20 design or a COL Applicant reference in the NuScale
21 design.

22 The staff found that the Applicant
23 provided onsite X/Qs site parameters values at the
24 main control room and technical support center doors
25 and heating, ventilation, air conditioning intake that

1 were representative of a reasonable number of sites
2 that may be considered for a COL Application.

3 As for the long-term accident dispersion
4 estimates for routine releases that found that the
5 long-term routine release site parameter values
6 selected by that Applicant are representative of a
7 number of -- a reasonable number of sites that have
8 been already considered for a COL Application.

9 MEMBER KIRCHNER: So, I was asking my
10 colleagues, maybe it was before my time on the
11 Committee, are you going to then come before us with
12 this accident source term methodology review?

13 DR. CHOWDHURY: Will that be presented?

14 MEMBER KIRCHNER: Yes.

15 DR. CHOWDHURY: Yes, it will be.

16 MEMBER KIRCHNER: Okay, thank you.

17 MEMBER CORRADINI: So, and again, just so
18 I have it clear, there's two things that sit in the
19 open item. One is the methodology for EAB and LPZ and
20 the source term that is yet to be --

21 DR. CHOWDHURY: Right.

22 MEMBER CORRADINI: -- the final? Okay.

23 DR. CHOWDHURY: That's correct.

24 MEMBER CORRADINI: All right.

25 DR. CHOWDHURY: And that's the topical

1 report.

2 MEMBER CORRADINI: Thank you.

3 DR. CHOWDHURY: Hydrology Section 2.4 in
4 all areas of hydrology, the Applicant provided
5 adequate site parameters as well as COL items 2.0-1
6 and 2.4-1.

7 So, essentially, a COL Applicant
8 referencing the NuScale Power Plant Design
9 Certification should provide information sufficient to
10 demonstrate that the actual site characteristics
11 described in this application falls within the range
12 of site parameter values consistent with the
13 stipulation in COL items 2.0-1 and 2.4-1.

14 And the staff finds this, including the
15 stipulations in COL items acceptable for 2.4.

16 Section 2.5, Geology, Seismology,
17 Geotechnical Engineering, again, in all areas of this
18 topic, the Applicant provided adequate information
19 including COL item 2.5-1 that specifically belongs to
20 that section.

21 And also referenced COL items for Section
22 3.7 and 3.8. So, those COL items, 3.7-3, 3.7-5 and
23 3.8-6, 3.7-8 that -- and specified that a COL
24 Applicant referencing the NuScale Design Certification
25 should provide the information sufficient to

1 demonstrate that the actual site characteristics falls
2 within the range of site parameter values.

3 The staff finds the Applicant's
4 information, including stipulations in all those COL
5 items acceptable.

6 And, I think staff made some -- Weijun,
7 you are here, right, in the audience?

8 Okay. So, the -- since we presented at
9 the Subcommittee meeting some change -- some
10 corrections are made in this -- on those drafts or
11 some consistency, right?

12 Okay, would you please come forward and
13 explain what the changes were?

14 MEMBER CORRADINI: Your comments only get
15 on the record if you come forward.

16 MR. WANG: Okay, Weijun Wang.

17 MEMBER CORRADINI: And you have to speak
18 right in to that mic, otherwise, we can't hear you,
19 I'm sorry.

20 MR. WANG: Okay. I'm Weijun Wang,
21 Geotechnical Engineer in the NRO. I am the reviewer
22 of the NuScale Section 2.5 with other of my
23 colleagues.

24 Okay, this chart here, it's a little bit
25 different from what we presented at the Subcommittee

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 because the figure on the left, that one, because here
2 we said we present the chart for the -- so far the
3 design seismic response spectrum for the horizontal
4 plot.

5 And in Subcommittee presentation,
6 actually, we presented on the left one, it was
7 vertical components.

8 So, now the -- on the left one, it's
9 correct. It's horizontal components certified the
10 design seismic response spectrum. That's the only
11 difference.

12 CHAIRMAN RICCARDELLA: It's horizontal in
13 both the right -- in the left and the right now?

14 MR. WANG: Right. The -- in the design,
15 it had provided both horizontal and vertical, the
16 components.

17 And, as an example, we only provide
18 horizontal. The only different is the anchor, the
19 acceleration, it's like in the horizontal one, it was
20 .4g and the vertical was .5g. That's the major
21 difference here.

22 CHAIRMAN RICCARDELLA: Okay, thank you.

23 DR. CHOWDHURY: Okay, that's all the --

24 MEMBER CORRADINI: Do you want to move on
25 now to NuScale?

1 So, for the Committee, there were
2 questions in the Subcommittee about ODI, so I think
3 NuScale's presentation is going to try to specifically
4 address some of our questions.

5 MR. INFANGER: Good afternoon, I'm Paul
6 Infanger. I'm Regulatory Affairs at NuScale.

7 My background is a Master's degree in
8 nuclear engineering and I've been in licensing for 35
9 years, 25 years at the operating fleet, about 10 years
10 in new reactors and the last 4 years, I've been at
11 NuScale.

12 Next to me is the lead presenter is Neil
13 Olivier, he'll give a little background.

14 MR. OLIVIER: Yes, my name is Neil
15 Olivier. I'm the Corporate Services Director at
16 NuScale.

17 My background is mainly in operations
18 previous to NuScale. I've got licenses on Limerick
19 Generating Station in Columbia and I worked at San
20 Onofre before that. And I was in the Navy before
21 that.

22 And, if you want me to go ahead, I can
23 start presenting.

24 So, I was asked to come today to give a
25 background and an overview of NuScale's ODI program.

1 So, our ODI program is mandated from the quality
2 assurance -- NuScale's quality assurance program is
3 based on NQA-1.

4 Specifically, Requirement 3, Section 500,
5 it allows for the deferral of design verification
6 activities provided that we identify and control those
7 items.

8 Those ODIs are a form of engineering
9 assumptions that are controlled --

10 MEMBER RAY: Wait, let's stop here --

11 MR. OLIVIER: Okay.

12 MEMBER RAY: -- for a bit.

13 What it's based on, of course, this is the
14 boiler and pressure vessel code and there are a lot of
15 things not covered by the boiler and pressure vessel
16 code. But that's a minor point.

17 The inspection report which is a public
18 document, so I won't refer to the SER, is, as you
19 know, uses Appendix B as its criterion. It
20 acknowledges the source of requirements.

21 But criterion 3 and 16 are basically the
22 same as in boiler and pressure vessel code as it is in
23 Appendix B. And Appendix B is, I think, the thing we
24 should use as our reference here, particularly when
25 we're talking about design certification.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Now, the inspection report says that
2 there's a NuScale -- they refer to a memo, but let's
3 just call it a procedure and policy that identified
4 ODI's necessary for closure prior to support the DCA
5 submittal.

6 And there were ODIs not necessary to be
7 closed prior to the DCA submittal.

8 So, there's a distinction that I believe
9 NuScale has between the things that are required to
10 support DCA submittal and those that can be deferred.

11 And, the issue that we want to, I think,
12 get clarity around is the NRC inspection report also
13 refers to sufficient closure of ODIs to allow a 52.50
14 -- a reasonableness finding to be made.

15 And it's in that domain that we want to
16 get clarity.

17 So, the issue of deferral isn't a
18 question, the question is, what do we do -- what do we
19 need in order to support the design certification and
20 what do we do to identify those things which we don't
21 need for design certification but which are needed to
22 support operability perhaps well down the road. How
23 is that distinction made from NuScale's point of view?

24 MR. OLIVIER: So, the memo you speak of,
25 the ODIs that we classified as not -- we had to close

1 them for DCA which are all closed. Those address
2 content analysis or results of conclusions or an
3 engineering deliverable is needed for DCA.

4 So, the ones that are open are categorized
5 in the latter category that don't need to be closed
6 for DCA.

7 So, I don't know how to word it any other
8 way than that.

9 MEMBER RAY: Well, at the time of the
10 inspection, there were 173 closed that were considered
11 necessary to close and 1,500 that were open.

12 MR. OLIVIER: There were 1,500 open, they
13 looked at 173 in detail and did not find any
14 conclusion or nonconformances in the inspection.

15 MEMBER RAY: I think we're mixing up two
16 things here. Let me just read from the inspection
17 report.

18 NuScale identified 173 ODIs that required
19 closure, blah, blah, blah. The NRC inspection team
20 reviewed 170 from the list of 1,563.

21 But, at the time, they recorded, they can
22 be wrong, of course, but that there were 173 that were
23 identified as needing to be closed and they were
24 closed, as you said.

25 MR. OLIVIER: That's correct. That

1 happened before the --

2 MEMBER RAY: So, how's the distinction
3 made because we have to make a similar distinction.
4 We have to come to some conclusion.

5 MR. OLIVIER: Right, and I was going to go
6 into that as far as the interactions between the NRC
7 and NuScale and they've done various chapter audits.
8 They did the QA inspection. I believe there's another
9 Q&A inspection scheduled.

10 They've reviewed them in RAIs. They've
11 reviewed thousands of documents and yet to tell us
12 that there's an ODI that needed to be closed prior for
13 DCA. It's just we have closed the ones necessary for
14 the DCA.

15 The ones open, and I can provide examples
16 and give you some statistics on what's open now. I
17 don't think anybody's --

18 MEMBER RAY: Well, I think we're trying to
19 get what the criteria are both you guys and, of
20 course, we'll talk to the staff as well, for what it
21 is that needs to be closed.

22 Now, to an extent, what needs to be closed
23 is a function of how visible the ODIs are. So, for
24 example, if you have ITAAC that covers, and I'm not
25 suggesting that's the right solution, but if you have

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 ITAAC that cover ODIs then that's a very visible
2 mechanism for handling those things that are not
3 closed, but what you relied upon in the design
4 certification.

5 MR. OLIVIER: I agree.

6 MEMBER RAY: That's the way we look at it
7 anyway.

8 And we're trying to understand that.
9 There isn't any explanation that we can find. ITAAC,
10 of course, are a perfectly logical and ordinary way to
11 cover things that are not capable of being resolved at
12 the time of certification.

13 And, how many of these 1,500 ODIs, if any,
14 would be subject to having ITAAC established?

15 Well, that depends, in my personal
16 individual judgment, on how visible the tracking of
17 the ODIs is.

18 There's references here to the ODIs
19 existing at different levels in the design
20 documentation.

21 Now, I think you're going to be able to
22 tell us that you have very solid tracking system for
23 the ODIs that exist and it's that that is going to be
24 important in what you say here, so please, emphasize
25 it.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER BLEY: I'd like to add something to
2 Harold's question. One thing to know what the ODIs
3 are and track them as they close, it's another if they
4 affect other aspects of the design or anything in the
5 DCD such as the PRA. And how are you tracking that as
6 well?

7 You know, if you change one of these
8 assumptions you haven't yet settled on, it could
9 affect many other things.

10 MR. OLIVIER: Agreed. The configuration
11 management system is what we're relying to make sure
12 that the impact analysis is accurate when we change
13 something. There's no -- I couldn't tell you that a
14 specific item does or does not affect something
15 without doing an impact analysis which is part of the
16 design verification and design control.

17 The design control system is set up as
18 required by NQA-1 to do that impact analysis to ensure
19 that all changes are -- all impacts are assessed.

20 MEMBER CORRADINI: So, can I take an
21 example? So, let's say, for example, I'll pick this
22 as an example, that you want to have a CVCS pump of
23 some output and you assume so many GPM under normal
24 operation and under accident for injection purposes.

25 And instead of what you assumed you'd find

1 by the manufacturer that you eventually have it
2 procured from that it's 10 percent less.

3 Explain to me how that then is promulgated
4 through the whatever you call the checking program to
5 make sure that doesn't have an impact either in a
6 Chapter 15 analysis or in a PRA analysis? Can you
7 help me there?

8 MR. OLIVIER: Yes, so the --

9 MEMBER CORRADINI: Is that a good example?

10 MR. OLIVIER: It is. It is and I have a
11 few examples with me, but we can use your example.

12 MEMBER CORRADINI: Okay, that's fine. If
13 you've got an example --

14 MR. OLIVIER: Well, it's the same -- those
15 are -- it's very similar to what I have --

16 MEMBER CORRADINI: Oh, okay.

17 MR. OLIVIER: -- in that it's weight
18 versus a flow.

19 It's that our design control program is
20 managed in a way, whether it's in ODI or it's a
21 change, say we wanted to change the flow, we would
22 then do an impact analysis against all documents that
23 are related to that function.

24 So, if it's the design description, it's
25 the engineering calc that did the flow and through our

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 -- I will call it a reference, but a link inside CMIA,
2 our system, configuration management information
3 system, it will tell me what other impacts there are.

4 The engineer then does the impact analysis
5 and it should inform upon every other document that
6 needs to be changed and every impact from there, it
7 would chain tell us whether the DCA is affected in any
8 fashion.

9 And then, that would drive a change, if
10 needed, we would inform the NRC.

11 MEMBER CORRADINI: Okay. So now, I'm
12 going to pick up to be another member who doesn't
13 trust computers.

14 Have you done a check so that you actually
15 invent an ODI that had a significant change and wanted
16 to look for and you expect to an effect over there and
17 you double check that you do see those effects?

18 That the configuration control management
19 system actually says when I change the pump flow or
20 the weight or something, I expect to see a big effect
21 over here and, ergo, I do see the effect? Do you know
22 what I'm asking?

23 MR. OLIVIER: Yes, and I don't think we've
24 done --

25 MEMBER CORRADINI: I want to make sure the

1 software program actually captures --

2 MR. OLIVIER: So, the software program
3 only lists the impacted documents, the engineer --

4 MEMBER CORRADINI: And the engineer will
5 check it?

6 MR. OLIVIER: -- is required to check
7 every single line item.

8 MEMBER CORRADINI: Okay, okay.

9 MEMBER RAY: Yes, they say very clearly
10 that the design control process, and it's a design
11 change --

12 MEMBER CORRADINI: Okay.

13 MEMBER RAY: -- would be or choose --

14 MR. OLIVIER: Yes, we can -- we use the
15 same exact process for an ODI. If an ODI changes,
16 it's entered and the change control process is treated
17 like any other change.

18 MEMBER CORRADINI: Okay, thank you, I got
19 it.

20 MEMBER RAY: But, again, what's -- what
21 we're struggling with is the idea that certain things
22 are needed to get the design certification and other
23 things are not and how is that distinction made,
24 particularly given that the -- everything you read
25 here is very explicit. I'd give you citations, but

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 some of them are not where I want to go in terms of
2 documentation.

3 But, in any event, this only applies to
4 the certification process, this, by that I mean, the
5 QA program or the -- it's emphasized that we're only
6 looking at a program and you're, I know, describing
7 program controls of open design items.

8 The program only applies through design
9 certification. How, unless we are sure, and this is
10 the bottom line for me, that we've listed and
11 identified the ODIs that need to be controlled, how do
12 we know that, yes, they're going to get handled after
13 design certification?

14 MR. OLIVIER: So, in our database and I
15 reviewed it and I've reread it multiple times, there's
16 a 1,098 that are explicitly listed. Every one of
17 them's been reviewed and the justification has been
18 reviewed by engineering and another engineer to verify
19 that the justification is sound. That's for the open
20 design item.

21 They've also been reviewed to make sure
22 that we didn't need to have them closed before we
23 submitted the DCA.

24 The -- every one that I've reviewed is
25 confirmatory in nature. And I've got listed and I can

1 give you some statistics if you'd like them.

2 MEMBER RAY: But, would you accept the
3 idea that the design certification itself needs to say
4 that these items need to be closed in accordance with
5 a program that complies with Appendix B or that your
6 topical report, whatever you want?

7 I mean, does that make sense? I think
8 that's your intent, isn't it?

9 MR. OLIVIER: It's in our -- I can't speak
10 to that what's in -- Tom, maybe you can speak to it,
11 but --

12 MEMBER RAY: Yes, we're just looking for
13 some way to make sure that four years down the road,
14 in a situation in which the program you're talking
15 about now may not apply. There's no obligation to use
16 it, these things are going to get closed.

17 MR. BERGMAN: So, Tom Bergman, Vice
18 President, Regulatory Affairs, NuScale.

19 It isn't necessary to put things that will
20 be required later in the DCA. So, the -- what we're
21 seeking approval of is the design that's in the DCA,
22 not a perspective design down the road.

23 So, it's strange, but by rule, we can
24 terminate our QA program the day we're certified. And
25 then, when COL comes in that uses our information,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 everything has to be back under Appendix B the day the
2 application is submitted.

3 And then, once that COL is issued, it
4 stops again for us, not for the licensee at that
5 point.

6 As a practical matter, you don't do that,
7 right? Because, especially in our case where you've
8 got a COL coming in right on our heels.

9 But, by rule, we're not seeking approval
10 of what the COL will submit, it's have we made the
11 case that we've, with reasonable assurance, met the
12 NRC's regulations with the application as it's
13 submitted.

14 I get the interest in control --

15 MEMBER RAY: Well, let me stop you right
16 there, because respond to this. The Agency certifies
17 a design and information has been relied upon which
18 includes, I won't say a lot, but includes a fair
19 number of unverified design assumptions.

20 Shouldn't those be part of the
21 certification? I mean, you, yourself, don't want at
22 least some of the ODIs to remain open at the time of
23 certification. There's a bunch that you've said,
24 these need to be closed. What about the others?

25 And, if they are left open, what is

1 exactly our assurance that, although we relied on
2 them, we relied on those assumptions and you can't
3 say, well, no, no, you didn't because of whatever
4 reason. I don't know what it would be.

5 But, let's just say we rely on all of
6 those assumptions and unverified design inputs, how do
7 we then gain the confidence necessary that, in fact,
8 they're going to be resolved and if there are any
9 changes, I don't have any doubt that it'll be -- the
10 changes will be processed under your change procedure.

11 But, it's the idea and I could cite to you
12 here comments about how the ODIs exist at various
13 levels in documents and so on. You can't go look at
14 the documents. You've got to work off of some set of
15 identified ODIs to ever find them later when
16 operability of the system's required.

17 Help us understand which ones you think
18 need to be closed? Which ones can remain open? And
19 how we can be certain that they will be closed?

20 Because we rely on all of them, not just
21 the ones you think need to be closed.

22 MR. BERGMAN: And I'll need Neil to
23 correct me if I misstate, but most of the ones are
24 left open because the information simply doesn't
25 exist. Right?

1 So --

2 MEMBER RAY: That's what ITAAC do very
3 explicitly.

4 MR. BERGMAN: No, ITAAC -- well, most of
5 these ODIs are not touched by ITAAC.

6 MEMBER RAY: I know that, I'm not
7 proposing ITAAC, I'm just telling you that that's what
8 ITAAC were established to do in a design certification
9 was to make sure, and I can read the definition to you
10 here if you'd like me to, to make sure that the things
11 that could not be verified at the time of
12 certification would be verified before operability.

13 That's what it is. The inspection test,
14 analysis and, you know --

15 MR. BERGMAN: I have a different view of
16 ITAAC.

17 MEMBER RAY: Acceptance criteria.

18 MR. BERGMAN: Which are to confirm that
19 the design that is built conforms to the design that
20 was proposed, both in the DC and as modified in the
21 COL and is ultimately modified during construction.

22 So, I think the CVCS example is very
23 clear, but that, as you said, would be visible in the
24 DCA.

25 But, to use an example, and again, I'll

1 look to Neil for the details, but a component weight
2 is going to be an assumption today because we don't
3 have procured component.

4 That component weight is going to still be
5 an open item at the COL because they still haven't
6 procured a component.

7 During construction, they'll procure the
8 component. If the weight, depending on how you
9 characterize the open item, sometimes it can be above
10 than or less than or you just said, you know, 6,000
11 pounds.

12 If it comes in, whether it's 5,500 pounds
13 or it's 6,500 pounds, that's a change that goes
14 through the change control process.

15 If that change doesn't affect the FSAR,
16 the NRC would only verify it through inspection. They
17 rely on the design control process to make sure the
18 design changes, if we've changed an assumption, the
19 design changes have been properly controlled.

20 If it does affect the FSAR, of course, you
21 know, it goes 50.59 and then you have to evaluate, is
22 it a departure and during licensing or after
23 licensing? Is it a 50.59 licensing change?

24 MEMBER RAY: Truly, we do know. We --

25 MR. BERGMAN: Right.

1 MEMBER RAY: -- we've done all of this
2 ourselves. The problem -- some of us, many times --
3 but the issue that's still unanswered here is, we've
4 got this large number of items, some of them may be --

5 MR. BERGMAN: I disagree it's large.

6 MEMBER RAY: -- the table of the weight of
7 a pump that's assumed to be something and it turns out
8 to be something greater, for example. Yes, I totally
9 understand that.

10 But it could be something much different
11 from that as well. There are, I mean, again, I can go
12 through and give examples here, but I don't want to
13 take the time to do it, you know them better than I
14 do, of things that are assumptions relative to system
15 performance.

16 They're identified -- we just want to be
17 sure that they are tracked to closure whenever that
18 happens.

19 One way to do it, and the way that's
20 established and accepted so far and one of the
21 certifications that we've done and plants that are
22 under construction today, are ITAAC.

23 But I'm not suggesting that here, I just
24 want to get to the point where we say we're confident
25 that the ODI are identified, they will be attached in

1 some way to the design certification and they will be
2 tracked to closure whenever that happens.

3 MR. BERGMAN: I do not believe that's ever
4 been done for any certified design by the Agency.

5 MEMBER CORRADINI: So, what's been done?

6 MEMBER RAY: No, I agree with you because
7 people would go back and look at the weight of a pump
8 and say, this is more than was assumed in the design
9 and they would go through 50.59. Absolutely right.

10 The point is, you identify that as an open
11 design item. There are others as well that may be
12 much more significant and subtle than the weight of a
13 pump.

14 MEMBER CORRADINI: But that's --

15 MR. BERGMAN: But that's what --

16 MEMBER CORRADINI: Can I -- hold --
17 because we're running out of -- I hate to be the time
18 watcher, but I'm watching the time. I want to make
19 sure I get the staff up here on Chapter 17.

20 What I think the back and forth is, is
21 that we're trying to find a way that we get confidence
22 in what appears to be a much more sophisticated way of
23 tracking things than we've seen before in other
24 certified designs. That's my impression.

25 I won't pick other certified designs, but

1 I don't suspect that these things were watched as
2 these are being watched.

3 MR. BERGMAN: I actually agree. I think
4 the only reason this became an issue was because we
5 were the first Applicant to actually compile the list.

6 MEMBER CORRADINI: I didn't say that, but
7 that's the sense that I get, too.

8 MR. BERGMAN: Yes, but the rest of them
9 simply relied on their NQA-1 compliant program to
10 bring it to closure.

11 MEMBER RAY: I don't want to be -- suggest
12 any criticism here of the process.

13 MR. BERGMAN: Sure.

14 MEMBER RAY: We're just trying to marry it
15 up with design certification. So, understand that.

16 But let me tell you, as somebody who's
17 been through this, like I said, for a long, long time,
18 if you come in with a component that differs from what
19 was in the design that was presented and approved,
20 whether it's the CP or OL or whatever, by the NRC, you
21 identified that.

22 You don't need an ODI to say check the
23 weight versus what was assumed in the design. What
24 was assumed in the design is in the design and you can
25 compare it and check it yourself. You don't go and

1 have to, I think, but your system is great.

2 But we're trying to identify, like I said,
3 where ODIs get -- have the potential to get buried and
4 make sure that they aren't.

5 First of all, that all the ones that
6 should be dealt with in order to certify the design
7 have been closed. That's number one.

8 And, number two, that given that there are
9 many assumptions and they aren't just the weight of a
10 pump out there, that years down the road, they get
11 picked up and closed. They may be esoteric
12 assumptions that were made.

13 And that's the whole point.

14 MEMBER CORRADINI: You get the last word
15 because I think we've got to get back to the
16 presentation.

17 MR. BERGMAN: I will. And so, that's what
18 Neil tried to explain is for items that, quote, are
19 significant enough to be in the DCA that's been part
20 of the NRC's review. It was part of the inspection.
21 The licensing audits which have been at least several
22 thousand documents now, all of those contain
23 assumptions, not all, many of those contain
24 assumptions.

25 The staff considers those at the time. If

1 they believed an assumption needed to be in the FSAR,
2 they would raise it at that time either through an RAI
3 or just a question in the assumption, not every
4 question in the audit, excuse me, gets an RAI.

5 So, that process is very thorough. And
6 so, that screening's been done. There are, and again,
7 I've let Neil give you the stats, most of these are
8 minor in the nonsafety related areas or they're things
9 you simply can't validate like component weights.

10 MEMBER CORRADINI: So, at this point, I'm
11 going to say, Neil, you're back up.

12 MR. OLIVIER: All right, thank you.

13 I will move expeditiously. Most of this
14 stuff, we've already covered.

15 So, ODIs are resolved and verified via the
16 design verification process. We've already gone over
17 this. They're ideally per NQA-1, they're to be closed
18 out prior to procurement manufacture, construction or
19 by use for another design organization with a
20 different QA program.

21 But, in all cases, that design
22 verification is required to be done prior to relying
23 on the component to perform its function.

24 Moving on to slide four, the interactions
25 that we've had with the NRC regarding ODIs, we've

1 already talked about the 2017 inspection. We've had
2 numerous communications with the staff, numerous
3 chapter audits where thousands of documents were
4 reviewed and ODI questions were asked and subsequently
5 answered along with RAIs. And I couldn't give you a
6 solid number, but it's -- there's thousands of
7 documents that were reviewed.

8 The highlights from the inspection, they
9 reviewed 170 specific ODIs. So, we gave them the list
10 and at the time, it was 1,500. It's currently 1,098
11 -- correction, 93, excuse me, 1,093 that are open.

12 They had no concerns about no
13 nonconformances or violations. They did note we had
14 a conservatively low threshold for opening ODIs. And
15 I bring that up as part of what Tom said.

16 Some examples, we talked about weight, but
17 300 I classify and have binned them, my staff did, 317
18 of those 1,093 that are open are specific to mass to
19 a cabinet.

20 MEMBER CORRADINI: Can you repeat that
21 again?

22 MR. OLIVIER: So, 317 of those ODIs that
23 are currently open are due to mass of a component.
24 That's a third of them, basically.

25 We have another 114 that are due to the

1 secondary plant. One of them that I've used an empale
2 before is tower selection, what type of tower are you
3 going to use.

4 And different -- I've worked at three
5 plants, one didn't have a tower, San Onofre was a
6 single passthrough.

7 Depending on the site location, depending
8 on the environment, you have a different tower, things
9 like that.

10 The size of the containment or the -- not
11 the containment, the tower intake, depending on what
12 type of tower you pick, what have different sites,
13 those are the many assumptions, 115 of those that are
14 around the secondary plant. They are open items that
15 need to be confirmed later on down when we have that
16 information.

17 And then, there's 45 that are specific to
18 the layout and they're basically open items to ensure
19 that we get proper isometric drawings done in the
20 detailed design, nothing more than that.

21 MEMBER RAY: Okay, let me add to your
22 highlights some highlights that I'll provide from the
23 same report.

24 MR. OLIVIER: Okay.

25 MEMBER RAY: The NRC inspection team also

1 reviewed a small section -- a small sample of design
2 supporting documentation for the DCA.

3 The inspection team identified an example
4 where inaccurate information was present in a topical
5 report at the time of submittal, specifically, the
6 cover page to the calculation made a statement that a
7 value was obtained by analysis when it was an assumed
8 value identified as an ODI.

9 Now that's not a problem in that it was
10 identified as an ODI, just not in the report that was
11 being submitted. Which, again, we're looking at this
12 from the standpoint of what our role is here.

13 NuScale documented the issue in correction
14 action report.

15 The NRC inspection team identified an
16 example where an assumption was not identified as an
17 ODI by NuScale, specifically, the fuel pool heat load.

18 Specifically, NuScale made the assumption
19 to neglect the main reactor coolant pump pool heat
20 input, excuse me, into the spent fuel pool heat load.

21 The DCA supporting documentation, NuScale
22 identified that this is an assumption that should be
23 verified which is an ODI by NuScale definition.

24 Now, this was two years ago. Nobody
25 expects perfection, that's not the point. But these

1 are two specific examples of where the system went
2 awry.

3 Elsewhere, there was a reference, and I
4 guess this gets to the bottom line for me again is,
5 are these things being captured in a way that's
6 visible at a high level? All of them, regardless of
7 where they may be buried on the back page of some
8 report or otherwise.

9 Or do you have to go looking for them with
10 an audit?

11 MR. OLIVIER: No, sir. And, I can answer
12 that.

13 MEMBER RAY: And you're going to, I know,
14 but --

15 MR. OLIVIER: Well, there's not much. And
16 to your specific question, they are in a specific ODI
17 database. I can search for them, I can look at them
18 and I can tabulate them and you can search for data by
19 ODI number, by their type, by their parameter, whether
20 system.

21 MEMBER RAY: As you and I both know,
22 having done it, the verification of the fact that ODIs
23 are getting associated with other things, again, never
24 going to be perfect but it is a key part of it as well
25 as the visibility which, as they say in this topical

1 report, the visibility didn't exist in the front of a
2 report -- a topical report that's being issued.

3 So, having an inventory that enables and
4 facilitates going back and saying, wait a minute,
5 here's one that we didn't capture because it wasn't
6 obvious or whatever to the verifying responsible
7 engineer is a part of what we're looking at.

8 Again, the main thing for us is the
9 certification process, what's in, what's out and the
10 things that don't get closed at certification. Are we
11 sure they're going to be? That's the issue.

12 MR. OLIVIER: Yes, and they're visible and
13 tied to the source document that they came from.

14 MEMBER CORRADINI: Please go ahead.

15 MR. OLIVIER: And, there's not much more.

16 The conclusion is that, in the concluding
17 slide that NuScale's ODI process properly controls
18 unverified engineering assumptions in accordance with
19 NQA-1 and that the NRC has reviewed the ODI process in
20 various ways including the inspection, detailed
21 inspection, chapter audits and RAIs.

22 That's the end of the presentation.

23 MEMBER CORRADINI: So, let me ask a
24 question as an observer of the conversation.

25 So, once the DCA is, assuming, becomes the

1 DCD and we're all squared away, these pass on to the
2 owner/operator and will have this list to check as
3 construction is going on?

4 MR. OLIVIER: Absolutely, it's part of the
5 design.

6 MEMBER CORRADINI: And they have to
7 develop their own program of -- or do they follow this
8 NQA procedure in the COL phase?

9 MR. OLIVIER: Hypothetically, that group,
10 whoever does the COL --

11 MEMBER CORRADINI: They have to decide?

12 MR. OLIVIER: -- they have to, using NQA-
13 1, their engineering assumptions by different whatever
14 name, they need to be verified so they will be
15 transferred with the design to that group.

16 MEMBER CORRADINI: And there's no other
17 instrument from your perspective that's necessary
18 other than that?

19 MR. OLIVIER: Absolutely.

20 MEMBER CORRADINI: Okay.

21 And, let me ask another way, let me try a
22 different approach.

23 I can't -- for want of a better term, I
24 can't come up with a -- is -- are there levels of
25 importance of these ODIs so that you actually have 10

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 or 20 that you watch because they're such large
2 sections that have such a large impact?

3 How do you know which are more or less
4 important than others? We used weight and pump
5 capacity, but I could come up with some past
6 certifications that didn't turn out to be so mundane.

7 MR. OLIVIER: The ODIs are owned by the
8 document and the engineer who authored the document.
9 They keep track of what they -- as an overall process,
10 they're responsible for closing out those ODIs. They
11 know which ones are important, which ones need to be
12 closed out.

13 Other than that, I don't keep a top 10
14 list, if that's what you're asking.

15 MEMBER CORRADINI: That's kind of what I
16 was asking.

17 MR. OLIVIER: I don't personally because
18 I run the program, but they do, the engineers know
19 which ones -- they own them, that's the program puts
20 the ownership on the engineer.

21 MEMBER CORRADINI: Okay, so any more
22 questions for NuScale before we drag the staff up here
23 and get after them?

24 Okay, thank you.

25 Omid, are you the lead here?

1 MR. TABATABAI: Yes, I am.

2 MEMBER CORRADINI: You have so many, I'm
3 not sure.

4 MR. TABATABAI: Good to see you, too.

5 MEMBER CORRADINI: You're on.

6 MR. TABATABAI: All right, good afternoon,
7 everyone. Thank you very much for giving us this
8 opportunity to present to you the staff's review of
9 Chapter 17 of NuScale Design Certification
10 Application.

11 My name is Omid Tabatabai, I'm the Senior
12 Project Manager in the Office of New Reactors and I
13 have the responsibility for Chapter 17.

14 With me today, we have Alissa Neuhausen
15 and Andrea Keim. They will be presenting reliability
16 assurance portion and also QA portion.

17 And also, Ian Jung is here and he will be
18 supporting us with reliability assurance portion of
19 the meeting.

20 Just on the agenda for the staff today, I
21 just wanted to go over the staff's review. Under
22 quality assurance, Member Ray, you had some questions
23 for the staff during the Subcommittee. And, although
24 NuScale went through the ODI process extensively, but
25 we wanted to be responsive to those questions. And we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 will touch on the questions that you asked during the
2 Subcommittee presentation.

3 MEMBER RAY: Thank you.

4 MR. TABATABAI: Just to mention the names
5 of the staff who reviewed this Chapter 17, these are
6 our key reviewers for Chapter 17.

7 Quickly, I will give you a high level
8 overview of Chapter 17 SER that the staff has
9 prepared. Our SER is based on Revision 1 to the DCA.

10 The latest revision that we have in house
11 is Revision 2. But, by the time that we were going
12 through the process of concurring or and approving the
13 SER, we had Revision 1.

14 The SER has two open items and no
15 confirmatory item. One open item is related to
16 quality assurance and one open is related to
17 reliability assurance section.

18 During the review, the staff performed two
19 audits and one inspection that we have already touched
20 on.

21 Again, during the December 18
22 Subcommittee, we provided some information on the SER.
23 It has not changed, we don't have any update except to
24 touch on ODI process from the staff's perspective
25 again.

1 This concludes my introduction and, with
2 that, I will turn the presentation to Andrea.

3 MS. KEIM: Hi, I'm Andrea Keim, I work in
4 the Vendor Inspection Quality Assurance Branch of NRO,
5 which is New Reactors.

6 I have a Bachelor's degree in material
7 science and engineering and I also have a Master's
8 degree.

9 The Quality Assurance Branch, we currently
10 have two branches and these branches perform routine
11 and reactive vendor inspections.

12 We also conduct QA implementation
13 inspections for the new operating reactors -- for the
14 new reactors, sorry.

15 We also perform QA licensing reviews for
16 Part 50 and 52, where we review the QA programs and we
17 also do the initial test program.

18 So, with that, I'm going to discuss
19 Section 17.5 of the NuScale Design Certification
20 Application.

21 So, the first thing we're going to talk
22 about is the regulatory basis which the first one is
23 Appendix A, GDC 1 which requires quality standards be
24 applied to the structure systems and components
25 important to safety, that these shall be designed,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 fabricated, directed and tested to quality standards
2 commensurate with the importance of the safety
3 function to be performed.

4 The next requirement is that they -- is
5 Appendix B which is 10 CFR Part 50 which is our
6 quality assurance requirements and it addresses the 18
7 criteria.

8 52.47 address the contents of an
9 application which includes that they -- that the
10 application must include the quality assurance
11 program.

12 And, the description of the quality
13 assurance program for the nuclear power plant shall
14 include a discussion of how they meet the requirements
15 of Appendix B.

16 MEMBER RAY: Okay, let's stop there then.
17 What we're talking about is issuing a certification
18 for a design that has what we're now calling open
19 design items.

20 How do you reconcile that with what's on
21 the screen here? And, also that the quality assurance
22 program that is approved, excuse me, the quality
23 assurance programs that's applicable ends as NuScale
24 just reaffirmed at the time of design certification?

25 The bottom line is, what provision should

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 be made for things that are not yet done but are
2 assumed in the certification? Because that's what
3 we're talking about.

4 MS. KEIM: But that's going to be like a
5 hold point until you get your COL Applicant in.

6 MEMBER RAY: No, I'm asking about the --
7 just read the words. It doesn't talk about a hold
8 point. A certification is issued and the provisions
9 for certification require, as you have pointed out,
10 that you have a QA program that applies to everything
11 that's in the certification.

12 You've got assumptions here. The
13 assumptions are unverified. How should they be
14 identified at the time of certification consistent
15 with this requirement up here?

16 The way that we've done before, I won't
17 name names, but plants that include those being built
18 are you have design acceptance criteria. You have
19 ITAAC that are associated with things that can't yet
20 be done to use the heavy pump example, you don't
21 identify those because that's a deviation from the
22 approved design that you then have to process when it
23 occurs.

24 You don't identify everything that might
25 someday have a deviation. But those things that you

1 have assumed that aren't verified, how are they
2 supposed to be identified?

3 You've taken credit for something that's
4 an only a design assumption that doesn't comply with
5 Criterion 3 of Appendix B or the equivalent in NQA-1
6 or the topical report or where ever.

7 But the point is, you've taken credit for
8 it, it isn't yet verified and nobody's trying to say
9 it has to be. Although, strangely, there are some
10 that have to be, as pointed out in the inspection
11 report in order to reach a reasonable assurance
12 determination.

13 We're trying to figure out how these
14 things are identified that remain at the time of
15 certification. And I don't think we should call
16 certification a hold point.

17 MS. KEIM: Technical reviewers have gone
18 through their process of reviewing their chapters and
19 they do audits and do RAIs and they come to a
20 conclusion of reasonable assurance.

21 MEMBER RAY: Well, NuScale has a system in
22 which they've at least identified which ODIs need to
23 be closed. Do we concur in that determination or is
24 it only a result of the inspections that are -- the
25 reviewers work that's -- that you referred to?

1 Have we looked at the ODIs to say, gee,
2 this one should be closed? NuScale fell short here or
3 made a mistake or something. This is a verification
4 that should occur.

5 I'm going to ask you -- we'll get to her
6 in a minute.

7 MS. KEIM: That's my boss.

8 MEMBER RAY: Okay, go ahead.

9 MS. KAVANAGH: Hi, my name's Kerri --

10 MEMBER RAY: Sorry.

11 MS. KAVANAGH: That's okay. I'm Kerri
12 Kavanagh, I'm the Chief of the Quality Assurance
13 Vendor Inspection Branch.

14 Quality assurance does not require a 100
15 percent inspection and verification. The goal of a
16 design cert is reasonable assurance.

17 We assure that they're implementing their
18 QA program at specific times when the tech staff goes
19 out and they do audits, if there are already concerns,
20 they report back and we will continue evaluating
21 whether or not we need to perform more quality
22 assurance inspections to verify that the QA program is
23 implemented while the design is under certification
24 review.

25 MS. KEIM: So, let me --

1 MEMBER RAY: You know, but wait a minute.
2 I'm sorry, Joy, we're not -- I'm trying not to talk
3 about what you do. I'm trying -- which is very fun --
4 good job, I like the inspection report. It was very
5 helpful.

6 What I'm trying to do is understand the
7 certification process which you provide input to, I
8 know.

9 MS. KAVANAGH: Yes.

10 MEMBER RAY: But we are trying to look at
11 this from the standpoint of the things that have been
12 taken credit for that are important to certification
13 but which have not been verified.

14 How is that done? You make an important
15 contribution to that. But another way of saying it
16 is, well, we've looked at the open design items and
17 we're good with those that remain to be closed later.

18 MS. KARAS: This is Becky Karas. I'm the
19 Branch Chief for the Reactor Systems Branch. I was
20 also supporting the 2017 inspection that's been
21 referred to.

22 And my staff does look at some of the ODIs
23 when there are calculations that they're looking at
24 for the audits.

25 So, we have had circumstances where we've

1 been looking at a calculation through an audit process
2 that is something that's supporting the conclusions
3 and the results that are in the DCD.

4 And, in those cases, my staff engages in
5 a discussion with NuScale. They also sort of
6 independently look at that. And these are usually
7 things that are like engineering assumptions and
8 that's how we've seen it for other designers that
9 there'll be things that are listed as, you know,
10 assumptions or conservative assumptions in the
11 calculations.

12 If we look at that and it makes sense to
13 us that that's a conservative assumption that's very
14 clear, then that may end it. Also, if it's something
15 that doesn't matter, there's no sensitivity and we
16 know that, that may end it.

17 But in some cases, we have gone back to
18 the Applicant and we've said, you know, you've got an
19 open design issue, you've got an assumption for this
20 certain parameter. And it's not apparent to us that
21 that would be obviously conservative. We need the
22 calculations supporting that that shows that that's,
23 you know, the right value.

24 And then, you know, either they have it
25 because, in some cases, they have that later

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 calculation that's already been done but the paperwork
2 for closing the ODI or the updated Rev to that first
3 calculation might not be completed.

4 But we engage in those discussions with
5 them. We may submit an RAI if we need to to make sure
6 that that value is calculated.

7 I've got some specific examples where
8 we've done that.

9 MEMBER RAY: Well, let me interrupt you
10 before you get too far. And I think you should please
11 continue.

12 But the -- in the very beginning of what
13 you said, you said in our audit process. And, I've
14 done a lot of audits and I do understand auditing. It
15 is not review, it's not what we do.

16 If -- what's different between an audit
17 where you do what you've just described, and please
18 continue when I'm done with my spiel.

19 What's different between an audit which
20 surfaces something and you send an RAI and you ask for
21 more information and you're not satisfied with it or
22 whatever, and what we're talking about or what we're
23 trying to talk about is, you should have or the
24 certification should contain an identification of all
25 the ODIs so you don't pick it up in an audit.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MS. KARAS: So, let me explain how we're
2 conducting the review then maybe from a basic
3 perspective.

4 So, let's say there's a calculation in
5 Chapter 15, right, the key assumptions will be listed.
6 The output results will be listed. It won't
7 necessarily -- it won't indicate there that there's an
8 ODI or anything. Right?

9 MEMBER RAY: Exactly.

10 MS. KARAS: But we don't, you know, look
11 solely at what's written in the DCD, right? There's
12 always a calculation supporting that, so we open
13 audits for the chapters.

14 And, you know, those key calculations we
15 then audit in that supporting documentation, it will
16 indicate if there's an ODI or not.

17 And sometimes that could be with a value
18 or an assumption that isn't important enough to rise
19 to the list that's listed in the DCD. We can then
20 either, you know, request that they place that in the
21 DCD, we can -- we will ask for the basis behind that.

22 So, there have been instances where we've
23 done that.

24 MEMBER RAY: Okay, but again, we're
25 talking about an audit process and I'm trying to -- if

1 I could, because of time, I just want to ask staff to
2 please stick with the idea that we're trying to
3 distinguish between discovering something in an audit
4 that isn't satisfying and getting it corrected as
5 opposed to having an identified list of assumptions
6 that we rely upon implicitly whether we happen to pick
7 it up in an audit or don't in the design
8 certification.

9 That's what we're trying to talk about.
10 So, terrific auditing job, you know, I don't have any
11 criticism or question about it. I know that that goes
12 very well.

13 But still, when you've got over a 1,000
14 currently of open ODIs, the changes of picking up
15 something and take the difference between the weight
16 of a pump and the heat input to the spent fuel pool
17 from the -- those are two quite different issues.

18 And one can be identified when the plant
19 is being built that the plant -- the pump weight is
20 different than what was in the design. The absence of
21 consideration of the heat input to the overall
22 performance in an accident is not going to be picked
23 up during construction. It's not a 50.59 item.

24 And so, help us get to the point where we
25 can understand, you know, we're just relying upon the

1 down stream post certification QA programs, whoever's
2 implementing them, to pick these things up and deal
3 with them because there's a list kept somewhere that
4 isn't part of the certification.

5 It sounds to me like that's the case.

6 MEMBER BLEY: Harold, let me try
7 something.

8 MEMBER RAY: Okay, I'm sorry to go on and
9 on.

10 MEMBER BLEY: I know and I think I
11 understand where you're coming from.

12 We have, in other cases, other plants,
13 other design certs, but actually in operating plants,
14 too, found situations where the design assumptions
15 were wrong and it was never checked.

16 Now, I kind of think, listening to all
17 I've heard today, that what NuScale has done is the
18 first step in what we're looking for.

19 These ODIs, everybody has them, but they
20 don't make a list of them. They've tried to make a
21 list, we haven't seen -- at least I haven't seen the
22 list, I don't know how thorough it is.

23 MEMBER RAY: It's a big list.

24 MEMBER BLEY: But, it's a big list, but
25 it's not big compared to the -- everything that's in

1 the plant.

2 But what they haven't done, they told us,
3 is set priorities on that. Some of these design
4 assumptions have a very minor effect on overall
5 safety. Some go right to the heart of being able to
6 remove heat, being able to contain fission products,
7 whatever.

8 If there were some structure to look for
9 which of these have the greatest impact, could have
10 the greatest impact on safety, you'd want to have a
11 top ten list. You want to look at these more
12 thoroughly and try to make sure you met all of those
13 estimations.

14 MEMBER RAY: Well, NuScale --

15 MEMBER BLEY: Now, NuScale --

16 MEMBER RAY: NuScale did do that for the
17 -- in their judgment for the design --

18 MEMBER BLEY: Well, no, they've got a big
19 list and they said they haven't put any priorities on
20 them.

21 MEMBER RAY: But they did close 173.

22 MEMBER BLEY: They did, for design cert.

23 MEMBER RAY: That's right.

24 MEMBER BLEY: But there's a whole bunch
25 more that we don't know exactly how they decided which

1 ones to close for design cert and we don't know how
2 you -- yes, what all the others are on the list.

3 But there are, certainly, are ways to put
4 them in priority that would help us avoid the problem
5 we've seen in the past. And I think that's what --
6 we're started on the road that way with just having
7 this, which is --

8 MEMBER RAY: And I don't want to diminish
9 the auditing process or the inspection process.

10 MEMBER BLEY: Oh no.

11 MEMBER RAY: I mean, they're very good,
12 very good processes, but that's not what we deal with
13 in certification. We need to know what the
14 assumptions are.

15 Okay, enough. Thank you.

16 MEMBER CORRADINI: Please continue.

17 MR. TABATABAI: We're on slide seven now.

18 MS. KEIM: So, slide seven talks about our
19 topical report review. The NuScale Quality Assurance
20 Topical Report Review was completed separate from the
21 design application process. It followed a topical
22 report process.

23 The topical report was reviewed to ensure
24 that the preliminary work on the application was done
25 in accordance with Appendix B to 10 CFR Part 50

1 requirements.

2 The staff used the standard review plan,
3 NUREG-0800, Section 17.5 which is for safety analysis
4 reports as the guidance.

5 And the Applicant QA topical report
6 submittal was in accordance with our Reg Guides and
7 with the standard review plan and it met the
8 requirements of NQA-1 2008 and 2009 addenda.

9 So, we found the topical report acceptable
10 and it met the requirements of Appendix B.

11 Slide eight?

12 MEMBER RAY: The only thing I'd say there
13 is, Appendix B doesn't say anything about, and I don't
14 think the topical report does, either, about things
15 that are covered by ITAAC, for example.

16 So, there's no issue over unresolved or
17 unresolvable items. We've to a system to deal with
18 that.

19 What we're talking about here is a system
20 that isn't included within those things that are
21 covered by ITAAC. There's a really nice explanation
22 of why they -- why ITAAC exists, what it's supposed to
23 do and so on and so forth.

24 It's really not part of QA because it's
25 something that's built in to the certification and, if

1 you take credit for the ITAAC, the QA program is
2 satisfied.

3 The issue is, we're taking credit for ODI
4 that we don't know what they are. And does that
5 satisfy the QA Appendix B requirements for design
6 certification?

7 It's, you know, I'm trying to use
8 something that illustrates what it is we're talking
9 about. It's well-establish that you can satisfy
10 Appendix B and have unresolved design items that are
11 reflected in ITAAC.

12 The question is, can you satisfy Appendix
13 B and have unresolved items that are in the hands of
14 the responsible design engineers.

15 MEMBER BLEY: Mike had to step away for a
16 minute.

17 MEMBER RAY: Yes, I --

18 MEMBER BLEY: But we're within just a few
19 minutes of our ending time and you aren't quite there
20 yet. So, I think if you can go ahead, it would be a
21 good thing.

22 MS. KEIM: Yes.

23 MEMBER RAY: I've created too much
24 turmoil, I'm sorry.

25 MS. KEIM: So, the staff's review of the

1 design certification application Section 17.5 was done
2 to -- it references the appropriate quality assurance
3 topical report and the staff has assigned an open item
4 to address the quality assurance implementation
5 inspection.

6 We've done a preliminary one or an initial
7 one and we plan to go out and do a second inspection.
8 The next slide talks about our completed inspection.

9 We went out in June 5th through the 9th of
10 2017. We were in the Corvallis, Oregon location. The
11 staff used Inspection Procedure 35017 which is the
12 quality assurance implementation inspection procedure.

13 There were no findings of significance
14 were identified, yet, there were some issues to look
15 into.

16 The QA inspection report is available on
17 our public site. And, as noted in the SER for the
18 Design Certification Application, we will have an open
19 item to perform a follow up inspection which has been
20 scheduled for the end of February.

21 The announcement letter went out and it
22 was dated January 27th, so we are planning to be there
23 on February 25th through March 1st.

24 So then, we did try and address these
25 questions that were brought up at the Subcommittee

1 meeting.

2 So, how does the NEC staff ensure all open
3 design items are sufficiently closed by the time of
4 the Design Certification Application as approved?

5 So, I don't know if you're still going to
6 -- how these answers are going to meet your needs, but
7 the technical reviewers use audits and the RAIs during
8 the review process to obtain sufficient information to
9 make a reasonable assurance determination for the
10 assigned review areas.

11 Any ODI that prevents the reviewer from
12 making a reasonable assurance determination will need
13 to be closed prior to the approval of the Design
14 Certification Application. So, they would have been
15 assigned an open item.

16 The NRC performed an initial quality
17 assurance inspection that reviewed the ODI tracking
18 and closure process and there were no findings of
19 significance identified.

20 So, the second question, what does
21 sufficiently closed mean?

22 The response that we came up with it,
23 sufficiently closed means the technical staff are able
24 to make a reasonable assurance determination.

25 So, for the third question, what --

1 MEMBER RAY: And, in doing that, are they
2 aware of the open ODIs that they may be relying upon?

3 MS. KEIM: Yes.

4 MEMBER RAY: They are?

5 MS. KEIM: Yes.

6 MEMBER CORRADINI: So, can I say it
7 another way, just so we're on the same page?

8 MS. KEIM: Okay.

9 MEMBER CORRADINI: There's an engineering
10 calc. In the engineering calc, you guys are reviewing
11 or auditing. It's listed that I have assumed A, B, C,
12 D, and E in this. And then, staff is deciding, well,
13 A, C, C, D, and E don't matter or it's conservative or
14 something.

15 It's listed in the engineering calc?

16 MR. TABATABAI: That was actually the
17 specific example --

18 MEMBER CORRADINI: That's why -- I just
19 wanted to make sure I'm on the same page.

20 MR. TABATABAI: Yes.

21 MEMBER CORRADINI: Okay.

22 MS. KEIM: So now, we're on question
23 three.

24 What if unverified assumptions changed
25 after the DCA is approved? For instance, unverified

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 assumptions that are used in the PRA model?

2 So, the response here, I didn't address
3 the specific PRA model question, but for the main
4 question, NRC's Regulatory Information Summary 2010-05
5 discusses the applicability of 10 CFR Part 21.

6 And these requirements are applicable for
7 standard design certifications. And the RIS clarifies
8 that the regulatory requirements of Section 206 of the
9 Energy Reorganization Act are applicable through the
10 entire regulatory life of a standard design
11 certification.

12 So, the NRC considers the regulatory life
13 as the period of time which the standard design
14 certification needs to meet the regulations in effect.
15 And this period is when an application is docketed,
16 and ends when the termination or expiration date of
17 the standard design certification or the termination
18 or expiration of the last license directly or
19 indirectly referencing the standard.

20 Therefore, the vendor in this case,
21 NuScale, would evaluate the defect or failure to
22 comply in accordance with their procedures.

23 The NuScale procedure addresses discovery
24 of the issue, the evaluation, and notification.

25 The NuScale Part 21 program is also

1 reviewed during the NRC staff inspections as in the
2 one in June and it will -- the one in February of
3 2018.

4 And, for the final question, it wasn't
5 really a question, it was making a statement that we
6 need to clarify with NuScale that they've run a RIS
7 with these open items.

8 MEMBER BALLINGER: So, let me try to
9 simplify what I'm hearing. Item number one, an
10 engineer or somebody goes and looks at an ODI and
11 lists the assumptions. And, if they're satisfied with
12 the assumptions or they're conservative or something,
13 they say, okay, we're fine.

14 If they don't, then it becomes an open
15 item.

16 MS. KEIM: Yes.

17 MEMBER BALLINGER: Right? Right? It
18 becomes and open item.

19 MEMBER RAY: No, actually, you have to be
20 more than satisfied.

21 MEMBER BALLINGER: Okay, well, let --

22 MEMBER RAY: You have to meet Criterion 3
23 of Appendix B, period.

24 MEMBER BALLINGER: Right, okay. So, let's
25 -- you're more exact than I am, right?

1 So, what if unverified assumptions change
2 after the DCA is approved? If the DCA is approved,
3 there's no open items. Or can there be open items?

4 MEMBER RAY: That's what we're talking
5 about is, how do we know what the open items are that
6 we relied upon in the design certification and which
7 continue to exist?

8 MEMBER CORRADINI: Don't get confused with
9 the open items and ODIs. Are you -- I assume you're
10 not confused.

11 MEMBER BALLINGER: An open item is
12 generated if they can't verify the assumptions or the
13 staff is not satisfied.

14 MEMBER CORRADINI: Or they'll ask an RAI
15 or require --

16 MEMBER BALLINGER: Or yes, something like
17 that.

18 MEMBER RAY: An open design item, just as
19 a --

20 MEMBER BALLINGER: Right, but all the open
21 items have to be cleared.

22 MEMBER RAY: Open design items.

23 MEMBER CORRADINI: There is a difference,
24 there's a difference.

25 MEMBER BALLINGER: I know there's a

1 difference, but I'm saying open items.

2 MEMBER RAY: Well, open items are a
3 different subject.

4 MEMBER BLEY: Open items in the SER
5 supporting the design cert.

6 MEMBER BALLINGER: yes.

7 MEMBER BLEY: All those open items must be
8 closed.

9 MEMBER BALLINGER: Right.

10 MEMBER BLEY: The open ODIs don't all have
11 to be closed, that's what --

12 MEMBER BALLINGER: Okay, that's what
13 you're saying, because I'm reading that, if there's an
14 ODI that generates an open item --

15 MEMBER BLEY: It has to be closed.

16 MEMBER BALLINGER: -- it has to be closed.

17 MEMBER BLEY: Yes. That's -- sure.

18 MEMBER BALLINGER: So, that's what I'm
19 understanding.

20 MEMBER RAY: But that's --

21 MEMBER BALLINGER: No, where I'm going is,
22 when you get through this, you're finished. If the
23 DCA is issued, all open items, open items, have been
24 closed. And, those open items may have been generated
25 by ODIs --

1 MEMBER BLEY: Or other --

2 MEMBER BALLINGER: -- or other.

3 MEMBER RAY: Mostly other things.

4 MEMBER CORRADINI: But, I think staff's
5 point is, as I understand it, to summarize because, a,
6 have run out of time; and, b, they still have another
7 part of the presentation to talk about, is that they,
8 by accommodation of their review, inspections, and
9 audits, have satisfied themselves that they have
10 captured the important ones that they require to be
11 closed ODIs.

12 They require to be closed so the design
13 certification can go forward. That's my impression of
14 their statement.

15 MR. TABATABAI: That's correct. I mean,
16 they have 15 -- I mean, last -- two years ago, when
17 the staff did an inspection, there were about 1,500
18 ODIs, but that doesn't mean the staff's SER would
19 include 1,500 open items.

20 No, open items are a very, very, very
21 small subset of ODIs. Not all ODIs are required to be
22 -- there's no regulation -- the NRC staff has no
23 regulatory requirements to demand all of the ODIs be
24 closed by the time of DCA approval. There's no
25 regulations in place.

1 The staff reviews what comes in the
2 application, which is defined by the Code of Federal
3 -- what the Applicant needs to provide and that's what
4 the staff reviews based on all of the guidance
5 documents, DRP or DSRs and things like that.

6 And so, for -- and if they are not happy
7 with the level of information or clarity of the
8 information in the application, the staff uses RAIs,
9 audits, and confirmatory analysis to make sure that
10 those open items or ODIs that have an impact of the
11 finding, reasonable assurance finding, those are
12 closed. So, that item is closed.

13 MEMBER RAY: Wait a minute, I got to jump
14 in here and say, they don't -- the staff doesn't
15 review all ODIs.

16 MR. TABATABAI: That's what I was --

17 MEMBER RAY: As you just --

18 MR. TABATABAI: -- about to say.

19 MEMBER RAY: -- heard explained.

20 MR. TABATABAI: Okay.

21 MEMBER RAY: They review what they're
22 reviewing when they have issues that come up that are
23 associated with ODIs, it's conceivable it'll generate
24 and open item. But, it'd be very rare.

25 The issue is, the two things are just --

1 the words sound similar, but they're very, very
2 different. And you shouldn't assume that all ODIs get
3 reviewed as part of the design certification.

4 MEMBER BALLINGER: That was the point I
5 was missing.

6 MEMBER CORRADINI: Sam?

7 MR. LEE: Yes, this is Sam Lee from NRO
8 Licensing Branch 1.

9 I think the last exchanges there, I think
10 those reflect a clearer understanding. If I could
11 just step back a little bit to provide a perspective.

12 And, I'm going to say something that might
13 actually raise your eyebrows, but I'm going to qualify
14 it, so allow me to expand on what I'm about to say.

15 Open design item is not within the scope
16 of the staff's review of the DCA application package.

17 Again, I'll say, it's not within the scope
18 of the design review of the staff's review of the
19 design application package.

20 The way we came across ODI, as you know,
21 we -- as part of the design application package, we
22 have the FSAR, the topical reports that's a report
23 that come to you for review, as well as supporting
24 technical reports.

25 So, we have a plethora of associated

1 reports to review as part of the DCA.

2 And, one of those is a topical report on
3 quality assurance program development, QAPD. And, as
4 Kerri was saying earlier, in the midst of performing
5 a review of QAPD, and as part of a follow up action to
6 do a QA inspection, we came across NuScale's program
7 called open design item program.

8 And when we came across it, the name
9 itself is kind of altering enough, right, the open
10 design items. And it is associated with our notion of
11 open items.

12 So, obviously, we were very curious and we
13 made a separate inspection effort to look into that.

14 And what we found was that the level of
15 detail of what's covered in the ODI really is below
16 the scope of the staff's review. Right? It's not
17 even in our radar.

18 As I said, I'm going to qualify what I'm
19 about to say or what I just did say.

20 And so, the more we looked into that, the
21 more we realized that these don't rise to the level of
22 the open items that you and I -- that we've been
23 talking about.

24 And, but however, as part of the review
25 process, through the RAI exchange and getting the RAI

1 responses, at times, the staff has had to conduct
2 audits, regulatory audits.

3 And we look at the information in more
4 detail, information that's, in the cases, it's not
5 docketed. And sometimes, we would come across
6 questions that would be directly at the related --
7 particular related ODI.

8 And if that ODI needs to be addressed and
9 closed in order to satisfy, as the staff's need to
10 make a disposition, a regulatory disposition, we would
11 pursue that and make sure that that is closed.

12 Whether that's pursued as an RAI or an
13 open item, it remains to be seen. And I'm not sure if
14 there's any open item that we have in any of our
15 chapters today that was born out of an ODI, per se.
16 But, it could be, it could be.

17 And so, I just wanted to state up front
18 that we don't approach ODI as a program to reviewed.
19 We encounter them on a case by case basis as our
20 review directed to ODI, if needed.

21 MEMBER RAY: Well, let me say that, from
22 just reading the introduction to Part 50, every
23 Applicant for a design certification under Part 52 is
24 required to include the description of the quality
25 assurance program applied to the design and blah,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 blah, blah.

2 The point is, this is something, here in
3 this case, you said these are trivial items. An
4 assumption was made according to the inspection report
5 to neglect main reactor coolant pool heat input to the
6 spent fuel pool heat load.

7 That's the kind of thing that we do look
8 at and it's not necessarily trivial. It wasn't even
9 identified with an ODI until the inspection occurred.
10 So, good things come out of inspections, don't get me
11 wrong.

12 And, NuScale does track these ODIs. The
13 issue before us is, should they be identified as
14 existing at the time of design certification? Whether
15 it's itsy-bitsy things, and we're only talking about
16 stuff that's covered by Chapter 15, by the way, not
17 things that are in the balance of plant or whatever,
18 that's not anything that we're concerned about in the
19 certification.

20 It's only those things that pertain to the
21 certification.

22 If you were able to tell us that ODIs that
23 are identified and not resolved and that are
24 important, any of them would be identified as open
25 item, like Ron had assumed, great. That basically

1 would answer our question.

2 But we're looking for something less than
3 that, which is just that, in the process, we are
4 assured the ODIs that exist at the time of
5 certification are identified, that's all we're looking
6 for.

7 And, you know, I would Chair the AP1000
8 Subcommittee, we went through and identified things
9 that couldn't or hadn't been resolved and we made up
10 ITAAC.

11 And, sometimes, they'd fail the damn thing
12 and we had to go through a pretty difficult process
13 after the Amendment 6 was issued.

14 So, it isn't something that is just a lot
15 of trivia, necessarily.

16 MR. LEE: This is Sam Lee, again.

17 For the record, I didn't refer to ODI as
18 being trivial. So, but, I understand what you're
19 saying.

20 I think, as I hear you, I'm thinking about
21 the process that we have in place. And I have to
22 trust the process. And the process allows for the
23 staff to be able to conduct its review in the manner
24 that the Part 52 requires.

25 It talks about, essentially, complete

1 design, not complete design. It talks about
2 reasonable assurance finding, not complete assurance
3 finding.

4 And, I think the, again, if we are
5 trusting the process and conducting the review per our
6 process, I don't know that we are doing this review in
7 any less rigorous way than what we did for AP1000, per
8 se.

9 And so, we have to trust the process to be
10 able to arrive at a regulatory finding that we must
11 make. And, in the course of doing so, if we run into
12 an ODI that speaks to a particular question that the
13 staff has, we would pursue that. And I think we have.

14 MEMBER RAY: Is there any reason why --

15 MR. LEE: And, I think we have several
16 examples that we have and I'll turn the mic over to
17 Becky.

18 MS. KARAS: I can -- this is Becky Karas,
19 again. I can give you a couple of examples of -- or
20 if you ask a lot of questions about them, I'll have to
21 get Tim to come up here.

22 And these are only a few examples of
23 places where we have pursued issues.

24 There was one case in the return to power
25 recriticality calculation where they had an assumed

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 power peaking factor. And it was stated that it was,
2 you know, that was an assumed value based on
3 engineering judgment.

4 When we audited that, we couldn't
5 immediately come to the conclusion that that was
6 clearly conservative. So, we raised that with
7 NuScale.

8 They performed the calculation that would
9 determine that peaking factor and it did confirm that
10 it was conservative.

11 We audited that calculation as well and
12 they closed the ODI.

13 We also had a case where the subchannel
14 analysis, they had a value listed for the input P-rise
15 engineering uncertainty factor that was incorporated
16 into that analysis in the topical report.

17 And, later, they did verify that analysis
18 to be conservative and closed the ODI.

19 So, those are a couple of examples. You
20 know, there are certainly, I think, some, you know,
21 isolated circumstances like by the inspection that we
22 noted like with the pool heat load, I think, you know,
23 any inspection can uncover those things.

24 I was there for that inspection, that was
25 one that had been failed to be identified as an ODI

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 when the ODI process was more in its infancy within
2 NuScale. And, they have since that time, put in more
3 controls to capture things like that. So --

4 MEMBER CORRADINI: I'm sorry, Becky.

5 MS. KARAS: Yes.

6 MEMBER CORRADINI: Were you finished?

7 MS. KARAS: Yes, sorry.

8 MEMBER CORRADINI: Okay, so, I'm going to
9 do a time check. We're about 15 minutes over. I
10 think we've had enough interchange for the moment.

11 I think you have more to talk about
12 relative to the second part, which is the RAP or the
13 D-RAP.

14 MR. TABATABAI: That's correct.

15 MEMBER CORRADINI: So, can we get to that?

16 MR. TABATABAI: Sure.

17 CHAIRMAN RICCARDELLA: Are we still going
18 to have a closed portion of the meeting?

19 MEMBER CORRADINI: I don't think we're
20 going to have a closed portion unless we need to in
21 the D-RAP.

22 CHAIRMAN RICCARDELLA: In the what?

23 MEMBER CORRADINI: Unless we need to in
24 the D-RAP portion, we're not going to have a closed
25 portion.

1 CHAIRMAN RICCARDELLA: All right.

2 MEMBER CORRADINI: So, why don't you keep
3 on going?

4 MS. NEUHAUSEN: Okay, good afternoon. My
5 name is Alissa Neuhausen. I'm covering Section 17.4
6 on the reliability assurance program.

7 MEMBER CORRADINI: Closer to your mic.

8 MS. NEUHAUSEN: Closer -- move it closer
9 to me.

10 So, for the reliability assurance program,
11 staff's review was performed in accordance with SRP
12 Section 17.4, Revision 1.

13 The Applicant's -- sorry, the staff
14 reviewed the program description and implementation
15 programmatic controls SEC selection methodology expert
16 panel member requirements and the determination of
17 risk significant SSEs.

18 The first stage of the RAP is the design
19 reliability assurance program which encompasses the
20 reliability assurance activities that occur before
21 initial fuel load which includes the DC and COL
22 phases.

23 The second stage comprises the reliability
24 assurance activities conducted during the operations
25 phase.

1 The DC review is the subject of today's
2 presentation.

3 Specifically, staff found that the D-RAP
4 list was developed in accordance with its RAP
5 methodology.

6 NuScale adequately implemented the expert
7 panel in developing the D-RAP list and the D-RAP list
8 is comprehensive.

9 The three COL items, respectively, for
10 integrating RAP into operational programs, QA controls
11 during site specific design, procurement, fabrication,
12 construction, and pre-operational testing activities,
13 and the identification of site specific SSEs provide
14 an appropriate level of assurance that a COL Applicant
15 referencing the NuScale design will implement an
16 adequate reliability assurance program.

17 And then, the last item, the inclusion of
18 the D-RAP ITAAC is currently the only open item in
19 Section 17.4.

20 I do want to correct this slide, it should
21 be open item 17.4-1 to be consistent with the SER.

22 And then, SECY -- there's been no change
23 since the Subcommittee meeting SECY-18-0093 is still
24 with the Commission.

25 The staff recommended that the Commission

1 discontinue the use of the D-RAP ITAAC and the staff
2 is waiting -- still waiting for the response.

3 MEMBER CORRADINI: Question by the
4 Members?

5 Okay, so, with that, I think we asked you
6 enough questions for the moment.

7 I'll turn it back to -- oh, I'm sorry,
8 excuse me, we have to get public comments. My
9 apologies.

10 So, are there people in the audience, if
11 we can open the outside line, please?

12 Anybody that has a comment may come to the
13 podium. Hearing none, can we go to the outside line?

14 Can somebody on the phone at least verify
15 that you can -- we can hear you?

16 Anybody on the outside line?

17 PARTICIPANT: We can hear you.

18 MEMBER CORRADINI: Okay. So, anybody that
19 wants to make a comment, please go ahead. Hearing
20 nothing, we will close the outside line and I'll turn
21 it back -- well, before I do that, let me see, do I
22 have any more members that want to make comments?

23 MEMBER RAY: I interrupted Joy at one
24 point.

25 MEMBER REMPE: I was -- Dennis made my

1 comment about prioritization and that's what I was
2 trying to get in.

3 At some point, I interrupted the gentleman
4 who was trying to ask -- answer my question, was Surry
5 one of the six that he evaluated? And I'd like to
6 know that before we get to Chapter 19, just for my own
7 future perspective.

8 MEMBER CORRADINI: Okay.

9 MEMBER REMPE: And I -- it doesn't have to
10 be today.

11 MEMBER CORRADINI: Can we take it as an
12 action item?

13 MEMBER REMPE: Yes, please.

14 MEMBER CORRADINI: Okay, good.

15 So, I'll turn it back to the Chairman.
16 Mr. Chairman, it's all yours.

17 CHAIRMAN RICCARDELLA: Okay, so, we're
18 about 15 minutes over, so we're going to delay the
19 start of the next session by 15 minutes. So, we'll be
20 back here at 3:00 p.m.

21 MEMBER MARCH-LEUBA: Yes, the next session
22 is going to be closed, so we'll need to start doing
23 the set up during the break.

24 CHAIRMAN RICCARDELLA: Oh.

25 MEMBER MARCH-LEUBA: And, do the --

1 CHAIRMAN RICCARDELLA: Okay.

2 MEMBER MARCH-LEUBA: Only the NuScale
3 people are not invited for the next session.

4 (Whereupon, the above-entitled matter went
5 off the record at 2:47 p.m.)

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25



ACRS Full Committee

Draft Commission Paper (and related draft regulatory guide)

*“Technology-Inclusive, Risk-Informed,
Performance-Based Approach to Inform the
Licensing Basis and Content of Applications for
Licenses, Certifications, and Approvals for
Non-Light Water Reactors,”*


February 6, 2019




Outline

- Background
- NEI 18-04 & Draft Regulatory Guide DG-1353
 - Licensing Basis Events
 - Safety Classification and Performance Measures
 - Assessing Defense in Depth
 - Content of Applications
- Draft Commission Paper


Strategies & Contributing Activities



Integrated Design/Review



Fundamental Safety Functions and Mechanistic Source Term



$I(RN_j)$	Inventory
RN_j	Radionuclide Groups (j)
E	Heat Energy
Pwr	Power Level
ρ	Reactivity
F	Fuel Release Fraction
MR	Matrix Release Fraction
PSR	Primary System Release Fraction
LPF	Building Leak Path Factor
S_i	Event Sequences (i)
t	Time
\dot{Q}	Heat Transfer
FM	Fuel to Matrix
MPS	Matrix to Primary System
$PS-CS$	Primary System to Cooling System
$CS-Env$	Cooling System to Environment
ΔT	Temperature difference


- Licensing Basis Events
 - Probabilistic Risk Assessment
 - Deterministic
- SSC Classification
 - Function and Risk Considerations
 - Safety Related
 - Non-Safety Related with Special Treatment
- Defense-in-Depth Assessment
 - Structures, Systems and Components
 - Programmatic
 - Integrated Decision-making Process

Other Requirements

- Associated requirements include:
 - Quality Assurance
 - Maintenance Rule
- Interfaces with requirements for:
 - Siting
 - Emergency Preparedness
 - Environmental Reviews
- Additional requirements for design/operation include:
 - Routine Effluents
 - Worker Protections
 - Security
 - Aircraft Impact Assessments

Event Selection & Analysis

The F-C Target values shown in the figure should not be considered as a demarcation of acceptable and unacceptable results. The F-C Target provides a general reference to assess events, SSCs, and programmatic controls in terms of sensitivities and available margins.




* F-C Target considered along with cumulative risk metrics, safety classification, and assessment of defense in depth

Safety Classification and Performance Criteria

- **Safety-Related (SR):**
 - SSCs selected by the designer from the SSCs that are available to perform the required safety functions to mitigate the consequences of DBEs to within the LBE F-C Target, and to mitigate DBAs that only rely on the SR SSCs to meet the dose limits of 10 CFR 50.34 using conservative assumptions
 - SSCs selected by the designer and relied on to perform required safety functions to prevent the frequency of BDBE with consequences greater than the 10 CFR 50.34 dose limits from increasing into the DBE region and beyond the F-C Target
- **Non-Safety-Related with Special Treatment (NSRST):**
 - Non-safety-related SSCs relied on to perform risk significant functions. Risk significant SSCs are those that perform functions that prevent or mitigate any LBE from exceeding the F-C Target, or make significant contributions to the cumulative risk metrics selected for evaluating the total risk from all analyzed LBEs.
 - Non-safety-related SSCs relied on to perform functions requiring special treatment for DID adequacy
- **Non-Safety-Related with No Special Treatment (NST):**
 - All other SSCs (with no special treatment required)

Assessing Defense in Depth



Additional Discussion Topics

- Integrated Decisionmaking Process
 - Multi-Disciplinary assessments
 - General guidance from RG 1.201 & NEI-00-04 (10 CFR 50.69)
 - No specific NRC documentation on assessment of similar panels
 - Key focus area for implementation by developers
- Reliability of Passive Heat Removal Systems
- Table Top Exercises
 - X-energy (ADAMS Accession No. ML18228A779)
 - PRISM (ADAMS Accession No. ML19036A584)
 - Additional Planned
- Nuclear Energy Innovation and Modernization Act

Draft SECY Paper

- Paper
 - The purpose of this paper is to seek Commission approval of the U.S. Nuclear Regulatory Commission (NRC) staff's recommendation to adopt a technology-inclusive, risk-informed, and performance-based methodology for informing the licensing basis and content of applications for licenses, certifications, and approvals for non-light-water-reactors (non-LWRs).
- Enclosure 1, "Background"
- Enclosure 2, "Technology-Inclusive, Risk-Informed, Performance-Based Approach"

Policy Background

- Advanced Reactor Policy Statement
- Pre-application evaluations (e.g., PRISM, MHTGR)
- SECY-93-092, “Issues Pertaining to the Advanced Reactor (PRISM, MHTGR, and PIUS) and CANDU 3 Designs and Their Relationship to Current Regulatory Requirements”
- SECY-03-0047, “Policy Issues Related to Licensing Non-Light Water Reactor Designs”
- Related initiatives to develop and implement risk-informed, performance-based regulation

Policy Background

SECY-03-0047, “Policy Issues Related to Licensing Non-Light Water Reactor Designs,” and the related staff requirements memorandum (SRM) dated June 26, 2003.

- Greater emphasis can be placed on the use of risk information by allowing the use of a probabilistic approach in the identification of events to be considered in the design, provided there is sufficient understanding of plant and fuel performance and deterministic engineering judgment is used to bound uncertainties;
- A probabilistic approach for the safety classification of structures, systems, and components is allowed; and
- The single-failure criterion can be replaced with a probabilistic (reliability) criterion.

Event Selection

- Consistent with SRM approving the use of a probabilistic approach to identify events provided there is sufficient understanding of plant and fuel performance and engineering judgment is used to address uncertainties
- ❖ Including a lower frequency range for licensing basis events, when combined with other considerations and engineering judgment, is an inherent part of a risk-informed approach and is consistent with the Commission's SRM
- The F-C targets support defining needed SSC capabilities and reliabilities to support the design process and to inform the content of applications, considering uncertainties and multi-module issues
- Consistent with the Commission's SRM approving replacement of the single-failure criterion with a probabilistic (reliability) criterion

Safety Classification & Performance Criteria

- The safety classification of SSCs and determination of performance criteria are directly related to and performed in an iterative process along with the identification and assessment of LBEs and the assessment of defense in depth
- Consistent with SRM allowing a probabilistic approach for the safety classification of SSCs
- Systematic approach to assessing and determining appropriate relationships between the needed capabilities and reliabilities for SSCs and the role of those SSCs in mitigating and preventing LBEs

Assessing Defense in Depth

- Framework that includes probabilistic and deterministic assessment techniques to establish defense in depth using a combination of plant capabilities and programmatic controls
 - Assessments performed using several approaches to assess a reactor design and determine if additional measures are appropriate to address an over-reliance on specific features or to address uncertainties
 - Includes verification that two or more independent plant design or operational features are provided to meet the guidelines for each licensing basis event
 - Methodology includes use of an Integrated Decision-Making Process
- ❖ Staff is not proposing to more universally define or impose DID criteria and seeks Commission acceptance of the NEI 18-04 approach for this specific case (see SECY-15-0168).

Informing Content of Applications

- NEI 18-04 provides useful guidance for reactor designers and the NRC staff for selecting and evaluating licensing basis events, identifying safety functions and classifying SSCs, selecting special treatment requirements, identifying appropriate programmatic controls, and assessing defense in depth
 - ❖ Taken together, these activities support documenting the safety arguments and determining the appropriate scope and level of detail in applications for licenses, certifications, or approvals for non-LWRs

Recommendation

The staff recommends that the Commission approve the use of the technology-inclusive, risk-informed, and performance-based approach described in the paper (consistent with NEI 18-04 and DG-1353) for identifying LBEs, classifying SSCs, and assessing the adequacy of defense in depth. These key aspects of the proposed approach will also be used to inform the appropriate scope and level of detail for information to be included in applications to the NRC for licenses, certifications, and approvals for non-LWRs.



ACRS Full Committee Meeting:

Non-power Production or Utilization Facility (NPUF) License Renewal Rulemaking

February 6, 2019

NRC Staff Presenters

- Robert Beall, NMSS: Rulemaking PM
- William “Duke” Kennedy, NRR: Acting Branch Chief
- Al Adams, NRR: Senior Project Manager

Purpose of the NPUF Final Rule


- Implement Commission direction to streamline the license renewal process by establishing a more efficient, effective and focused regulatory framework
- Use innovative and transformative approaches to address existing shortcomings in the current regulations for non-power licensees

⇒ 9 rulemaking objectives

Public Comments on the NPUF Proposed Rule

- Proposed rule was published for comment on March 30, 2017
 - 75-day public comment period
 - Public meeting was held on May 24, 2017
 - Received 16 comment submissions
 - Public comments generally supported the proposed rulemaking and recommended alternative approaches to certain aspects of the rule
- The draft final rule was presented to the ACRS Subcommittee on January 23, 2019
 - The TRTR Chairman stated at the meeting that the draft final NPUF rule was a “win-win” for the NRC and NPR community.

Relationship of NPUF Entities (Post-Final Rule)




**Deletes previous power levels and notable safety considerations:

- Circulating loop through the core used for fuel experiments
- Liquid fuel loading
- Large experimental facility in the core (> 16 in² in cross-section)

1. Update Terms and Definitions

- Establish a single term (“non-power production or utilization facility”) to capture all non-power facilities licensed under part 50
- **Revise definitions for “non-power reactor,” “research reactor,” and “testing facility” in response to public comment and make conforming changes***
- Ensure clarity and consistency for the applicability of NPUF regulations



* Text in red are changes from the proposed rule.

1. Update Terms and Definitions


- National Institute of Standards and Technology public comment
 - Revise definitions of “testing facility” and “research reactor” to “remove the arbitrary 10MW(t) threshold, and apply, instead, a risk-based approach to its regulation of a testing facility.”
 - “... risk is best quantified by accident analyses performed under a licensing safety analysis”
 - Recommended definitions refer to the proposed accident dose criterion of 1 rem (0.01 Sv)

1. Update Terms and Definitions

- NRC staff determination
 - 10 MW(t) threshold, while generally based on safety significance, is not documented.
 - Prescriptive power thresholds do not account for the safety features that are engineered into the facility design and those barriers that must be breached during an accident before a release of radioactive material to the environment can occur.
 - Power thresholds do not accurately represent the risk associated with a particular facility.
 - Use of a postulated accident dose is a more risk-informed, performance-based approach.

2. Eliminate License Terms

- Exempt Class 104a and 104c NPUFs, other than testing facilities, from 40-year fixed term in 10 CFR 50.51
- No license term specified in AEA for Class 104 NPUFs
- Consistent with AEA's minimum regulation standard
- Reduce burden for licensees and NRC, but maintains public health and safety



No Notable Safety Considerations

- Accident dose criterion of 1 rem (0.01 Sv) TEDE or less
 - small fission product inventory
 - small radiological consequence for maximum hypothetical accident
- Low energy systems
 - low operating power and temperatures
 - minimal decay heat
- No significant aging considerations
 - simple designs
 - proactive aging management / aging-related surveillance requirements
 - loss of coolant is an analyzed condition
- Slowly evolving licensing basis
 - Very low number of design changes each year
 - Few rulemakings apply


Maintaining Safety without License Renewal

Class 104a or c, except testing facilities

- **NUREG-1537**
 - License renewal under NUREG-1537
- **Inspection program**
- **Technical specifications**
- **Existing reporting requirements**
 - Safety issues with SSCs
 - Maintenance activities
- **FSAR Update rule requirement**


3. Define the License Renewal Process

- Consolidate license renewal requirements under 10 CFR 50.135 for testing facilities and NPUFs licensed under 10 CFR 50.22
- Clarify license renewal process
- Licenses will be effective immediately
- Maintains 40-year term for licenses
- Enhance regulatory efficiency




4. Require Updated FSAR Submittals

- Extend applicability of 10 CFR 50.71(e) to NPUFs
- Ensure timely documentation of changes to licensing basis
- Benefit knowledge management, NRC's inspection program, and licensee operator training and exams
- **Reg Guide 2.7 provides guidance on the FSAR updates.**




5. Amend Timely Renewal Provision

- Create two-year timely renewal for Class 103 and testing facilities and exempt Class 104a and 104c NPUFs, other than testing facilities
- 30 days in 10 CFR 2.109 is not a sufficient period of time for adequate assessment of license renewal application
- Two years provides sufficient time
- **Maintain 30-day timely renewal provision for certain facilities**




6. Provide an Accident Dose Criterion

- Create new accident dose criterion for NPUFs, other than testing facilities, in 10 CFR 50.34
- Part 20 public dose limits are unnecessarily restrictive as accident dose criteria
- Criterion would align with early phase EPA PAG and provide adequate protection from unnecessary exposure to radiation
- Revised the location within 10 CFR 50.34 of the accident dose criterion




7. Extend Applicability of 10 CFR 50.59

- Extend applicability to NPUFs regardless of decommissioning status
- 10 CFR 50.59 currently is not applicable to NPUFs once fuel is moved offsite
- Avoid burden of issuing license amendments




8. Clarify Existing Environmental Reporting Requirements

- Add requirement in 10 CFR 51.56 for NPUFs to provide an environmental report per 10 CFR 51.45
- Historically, NRC has relied on 10 CFR 51.41 to collect “environmental information”
- Improve consistency and clarify Part 51 requirements for licensing actions



9. Eliminate NPUF Financial Qualification Information Requirement

- Eliminate 10 CFR 50.33(f)(2) financial qualification requirement at license renewal
- Primary means to ensure safety is through NRC's oversight and enforcement programs
- Reduce licensee burden without compromise to public health and safety



Significant Changes from the NPUF Proposed Rule

- Revised the proposed definition of “non-power production or utilization facility”
- Revised the existing definitions of “non-power reactor,” “research reactor,” and “testing facility”
- Made conforming changes to terms and definitions throughout 10 CFR Chapter I
- Revised proposed 10 CFR 50.135 so that renewed licenses will be effective immediately
- Clarified proposed 10 CFR 50.135 to maintain 40-year terms for renewed licenses
- Maintained timely renewal provision for certain facilities
- Revised the location within 10 CFR 50.34 of the accident dose criterion

NPUF Final Rule Summary

NPUF Final Rule Change	Class 103 Facilities	Class 104a Facilities	Class 104c Facilities	
	Commercial	Medical Therapy	R&D	Testing
1. Update terms and definitions	✓	✓	✓	✓
2. Eliminate license terms	N/A	✓	✓	N/A
3. Define the license renewal process	✓	N/A	N/A	✓
4. Require updated FSAR submittals	✓	✓	✓	✓
5. Amend timely renewal provision	✓	✓	✓	✓
6. Provide an accident dose criterion	✓*	✓	✓	N/A
7. Extend applicability of 10 CFR 50.59	✓	✓	✓	✓
8. Clarify existing environmental reporting requirements	✓	✓	✓	✓
9. Eliminate NPUF financial qualification information for license renewal	✓	N/A	N/A	✓

* Not applicable for Class 103 testing facilities

NPUF Rulemaking Schedule

- Final NPUF rule milestones:
 - Currently in concurrence
 - Public meeting on the draft final rule implementation scheduled for late February
 - Due to Commission in June 2019

QUESTIONS?



BACK UP SLIDES

The policy for regulation of Class 104 NPUFs is described in the Atomic Energy Act of 1954, as amended, Section 104a. and c.

Sec. 104. Medical Therapy and Research and Development

a. ...the Commission is directed to permit the widest amount of effective medical therapy possible with the amount of special nuclear material available for such purposes and to impose the minimum amount of regulation consistent with its obligations under this Act to promote the common defense and security and to protect the health and safety of the public.

c. The Commission is directed to impose only such minimum amount of regulation of the licensee as the Commission finds will permit the Commission to fulfill its obligations under this Act to promote the common defense and security and to protect the health and safety of the public and will permit the conduct of widespread and diverse research and development.

The policy for regulation of Class 103 NPUFs is described in the Atomic Energy Act of 1954, as amended, Section 103.

Sec. 103. Commercial Licenses

- a. The Commission is authorized to issue licenses to persons applying therefor to transfer or receive in interstate commerce, manufacture, produce, transfer, acquire, possess, use, import, or export under the terms of an agreement for cooperation arranged pursuant to section 123, utilization or production facilities for industrial or commercial purposes. Such licenses shall be issued in accordance with the provisions of chapter 16 and subject to such conditions as the Commission may by rule or regulation establish to effectuate the purpose and provisions of this Act.

- c. Each such license shall be issued for a specified period, as determined by the Commission, depending on the type of activity to be licensed, but not exceeding forty years from the authorization to commence operations and may be renewed upon the expiration of such period.


Regulatory Definitions

- Non-power reactor means a research or test reactor licensed under § 50.21(c) or 50.22 of this part for research and development [*10 CFR 50.2 Definitions*].
- Research reactor means a nuclear reactor licensed by the Commission under the authority of subsection 104c of the Act and pursuant to the provisions of § 50.21(c) of this chapter for operation at a thermal power level of 10 megawatts or less, and which is not a testing facility as defined by paragraph (m) of this section [*§ 170.3 Definitions*].

Regulatory Definitions (cont.)

- Testing facility means a nuclear reactor which is of a type described in § 50.21(c) of this part and for which an application has been filed for a license authorizing operation at:
 - (1) A thermal power level in excess of 10 megawatts; or
 - (2) A thermal power level in excess of 1 megawatt, if the reactor is to contain:
 - (i) A circulating loop through the core in which the applicant proposes to conduct fuel experiments; or
 - (ii) A liquid fuel loading; or
 - (iii) An experimental facility in the core in excess of 16 square inches in cross-section. [§ 170.3 Definitions]

Characteristics of Current NPUF Entities



- Notable safety considerations:
- Circulating loop through the core used for fuel experiments
 - Liquid fuel loading
 - Large experimental facility in the core (> 16 in² in cross-section)



Presentation to the ACRS Full Committee

NuScale Design Certification Application Review

Safety Evaluation Report

Chapter 2: SITE CHARACTERISTICS

Project Manager: Prosanta Chowdhury

February 6, 2019

ACRS subcommittee meeting on December 18, 2018



Topics covered:

- Geography and Demography (SRP Section 2.1)
- Nearby Industrial, Transportation, and Military Facilities (SRP Section 2.2)
- Meteorology (SRP Section 2.3)
- Hydrologic Engineering (SRP Section 2.4)
- Geology, Seismology, Geotechnical Engineering (SRP Section 2.5)

Note: Staff review is based on DCA, revision 1 (March 15, 2018)

Geography and Demography (SRP 2.1), and Nearby Industrial, Transportation, and Military Facilities (SRP 2.2)

Conclusion

COL Items provided in the DCA are acceptable. The COL applicant referencing the NuScale Power Plant DC should describe and address -

- ♦ site specific geographic and demographic characteristics as part of COL Item 2.1-1;
- ♦ nearby industrial, transportation, and military facilities to demonstrate that the design is acceptable for each potential accident or provide site-specific design alternatives - as part of COL Item 2.2-1;
- ♦ site specific information in a COL application should be bounded by the design parameters.

Topics and Conclusions

Meteorology (SRP 2.3)

Conclusion

Site parameters related to FSAR Section 2.3 were postulated in accordance with 10 CFR 52.47(a)(1).

- **Regional Climatology (SRP 2.3.1):** Precipitation (rain/snow), winds (i.e., straight-line, tornado, hurricane), ambient dry- and wet-bulb temperatures are generally representative of a reasonable number of potential plant site locations;
 - ♦ However, because design may be deployed in remote locations or at sites subject to harsh weather conditions, some postulated site parameter values may be challenged.
- **Local Meteorology and the Onsite Meteorological Measurements (SRP 2.3.2 and 2.3.3):** Local Meteorology and the Onsite Meteorological Measurements Program are site-specific and addressed by the COL applicant.

Topics and Conclusions

Meteorology (SRP 2.3) (contd)

Conclusion

- ♦ **Short-Term Atmospheric Dispersion Estimates for Accident Releases (SRP 2.3.4): Open Item 02.03.04-1** - Staff currently evaluating TR-0915-17565 (Accident Source Term Methodology) to determine if NuScale methodology is acceptable for calculating DBA offsite χ/Q values at EAB and LPZ in relation to NuScale design or a COL applicant referencing NuScale design.
- ♦ Staff found that Applicant provided onsite χ/Q site parameter values at the MCR and TSC doors and HVAC intake that are representative of a reasonable number of sites that may be considered for a COL application.
- ♦ **Long-term Atmospheric Dispersion Estimates for Routine Releases (SRP 2.3.5):** Staff found that the long-term (routine release) site parameter values selected by the Applicant are representative of a reasonable number of sites that have been or may be considered for a COL application.

Hydrology (SRP 2.4)

Conclusion


- ♦ In all areas of hydrology, the applicant provided adequate site parameters as well as COL Items 2.0-1 and 2.4-1. A COL applicant referencing the NuScale Power Plant DC should provide information sufficient to demonstrate that the actual site characteristics described in its application falls within the range of site parameter values consistent with COL Items 2.0-1, and 2.4-1. The staff finds the applicant's information, including stipulations in the COL Items, acceptable.

Geology, Seismology, Geotechnical Engineering (SRP 2.5)


Conclusion

- ♦ In all areas of Geology, Seismology, Geotechnical Engineering, the applicant provided adequate information, including COL Item 2.5-1, and referenced COL Items 3.7-3, 3.7-5, 3.8-6, and 3.7-8, and specified that a COL applicant referencing the NuScale Power Plant DC should provide information sufficient to demonstrate that the actual site characteristics fall within the range of site parameter values specified in the NuScale Power Plant DC. The staff finds the applicant's information, including stipulations in the COL Items, acceptable.

NuScale Horizontal Certified Seismic Design Response Spectra at 5% Damping




CSDRS vs RG 1.60



CSDRS and CSDRS-HF

Chapters 2 and 17

ACRS Full Committee



Neil Olivier

Corporate Services, Director

Paul Infanger

Regulatory Affairs, Supervisor

Background: NuScale ODI Program

- NuScale's Quality Assurance program is based on ASME NQA-1-2008.
 - ASME NQA-1-2008 Part I, Requirement 3, Section 500, Part (b) allows the deferral of design verification activities provided the unverified portions of the design are identified and controlled.
 - Open Design Items (ODIs) are a form of engineering assumption controlled under the NuScale Design Control Process. Assumptions are information or data that is selected for a design activity, other than previously validated design criteria, which are taken to be true for the sake of analysis.
 - Assumptions, along with verified design inputs, describe the conditions under which design activity results are considered valid.
 - Assumptions are documented and tracked
 - Basis statements provide engineering justification that the assumption is reasonable
 - Verifier assures assumptions are reasonable
-

Background: NuScale ODI Program (cont.)

- ODIs are resolved/verified via the design verification process.
- Design Verification is required:
 - Ideally before releasing the design for procurement, manufacture, or construction, or for use by another design organization (with a different QA program)
 - In all cases, the design verification is required prior to relying on that SSC to perform its function

NuScale NRC Interactions on ODIs

- 2017 QA Inspection
- Training/Communication of Staff
- DCA Chapter Audits - Review of NuScale ODIs present in source documentation reviewed.
- RAIs

2017 QA Inspection Highlights

- Included review of NuScale's ODI Process
- The NRC report (ML17201J382) cited:
 - Review of 170 specific ODIs
 - NuScale had a conservatively low threshold for opening ODIs
 - No violations or nonconformances were identified
 - NuScale ODI process adequately manages unverified assumptions

Conclusion

- The NuScale ODI process properly controls unverified engineering assumptions in accordance with NQA-1.
- NRC has reviewed ODI process thru various interactions:
 - RAIs
 - DCA Chapter Audits
 - QA Inspection



Safety Evaluation with Open Items: Chapter 17, “Quality Assurance and Reliability Assurance”

NuScale Design Certification Application

ACRS Full Committee Meeting
February 6, 2019

Agenda

- NRC Staff Review Team
- Summary of the NRC Staff's Review
- Quality Assurance
 - ACRS Subcommittee Questions on the Applicant's ODI Process
- Reliability Assurance
- Abbreviations

NRC Staff Review Team

- NRC Technical Reviewers
 - Odunayo Ayegbusi, NRO
 - Andrea Keim, NRO
 - Mark Caruso, NRO (Retired)
 - Alissa Neuhausen, NRO
- Project Management
 - Omid Tabatabai, Senior Project Manager
 - Greg Cranston, Lead Project Manager

Overview of the Staff Review

- NRC Staff's safety evaluation report (SER) is based on DCA, Rev. 1,
- SER contains two Open Items and no Confirmatory Items,
- NRC Staff conducted two regulatory audits concerning reliability assurance program and one quality assurance implementation inspection,
- NRC Staff briefed the ACRS subcommittee on 12/18/18,
- The staff will discuss ACRS Subcommittee members' questions regarding the applicant's ODI process.

DCA, Part 2, Tier 2 Section 17.5

Quality Assurance

Regulatory Basis

- 10 CFR Part 50, Appendix A, GDC 1 requires that QA program be established and implemented
- 10 CFR Part 50, Appendix B specifies 18 quality criteria that the QA program description must address
- 10 CFR 52.47(a)(19) requires that a standard DC applicant include a QAPD that satisfies applicable portions of Appendix B to 10 CFR Part 50

Topical Report Review

- NuScale submitted Topical Report NP-TR-1010-859-NP, “Quality Assurance Program Description for the NuScale Power Plant,” Revision 3 on March 24, 2016
- NuScale commits to NQA-1-2008 and NQA-1a-2009 addenda as endorsed by RG 1.28, Revision 4
- The NRC staff reviewed the QAPD using NUREG-0800 Section 17.5
- The NRC staff SER dated September 22, 2016

Staff's Review of DCA, Section 17.5

- References “Quality Assurance Program Description for the NuScale Power Plant,” NP-TR-1010-859-NP-A, Revision 3
- COL Item 17.5-1: A COL applicant that references the NuScale Power Plant design certification will describe the quality assurance program applicable to the site-specific design activities and to the construction and operations phases.
- Open Item 17.5-1: Additional QA implementation inspection

QA Implementation Inspection

- June 5 - 9th, 2017
- NuScale Office Facility in Corvallis, Oregon
- Inspection Procedure 35017, “Quality Assurance Implementation Inspection”
- No findings of significance were identified
- QA Inspection Report is publicly available at (ML17201J382).
- Additional QA inspection is being scheduled and is listed in SER Open Item 17.5-1

ACRS Subcommittee Comments/Questions

- How does the staff ensure all ODIs are closed by the time DCA is approved?
- What does “sufficiently closed” mean?
- What if unverified assumptions change after the DCA is approved?
- ACRS Subcommittee Comment: The NRC staff should convey to NuScale that they are taking a “risk” by not closing all ODIs before the DCA is approved, particularly, those unverified assumptions that could trigger a Tier 1 change.

DCA Part 2, Tier 2, Section 17.4 Reliability Assurance Program

Reliability Assurance Program

- Staff evaluated NuScale's reliability assurance program, including the design RAP (D-RAP) list in accordance with SRP Section 17.4, Rev. 1
- Staff found the RAP program sufficient in:
 - Program description and implementation
 - Programmatic controls
 - SSC selection methodology
 - Expert panel member requirements
 - Determination of risk significant SSCs

Reliability Assurance Program

- Staff found:
 - the D-RAP list was developed in accordance with its RAP methodology and the D-RAP list is comprehensive.
 - NuScale adequately implemented the expert panel in developing the D-RAP list.
 - COL items provide reasonable assurance that the RAP for a COL applicant which references the NuScale design will be adequate.
- Open Item 17.5-2: D-RAP ITAAC (SECY-18-0093)

Abbreviations

ACRS	<i>Advisory Committee on Reactor Safeguards</i>
CFR	<i>Code of Federal Regulation</i>
COL	<i>Combined License</i>
DC	<i>Design Certification</i>
DCA	<i>Design Certification Application</i>
D-RAP	<i>Design Reliability Assurance Program</i>
GDC	<i>General Design Criteria</i>
ITAAC	<i>Inspections, Tests, Analyses, and Acceptance Criteria</i>
NRO	<i>NRC Office of New Reactors</i>
ODI	<i>Open Design Item</i>
QA	<i>Quality Assurance</i>
QAPD	<i>Quality Assurance Program Plan</i>
RAP	<i>Reliability Assurance Program</i>
SER	<i>Safety Evaluation Report</i>
SSC	<i>Structures, Systems, and Components</i>
SRP	<i>Standard Review Plan (NUREG-0800)</i>