



UNITED STATES  
NUCLEAR REGULATORY COMMISSION

REGION III  
2443 WARRENVILLE ROAD, SUITE 210  
LISLE, ILLINOIS 60532-4352

April 15, 2019

Mr. Paul Fessler, Senior VP  
and Chief Nuclear Officer  
DTE Energy Company  
Fermi 2 – 260 TAC  
6400 North Dixie Highway  
Newport, MI 48166

SUBJECT: FERMI POWER PLANT, UNIT 2—NOTIFICATION OF AN NRC TRIENNIAL HEAT  
SINK PERFORMANCE INSPECTION AND REQUEST FOR INFORMATION;  
INSPECTION REPORT 05000341/2019004

Dear Mr. Fessler:

On October 28, 2019, the U.S. Nuclear Regulatory Commission (NRC) will begin the onsite portion of the Triennial Heat Sink Performance Inspection at your Fermi Power Plant, Unit 2. This inspection will be performed in accordance with NRC baseline Inspection Procedure 71111.07.

In order to minimize the impact that the inspection has on the site and to ensure a productive inspection, we have enclosed a request for documents needed for the inspection. The documents have been divided into three groups.

- The first group lists information necessary for our initial inspection scoping activities. This information should be available to the lead inspector no later than June 17, 2019. By July 5, 2019, the inspector will communicate the initial selected set of approximately 2-3 risk significant heat exchangers, and 3-4 risk significant pumps, tower fans, and/or valves for the safety-related service water system.
- The second group is needed to support our in-office preparation activities. This set of documents, including the calculations associated with the selected heat exchangers, should be available at the Regional Office no later than October 7, 2019. This information should be separated for each selected component, especially if provided electronically (e.g., folder with component name that includes calculations, condition reports, maintenance history, etc.). During the in-office preparation activities, the inspector may identify additional information needed to support the inspection.
- The last group includes the additional information above as well as plant specific reference material. This information should be available at the Regional Office no later than October 15, 2019. It is also requested that corrective action documents and/or questions developed during the inspection be provided to the inspector as the documents are generated.

All requested documents are to be for the time period from the onsite inspection period back to the documents that were provided in response to the previous Heat Sink Performance Inspection. If no activities were accomplished in that time period, then the request applies to the last applicable document in the previous time period. It is important that these documents be as complete as possible, in order to minimize the number of documents requested during the preparation week or during the onsite inspection.

The lead inspector for this inspection is Vance Petrella. We understand that our licensing contact for this inspection is Shane Gatter of your organization. If there are any questions about the inspection or the material requested in the enclosure, please contact the lead inspector at 630-829-9847 or via e-mail at [Vance.Petrella@nrc.gov](mailto:Vance.Petrella@nrc.gov).

This letter does not contain new or amended information collection requirements subject to the Paperwork Reduction Act of 1995 (44 U.S.C. 3501 et seq.). Existing information collection requirements were approved by the Office of Management and Budget, Control Number 3150-0011. The NRC may not conduct or sponsor, and a person is not required to respond to, a request for information or an information collection requirement unless the requesting document displays a currently valid Office of Management and Budget Control Number.

This letter and its enclosure will be made available for public inspection and copying at <http://www.nrc.gov/reading-rm/adams.html> and at the NRC Public Document Room in accordance with 10 CFR 2.390, "Public Inspections, Exemptions, Requests for Withholding."

Sincerely,

**/RA/**

Vance Petrella, Reactor Inspector  
Engineering Branch 2  
Division of Reactor Safety

Docket No. 50-341  
License No. NPF-43

Enclosure:  
Document Request for Triennial Heat Sink  
Performance Inspection

cc: Distribution via LISTSERV®

Letter to Paul Fessler from Vance Petrella dated April 15, 2019.

SUBJECT: FERMI POWER PLANT, UNIT 2—NOTIFICATION OF AN NRC TRIENNIAL HEAT SINK PERFORMANCE INSPECTION AND REQUEST FOR INFORMATION; INSPECTION REPORT 05000341/2019004

DISTRIBUTION:

Michael McCoppin  
RidsNrrDorlLpl3  
RidsNrrPMFermi2 Resource  
RidsNrrDirslrib Resource  
Darrell Roberts  
John Giessner  
Jamnes Cameron  
Allan Barker  
DRPIII  
DRSIII

ADAMS Accession Number: ML19106A043

OFFICE	RIII						
NAME	VPetrella:cl						
DATE	04/15/19						

**OFFICIAL RECORD COPY**

## DOCUMENT REQUEST FOR TRIENNIAL HEAT SINK PERFORMANCE INSPECTION

**Inspection Report:** 05000341/2019004

**Inspection Dates:** October 28, 2019, through November 1, 2019

**Inspection Procedure:** 71111.07, "Heat Sink Performance"

**Lead Inspector:** Vance Petrella  
630-829-9847  
[Vance.Petrella@nrc.gov](mailto:Vance.Petrella@nrc.gov)

Please provide the information electronically in "pdf" files, Excel, or other searchable formats, preferably on some portable electronic media (e.g., CD-ROM, DVD). The portable electronic media should contain descriptive names, and be indexed and hyperlinked to facilitate ease of use. Information in "lists" should contain enough information to be easily understood by someone who has knowledge of light water reactor technology.

### ***I. Information Requested By June 17, 2019***

1. List of the Generic Letter (GL) 89-13, "Service Water System Problems Affecting Safety-Related Equipment," heat exchangers in order of risk significance.
2. Copy of heat exchanger performance trending data tracked for each GL 89-13 heat exchanger.
3. List of Corrective Action Program (CAP) documents (with a short description) associated with GL 89-13 heat exchangers, heat sinks, silting, corrosion, fouling, or heat exchanger testing, for the previous 3 years or since the last CAP document list was sent to the U.S. Nuclear Regulatory Commission for the previous Heat Sink Performance Inspection. The list should include all CAP documents not on the last CAP document list.
4. Copy of any self-assessment done on any of GL 89-13 heat exchangers, Ultimate Heat Sink (UHS), and safety-related service water systems since the last Heat Sink Performance Inspection.
5. Last two System Health Report(s) and maintenance rule system notebooks for all the GL 89-13 heat exchangers, UHS, and safety-related service water systems.
6. List of engineering-related operator workarounds (with a short description) associated with GL 89-13 heat exchangers. The requested documents are to be for the time period from the onsite inspection period back to the documents that were provided in response to the previous Heat Sink Performance Inspection.

Enclosure

## DOCUMENT REQUEST FOR TRIENNIAL HEAT SINK PERFORMANCE INSPECTION

7. List of permanent and temporary modifications (with a short description) associated with GL 89-13 heat exchangers, UHS, and safety-related service water systems. The requested documents are to be for the time period from the onsite inspection period back to the documents that were provided in response to the previous Heat Sink Performance Inspection.
8. Electronic copies of the current Final Safety Analysis Report, Technical Specifications, Technical Specifications Basis, and Technical Report Manual.
9. List of enhancements and/or commitments made during license renewal for GL 89-13 heat exchangers, UHS, and safety-related service and closed cooling water systems (as applicable).
10. Electronic copies of the current Probability Risk Assessment Summary Note Books.
11. A list of the top 30 risk-significant pumps, tower fans, and/or valves for the safety-related service water system in order of risk significance.
12. Provide an electronic copy of piping and instrumentation diagrams for the safety-related service water system, including the intake structure.

### ***II Information Requested By October 7, 2019***

1. Copies of the GL 89-13 responses.
2. Copies of procedures developed to implement the recommendations of GL 89-13 (e.g., the GL 89-13 Heat Exchanger Program description).
3. Copies of the selected CAP documents.
4. For the specific heat exchangers selected:
  - a. Copies of the Updated Final Safety Analysis Report (UFSAR) sections applicable for each heat exchanger.
  - b. Copy of system description and design basis document for the heat exchangers (as applicable).
  - c. Provide the calculations or evaluations that:
    - i. Establish the limiting design basis heat load required to be removed by each of these heat exchangers;
    - ii. Demonstrate the heat exchangers capacity to remove the limiting heat load;
    - iii. Correlate surveillance testing and/or inspection results from these heat exchangers with design basis heat removal capability (e.g., basis for surveillance test and/or inspection acceptance criteria);

## DOCUMENT REQUEST FOR TRIENNIAL HEAT SINK PERFORMANCE INSPECTION

- iv. Evaluate the potential for water hammer in each heat exchanger or associated piping; and
    - v. Evaluate excessive tube vibration in each heat exchanger.
  - d. Copy of any operability determinations or other documentation of degradation associated with the heat exchangers or the systems that support the operation for the selected heat exchangers.
  - e. Copy of the construction code, design specification, heat exchanger data sheets, and vendor documents including component drawings applicable for the heat exchangers.
  - f. Copies of normal, abnormal, and emergency operating procedures associated with the selected heat exchangers.
  - g. Copies of the Aging Management Programs (AMP) and the implementing procedures that manage aging of the selected heat exchangers (as applicable).
- 5. For the UHS and the safety-related service water system (or equivalent):
  - a. Copies of the applicable Updated Final Safety Analysis Report (UFSAR) sections.
  - b. Copy of system description and design basis document (as applicable).
  - c. Copy of any operability determinations or other documentation of degradation associated with the UHS and the safety-related service water system.
  - d. Copy of the document (e.g., UFSAR or Technical Requirements Manual) that states the maximum cooling water system inlet temperature limit that still allows full licensed power operation of the nuclear reactor.
  - e. Copy of the construction code and design specification.
  - f. Copies of normal, abnormal, and emergency operating procedures associated with the UHS and safety-related service water systems including procedures for loss of these systems.
  - g. Copies of corrective action documents associated with waterhammer or hydraulic transients in the service water system since the last Heat Sink Inspection.
  - h. If available, provide electronic copies of the structural drawings of the intake structure and UHS.
  - i. Provide a list of calculations (with a short description), which currently apply to UHS and safety-related service water system.

## DOCUMENT REQUEST FOR TRIENNIAL HEAT SINK PERFORMANCE INSPECTION

- j. Provide a list of instruments (with a short description) associated with automatic or alarm functions for the safety-related service water system and/or UHS.
  - k. Provide a list of any design change (with a short description) performed on the UHS or safety-related service water system since the last Heat Sink Performance Inspection.
  - l. Copies of the AMPs and the implementing procedures that manage aging of the UHS (including the intake structure) and the safety-related service and closed cooling water systems (as applicable).
6. A schedule of all inspections, cleanings, maintenance, or testing of any safety-related plant heat exchanger to be performed during the on-site portion of the inspection.

### ***III Information Requested by October 15, 2019***

- 1. For the specific heat exchangers selected.
  - a. Copies of the two most recent completed tests and evaluation data confirming thermal performance for those heat exchangers which are performance tested.
  - b. Documentation and procedures that identify the types, accuracy, and location of any special instrumentation used for the two most recently completed thermal performance tests for the heat exchangers (e.g., high accuracy ultrasonic flow instruments or temperature instruments). Include calibration records for the instruments used during these tests.
  - c. Information regarding any alarms which monitor on-line performance.
  - d. Copy of the document describing the inspection results of each heat exchanger. The requested documents are to be for the time period from the onsite inspection period back to the documents that were provided in response to the previous Heat Sink Performance Inspection.
  - e. The cleaning and inspection maintenance schedule for each heat exchanger for the next 5 years.
  - f. Copy of the operating procedure that ensures that the maximum cooling water system inlet temperature limit is not exceeded.
  - g. Copy of the calculations or documents which evaluate the potential for water hammer in each heat exchanger or associated piping.
  - h. The documents that describe the controls that prevent heat exchanger degradation due to excessive flow induced vibration during operation.

## DOCUMENT REQUEST FOR TRIENNIAL HEAT SINK PERFORMANCE INSPECTION

- i. Copy of the periodic flow testing at or near maximum design flow. The requested documents are to be for the time period from the onsite inspection period back to the documents that were provided in response to the previous Heat Sink Performance Inspection.
  - j. Copy of the document which identifies the current number of tubes in service for each heat exchanger and the supporting calculation which establishes the maximum number of tubes which can be plugged in each heat exchanger.
  - k. Copy of the document establishing the repair criteria (plugging limit) for degraded tubes which are identified in each heat exchanger.
  - l. Copies of the documents that verify the structural integrity of the heat exchanger (e.g., eddy current summary sheets, ultrasonic testing results, and visual inspection results).
  - m. Copies of those documents that describe the methods taken to control water chemistry in the heat exchangers.
  - n. Copies of those documents that describe the methods taken to control water chemistry in the heat exchangers, including those credited by any AMPs (as applicable).
  - o. Copies of any credited AMP monitoring/inspection results for the selected heat exchangers (as applicable). The requested documents are to be for any completed monitoring/inspection in the time period from the onsite inspection period back to the documents that were provided in response to the previous Heat Sink Performance Inspection.
2. For the UHS:
- a. Copies of calculations and surveillances that determine the UHS reservoir capacity and heat transfer capability.
  - b. Copies of surveillance procedures and testing results performed on the instrumentation relied upon to determine UHS reservoir capability. The requested documents are to be for the time period from the onsite inspection period back to the documents that were provided in response to the previous Heat Sink Performance Inspection.
  - c. Copies of documents associated with the periodic monitoring and trending of sediment built-up.
  - d. Copies of the procedures used for verifying that adjacent non-seismic or non-safety related structures cannot degrade or block safety-related flow paths during severe weather or seismic events.



## DOCUMENT REQUEST FOR TRIENNIAL HEAT SINK PERFORMANCE INSPECTION

- e. Copies of procedures for the periodic performance monitoring of heat transfer capacity and the associated results. The requested documents are to be for the time period from the onsite inspection period back to the documents that were provided in response to the previous heat sink performance inspection.
  - f. Copies of the inspection procedures for the verification of the structural integrity of the UHS and the associated results. The requested documents are to be for the time period from the onsite inspection period back to the documents that were provided in response to the previous Heat Sink Performance Inspection.
  - g. Copy of the calculation associated with the structural integrity of the UHS. The requested documents are to be for the time period from the onsite inspection period back to the documents that were provided in response to the previous Heat Sink Performance Inspection.
3. For the review of the performance testing of the safety-related service water system (or equivalent) and the UHS:
- a. Copies of the last two performance tests, such as the ASME in-service test, for the selected pumps, valves, and, if applicable, the towers fans in the safety-related service water system. If the components are not performance tested, please provide documentation verifying performance by the methods actually used.
  - b. Copies of the documents that demonstrate that flow balance testing was performed during the last 3 years. If the last flow test was performed longer than 3 years, then provide the last flow test.
  - c. Copies of the documents that demonstrate that flow balance testing will continue to be periodically done in the future.
  - d. Copies of procedures used to monitor interface valves between the safety-related section of the service water system and the nonsafety-related section and the associated results. The requested documents are to be for the time period from the onsite inspection period back to the documents that were provided in response to the previous Heat Sink Performance Inspection.
  - e. Copies of the procedures that verify the performance of risk-significant non-safety functions and the associated results. The requested documents are to be for the time period from the onsite inspection period back to the documents that were provided in response to the previous Heat Sink Performance Inspection.
4. Copies of any credited AMP monitoring/inspection results for the safety-related service and closed cooling water systems, and the UHS (as applicable). The requested documents are to be for any completed monitoring/inspection in the time period from the onsite inspection period back to the documents that were provided in response to the previous Heat Sink Performance Inspection.

## DOCUMENT REQUEST FOR TRIENNIAL HEAT SINK PERFORMANCE INSPECTION

If the information requested above will not be available, please contact Vance Petrella as soon as possible at 630-829-9847 or e-mail [Vance.Petrella@nrc.gov](mailto:Vance.Petrella@nrc.gov).