



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

April 23, 2019

Mr. Daniel G. Stoddard
Senior Vice President and
Chief Nuclear Officer
Innsbrook Technical Center
5000 Dominion Blvd.
Glen Allen, VA 23060-6711

SUBJECT: NORTH ANNA POWER STATION, UNIT NO. 1 – REVIEW OF STEAM
GENERATOR TUBE INSPECTION REPORT FOR THE CYCLE 26
SPRING 2018 REFUELING OUTAGE (EPID L-2018-LRO-0033)

Dear Mr. Stoddard:

By letter dated September 4, 2018 (Agencywide Documents Access and Management System (ADAMS) Accession No. ML18255A061), Virginia Electric and Power Company (the licensee) submitted its steam generator (SG) tube inspection report for the North Anna Power Station (North Anna), Unit No. 1, in accordance with Technical Specification (TS) 5.6.7, "Steam Generator Tube Inspection Report." The report summarizes the SG tube inspections performed during the North Anna, Unit No. 1 Cycle 26 refueling outage, in the spring of 2018.

The U.S. Nuclear Regulatory Commission (NRC) staff completed its review of the submittal and concluded that the licensee provided the information required by the North Anna, Unit No. 1 TSs. No additional follow-up is required at this time. This completes the NRC staff's efforts for EPID L-2018-LRO-0033. The enclosure documents the NRC staff's review of the submittal.

Sincerely,

A handwritten signature in cursive script that reads "James R. Hall".

James R. Hall, Senior Project Manager
Plant Licensing Branch II-1
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. 50-338

Enclosure:
Review of Steam Generator Tube
Inspection Report

cc: Listserv

REVIEW OF THE 2018 STEAM GENERATOR TUBE INSPECTION REPORT

VIRGINIA ELECTRIC AND POWER COMPANY

NORTH ANNA POWER STATION, UNIT NO. 1

DOCKET NO. 50-338

By letter dated September 4, 2018 (Agencywide Documents Access and Management Systems (ADAMS) Accession No. ML18255A061), Virginia Electric and Power Company, Inc. (the licensee), submitted information summarizing the results of the 2018 steam generator (SG) inspections at North Anna Power Station (North Anna), Unit No. 1. These inspections were performed during refueling outage 26.

North Anna, Unit No. 1 has three Westinghouse Model 54F replacement steam generators that were installed in 1993, each containing 3,592 thermally treated Alloy 690 tubes. The tubes have a nominal outside diameter of 0.875 inches, a nominal wall thickness of 0.050 inches, and are supported by seven stainless steel tube support plates and a baffle plate. Most of the tube support plate holes are quatrefoil-shaped. The U-bend regions of the tubes in rows one through eight were stress-relieved after bending.

The licensee provided the scope, extent, methods, and results of its SG tube inspections in the document referenced above. In addition, the licensee described corrective actions, such as tube plugging, taken in response to the inspection findings.

Based on its review of the information provided, the U.S. Nuclear Regulatory Commission (NRC) staff concludes that the licensee provided the information required by North Anna, Unit No. 1 Technical Specification 5.6.7, "Steam Generator Tube Inspection Report." In addition, the NRC staff concludes that there are no technical issues that warrant follow-up action at this time, since the inspections appear to be consistent with the objective of detecting potential tube degradation, and the inspection results appear to be consistent with industry operating experience at similarly designed and operated units.

SUBJECT: NORTH ANNA POWER STATION, UNIT NO. 1 – REVIEW OF STEAM GENERATOR TUBE INSPECTION REPORT FOR THE CYCLE 26 SPRING 2018 REFUELING OUTAGE (EPID L-2018-LRO-0033) DATED APRIL 23, 2019

DISTRIBUTION:

PUBLIC
 PM Reading File
 RidsNrrLAKGoldstein Resource
 RidsNrrDorl Resource
 RidsRgn2MailCenter Resource
 RidsNrrPMNorthAnna Resource
 RidsNrrDmlrMccb Resource
 RidsNrrDmlrMphb Resource
 PKlein, NRR
 AJohnson, NRR
 AHuynh, NRR

ADAMS Accession No. ML19106A356

***via email**

OFFICE	DORL/LPL2-1/PM	DORL/LPL2-1/LA	DORL/LPL2-1/LAit
NAME	JRHall	KGoldstein (JBurkhardt for)	KZeleznock
DATE	04/17/19	04/17/19	04/17/19
OFFICE	DMLR/MPHB/BC*	DORL/LPL2-1/BC	DORL/LPL2-1/PM
NAME	SBloom	MMarkley (SWilliams for)	JRHall
DATE	03/06/19	04/18/19	04/23/19

OFFICIAL RECORD COPY