

ENCLOSURE 2

M190069

Comment Summary Table and Draft SE Markup

Non-Proprietary Information

IMPORTANT NOTICE

This is a non-proprietary version of Enclosure 1, from which the proprietary information has been removed. Portions of the enclosure that have been removed are indicated by an open and closed bracket as shown here [[]].

**Comment Summary for Draft Safety Evaluation for
NEDC-33173P Supplement 6, “Applicability of GE Methods to Expanded Operating
Domains – Removal of the Safety Limit Minimum Critical Power Ratio (SLMCPR)
Penalty”**

Note: Page numbers shown in this table reflect the page numbers in this enclosure. Due to suggested changes in the Safety Evaluation (SE) and the addition of proprietary marking, these page numbers differ from the page numbers in the draft SE sent to GEH for review.

Location	Comment
<p>Section 1.1 Background</p>	<p>Page 4: It is unusual to call out this one component of the integrated power uncertainty and not the other one (four bundle power, of P4B), particularly because the majority of this work was developed to directly demonstrate that the P4B does not change as a function of power-to-flow ratio. Recommend including discussion of the P4B term here.</p> <p>GEH suggests the following change (Line 35): “...[[]] the four-bundle power uncertainty (σ_{P4B}), and the...”</p> <p><i>Suggested change shown in the markup.</i></p>
<p>Section 1.1.1 Interim Methods Licensing Topical Report NEDC-33173P-A</p>	<p>Page 5: It is not a given that EPU or 24-month cycles will lead to flatter core radial power distributions at the limiting point in the cycle.</p> <p>GEH suggests the following change (Line 6): “...the average bundle power can increases, leading...”</p> <p><i>Suggested change shown in the markup.</i></p>

Location	Comment
<p>Section 1.1.1 Interim Methods Licensing Topical Report NEDC-33173P-A</p>	<p>Page 5: While this statement is generally true for the critical power ratio (CPR), it is not always true for linear heat generation rate (LHGR), where the thermal-mechanical operating limit (TMOL) curve has an exposure dependence. The highest kw/ft rod in the core does not necessarily have the least margin to its limit.</p> <p>And with regard to the core design of extended power uprate (EPU) and non-EPU plants, the margin to limits is controlled through bundle nuclear design and core loading strategies. The amount of margin to the limit in operation is not directly a function of whether or not a plant is EPU or non-EPU.</p> <p>GEH suggests the following change (Lines 9-10): “Since the maximum powered bundles <u>can</u> set the thermal limits, EPU operation <u>can</u> reduce the margins to the thermal limits.”</p> <p><i>Suggested changes shown in the markup.</i></p>
<p>Section 1.1.1 Interim Methods Licensing Topical Report NEDC-33173P-A</p>	<p>Page 5: Would be more accurate to state “all bundles”</p> <p>GEH suggests the following change (Line 16): “The maximum powered<u>All</u> bundles must meet the thermal limits...”</p> <p><i>Suggested change shown in the markup.</i></p>
<p>Section 1.1.1 Interim Methods Licensing Topical Report NEDC-33173P-A</p>	<p>Page 5: Would be more accurate to state “all bundles”</p> <p>GEH suggests the following change (Lines 18-19): “Since the high-powered bundle’s ability to operate within the thermal limits <u>of all bundles</u> is...”</p> <p><i>Suggested changes shown in the markup.</i></p>

Location	Comment
<p>Section 1.1.2 Supplement 2 to NEDC-33173P-A</p>	<p>Page 10: This value can be higher for some plants, up to ~57 MWt/(lbm/hr) at the limiting point on the curve.</p> <p>GEH suggests the following change (Line 32): “...for MELLLA+ operation is up to 50~57 MWt/(Mlbm/hr)”</p> <p><i>Suggested change shown in the markup.</i></p>
<p>Section 3.1 Bundle Power Uncertainty</p>	<p>Page 14: Recommend ending the sentence with “if a statistically significant trend exists”.</p> <p>GEH suggests the following change (Line 10): “...historically established value <u>and if a statistically significant trend exists.</u>”</p> <p><i>Suggested change shown in the markup.</i></p>
<p>Section 3.1.1 Assessment of Core TIP Data</p>	<p>Page 14: Correct the power density for Peach Bottom Units 2 and 3.</p> <p>GEH suggests the following change (Line 24): “...BWR/4 with power densities of 58.459.43 kW/L,...”</p> <p><i>Suggested change shown in the markup.</i></p>

1 **DRAFT SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION**
2 **FOR THE REVIEW OF TOPICAL REPORT NEDC-33173P SUPPLEMENT 6,**
3 **“APPLICABILITY OF GE METHODS TO EXPANDED OPERATING DOMAINS – REMOVAL**
4 **OF THE SAFETY LIMIT MINIMUM CRITICAL POWER RATIO (SLMCPR) PENALTY”**
5 **EPID: L-2017-TOP-0040/DOCKET 99902024**
6 **GE-HITACHI NUCLEAR ENERGY AMERICAS LLC.**

7
8
9 **1.0 INTRODUCTION**

10
11 By letter dated September 15, 2017 (Ref. 1), General Electric (GE) Hitachi Nuclear Energy
12 (hereafter GEH) submitted Licensing Topical Report (LTR) NEDC-33173P, Supplement 6,
13 Revision 0, “Applicability of GE Methods to Expanded Operating Domains – Removal of the
14 Safety Limit Minimum Critical Power Ratio (SLMCPR) Penalty” (Ref. 2) to the U.S. Nuclear
15 Regulatory Commission (NRC) for review and approval for licensing applications.
16 NEDC-33173P, Supplement 6, Revision 0 (Supplement 6) is the sixth supplement to the interim
17 methods LTR (IMLTR) NEDC-33173P-A, Revision 4, “Applicability of GE Methods to Expanded
18 Operating Domains” (Ref. 3). Supplement 6 seeks removal of the SLMCPR penalty imposed on
19 plants operating in the Maximum Extended Load Line Limit Analysis Plus (MELLLA+) expanded
20 operating domain. The SLMCPR penalty for plants operating with GEH methods in the
21 MELLLA+ domain was introduced in the NRC review of the IMLTR. Initially set at a value of
22 0.03, the SLMCPR penalty was subsequently reduced in the NRC review of NEDC-33173P-A,
23 Revision 0, Supplement 2, “Applicability of GE Methods to Expanded Operating Domains –
24 Power Distribution Validation for Confrontes” (Supplement 2, Reference 4) to the current values
25 of 0.01 for power-to-flow (P/F) ratios less than 42 MWt/(Mlbm/hr) and 0.02 for P/F ratios greater
26 than 42 MWt/(Mlbm/hr).
27

28 **1.1 Background**

29
30 The IMLTR provides the basis for the application of the suite of GEH and Global Nuclear Fuel
31 (GNF) computational methods to perform safety analyses relevant to extended power uprate
32 (EPU) and MELLLA+ operating domain licensing. During its review of the IMLTR, the NRC staff
33 identified concerns regarding the power distribution uncertainties applied in the calculation of
34 the safety and operating limits. These power distribution uncertainties include the bundle
35 [[[the four-bundle power uncertainty \(\$\sigma_{P4B}\$ \)](#)], and the
36 overall pin power peaking uncertainty (σ_{peak}). In its safety evaluation (SE) of the IMLTR, the
37 NRC staff imposed penalties on the SLMCPR to account for inadequate qualification of these
38 component uncertainties for modern fuel designs operating under conditions of expanded
39 operating domains, such as EPU or MELLLA+ (Ref. 3). The penalties imposed on SLMCPR
40 were partially relaxed during the NRC staff review of Supplement 2. Supplement 6 seeks to
41 remove the remaining SLMPCR penalties.
42

43 To better inform the technical evaluation that is to follow, it is beneficial to review the history of
44 the penalties applied to the SLMCPR in the EPU and MELLLA+ operating domains. The
45 discussion presented in the following subsections discusses the origins and subsequent
46 relaxations thus far approved of the SLMCPR penalties.
47

1 **1.1.1 Interim Methods Licensing Topical Report NEDC-33173P-A**
2

3 The IMLTR provides the basis for the application of the suite of GEH and GNF computational
4 methods to EPU and MELLLA+ operating domains. To implement EPU and maintain a
5 24-month cycle, a higher number of maximum powered bundles are loaded into the core and
6 the average bundle power can increases, leading to a flatter core radial power distribution. Due
7 to an increased two-phase pressure drop and higher coolant voiding, the coolant flow in the
8 maximum-powered bundles decreases. This leads to higher bundle P/F ratios and higher exit
9 void fractions. Since the maximum powered bundles can set the thermal limits, EPU operation
10 can reduces the margins to the thermal limits. For MELLLA+ operation, plants operate at EPU
11 power levels at lower core flow conditions. Therefore, the number of bundles operating at
12 higher P/F conditions, and consequently higher exit void fractions, increases.
13

14 There are no direct limits on the operating bundle powers, operating bundle P/F ratio, or void
15 fractions. Instead, the core design and the operating strategy employed are constrained by
16 thermal limits. ~~The maximum powered~~ All bundles must meet the thermal limits so that the
17 technical specification safety limits or the specific fuel design limits are not violated during
18 steady-state, transient, and accident conditions. Since the ~~high powered bundle's~~ ability to
19 operate within the thermal limits of all bundles is analytically determined, it is important that the
20 analytical tools being utilized are applied within the ranges for which they were derived and
21 benchmarked. It is for this reason that the NRC staff, as part of its review of the IMLTR,
22 assessed the applicability of GEH's analytical methods and codes used to predict EPU and
23 MELLLA+ responses during steady-state, transient, and accident conditions.
24

25 One of the areas the NRC staff assessed was the extrapolation of neutronic methods to high
26 (greater than 70 percent) void fractions. The neutronic parameters feed into almost all codes
27 that are used to perform the steady-state, transient, and accident condition analyses and
28 establish the core operating thermal limits. Therefore, the accuracy of the methods used to
29 calculate the neutronic parameters affects the analyses supporting operation at EPU and
30 MELLLA+ conditions. During the IMLTR review, the NRC staff examined confirmatory data
31 comparisons between GEH's lattice physics code TGBLA06 (Ref. 6) and the HELIOS lattice
32 physics code as well as core-tracking data validation, specifically, traversing in-core probe (TIP)
33 comparisons versus increasing power density and void fraction.
34

35 Boiling water reactors (BWRs) are instrumented with TIP strings, and each TIP string is
36 surrounded by four fuel bundles. The TIP readings provide a means to assess the normalized
37 axial power shape along the length of the four bundles surrounding the individual TIP string.
38 Therefore, for a given TIP string, the measurement is a response to the combined influence of
39 the surrounding four bundles. GEH's core simulator PANAC11 models the response of the
40 instrument to the appropriate particle species (thermal neutrons or gamma rays) at the detector
41 location to produce a simulated signal. For TIP comparisons, this simulated detector response
42 is compared to the relative strength of the measured signal.
43

44 GEH relies heavily on these TIP-measured and calculated four-bundle power comparisons and
45 on code-to-code comparisons (e.g., TGBLA06 to MCNP) to benchmark its neutronic methods.
46 However, during its assessment of the extrapolation of the neutronic methods to high void
47 fraction, the NRC staff concluded that, while these TIP data provide a basis to determine the
48 uncertainty associated with predicting the power of the four-bundle group (i.e., the four-bundle
49 power uncertainty σ_{P4B}), they do not provide bases to ascertain the accuracy of the individual
50 bundle-by-bundle prediction. This is because the TIP readings are predominantly due to the
51 power response of the four surrounding bundles, even in the highly voided top of the fuel

1 bundle. Additionally, because the TIP readings only provide [[
2
3]]. Furthermore, the TIP data
4 does not provide a means to validate the overall pin power peaking uncertainty (i.e., σ_{peak}).
5

6 All three of these uncertainties are applied in the thermal limits calculations, as indicated in the
7 NRC-approved GEH SLMCPR methodology TR NEDC-32601P-A (Ref. 7) and the associated
8 uncertainty treatments TR NEDC-32694P-A (Ref. 8). It was, therefore, necessary to determine
9 the continued applicability of their values for purposes of assessing the extrapolation of
10 neutronic methods to higher void fractions. [[

11
12]]. This value was validated to be appropriate for application to more recent fuel
13 designs during the NRC staff review of the IMLTR. The values associated with the [[
14]] and the overall pin power peaking uncertainty σ_{peak} of [[
15]], respectively, were originally established within the SLMCPR
16 methodology and uncertainty treatment TRs (NEDC-32601P-A and NEDC-32694P-A).
17 However, the TIP data provided in the IMLTR do not provide a means to verify these values
18 remain applicable.
19

20 The SLMCPR methodology and uncertainty treatment TRs established the values for [[]]
21 and σ_{peak} using bundle and pin gamma scan data from legacy fuel designs. Gamma scanning is
22 a non-destructive method used to determine the relative fission product inventory in nuclear
23 fuel, which is directly related to the core power distribution just prior to removal of the fuel from
24 the core. During the IMLTR review, the NRC staff investigated the then-available and
25 applicable gamma scan data and qualification database for GEH's neutronic methods. This
26 investigation identified that a comprehensive qualification of GEH's steady-state neutronic
27 method had, at the time, last been performed in 1985. Based on the differences in the current
28 fuel and core designs and operating strategies in comparison to the historically available
29 measurement data, the NRC staff concluded that additional gamma scans of contemporary fuel
30 were necessary to demonstrate the established values for [[]] and σ_{peak} remained
31 applicable. In order to capture the uncertainties in the neutronic methods for operation in
32 MELLLA+, GEH committed to a benchmark program wherein the vendor would gamma scan
33 bundles and pins that had been operated as close as possible to MELLLA+ conditions; the
34 associated data would be used to qualify the nuclear methods uncertainties.
35

36 Given that the specific measurement data would not be available for some time, GEH opted for
37 an interim approach. Within the IMLTR, GEH proposed statistically treating the then-available
38 GE 7x7 and GE 8x8 pin and bundle gamma scans to determine conservative values for the
39 overall pin power peaking and [[]]. GEH determined the
40 mean and uncertainty of the then-available axial pin power gamma scan data and determined
41 the 95-percentile upper tolerance limit. This tolerance limit was defined as the mean bias plus
42 2σ uncertainty based on the peak power rods. By using the upper tolerance limit in the

- 4 -

- 1 SLMCPR and uncertainty treatment methodologies, the overall pin power peaking uncertainty
- 2 σ_{peak} increased from [[]]¹. GEH propagated the higher overall pin

¹ The overall pin power peaking uncertainty is actually [[]].
The change observed in the overall pin power peaking uncertainty when utilizing the 95-percentile upper tolerance limit is the result of a change in one of these components, specifically [[

]]

- 5 -

1 power peaking uncertainty in the SLMCPR calculation, resulting in an increase of the SLMCPR
2 by 0.01 Δ CPR. Similarly, by using the 95-percentile upper tolerance limit for the available
3 bundle gamma scan data, [[

4
5
6]] Thus GEH, in the IMLTR, proposed adding a combined value of 0.02 to the cycle-
7 specific SLMCPR values calculated for core configurations operating at EPU and MELLLA+
8 conditions.

9
10 In assessing the acceptability of this approach, the NRC staff concluded that an adder of
11 0.02 was adequate for the cycle-specific SLMCPR for plants implementing EPU operation.
12 However, for plants implementing MELLLA+ operation, the NRC staff concluded an additional
13 0.01 value would be included for a total adder of 0.03 for the cycle-specific SLMCPR. The
14 additional 0.01 SLMCPR adder for MELLLA+ operation was meant to account for potential
15 changes in both the pin and bundle power uncertainties due to the higher bundle P/F ratios
16 (indicative of higher void fraction and harder neutron spectrum) in the MELLLA+ operating
17 domain. The NRC staff imposed the use of a 0.02 adder for EPU operation and a 0.03 adder
18 for MELLLA+ operation in Limitations 4 and 5, respectively, of the SE for the IMLTR. These
19 penalties on SLMCPR were to remain applicable until such time as GEH's neutronic methods
20 could be confirmed against appropriate measurement data from the gamma scan benchmark
21 program.

22 23 **1.1.2 Supplement 2 to NEDC-33173P-A**

24
25 In Supplement 2, GEH provided the results of bundle scan campaigns and pin-wise gamma
26 scan campaigns to validate, respectively, [[
27]] and established overall pin power peaking uncertainty for newer (10×10) fuel
28 designs. This effort was undertaken to address the cycle-specific SLMCPR penalties stemming
29 from the aforementioned uncertainties.

30
31 To validate [[
32]], two bundle-wise gamma scan
33 campaigns were performed at Confrontes Nuclear Power Plant (CNC), a high power density
34 (58.6 kW/L) BWR/6 plant in Spain (Ref. 4 and Reference 9). The campaigns were across two
35 cycles, one cycle at stretch power uprate (SPU) conditions and another cycle at EPU conditions,
36 and the scanned bundles were distributed throughout the core in sets of neighboring bundles.
37 The NRC staff found the gamma scan data are, to a reasonable extent, representative of the
38 void and spectral conditions expected at MELLLA+ conditions, and when both cycles of data are
39 considered together, the average [[
40]]². This is
41 well within the established value of [[
42]]. Assessments of bundle, axial, and nodal
43 TIP uncertainties in comparison to the historical qualification database were also performed,
44 and [[
45]] was observed. Based on this, the NRC staff
46 approved a reduction of the SLMCPR adder imposed by Limitations 4 and 5 by a margin of
47 0.01.

²The reduction in uncertainty is expected; [[
48]] utilized in the SLMCPR
49 calculation is based on qualification of the TGBLA04/PANAC10 code suite, and the improved
50 TGLBA06/PANAC11 code suite was qualified with a [[
51]]. GEH has chosen to
52 continue using the historically established uncertainty value.

- 6 -

- 1 To validate the overall pin power peaking uncertainty, a pin-wise gamma scan campaign was
- 2 performed at James A. Fitzpatrick Nuclear Power Plant (JAF), a BWR/4 plant with a power
- 3 density of 51.2 kW/l. The campaign was conducted for GE14 fuel assemblies depleted at JAF
- 4 under SPU conditions during Cycles 16 and 17. The NRC staff found the pin-wise gamma scan

- 7 -

1 data representative of bundles depleted at P/F ratios and exit void fractions consistent with EPU
2 operation. For conservatism, the NRC staff compared the pin-wise gamma scan results to a
3 smaller uncertainty criterion of [[]] instead of the established [[]].
4 The more restrictive uncertainty criterion was determined by reassessing the derivation of the
5 established σ_{peak} when ignoring [[]], and it was adopted during
6 examination of the pin-wise gamma scan data because it allowed the NRC staff to limit its
7 review of the [[]] of the scanned bundles. The NRC staff
8 found that the σ_{peak} uncertainties determined from the pin-wise gamma scan data are within the
9 more restrictive criterion of [[]]. Assessments of overall pin power peaking
10 uncertainty as a function of axial height were also performed. Axial height serves as a
11 surrogate to visualize any trending as a function of void fraction. [[]]
12 were observed. Based on this, the NRC staff approved a reduction of the SLMCPR adder
13 imposed by Limitations 4 and 5 by an additional margin of 0.01.

14
15 The reduction of the SLMCPR adder by a total margin of 0.02 effectively removed the SLMCPR
16 adder at EPU conditions, and the NRC staff therefore removed Limitation 4 in the approval of
17 Supplement 2. For MELLLA+ conditions, the 0.03 SLMCPR adder imposed by Limitation 5 was
18 reduced to 0.01. This remaining 0.01 adder is the additional margin the NRC staff imposed in
19 the IMLTR review to account for, in part, the potential changes in both pin and bundle power
20 uncertainties with the higher void fractions and harder neutron spectra that are characteristic of
21 operation in MELLLA+ conditions.

22
23 The pin-wise and bundle-wise gamma scan data in Supplement 2 was supplied to demonstrate
24 the continued applicability of established pin and bundle power uncertainties at both EPU and
25 MELLLA+ conditions. However, the NRC staff could not conclude the supplied gamma scan
26 data encompassed the range of void fractions and spectral conditions present at MELLLA+
27 operation. Specifically, the CNC core flow ranges did not extend as low as those proposed for
28 domestic BWRs at MELLLA+ conditions, and the bundles from which the JAF pin-wise gamma
29 scans were taken did not experience average exit void fractions in the expected range for
30 limiting bundles operating at MELLLA+ low-flow conditions. Additionally, the provided gamma
31 scan data was limited to P/F ratios up to 42 MWt/(Mlbm/hr), whereas the expected range of P/F
32 ratios for MELLLA+ operation is up to ~~50~~~57 MWt/(Mlbm/hr). Therefore, the NRC staff
33 modified Limitation 5 such that a cycle-specific SLMCPR adder of 0.01 would be imposed for
34 MELLLA+ applications with P/F ratios up to 42 MWt/(Mlbm/hr), and a cycle-specific SLMCPR
35 adder of 0.02 would be imposed for MELLLA+ applications with P/F ratios above 42
36 MWt/(Mlbm/hr).

37 38 **2.0 REGULATORY EVALUATION**

39
40 Title 10 of the *Code of Federal Regulations* (10 CFR) establishes the fundamental regulatory
41 requirements with respect to the reactivity control systems. Specifically, 10 CFR Part 50,
42 Appendix A, General Design Criterion (GDC) 10, "Reactor Design", states in part, that "the
43 reactor core and associated coolant, control, and protection systems shall be designed with
44 appropriate margin to assure that specified acceptable fuel design limits are not exceeded...."

45
46 Section 4.2 of NUREG-800, The Standard Review Plan (SRP) (Ref. 5) specifies the acceptance
47 criteria for the evaluation of the fuel design limits as it relates to the thermal limits. SRP Section
48 4.4 provides guidance on the review of the thermal-hydraulic design in meeting the requirement
49 of GDC 10 and the fuel design criteria established in SRP Section 4.2. For the critical power

- 8 -

- 1 correlation, there should be a 95 percent probability at 95 percent confidence level that the hot
- 2 rod in the core does not experience a departure from nucleate boiling or boiling

- 9 -

1 transition (BT) condition during normal operation or anticipate operational occurrence (AOOs),
2 or, for the critical power ratio (CPR) correlations, the minimum critical power ratio (MCPR) is to
3 be established such that 99.9 percent of the fuel rods in the core would be expected not to
4 experience BT during normal operation or AOOs. SRP Section 4.4 also states that the
5 uncertainties in the values of process parameters, core design parameters, and calculational
6 methods used in the assessment of the thermal margin should be treated with at least
7 95 percent probability at a 95 percent confidence level.
8

9 The regulation at 10 CFR 50.34, "Contents of applications; technical information," provides
10 requirements for the content of safety analysis reports for operating reactors. The purpose of
11 the IMLTR is to provide a licensing basis that allows the NRC to issue SEs for expanded
12 operating domains including constant pressure power uprate, EPU, and MELLLA+ applications.
13 The SE for the IMLTR approves the use of GEH/GNF methods for expanded operating
14 domains. Licensees applying for EPU or MELLLA+ license amendments may refer to the
15 IMLTR as a basis for the LAR regarding the applicability of GEH/GNF methods to the requested
16 changes.
17

18 In its SE for the IMLTR, the NRC staff specified its approval by including several limitations and
19 conditions. Licensees referencing the IMLTR must demonstrate compliance with the limitations
20 and conditions to ensure that the licensee-specific application of the IMLTR is within the scope
21 of the NRC staff's approval.
22

23 Limitation 5 of the IMLTR, as modified by Supplement 2, imposes an additive penalty of 0.01 to
24 the cycle-specific SLMCPR for MELLLA+ applications at P/F ratios up to 42 MWt/(Mlbm/hr) and
25 an additive penalty of 0.02 for P/F ratios greater than 42 MWt/(Mlbm/hr). Removal of this
26 limitation requires NRC review and approval.
27

28 **3.0 TECHNICAL EVALUATION**

29 **3.1 Bundle Power Uncertainty**

30 As indicated in the NRC-approved GEH SLMCPR methodology TR NEDC-32601P-A and the
31 associated uncertainty treatments TR NEDC-32694P-A, the uncertainty in the bundle power is
32 factored into thermal limit calculations, such as the cycle-specific SLMCPR. [[
33
34
35
36
37
38
39
40
41
42
43
44
45

46]]

47
48 The uncertainty associated with predicting the four-bundle power via simulated TIP is typically
49 derived by averaging the readings from all string nodes across the core for a given exposure.
50 The bundle (also referred to as radial because of the axially integrated nature of the

- 10 -

1 measurement), axial, and nodal TIP uncertainties are in fact weighted averages of the nodal TIP
2 string data (e.g., calculated and measured) across the core and for all exposures. In the GEH
3 methodology, [[

4
5]]. The original value associated
6 with σ_{P4B} of [[]] was validated to be appropriate for application to more recent fuel
7 designs during the NRC staff review of the IMLTR.
8

9 The uncertainty associated with the [[
10]] surrounding the TIP cell was originally determined to be [[]], based
11 on [[]] in the original NEDC-32694P-
12 A evaluation. Via additional bundle-wise gamma scan data provided in Supplement 2, this
13 value for the [[]] was validated for 10x10 fuel designs and
14 operation at EPU conditions.
15

16 Because [[]] was not validated for operation beyond EPU conditions, it remains a
17 contributor to the cycle-specific SLMPCR adder for MELLLA+ operation. In an effort to
18 demonstrate the established [[]] remains applicable to MELLLA+
19 conditions and remove the cycle-specific SLMPCR adder, GEH presents within Supplement 6
20 the results of TIP measurement campaigns for several cores across several cycles preceding
21 entry into and within the MELLLA+ operating domain.
22

23 As discussed in Section 1.1.1, because TIP readings only provide relative four-bundle powers,
24 they cannot be used to ascertain the accuracy of bundle-by-bundle power prediction, nor can
25 they be used to establish [[]]. Bundle-wise gamma scan campaigns of fuel assemblies
26 depleted at MELLLA+ conditions are necessary to determine these values.
27

28 However, TIP data can provide insight as to whether uncertainties previously established via
29 historical bundle-wise gamma scan campaigns ought to remain applicable. In the present case
30 of Supplement 6, GEH uses TIP data in lieu of bundle-wise gamma scan data to justify the
31 continued use of the historically established [[]] in the MELLLA+ operating domain. This
32 approach has its basis in the relationship between the predicted versus measured TIP response
33 and [[]]. GEH identified this relationship in the response to request for additional
34 information (RAI) 25-2 of the IMLTR, documented in MFN 05-029 (Ref. 3):
35
36

37 [[
38
39]] If the
40 TIP response continues to confirm the methods adequacy, it is
41 statistically improbable that the [[]] would
42 need to be revised.
43
44

45 The NRC staff agrees with this assessment. [[
46
47

48]] The resulting four-bundle power as measured by the TIP
49 would then deviate from the predicted response. [[

- 12 -

1 ultimately manifest, which would be in opposition to GEH's approach of demonstrating
2 continued applicability of the historically established [[]] value. Therefore, the NRC staff
3 requested an explanation for the [[]] in RAI-3 (Ref. 10).

4
5 In the response to RAI-3, GEH provided [[
6]]. GEH indicated that
7 no discernible exacerbation of [[]] is observed when
8 comparing the non-MELLLA+ data to the MELLLA+ data. GEH concludes that, given the
9 consistent behavior between non-MELLLA+ and MELLLA+ data, the phenomena underlying the
10 [[]] will not ultimately manifest as [[
11]] with increasing P/F ratio. [[]] were included with each of the supplied
12 data plots, and the NRC staff compared these [[]] for each set of non-MELLLA+
13 and MELLLA+ data. The [[]] between the non-
14 MELLLA+ and MELLLA+ data are nearly identical. [[
15
16
17]]. The [[
18]] does not appear to be operating-domain dependent. Therefore,
19 the NRC staff agrees with GEH's conclusion that [[]] will
20 not manifest with increasing P/F ratio.

21 22 **3.1.1.2 Radial TIP RMS Versus Core Power-To-Flow Ratio**

23
24 The core P/F-ratio is routinely used as a proxy for void fraction and spectral conditions because
25 void fraction increases and the neutron spectrum becomes harder with increasing core P/F
26 ratio. Both of these are exacerbated at MELLLA+ operation, with maximum bundle exit void
27 fractions approaching values greater than 90 percent. The NRC staff examined the plots of
28 radial RMS versus core P/F ratio, and did not identify any obvious adverse trending, either
29 before entry into the MELLLA+ operating domain or after. Comparison of the MELLLA+ RMS
30 TIP data to that of the non-MELLLA+ data shows the spread of data is largely consistent from
31 pre- to post-MELLLA+ operation.

32
33 Examination of the radial RMS TIP plots indicates approximately [[]] are
34 associated with MELLLA+ operation, with [[]] of these data points associated with P/F ratios
35 greater than 42 MWt/(Mlbm/hr). Given that GEH's approach to removing the SLMCPR adder is
36 to demonstrate no adverse trends exist in radial TIP RMS at these higher P/F ratios, the NRC
37 staff requested justification via RAI-4 that the number of data points provided is statistically
38 sufficient. GEH's response to this RAI indicates the data points above the P/F ratio of 42
39 MWt/(Mlbm/hr) are a subset of the overall TIP RMS data used to assess trends, and that the
40 use of 42 MWt/(Mlbm/hr) as a delimiter exists only because it was identified as the upper bound
41 on previously submitted TIP RMS measurement data (i.e., Supplement 2). The P/F ratio of 42
42 MWt/(Mlbm/hr) does not reflect or imply any expected discontinuity of physical data, and
43 therefore the entirety of the data population should be used when assessing trends. The NRC
44 staff agrees with this assessment, albeit with one caveat: because MELLLA+ operation exhibits
45 higher void fractions and harder neutron spectra as a result of increased power densities and
46 reduced core flows, comparing TIP RMS data between non-MELLLA+ and MELLLA+ operation
47 provides insight into the neutronic methods' performance between the operating domains.
48 Therefore, in the present case, MELLLA+ TIP RMS data should be examined for trending by
49 itself and in comparison to non-MELLLA+ data. In light of this, the NRC staff finds that the

- 13 -

1 count of [[] associated with MELLLA+ operation, while on the smaller side, is
2 reasonably sufficient to assess trending within the MELLLA+ operating domain due to the span
3 of the P/F-ratios it encompasses.

4
5 While the plots of radial TIP RMS versus P/F ratio do not appear to indicate any adverse
6 trending in TIP response, they are not sufficiently detailed for NRC staff to conclude this is
7 actually the case. Such a conclusion requires a thorough statistical analysis of the TIP RMS
8 source data. Additionally, as mentioned above, the TIP RMS data were normalized to the
9 plant-specific average RMS over the cycles evaluated. GEH indicates there are many ways in
10 which each individual plant can yield consistently higher or lower errors in bundle power
11 prediction by way of TIP measurements (e.g., thermal versus gamma TIP type, TIP alignment,
12 failed TIPs, heat balance discrepancies, plant operation and flow miscalibration), and the
13 normalization was performed to show bundle power predictability across the fleet. For purposes
14 of comparing performance between plants, the NRC staff finds this approach acceptable.
15 However, the NRC staff observes that this is a deviation from the manner in which GEH has
16 historically presented TIP data, by using RMS percent. Therefore, the NRC staff requested the
17 normalized and non-normalized radial, axial, and nodal TIP RMS data be tabulated. GEH
18 supplied this tabulated data in their response to the RAI-5.

19
20 The NRC staff converted the supplied non-normalized radial RMS TIP data to RMS percent,
21 performed ordinary least squares linear regressions, and analyzed the residuals to identify any
22 statistically significant trending with increasing P/F ratio. These regression analyses were
23 performed on the aggregate of the radial TIP RMS percent data as well as on MELLLA+ and
24 non-MELLLA+ subsets of the data. The analyses demonstrated [[]

25]]. The NRC staff
26 did identify [[]

27]], indicating an increasing accuracy in
28 overall TIP response. It is therefore not counter to GEH's approach of demonstrating continued
29 applicability of the historical [[]]. Breaking down the MELLLA+ data into plant-specific
30 subsets and performing additional analyses revealed the downward trend is associated with the
31 TIP data collected from Monticello. For the remaining plants, the plant-specific MELLLA+ TIP
32 data is very consistently behaved. Figure 3-1, below, illustrates this.

33

1 [[

2]]

3 **Figure 3-1: Radial TIP RMS% versus Core Power-To-Flow-Ratio for MELLLA+ Data**

4
5 Comparisons of overall radial TIP RMS percent data trending between the non-MELLLA+ and
6 MELLLA+ operating domains indicate consistent behavior between both: [[
7]] across the entire range of core P/F ratios that exhibits an approximate [[
8]] in RMS percent. When the aggregate data spanning both operating domains is
9 examined, a similar [[]] is also observed. This consistent behavior
10 supports GEH's assertion that the neutronic methods performance is comparable regardless of
11 the operating domain.
12

13 **3.1.1.3 Radial TIP RMS Versus Exit Void Fraction**

14
15 The NRC staff examination of the plots of radial RMS versus average exit void fraction yielded
16 the same observations as the P/F ratio plots. The staff did not identify any obvious adverse
17 trending (either before entry into the MELLLA+ operating domain or after), and comparison of
18 the MELLLA+ RMS TIP data to that of the non-MELLLA+ data shows the spread of data is
19 largely consistent from pre- to post-MELLLA+ operation.
20

21 The NRC staff converted the non-normalized radial RMS TIP data supplied by GEH in the RAI-5
22 response to RMS percent, performed ordinary least squares linear regressions, and analyzed
23 the residuals to identify any statistically significant trending with increasing average exit void
24 fraction. These regression analyses were performed on the aggregate of the radial TIP RMS
25 percent data as well as on MELLLA+ and non-MELLLA+ subsets of the data. The analyses
26 demonstrated [[
27]]. The NRC staff did identify [[
28]],
29 indicating an increasing accuracy in overall TIP response. It is, therefore, not averse to GEH's
30 approach of demonstrating continued applicability of the historical [[]]. Breaking down the

1 MELLLA+ data into plant-specific subsets and performing additional analyses revealed the
2 plant-specific MELLLA+ TIP data is very well-behaved. Figure 3-2, below, illustrates this.
3
4 [[

5
6 **Figure 3-2:** Radial TIP RMS% versus Core Average Exit Void Fraction for MELLLA+ Data
7
8 Comparisons of overall radial TIP RMS percent data trending between the non-MELLLA+ and
9 MELLLA+ operating domains indicate consistent behavior between both: [[
10]]
11]] exists across the entire range of core average exit void fractions. The magnitude of
12 the trend's slope changes from the non-MELLLA+ data subset to the MELLLA+ data subset,
13 with the MELLLA+ data subset trend exhibiting [[
14]]. When the aggregate
15 data spanning both operating domains is examined, a very slight [[
16]] is
17 observed. This is a result of the relative abundance of MELLLA+ data obtained from Monticello
18 compared to non-MELLLA+ data. The trend is not statistically significant, and represents only a
19 [[
20]] percent across the range of exit void fractions. It is
21 virtually flat. This reasonably supports GEH's assertion that the neutronic methods performance
22 is comparable regardless of the operating domain.

21 **3.1.1.4 Comparison of TIP RMS Data to Experience Base**

22
23 The well-behaved nature of the radial TIP RMS percent MELLLA+ data and the consistent
24 behavior of the data across the operating domains are indicative of the [[
25]]. However, a key element in the
26 relationship between the predicted versus measured TIP response and [[
27]] as expressed
28 by GEH in the MFN 05-029 RAI 25-2 response of the IMLTR (and discussed in Section 3.1 of
29 this SE) is that the TIP response continues to confirm the methods adequacy. The NRC staff
30 agrees with this statement and interprets it to apply not only across operating domains within a
given dataset, but also from one dataset to another. In other words, the TIP performance as

1 demonstrated by the Supplement 6 TIP RMS data must be comparable to the historical TIP
2 performance as presented in the NEDC-32694P-A, IMLTR, and Supplement 2 evaluations.

3
4 Table 3.1 of the original NEDC-32694P-A evaluation presents the historical TIP data. The
5 currently accepted four-bundle power uncertainty σ_{P4B} of [[]] was determined in
6 NEDC-32694P-A by performing a weighted average of this historical TIP data. For comparison,
7 the NRC staff determined the value of σ_{P4B} for the Supplement 6 TIP RMS percent data using
8 the same calculation as in the original NEDC-32694P-A evaluation, weighting the number of
9 data points and TIP strings appropriately for each plant. The calculation yielded a σ_{P4B} value of
10 [[]]. This is greater than the accepted value and is inconsistent with the expected
11 reduction in σ_{P4B} when using the improved TGLBA06/PANAC11 code suite as observed in the
12 IMLTR and Supplement 2 evaluations; Table 2-5 of the IMLTR and Table 3-1 of Supplement 2
13 indicate σ_{P4B} values of [[]] and approximately [[]], respectively.

14
15 Given the analysis results discussed above, the NRC staff further investigated the
16 Supplement 6 TIP data, beginning with the four-bundle power uncertainty σ_{P4B} . While the
17 calculated Supplement 6 σ_{P4B} value of [[]] exceeds the accepted value from the
18 NEDC-32694P-A evaluation, it is possible the Supplement 6 result may represent a slightly
19 different value from the same uncertainty distribution as the original result. The NRC staff
20 performed an independent 2-sample t-test between the two datasets to determine if this was the
21 case. The analysis results showed the t-value for the datasets is approximately 3.1, exceeding
22 the critical value of 1.97 for significance level of 5 percent (performing the same analysis while
23 not assuming equal variances between the datasets exacerbated the results). Therefore, it
24 cannot be reasonably concluded that the Supplement 6 σ_{P4B} result is from the same uncertainty
25 distribution as the original NEDC-32694P-A result; the two results are not comparable.

26
27 While performing the independent 2-sample t-test, the NRC staff observed a portion of the
28 Supplement 6 radial TIP RMS percent data belonging to a single plant possessed significantly
29 greater RMS percent values than the rest of the data. This suggests at least one of the
30 plant-specific datasets is from a significantly different uncertainty distribution as compared with
31 the rest of the data. To explore this, the NRC staff performed a series of one-way analysis of
32 variance (ANOVA) tests on various combinations of the four plant-specific datasets. The results
33 of these ANOVA tests demonstrated the radial TIP RMS percent datasets from Monticello and
34 Nine Mile Point Unit 2 are significantly different from the Peach Bottom Units 2 and 3 datasets,
35 and the Peach Bottom Units 2 and 3 datasets are substantially similar.

36
37 Examination of the Monticello and Nine Mile Point Unit 2 datasets indicates they are comprised
38 of larger radial TIP RMS percent values, with means of [[]],
39 respectively, as compared to the Peach Bottom datasets, each of which have a mean of
40 approximately [[]]. This difference drives the calculated σ_{P4B} for the aggregate of
41 the Supplement 6 data higher than expected.

42
43 An explanation for the differences in average radial TIP RMS percent lies in the nature of the
44 TIP systems employed by the various plants comprising the datasets: Peach Bottom Units 2
45 and 3 utilize gamma TIPs while Monticello and Nine Mile Point Unit 2 utilize thermal TIPs. This
46 is the primary difference between the plants within the Supplement 6 data. It is known that
47 thermal TIPs possess a greater sensitivity (wider variability) than that of gamma TIPs, and it has
48 been observed they produce slightly larger power distribution uncertainties compared to gamma
49 TIPs. It is because of this sensitivity the NRC staff indicated within the SE for the IMLTR
50 (Ref. 3) that, for EPU/MELLLA+ applications involving plants with thermal TIPs, the

- 17 -

1 plant-specific TIP core-tracking data should be evaluated against compiled EPU Reference
2 Plant core-tracking data with the objective of determining whether power distribution
3 uncertainties need to be increased for cores with thermal TIPs installed.

4
5 However, it should be noted that the four-bundle power uncertainty as described in
6 NEDC-32694P-A is a modeling uncertainty. In other words, it is an uncertainty due solely to the
7 calculational variability of the code methods when predicting bundle power, making it equally
8 applicable to both thermal TIP and gamma TIP plants. Ideally, its value should not contain a
9 measurement uncertainty component. Nevertheless, the original NEDC-32694P-A evaluation
10 quantifying σ_{P4B} makes use of comparisons to measured TIP data, suggesting the σ_{P4B} value of
11 [[] contains a measurement uncertainty component. This is confirmed in GEH's
12 response to RAI II.3 of the NEDC-32694P-A review, which identifies the integral TIP
13 measurement uncertainty was estimated to be [[

14]]. After examining the
15 NEDC-32694P-A evaluation, it is the NRC staff's understanding that GEH utilized data obtained
16 from the more precise of the two TIP measurement systems (gamma TIPs) in order to minimize
17 the measurement uncertainty component.

18
19 In light of this, the NRC staff reached two conclusions. First, given the σ_{P4B} value of
20 [[] is representative of a calculational uncertainty that is equally applicable to both
21 thermal and gamma TIP plants, the thermal TIP data of Supplement 6 demonstrates there
22 exists a larger instrumentation measurement uncertainty for thermal TIPs than that which
23 appears to be currently incorporated into GEH's methods. Further assessment of this
24 measurement uncertainty is discussed in Section 3.1.1.5 of this SE. Second, for purposes of
25 assessing continued methods adequacy via comparison of power distribution uncertainties
26 between the Supplement 6 data and the historical database, the Supplement 6 gamma TIP and
27 thermal TIP data should be respectively compared to the historical gamma TIP and thermal TIP
28 data. This is further discussed below.

29
30 The NRC staff recalculated the Supplement 6 weighted average σ_{P4B} using only the radial
31 gamma TIP RMS percent data from the Peach Bottom Units 2 and 3 datasets. The updated
32 value for σ_{P4B} using gamma TIPs is [[]], which matches the accepted value of [[
33]]] and is comparable to the historic database. Similarly, the NRC staff recalculated the
34 Supplement 6 weighted average σ_{P4B} using only the radial thermal TIP RMS percent data from
35 the Monticello and Nine Mile Point, Unit 2 datasets. The updated value for σ_{P4B} using thermal
36 TIPs is [[]]. The historic database value for radial thermal TIP RMS percent is
37 [[]], and is determined from the Plant E data as tabulated in GEH's MFN 05-029
38 RAI 25-2 response of the IMLTR. The Supplement 6 radial thermal TIP RMS percent value and
39 the historic database value are reasonably comparable. These results indicate the Supplement
40 6 gamma TIP performance is consistent with the historic TIP performance and supports the
41 continued adequacy of the neutronic methods.

42 43 **3.1.1.5 Assessment of Thermal TIP Measurement Uncertainty**

44
45 As discussed in Section 3.1.1.4 of this SE, the thermal TIP datasets of Supplement 6 have
46 significantly different uncertainty distributions compared to those of the gamma TIP datasets
47 and exhibit larger radial TIP RMS percent means. Thermal TIP data is under-represented in the
48 historical database; the NRC staff was only able to identify "Plant E" of the IMLTR data as a
49 thermal TIP plant. It was with the assessment of the power distributions for this data that the
50 NRC staff initially concluded thermal TIPs may yield higher power distribution uncertainties.

- 18 -

1 This was documented by the NRC staff in the SE for the IMLTR along with the recommendation
2 that future EPU/MELLLA+ TIP data be examined to assess the need for increased uncertainties
3 for cores with thermal TIP systems. However, given that the historical σ_{P4B} value of
4 [[] is representative of a calculational uncertainty that is equally applicable to
5 both thermal and gamma TIP plants, the Supplement 6 thermal TIP data demonstrates there
6 exists a larger instrumentation measurement uncertainty for thermal TIPs than for gamma TIPs.

7
8 The NRC staff examined the SLMCPR methodology presented in NEDC-32601P-A and
9 identified that a [[]
10] are utilized in SLMCPR evaluations. However, to the best of the
11 NRC staff's knowledge, these uncertainty values are based upon gamma TIPs. To ensure
12 thermal limits are properly determined for cores operating with thermal TIPs in the MELLLA+
13 domain, the larger thermal TIP measurement uncertainty evidenced by the Supplement 6 data
14 must be quantified and applied in the GEH methods.

15
16 In the absence of additional thermal TIP data specifically taken with the purpose of quantifying
17 the measurement uncertainty (e.g., repeated readings for a single power level or comparisons
18 of thermal TIP responses located along an axis of symmetry), the NRC staff issued RAI-7
19 requesting quantification of thermal TIP measurement uncertainties or justification that the TIP
20 integral instrument and TIP random reading uncertainties, as tabulated in Table 2.1 of
21 NEDC-32601P-A, are applicable to thermal TIP plants.

22
23 In its response to RAI-7, GEH first clarified that the instrument uncertainty value of
24 2.6 percent is a statistical super position of the TIP geometrical uncertainty of 2.3 percent and
25 the random reading uncertainty of 1.2 percent. GEH's response also indicated that the source
26 of both the random and geometrical TIP signal uncertainties is Oyster Creek, which utilizes a
27 thermal TIP system. Therefore, the instrument uncertainty of 2.6 percent is conservative when
28 applied to gamma TIP detectors and representative of thermal TIP detectors. The NRC staff
29 finds this response acceptable.

1 **3.1.2 Conclusions for Core TIP Data**

2
3 As discussed in Section 3.1.1.2, the radial TIP RMS percent data presented for Supplement 6
4 does not exhibit any statistically significant adverse trending with core P/F ratio. The observed
5 trending is favorable and consistent across operating domains for both thermal and gamma
6 TIPs. Additionally, as discussed in Section 3.1.1.4, σ_{P4B} is a modeling uncertainty due solely to
7 the calculational variability of the code methods, making it equally applicable to both thermal TIP
8 and gamma TIP plants. Statistically significant differences between thermal TIP datasets and
9 gamma TIP datasets are due to the differences in the instrumentation measurement uncertainty.
10 Comparisons of the radial gamma TIP RMS percent data presented in Supplement 6 (which
11 minimizes the instrumentation measurement uncertainty) to the historical database for radial
12 gamma TIPs shows consistent results. Likewise, comparison of the radial thermal TIP RMS
13 percent data of Supplement 6 to Plant E of the historical database also shows consistent
14 results. This demonstrates the continued neutronics methods adequacy for the prediction of the
15 four-bundle power uncertainty.

16
17 Therefore, the NRC staff finds that the radial TIP RMS percent data and trending analyses
18 provide reasonable assurance the [[] is not increasing
19 with void fraction and the harder neutron spectral conditions in MELLLA+ applications and
20 therefore neither is the [[]]. The historically established
21 values for these uncertainties remain applicable at MELLLA+ conditions within the range of P/F
22 ratios examined. On this basis, the NRC staff approves the reduction of the SLMCPR adder for
23 MELLLA+ applications by a margin of 0.005. Additionally, the radial TIP RMS percent data
24 provided in Supplement 6 covers P/F ratios up to 50 MWt/(Mlbm/hr) without exhibiting any
25 statistically significant adverse trending. On this basis, the NRC staff approves a reduction of
26 the SLMCPR adder for P/F ratios greater than 42 MWt/(Mlbm/hr) by an additional margin of
27 0.005 for a total reduction of 0.01. Limitation 5 has been updated to reflect these changes.
28

29 **3.2 Overall Pin Power Peaking Uncertainty**

30
31 The cycle-specific SLMCPR adders applied above and below P/F ratios of 42 MWt/(Mlbm/hr)
32 are to account for, in part, the potential changes in both pin and bundle power uncertainties with
33 the higher void fractions and harder neutron spectral conditions that are characteristic of
34 operation in MELLLA+ conditions. The discussion presented in Supplement 6 for removal of the
35 SLMCPR adders focuses on bundle power uncertainty and does not address overall pin
36 peaking uncertainty. Therefore, justification for full removal of the penalty is incomplete. In
37 RAI-1, the NRC staff commented on this and sought justification that the overall pin power
38 peaking uncertainty does not change with increasing P/F ratios.

39
40 In response to RAI-1, GEH indicated the NRC staff's SE for Supplement 2 discusses how
41 postulated anomalies associated with the prediction of pin power distributions at MELLLA+
42 conditions could manifest if modeling assumptions are not valid, but that these anomalies would
43 affect the overall transport solution methodology and would be observable in detailed TIP
44 comparisons. Ergo, the behavior in overall pin power peaking uncertainty may be assessed via
45 the TIP data of Supplement 6. The NRC staff agrees. While TIP data does not provide a
46 means to quantify the overall pin power peaking uncertainty, if the overall transport solution
47 methodology were unable to effectively model the harsher conditions present at MELLLA+
48 operation, then the trending in pin power distribution would be adversely affected and manifest
49 in TIP data comparisons, primarily those of the radial TIP RMS percent because the data are
50 derived from axially integrated bundle powers. As discussed in Section 3.1.1.2 and

- 20 -

1 Section 3.1.1.3 of this SE, the radial TIP RMS percent comparisons are very good; no
2 statistically significant adverse trending with increasing core P/F or average exit void fraction is
3 observed. This supports GEH's assertion that the historically established value for the overall
4 pin power peaking uncertainty remains applicable for MELLLA+ applications.
5

6 **3.2.1 Assessment of Continued Accuracy of Nuclear Methods**

7

8 Because of the qualitative nature of the approach discussed above for the removal of those
9 portions of the SLMCPR adders due to uncertainty in overall pin power peaking, the NRC staff
10 chose to further assess the continued accuracy of the nuclear methods. To do so, the NRC
11 staff determined the Supplement 6 axial and nodal TIP RMS percent uncertainties and
12 compared the results to the historical data. The NRC staff's understanding of GEH's response
13 to RAI SRXB-A-27 (Ref. 11) of the IMLTR is that the acceptance criteria for power distribution
14 uncertainties obtained from core-tracking data is [[
15]]. Although the nodal RMS criterion is not reflected in any licensing analysis, GEH
16 indicated any nodal RMS values over [[]] observed consistently require further
17 examination as well as review of the nuclear methods accuracy.
18

19 The weighted axial TIP RMS percent and nodal TIP RMS percent for the Supplement 6 dataset
20 are [[]], respectively. Both of these uncertainties exceed the
21 respective acceptance criteria, and they are inconsistent with the historical database's axial and
22 nodal TIP RMS percent uncertainties of approximately [[]],
23 respectively. Regarding the nodal TIP RMS percent data, approximately 65 percent of the
24 values exceed the acceptance criterion.
25

26 While no adverse trending is observed in the Supplement 6 axial and nodal TIP RMS percent
27 data versus core P/F ratio and average exit void fraction, the overall higher uncertainties with
28 respect to the historical database indicate the nuclear methods accuracy may require
29 reassessment. The NRC staff inquired about the axial and nodal uncertainties in RAI-6.
30

31 GEH provided a detailed response to RAI-6. As an initial point of discussion, GEH's response
32 clarified the NRC staff's understanding regarding the axial and nodal power distribution
33 acceptance criteria by indicating the cited [[]] uncertainty is not actually an
34 acceptance criterion, nor is it associated with axial TIP RMS percent. The cited [[]]
35 uncertainty actually refers to the overall nodal RMS percent results for the reference BWRs
36 presented within the IMLTR. In other words, it was only a statement of observation. After
37 further examination of the context surrounding the development of RAI SRXB-A-27 (from which
38 the [[]] value was cited), the NRC staff agrees with this statement.
39

40 As a second point of discussion, GEH's response indicated the [[]] criterion for
41 nodal TIP RMS percent cited from RAI SRXB-A-27 was not intended to be applied as an
42 acceptance criterion on a plant-specific basis and exceeding this value consistently in a subset
43 of nuclear plants does not signify inadequacy of the nuclear methods for the purpose of
44 SLMCPR evaluations. In support of this statement, GEH's response emphasizes that the use of
45 an average RMS over a number of plants is the appropriate approach for quantifying overall
46 methods performance and associated uncertainty because of the plant-to-plant variability that is
47 often observed in TIP comparisons. The NRC staff agrees with this assessment; given the
48 variability that can exist in TIP comparisons from plant-to-plant, care should be taken when
49 applying a TIP-related acceptance criterion on a plant-specific basis (or a sufficiently small
50 subset) because it may not be appropriate.

- 21 -

1 GEH's response does not directly specify what constitutes a subset of nuclear plants. Strictly
2 speaking, the population of plants involved in a TIP data collection campaign can be considered
3 a subset by comparison to the operating fleet. Turning to precedent, the NRC staff notes the
4 TIP data from a population of 4 nuclear plants was used to validate the continued adequacy of
5 GEH's nuclear methods for the purpose of SLMCPR evaluations in the original review of the
6 IMLTR. Specifically, the response to MFN 05-029 RAI-25 determines the average weighted
7 radial TIP RMS percent uncertainty using [[]] collected from 4 plants across
8 7 cycles and compares the result to the [[]] acceptance criterion established in
9 NEDC-32694P-A. By comparison, Supplement 6 presents a larger database comprised of
10 [[]] collected from 4 plants across a total of 14 cycles. Thus, the NRC staff
11 finds the comparison of the Supplement 6 TIP dataset to historical method performance
12 observations is appropriate and the concern regarding the inconsistency in results to be valid.
13

14 The Supplement 6 dataset contains a larger portion of thermal TIP data compared to that of the
15 historical database. Additionally, as discussed in Section 3.1.1.5 of this SE, thermal TIPs
16 possess a higher measurement uncertainty. To assess if these observations might contribute to
17 the inconsistencies between the Supplement 6 and historical method performances, the NRC
18 staff grouped the Supplement 6 axial and nodal TIP RMS percent data into thermal and gamma
19 TIP sets. The weighted axial thermal TIP RMS percent uncertainty is [[]] and the
20 weighted nodal thermal TIP RMS percent uncertainty is [[]]. These results are
21 consistent with the historical IMLTR and Supplement 2 axial and nodal thermal TIP uncertainties
22 of approximately [[]], respectively. In contrast, the weighted axial
23 and nodal gamma TIP RMS percent uncertainties are not consistent with the historical data; the
24 Supplement 6 weighted axial and nodal gamma TIP RMS percent uncertainties are [[
25]], respectively, and the historical axial and nodal gamma TIP RMS
26 percent uncertainties are approximately [[]], respectively. The
27 results suggest [[
28]].
29]].
30

31 GEH's response to RAI-6 includes a similar analysis of the Supplement 6 TIP dataset. Axial
32 and nodal TIP RMS percent uncertainties for the entire Supplement 6 dataset are presented as
33 well as the uncertainties for thermal and gamma TIPs individually. The results of the analysis
34 are consistent with those of the NRC staff's, and GEH makes note of the same observations:
35 1) the axial and nodal RMS percent uncertainties for the Supplement 6 [[]] are
36 consistent with the historically reported values and 2) the axial and nodal RMS percent
37 uncertainties for the Supplement 6 [[]] the historically reported
38 values.
39

40 Anticipating the latter observation as a possible source of concern for the NRC staff, GEH's
41 response to RAI-6 stressed that care should be taken when trying to compare a subset of TIP
42 comparisons from a new population of plants to historical method performance observations on
43 an absolute basis so as not to assign differences that are expected in plant-to-plant variability to
44 differences in methods behavior. As an example, GEH indicated the [[]] plants from
45 which the Supplement 6 data are sourced, [[
46]]] both
47 before and after implementation of extended operating domains. If a degradation of nuclear
48 methods accuracy had occurred at any point, whether within the extended operating domains or
49 not, [[]] TIP uncertainties would be observed more generally across the nuclear fleet.

- 22 -

1
2 In support of these statements, the response to RAI-6 included three evaluations,
3 1) comparisons of TIP statistics from a new plant similar to the Supplement 6 [[]]
4 plants, 2) comparisons of TIP statistics for the Supplement 6 [[]] plants prior to
5 and

- 23 -

1 after implementation of extended operating domains, and 3) updated evaluations of TIP
2 statistics for the plants discussed in MFN 05-029 RAI-25. Each of these is discussed below.
3 The first evaluation introduces a new plant, referred to as "Plant F". Plant F is extremely similar
4 to [[
5]], and a rated power density of 56.8 kW/L. The average nodal TIP RMS
6 percent uncertainty for this plant is [[
7]], which is consistent with the historical
8 results. Given the substantially similar design of Plant F to [[
9]],
10 the results support the assertion that [[
11]].

11 The second evaluation provides comparisons of the [[
12]] nodal TIP
13 RMS percent uncertainty prior to and after the implementation of extended operating domains.
14 The comparisons show no trending from cycle-to-cycle. The magnitude of nodal TIP RMS
15 percent uncertainty from the comparisons ([[
16]]) is also comparable
17 to that of the NRC staff analysis discussed above [[
18]]. These results provide
19 additional support that [[
20]], and they are not a result of the implementation of expanded
21 operating domains.

22 In the final evaluation, the nodal TIP statistics for the plants from MFN 05-029 RAI-25 are
23 updated and compared to the original results. The updated nodal TIP RMS percent
24 uncertainties are all within approximately 1 percent of the historical values. The results support
25 the continued nuclear methods accuracy across the nuclear fleet.

26 Based on the three [[
27]] evaluations presented in the response to RAI-6, the NRC
28 staff finds [[
29]], are not the result of
30 implementing expanded operating domains and, in the present case, the nodal statistic
31 exceeding GEH's internal [[
32]] acceptance criterion does not signify inadequacy of
33 the nuclear methods for the purpose of SLMCPR evaluations. Noting the axial and nodal
34 [[
35]] RMS percent uncertainties are consistent with the historical database, the
36 NRC staff therefore also finds the axial and nodal TIP performance of the Supplement 6 dataset
37 are indicative of the continued adequacy of the nuclear methods performance.

38 Given the axial and nodal TIP performance of the Supplement 6 dataset and the lack of
39 statistically significant adverse trending of radial TIP RMS percent with increasing core
40 P/F or average exit void fraction, the NRC staff finds there is reasonable assurance the
41 historically established value for the overall pin power peaking uncertainty remains applicable
42 for MELLLA+ applications within the range of P/F ratios examined. On this basis, the NRC staff
43 approves the reduction of the SLMCPR adder for MELLLA+ applications by a margin of 0.005.
44 Additionally, the radial RMS percent data provided in Supplement 6 covers P/F ratios up to
45 50 MWt/(Mlbm/hr) without exhibiting any statistically significant adverse trending. On this basis,
46 the NRC staff approves a reduction of the SLMCPR adder for P/F ratios greater than
47 42 MWt/(Mlbm/hr) by an additional margin of 0.005 for a total reduction of 0.01. Limitation 5 has
48 been updated to reflect these changes.

49 **4.0 CONDITIONS AND LIMITATIONS**

The NRC staff has revised IMLTR SE Limitation 5 as follows.

1 Limitation 5 in Section 9.0 of the IMLTR SE as updated in Section 4.0 of the Supplement 2 SE
2 states:

3
4 5. SLMCPR 2

5
6 For operation at MELLLA+, including operation at the EPU power levels at the
7 achievable core flow state-point, a 0.01 value shall be added to the cycle-specific
8 SLMCPR value for power-to-flow ratios up to 42 MWt/(Mlbm/hr), and a 0.02
9 value shall be added to the cycle-specific SLMCPR value for power-to-flow ratios
10 above 42 MWt/(Mlbm/hr).

11
12 On the basis of the subject review as presented within this SE, the NRC staff finds that
13 Supplement 6 provides the additional data and analyses needed to justify, with reasonable
14 assurance, that the original power distribution uncertainties used in GEH's nuclear methods are
15 applicable to MELLLA+ operation within the range of P/F ratios examined (i.e.,
16 50MWt/(Mlbm/hr). Therefore, the NRC staff has revised Limitation 5 in Section 9.4 of the
17 IMLTR SE, as updated in Section 4.0 of the Supplement 2 SE, as follows:

18
19 5. SLMCPR 2

20
21 For operation at MELLLA+, including operation at the EPU power levels at the
22 achievable core flow state-point, a 0.01 value shall be added to the cycle-specific
23 SLMCPR value for P/F ratios greater than 50 MWt/(Mlbm/hr).

24
25 **5.0 CONCLUSIONS**

26
27 In Supplement 6, GEH presents radial, axial, and nodal TIP data for four plants with histories of
28 MELLLA+ operation. The TIP data span several cycles preceding entry into and within the
29 MELLLA+ operating domain, and each of the radial, axial, and nodal RMS data are plotted
30 versus core P/F ratio, exposure, core average void fraction, and average bundle exit void
31 fraction. These data were provided to demonstrate there is no increase in four-bundle power
32 uncertainty and overall pin power peaking uncertainty as a function of void fraction and spectral
33 conditions in the MELLLA+ operating domain for GEH's interim methods. Demonstrating no
34 adverse trending in these uncertainties will provide a basis for the removal of the SLMCPR
35 penalty that was introduced in the IMLTR review.

36
37 The trending analyses performed by the NRC staff on the radial, axial, and nodal TIP RMS
38 percent data supplied by GEH for the present review showed no statistically significant adverse
39 trending with core P/F ratio or core average exit void fraction. Therefore, for the P/F ratios
40 examined, it is unlikely that a four-bundle power uncertainty exceeding the acceptance criterion
41 of [[]] as determined in NEDC-32694P-A will be encountered at MELLLA+
42 conditions. Hence, the established value for the [[

43]] remains applicable. Similarly, it is unlikely that an overall pin power peaking
44 uncertainty exceeding the acceptance criterion of [[]] will be encountered, and
45 therefore the established value remains applicable. As a result, the NRC staff finds there is
46 reasonable assurance that the imposition of a SLMCPR adder for MELLLA+ conditions is
47 unnecessary within the range of power-to-flow ratios examined in this SE. This conclusion is
48 contingent upon the use of TGBLA06/PANAC11-based methods by the plant core monitoring
49 system, and plant operation within the existing P/F database. For MELLLA+ operation at P/F
50 ratios greater than the range examined in this SE, a cycle-specific SLMCPR adder of 0.01 is

- 25 -

- 1 applied. This value has its basis in the original 0.01 SLMCPR adder for MELLLA+ operation
- 2 imposed in the IMLTR to account for potential changes in both the pin and bundle power
- 3 uncertainties due to higher bundle P/F ratios.

- 26 -

1 **6.0 REFERENCES**
2

- 3 1. Request for Review and Approval of NEDC-33173P, Supplement 6, Revision 0,
4 "Applicability of GE Methods to Expanded Operating Domains – Removal of the Safety Limit
5 Minimum Critical Power Ratio (SLMCPR) Penalty," September 15, 2017 (ADAMS Accession
6 No. ML17261A068 (Publically Available)).
7
- 8 2. NEDC-33173P Supplement 6, Revision 0, "Applicability of GE Methods to Expanded
9 Operating Domains – Removal of the Safety Limit Minimum Critical Power Ratio (SLMCPR)
10 Penalty," September 2017 (ADAMS Package Accession No. ML17261A067 (Publically
11 Available)).
12
- 13 3. NEDC-33173P-A, Revision 4, "Applicability of GE Methods to Expanded Operating
14 Domains," November 2012 (ADAMS Accession No. ML12313A107/ML12313A106
15 (Publically Available/Non-Publically Available)).
16
- 17 4. NEDC-33173P-A, Supplement 2, Parts 1-3P-A, "Applicability of GE Methods to Expanded
18 Operating Domains – Power Distribution Validation for Confrontes," April 2012 (ADAMS
19 Package Accession No. ML121150469 (Publically Available)).
20
- 21 5. NUREG-800, "Standard Review Plan for the Review of Safety Analysis Reports for Nuclear
22 Power Plants: Light Water Reactor Edition" (ADAMS Accession No. ML070810350
23 (Publically Available)).
24
- 25 6. NEDE-30130-P-A, "Steady State Nuclear Methods," April 1985 (ADAMS Accession No.
26 ML070400570 (Non-Publically Available)) and NEDE-24011-P-A (GESTAR II),
27 Amendment 26, "Implementing Improved GE Steady-State Methods," August 1999
28 (MFN-033-99) (ADAMS Package Accession No. ML993230387/ML993220237 (Publically
29 Available/Non-Publically Available)).
30
- 31 7. NEDC-32601P-A, Revision 0 "Method and Uncertainties for Safety Limit MCPR Evaluation,"
32 August 1999 (ADAMS Accession No. ML003740145 (Non-Publically Available)).
33
- 34 8. NEDC-32694P-A, Revision 0, "Power Distribution Uncertainties for Safety Limit MCPR
35 Evaluation," August 1999 (ADAMS Accession No. ML003740151 (Non-Publically
36 Available)).
37
- 38 9. NEDC-33173 Supplement 2 Part 1P-A, Revision 1, "Applicability of GE Methods to
39 Expanded Operating Domains – Power Distribution Validation for Concretres Cycle 13,"
40 April 2012 (ADAMS Accession No. ML12115A227/ML12115A234 (Publically
41 Available/Non-Publically Available)).
42
- 43 10. GE-Hitachi Nuclear Energy Letter (M190017) to NRC Dated February 13, 2019, "Response
44 to Request for Additional Information for NEDC-33173, Supplement 6, Revision 0,
45 'Applicability of GE Methods to Expanded Operating Domains – Removal of the Safety Limit
46 Minimum Critical Power Ratio (SLMCPR) Penalty' (EPID No. L-2017-TOP-0040)" (ADAMS
47 Package Accession No. ML19053A424/ML19053A425 (Publically Available/Non-Publically
48 Available)).
49
- 50 11. Entergy Letter (BVY 05-072) to NRC dated August 1, 2005, "Vermont Yankee Nuclear
51 Power Station, Technical Specification Proposed Change No. 263, Supplement No. 30,

- 27 -

- 1 Extended Power Uprate – Response to Request for Additional Information” (ADAMS
- 2 Accession No. ML052170310 (Non-Publically Available)).
- 3
- 4 Principal Contributor: A. Kevin Heller
- 5
- 6 Date: March 26, 2019