

Clinton Power Station
8401 Power Road
Clinton, IL 61727



Exelon Generation®

U-604478

April 17, 2019

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555-0001

Clinton Power Station, Unit 1
Facility Operating License No. NPF-62
NRC Docket No. 50-461

Subject: Notification of Readiness for NRC 95001 Inspection (EA-18-104)

Reference: Letter from Darrell J. Roberts (NRC) to Bryan C. Hanson (EGC), "Clinton Power Station - Final Significance Determination of a White Finding with Assessment Follow-Up and Notice of Violation; NRC Inspection Report No. 05000461/2018092," dated April 1, 2019

In the referenced letter, Exelon Generation Company, LLC (EGC) was informed of the final significance determination of a finding involving the Division 2 Emergency Diesel Generator (EDG). The letter states that the finding is associated with the failure to follow applicable procedures that resulted in the unavailability and inoperability of the Division 2 EDG while the Division 1 EDG was already out-of-service for planned maintenance. The NRC determined the finding was appropriately characterized as White, a finding of low to moderate safety significance. As a result, the NRC assessed the Clinton Power Station to be in the Regulatory Response column of the NRC's Action Matrix, effective the third quarter of 2018.

Because of being placed in the Regulatory Response column of the NRC's Action Matrix, the NRC informed EGC of their plans to conduct a supplemental inspection using Inspection Procedure (IP) 95001, "Supplemental Inspection Response to Action Matrix Column 2 Inputs," when EGC's staff had notified the NRC of its readiness for this inspection.

This letter serves as notification of EGC's readiness for a supplemental inspection using NRC IP 95001 at the Clinton Power Station as requested by the referenced letter.

IEDI
NRR

U-604478
U.S. Nuclear Regulatory Commission
Page 2

There are no regulatory commitments contained in this letter. If you have any questions, please contact Mr. Dale A. Shelton, Regulatory Assurance Manager, at (217) 937-2800.

Respectfully,

A handwritten signature in black ink, appearing to read 'T. Stoner', with a long horizontal flourish extending to the right.

Theodore R. Stoner
Site Vice President
Clinton Power Station

cc: Regional Administrator - NRC Region III
NRC Project Manager, NRR - Clinton Power Station
NRC Senior Resident Inspector - Clinton Power Station
Mr. Kenneth Riemer, Chief, Branch 1, Division of Reactor Projects – NRC Region III