

PUBLIC SUBMISSION

SUNSI Review Complete
Template = ADM-013
E-RIDS=ADM-03
ADD: Ian Tseng, Jazel Parks,
Tom Boyce

COMMENT (2)
PUBLICATION DATE:
2/27/2019
CITATION 84 FR 6444

As of: 4/30/19 7:28 AM Received: April 26, 2019 Status: Pending_Post Tracking No. 1k3-99kj-4zaa Comments Due: April 29, 2019 Submission Type: Web

Docket: NRC-2019-0061

Seismic Qualification of Electrical and Active Mechanical Equipment and Functional Qualification of Active Mechanical Equipment for Nuclear Power Plants

Comment On: NRC-2019-0061-0001

Seismic Qualification of Electrical and Active Mechanical Equipment and Functional Qualification of Active Mechanical Equipment for Nuclear Power Plants

Document: NRC-2019-0061-DRAFT-0002

Comment on FR Doc # 2019-03338

Submitter Information

Name: Chris Riedl

Address:

1101 Market Street
Chattanooga, 37402

Email: cjriedl@tva.gov

General Comment

TVA Comments April 26, 2019 in attached letter.

Attachments

CNL-19-049 TVA Comments on DG-1328



Tennessee Valley Authority, 1101 Market Street, Chattanooga, Tennessee 37402

CNL-19-049

April 26, 2019

84 FR 6444

Office of Administration
Mail Stop: TWFN-7-A60M
U.S. Nuclear Regulatory Commission
Washington, DC 20555-0001

ATTN: Program Management, Announcements and Editing Staff.

Subject: **Tennessee Valley Authority Comments on Draft Regulatory Guide DG-1328, "Seismic Qualification of Electrical and Active Mechanical Equipment and Functional Qualification of Active Mechanical Equipment for Nuclear Power Plants" (Docket ID NRC-2019-0061)**

Reference: 84 FR 6444, "Seismic Qualification of Electrical and Active Mechanical Equipment and Functional Qualification of Active Mechanical Equipment for Nuclear Power Plants," draft regulatory guide request for comment dated February 27, 2019

In the referenced Federal Register notice, the U.S. Nuclear Regulatory Commission (NRC) requested comments on the draft regulatory guide (DG), DG-1328, "Seismic Qualification of Electrical and Active Mechanical Equipment and Functional Qualification of Active Mechanical Equipment for Nuclear Power Plants," Docket ID NRC-2019-0061.

Tennessee Valley Authority (TVA) has one comment on the draft regulatory guide. The first sentence in section 1.2.1 should be changed to replace "electrical" with "mechanical" in two locations, as indicated below.

ASME QME-1-2017 is, in general, acceptable to the NRC staff for the seismic qualification of (1) ~~electrical~~ **mechanical** equipment in new NPPs and (2) new or replacement ~~electrical~~ **mechanical** equipment in operating NPPs, subject to the provisions found below.

There are no new regulatory commitments made in this letter. Please address any questions regarding this correspondence to Chris Riedl at 423-751-3835.

Respectfully,

A handwritten signature in blue ink, appearing to read "E. K. Henderson", is written over a horizontal line.

E. K. Henderson
Director, Nuclear Regulatory Affairs

cc: <http://www.regulations.gov>