



T.S. 6.9.1.12

LG-19-042

May 10, 2019

Attn: Document Control Desk  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555-0001

Limerick Generating Station, Unit 2  
Renewed Facility Operating License No NPF-85  
NRC Docket Nos. 50-353

Subject: Issuance of the Core Operating Limits Report (COLR) for Unit 2 Reload 15, Cycle 16

Enclosed is a copy of the Core Operating Limits Report (COLR) for Limerick Generating Station (LGS) Unit 2 Reload 15, Cycle 16 which incorporates the revised cycle specific parameters resulting from the new configuration implemented for LGS, Unit 2.

The COLR is being submitted to the NRC in accordance with LGS, Unit 2 Technical Specification 6.9.1.12.

If you have any questions or require additional information, please contact Shawn Pinney at 610-718-3560.

Respectfully,

A handwritten signature in black ink, appearing to read "R. Libra".







Richard W. Libra  
Site Vice President-Limerick Generating Station  
Exelon Generation Company, LLC

Attachment: Core Operating Limits Report for Limerick Generating Station Unit 2 Reload 15, Cycle 16

cc: D. Lew, Administrator, Region I, USNRC (w/attachments)  
S. Rutenkroger, USNRC Sr. Resident Inspector, LGS (w/attachments)  
V. Sreenivas, USNRC Project Manager for LGS (w/attachments)  
R. Janati, PADEP-BRP (w/attachments)

**CORE OPERATING LIMITS REPORT**  
**FOR**  
**LIMERICK GENERATING STATION UNIT 2**  
**RELOAD 15, CYCLE 16**

(This is a complete re-write; no annotations are used.)

Prepared By:	 _____	Date:	<u>29-APR-19</u>
	T. Ahn Preparer		
Reviewed By:	 _____	Date:	<u>April 29, 2019</u>
	K. Pfingsten Independent Reviewer		
Reviewed By:	 _____	Date:	<u>4/29/2019</u>
	T. Gutowski Reactor Engineering		
Reviewed By:	 _____	Date:	<u>4/29/2019</u>
	B. Sarikaya Engineering Safety Analysis		
Approved By:	 _____	Date:	<u>4/29/2019</u>
	K. McCoskey for A. Johnson Sr. Manager - BWR Cycle Management		
Station Qualified Reviewed By:	 _____	Date:	<u>4/30/2019</u>
	D. Doran Station Qualified Reviewer		

**Table of Contents**

	<u>Page</u>
Revision History	3
List of Tables	4
1.0 Terms and Definitions	5
2.0 General Information	7
3.0 MAPLHGR Limits	8
4.0 MCPR Limits	9
5.0 LHGR Limits	13
6.0 Control Rod Block Setpoints	16
7.0 Turbine Bypass Valve Parameters	18
8.0 Stability Protection Setpoints	19
9.0 Modes of Operation	20
10.0 Methodology	21
11.0 References	21

**Revision History**

**Revision**

**Description**

Revision 13

New issue for Cycle 16

**List of Tables**

	<u>Page</u>
TABLE 3-1 MAPLHGR versus Average Planar Exposure	8
TABLE 3-2 MAPLHGR Single Loop Operation (SLO) Multiplier	8
TABLE 4-1 Operating Limit Minimum Critical Power Ratio (OLMCPR)	10
TABLE 4-2 Power Dependent MCPR Limits and Multipliers MCPR(P) and $K_p$	11
TABLE 4-3 Flow Dependent MCPR Limits MCPR(F)	12
TABLE 4-4 Single Loop Operation (SLO) Flow Dependent MCPR Limits MCPR(F)	12
TABLE 5-1 Linear Heat Generation Rate Limits – UO <sub>2</sub> Rods	13
TABLE 5-2 Linear Heat Generation Rate Limits – Gad Rods	13
TABLE 5-3 LHGR Single Loop Operation (SLO) Multiplier	14
TABLE 5-4 Power Dependent LHGR Multiplier LHGRFAC(P)	14
TABLE 5-5 Flow Dependent LHGR Multiplier LHGRFAC(F)	15
TABLE 6-1 Rod Block Monitor Setpoints	16
TABLE 6-2 Reactor Coolant System Recirculation Flow Upscale Trip	17
TABLE 6-3 RBM Operability Limits	17
TABLE 7-1 Turbine Bypass System Response Time	18
TABLE 7-2 Minimum Required Bypass Valves to Maintain System Operability	18
TABLE 8-1 OPRM PBDA Trip Setpoints	19
TABLE 9-1 Modes of Operation	20
TABLE 9-2 “BASE” EOOS Option – Included Conditions	20

## 1.0 Terms and Definitions

APRM	Average Power Range Monitor
ARTS	APRM, RBM, and Technical Specification Improvement Program
BASE	This condition is defined by a group of individual operating conditions that are applicable to all Modes of Operation discussed in Section 9. The “BASE” condition includes the EOOS conditions provided in Table 9-2 as well as operation with FWHOOS/FFWTR.
DLO	Dual Loop Operation
DTSP	Rod Block Monitor Downscale Trip Setpoint
EOOS	Equipment Out of Service
EOR	End of Rated, the cycle exposure at which reactor power is equal to rated thermal power with recirculation system flow equal to 100%, all control rods fully withdrawn, all feedwater heating in service and equilibrium xenon.
FFWTR	Final Feedwater Temperature Reduction
FWHOOS	Feedwater Heater(s) Out of Service
HTSP	Rod Block Monitor High Trip Setpoint
ICF	Increased Core Flow
ITSP	Rod Block Monitor Intermediate Trip Setpoint
K <sub>p</sub>	Off-rated power dependent OLMCPR multiplier
LHGR	Linear Heat Generation Rate
LHGRFAC(F)	ARTS LHGR flow dependent multipliers
LHGRFAC(P)	ARTS LHGR power dependent multipliers
LTSP	Rod Block Monitor Low Trip Setpoint
MAPFAC(F)	Off-rated flow dependent MAPLHGR multiplier
MAPFAC(P)	Off-rated power dependent MAPLHGR multiplier
MAPLHGR	Maximum Average Planar Linear Heat Generation Rate
MCPR	Minimum Critical Power Ratio
MCPR(F)	Off-rated flow dependent OLMCPR

MCPR(P)	Off-rated power dependent OLMCPR
MELLLA	Maximum Extended Load Line Limit Analysis
MSIVOOS	Main Steam Isolation Valve Out of Service
OLMCPR	Operating Limit Minimum Critical Power Ratio
OOS	Out of Service
OPRM	Oscillation Power Range Monitor
PBDA	Period Based Detection Algorithm
PLUOOS	Power Load Unbalance Out of Service
PROOS	Pressure Regulator Out of Service
RBM	Rod Block Monitor
RPTOOS	Recirculation Pump Trip Out of Service
RWE	Rod Withdrawal Error
SLO	Single Loop Operation
SRVOOS	Safety Relief Valve Out of Service
TBSOOS	Turbine Bypass System Out of Service
TBVOOS	Turbine Bypass Valve(s) Out of Service
TCV	Turbine Control Valve
TCV/TSVOOS	1 Turbine Control Valve Out of Service and/or 1 Turbine Stop Valve Out of Service
TSV	Turbine Stop Valve

## 2.0 General Information

This report provides the following cycle-specific parameter limits for Limerick Generating Station Unit 2 Cycle 16:

- MAPLHGR
- OLMCPR
- SLO OLMCPR
- Off-rated OLMCPR (MCPR(P) or MCPR(F))
- Off-rated OLMCPR multipliers ( $K_p$ )
- Off-rated LHGR multipliers (LHGRFAC(P) or LHGRFAC(F))
- RBM setpoints
- RBM operability MCPR limits
- MAPLHGR SLO multiplier
- LHGR SLO multiplier
- LHGR
- Turbine Bypass Valve parameters
- Reactor Coolant System Recirculation Flow Upscale Trip and Allowable Value
- OPRM PBDA Setpoints

This report is prepared in accordance with Technical Specification 6.9.1.9 of Reference 1. Preparation of this report was performed in accordance with Exelon Nuclear, Nuclear Fuels T&RM NF-AB-120-3600. The core operating limits have been determined using NRC-approved methodology (Methodologies 1 and 2) and are established such that all applicable limits of the plant safety analysis are met (Reference 2).

The data presented in this report is valid for all licensed operating domains on the operating map, including:

- Maximum Extended Load Line Limit down to 82.9% of rated core flow during full power operation
- ICF up to 110% of rated core flow
- FFWTR up to 105°F during cycle extension operation
- FWHOOS up to 60°F feedwater temperature reduction at any time during the cycle prior to cycle extension
- End-of-cycle power coastdown operation to a minimum power level of 40% of rated thermal power

The Limerick Unit 2 Cycle 16 core is comprised entirely of GNF2 fuel. Further information on the cycle specific analyses for Limerick 2 Cycle 16 and the associated operating domains discussed above is available in Reference 2.



**3.0 MAPLHGR Limits**

3.1 Technical Specification

Section 3.2.1

3.2 Description

The limiting MAPLHGR value for the most limiting lattice of GNF2 fuel as a function of average planar exposure is given in Table 3-1. For single loop operation, a multiplier is used, which is shown in Table 3-2. The power and flow dependent LHGR multipliers are sufficient to provide adequate protection for the off-rated conditions and there is no need for off-rated MAPLHGR multipliers in addition to the off-rated LHGR multipliers; therefore, MAPFAC(P) and MAPFAC(F) are equal to 1.0 for all power and flow conditions (Reference 2). LHGRFAC(P) and LHGRFAC(F) are addressed in Section 5.0.

**TABLE 3-1  
 MAPLHGR versus Average Planar Exposure  
 (Reference 2)**

Average Planar Exposure (GWD/ST)	MAPLHGR Limit (kW/ft)
0.0	13.78
17.52	13.78
60.78	7.50
63.50	6.69

**TABLE 3-2  
 MAPLHGR Single Loop Operation (SLO) Multiplier  
 (Reference 2)**

SLO Multiplier	0.80
----------------	------

## 4.0 MCPR Limits

### 4.1 Technical Specification

Section 3.2.3

### 4.2 Description

The OLMCPR for GNF2 fuel is provided in Table 4-1. These values are determined by the cycle-specific reload analyses in Reference 2 and are valid for all Cycle 16 operating domains. The maximum scram insertion time verification is required per Technical Specification 3.1.3.2. Tau, a measure of scram time performance, is determined based on the cumulative scram time test results. The calculation of Tau shall be performed in accordance with site procedures. Linear interpolation shall be used to calculate the OLMCPR value if Tau is between 0.0 (Tau Option B) and 1.0 (Tau Option A). Table 4-1 includes treatment of these MCPR limits for all conditions listed in Section 9.0, Modes of Operation. Limerick Unit 2 Cycle 16 has a mid-cycle breakpoint, as defined in Table 4-1.

ARTS provides for power and flow dependent thermal limit adjustments and multipliers, which allow for an improved administration of the MCPR thermal limit. The flow dependent OLMCPR, MCPR(F), is sufficiently generic to apply to all operating domains. MCPR(P) and MCPR(F) are independent of Scram Time Option. In addition, there are ten sets of power dependent MCPR multipliers (Kp) for use with BASE, TBSOOS, RPTOOS, and PROOS equipment out of service combinations, in both DLO and SLO, as well as PROOS+TBSOOS and PROOS+RPTOOS equipment out of service combinations for DLO only. The PROOS+TBSOOS and PROOS+RPTOOS combinations were developed by selecting the more limiting OLMCPR from the PROOS condition and the other EOOS condition (TBSOOS or RPTOOS) (Reference 8). Section 7.0 contains the conditions for Turbine Bypass Valve Operability. MCPR(P) and MCPR(F) OLMCPRs are provided in Tables 4-2, 4-3, and 4-4, and Kp values are provided in Table 4-3 (References 2 and 8). The OLMCPR is determined for a given power and flow condition by evaluating the power dependent MCPR and the flow dependent MCPR and selecting the greater of the two.

**TABLE 4-1**  
**Operating Limit Minimum Critical Power Ratio (OLMCPR)**  
**(References 2 and 8)**

EOOS Combination	SCRAM Time Option <sup>1</sup>	Cycle Exposure	
		< EOR – 4202 MWd/ST	≥ EOR – 4202 MWd/ST
BASE	B	1.35	1.39
	A	1.43	1.47
BASE SLO <sup>2</sup>	B	1.60	1.60
	A	1.60	1.60
TBSOOS	B	1.37	1.44
	A	1.46	1.53
TBSOOS SLO <sup>2</sup>	B	1.60	1.60
	A	1.60	1.60
RPTOOS	B	1.38	1.40
	A	1.55	1.57
RPTOOS SLO <sup>2</sup>	B	1.60	1.60
	A	1.60	1.61
PROOS	B	1.35	1.39
	A	1.43	1.47
PROOS SLO <sup>2</sup>	B	1.60	1.60
	A	1.60	1.60
PROOS+TBSOOS	B	1.37	1.44
PROOS+RPTOOS	B	1.38	1.40

---

<sup>1</sup> When Tau does not equal 0 or 1, determine OLMCPR via linear interpolation.

<sup>2</sup> For single-loop operation, the MCPR operating limit is 0.04 greater than the analyzed two loop value. However, a minimum value of 1.60 is required to obtain an OLMCPR limit set by the Single Loop Operation Recirculation Pump Seizure Event.

**TABLE 4-2**  
**Power Dependent MCPR Limits and Multipliers MCPR(P) and Kp**  
 (References 2 and 8)

EOOS Combination	Core Flow (% of rated)	Core Thermal Power (% of rated)						
		0	25	≤ 30	> 30	65	85	100
		MCPR(P)			Operating Limit MCPR Multiplier, Kp			
Base	< 60	2.52	2.52	2.42	1.340	1.131	1.067	1.000
	≥ 60	2.78	2.78	2.57				
Base SLO	< 60	2.56	2.56	2.46	1.340	1.131	1.067	1.000
	≥ 60	2.82	2.82	2.61				
TBSOOS	< 60	3.28	3.28	2.78	1.340	1.131	1.067	1.000
	≥ 60	3.78	3.78	3.28				
TBSOOS SLO	< 60	3.32	3.32	2.82	1.340	1.131	1.067	1.000
	≥ 60	3.82	3.82	3.32				
RPTOOS	< 60	2.52	2.52	2.42	1.340	1.131	1.067	1.000
	≥ 60	2.78	2.78	2.57				
RPTOOS SLO	< 60	2.56	2.56	2.46	1.340	1.131	1.067	1.000
	≥ 60	2.82	2.82	2.61				
PROOS	< 60	2.52	2.52	2.42	1.367	1.236	1.160	1.000
	≥ 60	2.78	2.78	2.57				
PROOS SLO	< 60	2.56	2.56	2.46	1.367	1.236	1.160	1.000
	≥ 60	2.82	2.82	2.61				
PROOS+TBSOOS	< 60	3.28	3.28	2.78	1.367	1.236	1.160	1.000
	≥ 60	3.78	3.78	3.28				
PROOS+RPTOOS	< 60	2.52	2.52	2.42	1.367	1.236	1.160	1.000
	≥ 60	2.78	2.78	2.57				

**TABLE 4-3**  
**Flow Dependent MCPR Limits MCPR(F)**  
**(Reference 2)**

<b>Flow (% rated)</b>	<b>MCPR(F) Limit</b>
0.0	1.70
30.0	1.53
79.0	1.25
110.0	1.25

**TABLE 4-4**  
**Single Loop Operation (SLO) Flow Dependent MCPR Limits MCPR(F)**  
**(Reference 2)**

<b>Flow (% rated)</b>	<b>MCPR(F) Limit</b>
0.0	1.74
30.0	1.57
79.0	1.29
110.0	1.29

**5.0 LHGR Limits**

5.1 Technical Specification

Section 3.2.4

5.2 Description

The LHGR limit for the GNF2 fuel type is the product of the exposure dependent LHGR limit (from Table 5-1 for UO<sub>2</sub> fuel rods and Table 5-2 for Gadolinia fuel rods) and the minimum of: the power dependent LHGR Factor, LHGRFAC(P), and the flow dependent LHGR Factor, LHGRFAC(F). For single loop operation, a multiplier is used, which is shown in Table 5-3 and applied in Table 5-5. No further Single Loop Operating multipliers need to be applied to the values in Tables 5-4 and 5-5.

ARTS provides for power and flow dependent thermal limit multipliers, which allow for an improved administration of the LHGR thermal limits. There are two sets of flow dependent LHGR multipliers for dual loop and single loop operation. In addition, there are ten sets of power dependent LHGR multipliers for use with BASE, TBSOOS, RPTOOS, and PROOS equipment out of service combinations, in both DLO and SLO, as well as PROOS+TBSOOS and PROOS+RPTOOS equipment out of service combinations for DLO only. The PROOS+TBSOOS and PROOS+RPTOOS combinations were developed by selecting the more limiting LHGRFAC(P) from the PROOS condition and the other EOOS condition (TBSOOS or RPTOOS) (Reference 8). Section 7.0 contains the conditions for Turbine Bypass Valve Operability. The ARTS LHGR multipliers are shown in Tables 5-4 and 5-5 and are applicable to all operating domains. Linear interpolation should be used for points not listed in Appendix B of Reference 7.

Thermal limit monitoring must be performed with the more limiting LHGR limit resulting from the power and flow biased calculation.

**TABLE 5-1**  
**Linear Heat Generation Rate Limits – UO<sub>2</sub> Rods**  
 (References 5 and 7)

Fuel Type	LHGR
GNF2	See Table B-1 of Reference 7

**TABLE 5-2**  
**Linear Heat Generation Rate Limits – Gad Rods**  
 (References 5 and 7)

Fuel Type	LHGR
GNF2	See Table B-2 of Reference 7

**TABLE 5-3**  
**LHGR Single Loop Operation (SLO) Multiplier**  
 (Reference 2)

SLO Multiplier	0.80
----------------	------

**TABLE 5-4**  
**Power Dependent LHGR Multiplier LHGRFAC(P)**  
 (References 2 and 8)

EOOS Combination	Core Flow (% of rated)	Core Thermal Power (% of rated)																																																																																																																						
		0	25	≤ 30	> 30	65	85	100																																																																																																																
		LHGRFAC(P) Multiplier																																																																																																																						
BASE	< 60	0.485	0.485	0.490	0.750	0.817	0.922	1.000																																																																																																																
	≥ 60	0.434	0.434	0.473					BASE SLO	< 60	0.485	0.485	0.490	0.750	0.817	0.922	1.000	≥ 60	0.434	0.434	0.473	TBSOOS	< 60	0.463	0.463	0.490	0.750	0.817	0.922	1.000	≥ 60	0.352	0.352	0.386	TBSOOS SLO	< 60	0.463	0.463	0.490	0.750	0.817	0.922	1.000	≥ 60	0.352	0.352	0.386	RPTOOS	< 60	0.485	0.485	0.490	0.750	0.817	0.922	1.000	≥ 60	0.434	0.434	0.473	RPTOOS SLO	< 60	0.485	0.485	0.490	0.750	0.817	0.922	1.000	≥ 60	0.434	0.434	0.473	PROOS	< 60	0.485	0.485	0.490	0.725	0.817	0.922	1.000	≥ 60	0.434	0.434	0.473	PROOS SLO	< 60	0.485	0.485	0.490	0.725	0.817	0.922	1.000	≥ 60	0.434	0.434	0.473	PROOS+TBSOOS	< 60	0.463	0.463	0.490	0.725	0.817	0.922	1.000	≥ 60	0.352	0.352	0.386	PROOS+RPTOOS	< 60	0.485	0.485	0.490	0.725	0.817	0.922
BASE SLO	< 60	0.485	0.485	0.490	0.750	0.817	0.922	1.000																																																																																																																
	≥ 60	0.434	0.434	0.473					TBSOOS	< 60	0.463	0.463	0.490	0.750	0.817	0.922	1.000	≥ 60	0.352	0.352	0.386	TBSOOS SLO	< 60	0.463	0.463	0.490	0.750	0.817	0.922	1.000	≥ 60	0.352	0.352	0.386	RPTOOS	< 60	0.485	0.485	0.490	0.750	0.817	0.922	1.000	≥ 60	0.434	0.434	0.473	RPTOOS SLO	< 60	0.485	0.485	0.490	0.750	0.817	0.922	1.000	≥ 60	0.434	0.434	0.473	PROOS	< 60	0.485	0.485	0.490	0.725	0.817	0.922	1.000	≥ 60	0.434	0.434	0.473	PROOS SLO	< 60	0.485	0.485	0.490	0.725	0.817	0.922	1.000	≥ 60	0.434	0.434	0.473	PROOS+TBSOOS	< 60	0.463	0.463	0.490	0.725	0.817	0.922	1.000	≥ 60	0.352	0.352	0.386	PROOS+RPTOOS	< 60	0.485	0.485	0.490	0.725	0.817	0.922	1.000	≥ 60	0.434	0.434	0.473								
TBSOOS	< 60	0.463	0.463	0.490	0.750	0.817	0.922	1.000																																																																																																																
	≥ 60	0.352	0.352	0.386					TBSOOS SLO	< 60	0.463	0.463	0.490	0.750	0.817	0.922	1.000	≥ 60	0.352	0.352	0.386	RPTOOS	< 60	0.485	0.485	0.490	0.750	0.817	0.922	1.000	≥ 60	0.434	0.434	0.473	RPTOOS SLO	< 60	0.485	0.485	0.490	0.750	0.817	0.922	1.000	≥ 60	0.434	0.434	0.473	PROOS	< 60	0.485	0.485	0.490	0.725	0.817	0.922	1.000	≥ 60	0.434	0.434	0.473	PROOS SLO	< 60	0.485	0.485	0.490	0.725	0.817	0.922	1.000	≥ 60	0.434	0.434	0.473	PROOS+TBSOOS	< 60	0.463	0.463	0.490	0.725	0.817	0.922	1.000	≥ 60	0.352	0.352	0.386	PROOS+RPTOOS	< 60	0.485	0.485	0.490	0.725	0.817	0.922	1.000	≥ 60	0.434	0.434	0.473																					
TBSOOS SLO	< 60	0.463	0.463	0.490	0.750	0.817	0.922	1.000																																																																																																																
	≥ 60	0.352	0.352	0.386					RPTOOS	< 60	0.485	0.485	0.490	0.750	0.817	0.922	1.000	≥ 60	0.434	0.434	0.473	RPTOOS SLO	< 60	0.485	0.485	0.490	0.750	0.817	0.922	1.000	≥ 60	0.434	0.434	0.473	PROOS	< 60	0.485	0.485	0.490	0.725	0.817	0.922	1.000	≥ 60	0.434	0.434	0.473	PROOS SLO	< 60	0.485	0.485	0.490	0.725	0.817	0.922	1.000	≥ 60	0.434	0.434	0.473	PROOS+TBSOOS	< 60	0.463	0.463	0.490	0.725	0.817	0.922	1.000	≥ 60	0.352	0.352	0.386	PROOS+RPTOOS	< 60	0.485	0.485	0.490	0.725	0.817	0.922	1.000	≥ 60	0.434	0.434	0.473																																		
RPTOOS	< 60	0.485	0.485	0.490	0.750	0.817	0.922	1.000																																																																																																																
	≥ 60	0.434	0.434	0.473					RPTOOS SLO	< 60	0.485	0.485	0.490	0.750	0.817	0.922	1.000	≥ 60	0.434	0.434	0.473	PROOS	< 60	0.485	0.485	0.490	0.725	0.817	0.922	1.000	≥ 60	0.434	0.434	0.473	PROOS SLO	< 60	0.485	0.485	0.490	0.725	0.817	0.922	1.000	≥ 60	0.434	0.434	0.473	PROOS+TBSOOS	< 60	0.463	0.463	0.490	0.725	0.817	0.922	1.000	≥ 60	0.352	0.352	0.386	PROOS+RPTOOS	< 60	0.485	0.485	0.490	0.725	0.817	0.922	1.000	≥ 60	0.434	0.434	0.473																																															
RPTOOS SLO	< 60	0.485	0.485	0.490	0.750	0.817	0.922	1.000																																																																																																																
	≥ 60	0.434	0.434	0.473					PROOS	< 60	0.485	0.485	0.490	0.725	0.817	0.922	1.000	≥ 60	0.434	0.434	0.473	PROOS SLO	< 60	0.485	0.485	0.490	0.725	0.817	0.922	1.000	≥ 60	0.434	0.434	0.473	PROOS+TBSOOS	< 60	0.463	0.463	0.490	0.725	0.817	0.922	1.000	≥ 60	0.352	0.352	0.386	PROOS+RPTOOS	< 60	0.485	0.485	0.490	0.725	0.817	0.922	1.000	≥ 60	0.434	0.434	0.473																																																												
PROOS	< 60	0.485	0.485	0.490	0.725	0.817	0.922	1.000																																																																																																																
	≥ 60	0.434	0.434	0.473					PROOS SLO	< 60	0.485	0.485	0.490	0.725	0.817	0.922	1.000	≥ 60	0.434	0.434	0.473	PROOS+TBSOOS	< 60	0.463	0.463	0.490	0.725	0.817	0.922	1.000	≥ 60	0.352	0.352	0.386	PROOS+RPTOOS	< 60	0.485	0.485	0.490	0.725	0.817	0.922	1.000	≥ 60	0.434	0.434	0.473																																																																									
PROOS SLO	< 60	0.485	0.485	0.490	0.725	0.817	0.922	1.000																																																																																																																
	≥ 60	0.434	0.434	0.473					PROOS+TBSOOS	< 60	0.463	0.463	0.490	0.725	0.817	0.922	1.000	≥ 60	0.352	0.352	0.386	PROOS+RPTOOS	< 60	0.485	0.485	0.490	0.725	0.817	0.922	1.000	≥ 60	0.434	0.434	0.473																																																																																						
PROOS+TBSOOS	< 60	0.463	0.463	0.490	0.725	0.817	0.922	1.000																																																																																																																
	≥ 60	0.352	0.352	0.386					PROOS+RPTOOS	< 60	0.485	0.485	0.490	0.725	0.817	0.922	1.000	≥ 60	0.434	0.434	0.473																																																																																																			
PROOS+RPTOOS	< 60	0.485	0.485	0.490	0.725	0.817	0.922	1.000																																																																																																																
	≥ 60	0.434	0.434	0.473																																																																																																																				

**TABLE 5-5**  
**Flow Dependent LHGR Multiplier LHGRFAC(F)**  
**(Reference 2)**

EOOS Combination	Core Flow (% of rated)					
	0	30	44.1	70	80	110
	LHGRFAC(F) Multiplier					
Dual Loop	0.506	0.706		0.973	1.000	1.000
Single Loop	0.506	0.706	0.800			0.800



## 6.0 Control Rod Block Setpoints

### 6.1 Technical Specification

Sections 3.1.4.3 and 3.3.6

### 6.2 Description

The ARTS RBM provides for power-dependent RBM trips. Technical Specification 3.3.6 states control rod block instrumentation channels shall be OPERABLE with their trip setpoints consistent with the values shown in the Trip Setpoint column of Technical Specification Table 3.3.6-2. The trip setpoints/allowable values and applicable RBM signal filter time constant data are shown in Table 6-1. The Reactor Coolant System Recirculation Flow Upscale Trip is shown in Table 6-2. These setpoints are set high enough to allow full utilization of the enhanced ICF domain up to 110% of rated core flow.

The ARTS RWE analysis validated the MCPR values in Table 6-3 for use in Cycle 16. The RBM operability requirements have been evaluated and shown to be sufficient to ensure that the SLMCPR and the cladding strain criteria will not be exceeded in the event of an RWE.

**TABLE 6-1**  
**Rod Block Monitor Setpoints<sup>3</sup>**  
 (References 2 and 4)

Power Level	Analytical Limit	Allowable Value	Nominal Trip Setpoint
LTSP	123.0%	121.5%	121.5%
ITSP	118.0%	116.5%	116.5%
HTSP	113.2%	111.7%	111.0%
DTSP	No Limitation	2.0%	5.0%

---

<sup>3</sup> These setpoints are based on a Rod Block Monitor filter time constant between 0.1 seconds and 0.55 seconds.

**TABLE 6-2**  
**Reactor Coolant System Recirculation Flow Upscale Trip**  
**(Reference 4)**

Analytical Limit	N/A
Allowable Value	115.6%
Nominal Trip Setpoint	113.4%

**TABLE 6-3**  
**RBM Operability Limits<sup>4</sup>**  
**(Reference 2)**

<b>Power (% rated)</b>	<b>Analyzed RBM Operability Limit</b>	<b>Tech Spec RBM Operability Limit</b>
$30 \leq \text{Power} < 90$	MCPR < 1.68	MCPR < 1.70
$\text{Power} \geq 90$	MCPR < 1.38	MCPR < 1.40

---

<sup>4</sup> These are the MCPR limits below which the RBM is required to be operable (Reference 2 and Technical Specification 3.1.4.3).

**7.0 Turbine Bypass Valve Parameters**

7.1 Technical Specification

Section 3.7.8 and 4.7.8.c

7.2 Description

The operability requirements for the steam bypass system are found in Tables 7-1 and 7-2. If these requirements cannot be met, the MCPR, MCPR(P) and LHGRFAC(P) limits for inoperable Steam Bypass System, TBSOOS, must be used. Additional information on the operability of the turbine bypass system can be found in Reference 6.

**TABLE 7-1  
 Turbine Bypass System Response Time  
 (Reference 3)**

Maximum delay time before start of bypass valve opening following initial turbine inlet valve movement*	0.11 sec
Maximum time after initial turbine inlet valve movement* for bypass valve position to reach 80% of full flow (includes the above delay time)	0.31 sec

\* First movement of any TSV or any TCV (whichever occurs first)

**TABLE 7-2  
 Minimum Required Bypass Valves to Maintain System Operability  
 (References 1 and 3)**

Reactor Power	No. of Valves in Service
$P \geq 25\%$	7

## 8.0 Stability Protection Setpoints

### 8.1 Technical Specification

Section 2.2.1

### 8.2 Description

The Limerick Unit 2 Cycle 16 OPRM PBDA Trip Setpoints for the OPRM System are found in Table 8-1. These values are based on the cycle specific analysis documented in Reference 2. The setpoints provided in Table 8-1 are bounding for all modes of operation shown in Table 9-1.

**TABLE 8-1**  
**OPRM PBDA Trip Setpoints**  
**(Reference 2)**

PBDA Trip Amplitude	Corresponding Maximum Confirmation Count Trip Setting
$\leq 1.11$	$\leq 14$

## 9.0 Modes of Operation

### 9.1 Description

The following conditions are supported by the Limerick Unit 2 Cycle 16 licensing analysis; operation in a condition (or conditions) is controlled by station procedures. **If a combination of options is not listed, it is not supported.** Table 9-1 provides allowed modes of operation with thermal limit sets in this COLR. Table 9-2 provides allowed modes of operation that do not contain explicit thermal limit sets in this COLR.

**TABLE 9-1**  
**Modes of Operation**  
 (References 2 and 8)

EOOS Options <sup>5</sup>	Supported Scram Speed Option	Supported Recirculation Loops
BASE <sup>6,7</sup>	Option A or B	DLO or SLO
TBSOOS	Option A or B	DLO or SLO
RPTOOS <sup>8</sup>	Option A or B	DLO or SLO
PROOS	Option A or B	DLO or SLO
PROOS+TBSOOS	Option B	DLO
PROOS+RPTOOS	Option B	DLO

**TABLE 9-2**  
**“BASE” EOOS Option – Included Conditions<sup>7</sup>**  
 (Reference 2)

Condition
PLUOOS
1 MSIVOOS <sup>9</sup>
1 TCV/TSVOOS <sup>10</sup>
2 TBVOOS
2 SRVOOS

<sup>5</sup> All EOOS Options include the “BASE” EOOS Option. Any restrictions beyond the “BASE” condition’s restrictions are noted on the applicable EOOS option.

<sup>6</sup> The “BASE” condition includes the conditions listed in Table 9-2.

<sup>7</sup> The “BASE” condition includes operation with or without FWHOOS/FFWTR.

<sup>8</sup> PLUOOS is valid coincident with the RPTOOS condition, but only at power levels  $\leq 55\%$  rated thermal power.

<sup>9</sup> 1 MSIVOOS is valid only at power levels  $\leq 75\%$  rated thermal power.

<sup>10</sup> 1 TCV/TSVOOS, alone or coincident with another EOOS condition, is valid only at  $\leq 90\%$  rated thermal power, except when coincident with TBSOOS, which is valid only at  $\leq 85\%$  rated thermal power.

## 10.0 Methodology

The analytical methods used to determine the core operating limits shall be those previously reviewed and approved by the NRC, specifically those described in the following document:

1. “General Electric Standard Application for Reactor Fuel”, Global Nuclear Fuel Document, NEDE-24011-P-A-27, August 2018 and the U.S. Supplement NEDE-24011-P-A-27-US, August 2018.
2. “Reactor Stability Detect and Suppress Solutions Licensing Basis Methodology for Reload Applications”, GENE Document, NEDO-32465-A, August 1996.

## 11.0 References

1. “Technical Specifications and Bases for Limerick Generating Station Unit 2”, Exelon Document, Docket No. 50-353, License No. NPF-85.
2. “Supplemental Reload Licensing Report for Limerick Unit 2 Reload 15 Cycle 16”, Global Nuclear Fuel Document No. 004N5216, Rev. 0, February 2019.
3. “Final Resolved OPL-3 Parameters for Limerick 2 Cycle 16”, Exelon TODI ES1800030, Rev. 0, October 30, 2018.
4. “GE NUMAC PRNM Setpoint Study”, Exelon Design Analysis LE-0107, Rev. 2, February 23, 2012.
5. “Fuel Bundle Information Report for Limerick Unit 2 Reload 15 Cycle 16”, Global Nuclear Fuel Document No. 004N5217, Rev. 0, February 2019.
6. “Tech Eval Stop Valve Load Limit Documentation”, Exelon Document IR 917231 Assignment 7, November 11, 2009.
7. “GNF2 Advantage Generic Compliance with NEDE-24011-PA (GESTAR II)”, Global Nuclear Fuel Document No. NEDC-33270P, Rev. 9, December 2017.
8. “Limerick Generating Station (LGS) Units 1 and 2 TRACG Cycle-Independent PROOS Analysis Report”, GE Hitachi Document No. 002N4397 R1, Rev. 1, January 2016.