

May 21, 2019

TSTF-19-04  
PROJ0753

Attn: Document Control Desk  
U. S. Nuclear Regulatory Commission  
Washington, DC 20555-0001

SUBJECT: Transmittal of TSTF-568, Revision 2, "Revise Applicability of BWR/4  
TS 3.6.2.5 and TS 3.6.3.2"

Enclosed for NRC review is TSTF-568, Revision 2, "Revise Applicability of BWR/4 TS 3.6.2.5  
and TS 3.6.3.2."


Revision 2 of TSTF-568 addresses NRC comments provided at the August 9, 2018 and the  
February 21, 2019 TSTF/NRC public meetings.


Should you have any questions, please do not hesitate to contact us.

  
James P. Miksa (PWROG/CE)

  
Ryan M. Joyce (BWROG)

  
David M. Gullott (PWROG/W)

  
Jordan L. Vaughan (PWROG/B&W)

  
Wesley Sparkman (APOG)

Attachment

cc: Michelle Honcharik, Technical Specifications Branch, NRC  
Peter Snyder, Technical Specifications Branch, NRC  
Victor Cusumano, Technical Specifications Branch, NRC

## Technical Specifications Task Force Improved Standard Technical Specifications Change Traveler

### Revise Applicability of BWR/4 TS 3.6.2.5 and TS 3.6.3.2

NUREGs Affected: ☐ 1430 ☐ 1431 ☐ 1432 ☒ 1433 ☐ 1434 ☐ 2194

Classification: 1) Technical Change

Recommended for CLIIP?: Yes

Correction or Improvement: Correction

NRC Fee Status: Not Exempt

Changes Marked on ISTS Rev 4.0

See attached.

### Revision History

#### OG Revision 0

**Revision Status: Closed**

Revision Proposed by: NRC

Revision Description:  
Original Issue

#### Owners Group Review Information

Date Originated by OG: 18-May-17

Owners Group Comments  
(No Comments)

Owners Group Resolution: Superseded Date: 29-Sep-17

#### OG Revision 1

**Revision Status: Closed**

Revision Proposed by: BWROG

Revision Description:  
Replaced with Revision 1 based on BWROG comments.

#### Owners Group Review Information

Date Originated by OG: 11-Sep-17

Owners Group Comments  
(No Comments)

Owners Group Resolution: Approved Date: 02-Oct-17

#### TSTF Review Information

TSTF Received Date: 02-Oct-17

Date Distributed for Review 02-Oct-17

TSTF Comments:  
(No Comments)

TSTF Resolution: Approved

Date: 19-Dec-17

21-May-19

---

**OG Revision 1****Revision Status: Closed**

---

**NRC Review Information**

NRC Received Date: 19-Dec-17

NRC Comments:

Presubmittal discussion held with NRC on November 9, 2017. No changes identified.

Final Resolution: Superseded by Revision

---

**TSTF Revision 1****Revision Status: Closed**

---

Revision Proposed by: NRC

Revision Description:

Revised to address NRC comments during a May 2, 2018 teleconference.

Includes the GE Safety Communication SC02-10, referenced in the traveler, as an attachment.

Clarifies that the change to TS 3.6.2.5, "Drywell-to-Suppression Chamber Differential Pressure," is only applicable to BWRs with a Mark 1 containment.

Clarifies that the traveler is not a technical change. Indefinite plant operation in Mode 1 with power less than or equal to 15% RTP is currently allowed by Required Action B.1.

Revise the justification to the change to TS 3.6.3.2, "Primary Containment Oxygen Concentration" to state:  
oThe traveler is not a technical change. Indefinite plant operation in Mode 1 with power less than or equal to 15% RTP is currently allowed by Required Action B.1

oThe technical basis for the existing 15% allowance is not being changed. The proposed change is a clarification to the presentation of the existing 15% allowance, not a change to that limit.

oThe 24 hour startup/shutdown allowance is only applicable when power is &gt; 15%.

**Owners Group Review Information**

Date Originated by OG: 10-May-18

Owners Group Comments

(No Comments)

Owners Group Resolution: Approved Date: 22-May-18

---

**TSTF Review Information**

TSTF Received Date: 10-May-18

Date Distributed for Review 10-May-18

TSTF Comments:

(No Comments)

TSTF Resolution: Approved

Date: 31-May-18

**NRC Review Information**

NRC Received Date: 31-May-18

---

21-May-19

**TSTF Revision 1****Revision Status: Closed**

NRC Comments:

Draft provided to NRC on 5/31/18.

At the August 9, 2018 TSTF/NRC public meeting, the NRC stated that they support the change to TS 3.6.2.5, Drywell-to-Suppression Chamber Differential Pressure. That change is only applicable to three BWR plants (Dresden, Fitzpatrick, and Quad Cities). However, the NRC does not support the change to TS 3.6.3.2, Primary Containment Oxygen Concentration. All BWR/2, BWR/3, BWR/4, and BWR/5 units contain this specification. While the NRC acknowledges that the current TS Actions allow indefinite operation at  $\leq 15\%$  RTP with the LCO not met, they believe the Bases statement, "As long as reactor power is  $< 15\%$  RTP, the potential for an event that generates significant hydrogen is low and the primary containment need not be inert," cannot be technically justified. While the risk to the public is too small to warrant a backfit on the issue, the NRC staff is not comfortable with issuing a change to the TS that relies on that justification.

Final Resolution: Superseded by Revision

Final Resolution Date: 09-Aug-18

**TSTF Revision 2****Revision Status: Active**

Revision Proposed by: TSTF

Revision Description:

Revision 2 is a complete replacement of Revisions 0 and 1.

The exclusion of Browns Ferry from the TS 3.6.2.5 change was removed after discovery of an NRC-approved analysis similar to those referenced for Dresden, Quad Cities, and Fitzpatrick.

At the August 9, 2018 TSTF/NRC public meeting, the NRC stated that they support the change to TS 3.6.2.5, Drywell-to-Suppression Chamber Differential Pressure. That change is only applicable to three BWR plants (Dresden, Fitzpatrick, and Quad Cities). However, the NRC does not support the change to TS 3.6.3.2, Primary Containment Oxygen Concentration. All BWR/2, BWR/3, BWR/4, and BWR/5 units contain this specification. While the NRC acknowledges that the current TS Actions allow indefinite operation at  $\leq 15\%$  RTP with the LCO not met, they believe the Bases statement, "As long as reactor power is  $< 15\%$  RTP, the potential for an event that generates significant hydrogen is low and the primary containment need not be inert," cannot be technically justified. While the risk to the public is too small to warrant a backfit on the issue, the NRC staff is not comfortable with issuing a change to the TS that relies on that justification.

In response, the TSTF developed a draft change that:

- Revises the TS 3.6.2.5, "Drywell-to-Suppression Chamber Differential Pressure," Applicability to Mode 1 with thermal power  $> [15]\%$ .
- Revises the TS 3.6.3.2, "Primary Containment Oxygen Concentration," Applicability to Mode 1. Required Action B.1 is revised to be in Mode 2 in 8 hours.
- For both TS, the Required Action A.1 (restore the value to within limit) is changed from 8 and 24 hours to 72 hours and a Note is added stating LCO 3.0.4.c is applicable.

The effect of the changes is to permit entering the Applicability with the limit not met for up to 72 hours and to enter the action up to 72 hours prior to exiting the Applicability on a shutdown, replacing the current Applicability exceptions. The Completion Time is also long enough to permit deinerting the primary containment, making entries at low power, and inerting the containment, if needed.

21-May-19

**TSTF Revision 2****Revision Status: Active**

At the February 21, 2019 TSTF/NRC meeting, the NRC staff requested that the TSTF consider two changes to the proposed revision of TSTF-568, "Clarify Applicability of TS 3.6.2.5 & TS 3.6.3.2."

1. - The Applicability for TS 3.6.3.2, "Primary Containment Oxygen Concentration," should be Modes 1 and 2, not Mode 1 as the TSTF has proposed. While the reactor is critical, the potential for hydrogen generation post-accident exists.
2. - The last revision of 10 CFR 50.44, Combustible Gas Control, made containment inerting part of severe accident management, not part of DBA response. The staff recommended that the TS Bases be revised to state that 10 CFR 50.36(c)(2)(ii) Criterion 4 applies instead of Criterion 2.

Regarding the Applicability, the TSTF agreed to change the Applicability of TS 3.6.1.3 to Modes 1 and 2. Similar combustible gas control TS (NUREG-1433 TS 3.6.3.1, Drywell Cooling System Fans, and NUREG-1434 TS 3.6.3.1, Primary Containment and Drywell Hydrogen Ignitors) have an Applicability of Modes 1 and 2. The proposed 72 hour Completion Time will provide sufficient time to inert or deinert during startup and shutdown, even considering the additional time required by the expanded Applicability.

The issue of whether TS 3.6.3.2 falls under Criterion 2 or 4 has been considered by the NRC before. The TSTF submitted TSTF-447-A, "Elimination of Hydrogen Recombiners and Change to Hydrogen and Oxygen Monitors," based on the 2003 rule change to 50.44.

The NRC's Notice of Availability (68 FR 55416, dated 9/25/2003) for TSTF-447, "BWR Technical Specification Changes that Implement the Revised Rule for Combustible Gas Control," under "Public Notices," states:

In addition, the staff has made some minor changes to the model SE as a result of internal reviews. A specific change involves the reference to Criterion 2 (10 CFR 50.36(c)(2)(ii)(B)) as the basis for retention of primary containment oxygen concentration in the TS. In the model SE, the staff had proposed to change the basis to Criterion 4 (10 CFR 50.36(c)(2)(ii)(D)) since combustible gas generated from severe accidents was not risk significant for Mark I and II containments, provided that the required inerted atmosphere was maintained. Criterion 4 is intended to capture those constraints that probabilistic risk assessment or operating experience show to be significant to public health and safety, consistent with the Commission's Probabilistic Risk Assessment (PRA) Policies. Upon further review by the staff, it was determined that the basis for the primary containment oxygen concentration should remain Criterion 2 since the typical Updated FSAR Chapter 6 analyses assume that the primary containment is inerted when a design basis LOCA occurs. Therefore, primary containment oxygen concentration is a process variable, design feature, or operating restriction that is an initial condition of a design basis accident or transient analysis that either assumes the failure of or presents a challenge to the integrity of a fission product barrier.

The TSTF-447 Safety Evaluation, under "Evaluation," states:

However, for plant designs with an inerted containment, each licensee should verify that it has, and make a regulatory commitment to maintain, an oxygen monitoring system capable of verifying the status of the inert containment. In addition, separate requirements for primary containment oxygen concentration will be retained in TS for plant designs with an inerted containment. The basis for retention of this requirement in TS is that it meets Criterion 2 of 10 CFR 50.36(c)(2)(ii) in that it is a process variable, design feature, or operating restriction that is an initial condition of a design basis accident or transient analysis that either assumes the failure of or presents a challenge to the integrity of a fission product barrier. This is based on the fact that calculations typically included in Chapter 6 of Updated Final Safety Analysis Reports assume that the primary containment is inerted, that is, oxygen concentration < 4.0 volume percent, when a design basis LOCA occurs.

As this issue has been considered previously and the NRC made a determination, the TSTF did not propose a change.

21-May-19

**TSTF Revision 2****Revision Status: Active****Owners Group Review Information**

Date Originated by OG: 18-Apr-19

Owners Group Comments  
(No Comments)

Owners Group Resolution: Approved Date: 06-May-19

**TSTF Review Information**

TSTF Received Date: 06-May-19

Date Distributed for Review 06-May-19

TSTF Comments:  
(No Comments)

TSTF Resolution: Approved

Date: 21-May-19

**NRC Review Information**

NRC Received Date: 21-May-19

**Affected Technical Specifications**

Appl. 3.6.2.5	Drywell-to-Suppression Chamber Differential Pressure
Appl. 3.6.2.5 Bases	Drywell-to-Suppression Chamber Differential Pressure
Action 3.6.2.5.A	Drywell-to-Suppression Chamber Differential Pressure
Action 3.6.2.5.A Bases	Drywell-to-Suppression Chamber Differential Pressure
Appl. 3.6.3.2	Primary Containment Oxygen Concentration
Appl. 3.6.3.2 Bases	Primary Containment Oxygen Concentration
Action 3.6.3.2.A	Primary Containment Oxygen Concentration
Action 3.6.3.2.A Bases	Primary Containment Oxygen Concentration
Action 3.6.3.2.B	Primary Containment Oxygen Concentration
Action 3.6.3.2.B Bases	Primary Containment Oxygen Concentration

21-May-19

## 1. SUMMARY DESCRIPTION

The Applicability of Technical Specifications (TS) 3.6.2.5, "Drywell-to-Suppression Chamber Differential Pressure," and 3.6.3.2, "Primary Containment Oxygen Concentration," require the associated limiting conditions for operation (LCOs) to be met when the unit is in Mode 1 during the time period: a. from [24] hours after Thermal Power is  $> [15]\%$  Rated Thermal Power (RTP) following startup, to [24] hours prior to reducing Thermal Power to  $< [15]\%$  RTP prior to the next scheduled reactor shutdown. This change revises these Specifications in NUREG-1433, "Standard Technical Specifications General Electric BWR/4 Plants,"<sup>1</sup> to revise the Applicability and Actions, and presents the requirements in a manner more consistent with the Standard Technical Specifications (STS) format and content.

## 2. DETAILED DESCRIPTION

### 2.1. System Description and Operation

There are three containment designs used in the various boiling water reactor (BWR) plants. BWR/2, BWR/3, and early model BWR/4 plants have the Mark I containment. Later model BWR/4 and BWR/5 plants have the Mark II containment. BWR/6 plants have the Mark III containment.

The Mark I containment consists of a drywell (in the shape of an inverted light bulb), a suppression chamber (in the shape of a toroid), and a network of vents which extend radially outward and downward from the drywell to the suppression chamber. The Mark II containment consists of a drywell (in the shape of a truncated cone), a suppression chamber directly below the drywell (in the shape of a right circular cylinder), and a network of vertical vents extending downward from the drywell to the suppression chamber. The Mark III containment is cylindrical with a domed head, and surrounds the drywell and suppression pool.

The Mark I and II containment designs are inerted with nitrogen gas during normal operation to prevent an explosive mixture of hydrogen and oxygen from forming during accident conditions. Long term control of post LOCA hydrogen gas concentration is accomplished by adding additional nitrogen gas and then venting the primary containment through the Standby Gas Treatment System. The Mark III containment atmosphere is not inerted with nitrogen due to its large volume, and hydrogen ignitors are typically used for long-term combustible gas control following a postulated design basis event. The proposed change is only applicable to plants with Mark I and Mark II containment designs.

The Mark I and II primary containment inerting system consists of a nitrogen (N<sub>2</sub>) purge supply and an N<sub>2</sub> makeup supply. The N<sub>2</sub> purge supply is used to initially inert the atmosphere in the primary containment and is typically provided simultaneously to the suppression chamber air space and the drywell. At times, the suppression chamber pressure may increase at a rate faster

---

<sup>1</sup> NUREG-1433 is based on the BWR/4 plant design, but is also applicable of the BWR/2, BWR/3, and, for some requirements, to the BWR/5 plant designs.

than drywell pressure resulting in a differential pressure between the two volumes that is less than the TS 3.6.2.5 limit. The inerting process continues until primary containment oxygen concentration is less than 4% (or a plant-specific limit), as required by TS 3.6.3.2.

In a Mark I or II containment, the drywell is immediately pressurized when a postulated line break occurs within the primary containment. As drywell pressure increases, drywell atmosphere (primarily nitrogen gas) and steam are blown down through the vents into the suppression pool via the downcomers. The steam condenses in the suppression pool which suppresses the peak pressure in the drywell. Noncondensable gases discharged into the suppression pool collect in the free air volume of the suppression chamber, increasing the suppression chamber pressure. As steam is condensed in the suppression pool, drywell pressure decreases until the suppression chamber pressure exceeds the drywell pressure and the suppression chamber-drywell vacuum breakers open and vent noncondensable gases back into the drywell.

## **2.2. Current Technical Specifications Requirements**

The Applicability of NUREG-1433 TS 3.6.2.5 and 3.6.3.2 both state:

MODE 1 during the time period:

- a. From [24] hours after THERMAL POWER is  $> [15]\%$  RTP following startup, to
- b. [24] hours prior to reducing THERMAL POWER to  $< [15]\%$  RTP prior to the next scheduled reactor shutdown.

The Required Actions of the TS provide 8 hours to restore differential pressure and 24 hours to restore the oxygen concentration to within limit when the LCO is not met, followed by a requirement to reduce thermal power to  $\leq [15]\%$  RTP.

Only four BWR plants (Browns Ferry, Dresden, Fitzpatrick, and Quad Cities) contain a Drywell-to-Suppression Chamber Differential Pressure Specification (ISTS 3.6.2.5). All four of these plants have Mark I containments.

All BWR/2, BWR/3, BWR/4, and BWR/5 units contain a Primary Containment Oxygen Concentration specification (ISTS 3.6.3.2).

The 24-hour allowance above 15% RTP is provided in the Primary Containment Oxygen Concentration specification to delay inerting the primary containment in a plant startup and to accelerate de-inerting for a plant shutdown. This is for personnel safety considerations so that plant personnel can access the primary containment without breathing apparatus. This allowance is also needed for the Drywell-to-Suppression Chamber Differential Pressure specification due to the pressure fluctuations in the drywell and suppression chamber during the primary containment inerting process that make it difficult to maintain the differential pressure within the required limit.



### 2.3. Reason for the Proposed Change

The TS require primary containment oxygen concentration to be less than 4.0 volume percent (or a plant-specific limit) and drywell pressure to be at least [1.5] psid above the suppression chamber pressure when in Mode 1 during the time period from [24] hours after Thermal Power is > 15% RTP following startup to [24] hours prior to reducing Thermal Power to < 15% RTP prior to the next scheduled reactor shutdown.

The current convoluted presentation in the Applicability is difficult to interpret and can be understood to mean that the Applicability is Mode 1 when thermal power is > [15]% RTP, or that the Applicability is all of Mode 1, including when reactor power is below 15% RTP, except when the 24-hour allowance is being utilized. Also, the term "scheduled plant shutdown" is undefined and can be interpreted as a scheduled refueling outage or any scheduled outage. In addition, a technical basis for the primary containment oxygen concentration allowance, established in the late 1970's, could not be located. Lastly, the presentation is inconsistent with all other standard TS, leading to confusion. The proposed change improves these requirements.

### 2.4. Description of the Proposed Change

#### TS 3.6.2.5, "Drywell-to-Suppression Chamber Differential Pressure"

The Applicability of TS 3.6.2.5, "Drywell-to-Suppression Chamber Differential Pressure," is revised as shown. Deleted text is identified with ~~strike through~~ and inserted text is identified in *italics*.

MODE 1 *with THERMAL POWER > [15]% RTP.* ~~during the time period:~~

- a. ~~From [24] hours after THERMAL POWER is > [15]% RTP following startup, to~~
- b. ~~[24] hours prior to reducing THERMAL POWER to < [15]% RTP prior to the next scheduled reactor shutdown.~~

Required Action A.1, "Restore differential pressure to within limit," is revised by adding a Note that states, "LCO 3.0.4.c is applicable," and the Completion Time is changed from 8 hours to 72 hours.

#### TS 3.6.3.2, "Primary Containment Oxygen Concentration"

The Applicability of TS 3.6.3.2, "Primary Containment Oxygen Concentration," is revised as shown.

MODES 1 *and 2.* ~~during the time period:~~

- a. ~~From [24] hours after THERMAL POWER is > [15]% RTP following startup, to~~
- b. ~~[24] hours prior to reducing THERMAL POWER to < [15]% RTP prior to the next scheduled reactor shutdown.~~

Required Action A.1, "Restore oxygen concentration to within limit," is revised by adding a Note that states, "LCO 3.0.4.c is applicable," and the Completion Time is changed from 24 hours to 72 hours.

Required Action B.1 is revised from "Reduce THERMAL POWER to  $\leq$  [15]% RTP," to "Be in MODE 3." The Completion time is changed from 8 hours to 12 hours.

The proposed change is supported by changes to the TS Bases. The regulation at Title 10 of the Code of Federal Regulations (10 CFR), Part 50.36, states, "A summary statement of the bases or reasons for such specifications, other than those covering administrative controls, shall also be included in the application, but shall not become part of the technical specifications." A licensee may make changes to the TS Bases without prior NRC review and approval in accordance with the Technical Specifications Bases Control Program. The proposed TS Bases changes are consistent with the proposed TS changes and provide the purpose for each requirement in the specification consistent with the Commission's Final Policy Statement on Technical Specifications Improvements for Nuclear Power Reactors, dated July 2, 1993 (58 FR 39132). Therefore, the Bases changes are provided for information and approval of the Bases is not requested.

A model application is attached. The model may be used by licensees desiring to adopt the traveler following NRC approval.

### **3. TECHNICAL EVALUATION**

#### **3.1. Drywell-to-Suppression Chamber Differential Pressure Applicability Change**

The drywell-to-suppression chamber differential pressure limit ensures the containment conditions assumed in the safety analyses for Mark I containments are met by limiting the length of the suppression chamber downcomer water leg. High water level in the downcomers could result in excessive forces on the suppression chamber from the downcomer vents and higher pressure buildup in the drywell.

Revising the presentation of Applicability of the Drywell-to-Suppression Chamber Differential Pressure Specification to state that it is applicable in MODE 1 with thermal power above [15]% RTP clarifies the existing intent of the specification. Allowing the plant to remain in Mode 1  $\leq$  [15]% RTP with drywell-to-suppression chamber differential pressure limit not met has been evaluated and determined to be acceptable. General Electric Nuclear Energy Safety Communication 02-10 (Reference 1 and attached), discussed the STS LCO 3.6.2.5 Action when drywell-to-wetwell differential pressure is not within limit and the allowance for extended plant operation with reactor power below 15% RTP. The Safety Communication concluded that operation below 15% RTP with the differential pressure limit not met is acceptable for BWRs with Mark II containments and for BWRs with Mark I containments that have demonstrated acceptable loads with zero differential pressure. Only four BWR plants, all of which have Mark I containments, have a specification on drywell-to-suppression chamber differential pressure: Browns Ferry, Dresden, Fitzpatrick, and Quad Cities. Containment analyses were performed on Browns Ferry, Dresden, Fitzpatrick, and Quad Cities and approved by the NRC in Safety Evaluations dated May 6, 1985, September 18, 1985, December 12, 1984, and February 15,

1986, respectively, that demonstrated that operation at less than 15% RTP without meeting the differential pressure limit was acceptable.

### **3.2. Primary Containment Oxygen Concentration Applicability Change and Required Action B.1**

The primary containment oxygen concentration must be maintained below the limit to ensure that an accident that produces hydrogen does not result in a combustible mixture inside primary containment.

All BWR/2, BWR/3, BWR/4, and BWR/5 plants with Mark I or II containments have a specification on primary containment oxygen concentration. The Bases for the Primary Containment Oxygen Concentration states, "As long as reactor power is < 15% RTP, the potential for an event that generates significant hydrogen is low and the primary containment need not be inert." The allowance to not meet the limit when < 15% RTP has appeared in the Standard Technical Specifications since 1978 (NUREG-0123, Revision 1, "Standard Technical Specifications for General Electric Boiling Water Reactors.") However, a technical basis for the Applicability and the Bases statements could not be located.

In 2003, 10 CFR 50.44, "Combustible Gas Control for Nuclear Power Plants," was revised. The rule change made containment inerting part of severe accident management, not design basis accident response. 10 CFR 50.44(b)(2)(i) states, "All boiling water reactors with Mark I or Mark II type containments must have an inerted atmosphere." The rule does not specify the reactor conditions when a severe accident is assumed to occur, but other TS requirements on combustible gas control, such as TS 3.6.3.1, "Drywell Cooling System Fans," are applicable in Modes 1 and 2. Therefore, the proposed change revises the TS 3.6.3.2 Applicability to Modes 1 and 2.

To maintain consistency with the Applicability, Required Action B.1 is revised to require being in Mode 3 instead of Mode 1 with thermal power  $\leq$  [15] % RTP. The Completion Time is revised to 12 hours, which is the standard Completion Time for being in Mode 3 in the BWR/4 STS.

### **3.3. Replacement of the Applicability Exceptions with Completion Times**

The TS 3.6.2.5 and 3.6.3.2 Applicability 24 hour exceptions are unique in STS and difficult to interpret. In other specifications, similar allowances are addressed by Surveillance Requirement (SR) Notes, LCO Notes, or Actions. The most straightforward approach is to provide a Completion Time that permits a limited time to not meet the differential pressure or primary oxygen concentration limit.

The proposed 72 hour Completion Time was chosen to permit entry into the primary containment while in Mode 1, and is reasonable assuming:

- 24 hours to deinert the containment and drywell to permit safe personnel access,
- 24 hours to perform work, and
- 24 hours to inert the containment and drywell.

The longer Completion Time also provides operational flexibility to address problems found during startup from an outage which require containment entry.

#### TS 3.6.2.5, Required Action A.1

During the inerting and de-inerting process, the suppression chamber pressure may change at a different rate than drywell pressure resulting in a differential pressure between the two volumes that is less than the TS 3.6.2.5 limit. Therefore, the TS 3.6.2.5 and TS 3.6.3.2 Completion Times should be consistent.

As discussed in SC02-10 (Reference 1), the TS 3.6.2.5 LCO limit is based on maintaining a positive drywell-to-suppression chamber pressure differential to limit pool swell loads. As noted in SC02-10, the pool swell load calculations contain a large margin of conservatism in the Mark I pool swell load definition. This conservatism, when considered in light of the low probability of a large-break loss of coolant accident, justifies providing a limited time to restore compliance with the LCO, which is consistent with the time required to restore compliance with the primary containment oxygen concentration.

#### TS 3.6.3.2, Required Action A.1

The proposed 72 hour Completion Time addresses the additional time needed beyond the existing 24 hour allowance for a plant to transition from Mode 3 to Mode 1 > 15% RTP during startup, and from Mode 1 > 15% RTP to Mode 3 during shutdown.

The longer Completion Time for TS 3.6.3.2, Required Action A.1, is justified by the 2003 10 CFR 50.44 rule change that determined that hydrogen production was not risk significant for design basis accidents. As stated in 10 CFR 50.36(b), "The technical specifications will be derived from the analyses and evaluation included in the safety analysis report." Design basis accident response is described in the safety analysis report, but severe accident mitigation is not. Therefore, providing a longer Completion Time to restore compliance with a limit that is not risk-significant for the design basis accidents described in the safety analysis report is appropriate.

The proposed Completion Time also considers the low likelihood of a severe accident during the proposed 72 hour period that would create excessive suppression chamber loads or generate significant amounts of hydrogen, and the existence of severe accident management guidelines that would be used in a severe accident with the TS not met, and available alternatives such as the use of containment sprays and controlled venting.

### **3.4. Addition of LCO 3.0.4.c Allowance to Required Action A.1**

One of the purposes of the existing Applicability exceptions is to allow entry into Mode 1 with the LCO not met, permitting the oxygen concentration and differential pressure limits to be met during startup. The proposed change removes the Applicability exceptions and instead provides an extended Completion Time for that purpose. However, LCO 3.0.4 prohibits entering the Applicability of a TS with the LCO not met unless one of the three LCO 3.0.4 exceptions apply. The associated TS 3.6.2.5 and TS 3.6.3.2 Actions do not permit continued operation for an unlimited period of time (i.e., LCO 3.0.4.a) and a risk assessment can typically only be

performed on systems and components (i.e., LCO 3.0.4.b). LCO 3.0.4.c is typically applied to Specifications which describe values and parameters, such as drywell-to-suppression chamber differential pressure or primary containment oxygen concentration. LCO 3.0.4.c allows entry into a mode or other specified condition in the Applicability with the LCO not met based on a Note in the Specification which states LCO 3.0.4.c is applicable. Adding the LCO 3.0.4.c reference to Required Action A.1 permits entering the Applicability of the LCO with the LCO not met, similar to the existing Applicability exceptions in TS 3.6.2.5 and TS 3.6.3.2.

In summary, the proposed change to TS 3.6.2.5 and TS 3.6.3.2 simplifies the presentation and increases the consistency with the other TS and the licensing basis, while balancing more and less restrictive requirements.

#### **4. REGULATORY EVALUATION**

Section IV, "The Commission Policy," of the "Final Policy Statement on Technical Specifications Improvements for Nuclear Power Reactors" (58 Federal Register 39132), dated July 22, 1993, states in part:

The purpose of Technical Specifications is to impose those conditions or limitations upon reactor operation necessary to obviate the possibility of an abnormal situation or event giving rise to an immediate threat to the public health and safety by identifying those features that are of controlling importance to safety and establishing on them certain conditions of operation which cannot be changed without prior Commission approval.

...[T]he Commission will also entertain requests to adopt portions of the improved STS, even if the licensee does not adopt all STS improvements.

...The Commission encourages all licensees who submit Technical Specification related submittals based on this Policy Statement to emphasize human factors principles.

...In accordance with this Policy Statement, improved STS have been developed and will be maintained for [BWR designs]. The Commission encourages licensees to use the improved STS as the basis for plant-specific Technical Specifications.

...[I]t is the Commission intent that the wording and Bases of the improved STS be used ... to the extent practicable.

As described in the Commission's "Final Policy Statement on Technical Specifications Improvements for Nuclear Power Reactors," recommendations were made by NRC and industry task groups for new STS that include greater emphasis on human factors principles in order to add clarity and understanding to the text of the STS, and provide improvements to the Bases of STS, which provides the purpose for each requirement in the specification. Improved vendor-specific STS were developed and issued by the NRC in September 1992.

The regulation at Title 10 of the Code of Federal Regulations (10 CFR) Section 50.36(a)(1) requires an applicant for an operating license to include in the application proposed TS in accordance with the requirements of 10 CFR 50.36. The applicant must include in the application a "summary statement of the bases or reasons for such specifications, other than

those covering administrative controls...." However, per 10 CFR 50.36(a)(1), these technical specification bases "shall not become part of the technical specifications." The Final Policy Statement provides the following description of the scope and the purpose of the Technical Specification Bases:

Appropriate Surveillance Requirements and Actions should be retained for each LCO [limiting condition for operation] which remains or is included in the Technical Specifications. Each LCO, Action, and Surveillance Requirement should have supporting Bases. The Bases should at a minimum address the following questions and cite references to appropriate licensing documentation (e.g., FSAR, Topical Report) to support the Bases.

1. What is the justification for the Technical Specification, i.e., which Policy Statement criterion requires it to be in the Technical Specifications?
2. What are the Bases for each LCO, i.e., why was it determined to be the lowest functional capability or performance level for the system or component in question necessary for safe operation of the facility and, what are the reasons for the Applicability of the LCO?
3. What are the Bases for each Action, i.e., why should this remedial action be taken if the associated LCO cannot be met; how does this Action relate to other Actions associated with the LCO; and what justifies continued operation of the system or component at the reduced state from the state specified in the LCO for the allowed time period?
4. What are the Bases for each Safety Limit?
5. What are the Bases for each Surveillance Requirement and Surveillance Frequency; i.e., what specific functional requirement is the surveillance designed to verify? Why is this surveillance necessary at the specified frequency to assure that the system or component function is maintained, that facility operation will be within the Safety Limits, and that the LCO will be met?

Note: In answering these questions the Bases for each number (e.g., Allowable Value, Response Time, Completion Time, Surveillance Frequency), state, condition, and definition (e.g., operability) should be clearly specified. As an example, a number might be based on engineering judgment, past experience, or PSA [probabilistic safety assessment] insights; but this should be clearly stated.

Additionally, 10 CFR 50.36(b) requires:

Each license authorizing operation of a ... utilization facility ... will include technical specifications. The technical specifications will be derived from the analyses and evaluation included in the safety analysis report, and amendments thereto, submitted pursuant to [10 CFR] 50.34 ["Contents of applications; technical information"]. The Commission may include such additional technical specifications as the Commission finds appropriate.

The categories of items required to be in the TSs are provided in 10 CFR 50.36(c). As required by 10 CFR 50.36(c)(2)(i), the TSs will include LCOs, which are the lowest functional capability or performance levels of equipment required for safe operation of the facility. Per 10 CFR 50.36(c)(2)(i), when an LCO of a nuclear reactor is not met, the licensee shall shut down the reactor or follow any remedial action permitted by the TSs until the condition can be met.

The regulation at 10 CFR 50.36(c)(3) requires TSs to include items in the category of SRs, which are requirements relating to test, calibration, or inspection to assure that the necessary quality of systems and components is maintained, that facility operation will be within safety limits, and that the LCOs will be met.

Per 10 CFR 50.90, whenever a holder of a license desires to amend the license, application for an amendment must be filed with the Commission, fully describing the changes desired, and following as far as applicable, the form prescribed for original applications.

Per 10 CFR 50.92(a), in determining whether an amendment to a license will be issued to the applicant, the Commission will be guided by the considerations which govern the issuance of initial licenses to the extent applicable and appropriate.

The NRC staff's guidance for the review of TSs is in Chapter 16, "Technical Specifications," of NUREG-0800, Revision 3, "Standard Review Plan for the Review of Safety Analysis Reports for Nuclear Power Plants" (SRP), dated March 2010 (ADAMS Accession No. ML100351425). As described therein, as part of the regulatory standardization effort, the NRC staff has prepared STS for each of the light-water reactor nuclear designs.

In conclusion, based on the considerations discussed above, the proposed revision does not alter the current manner of operation and (1) there is reasonable assurance that the health and safety of the public will not be endangered by continued operation in the proposed manner, (2) such activities will be conducted in compliance with the Commission's regulations, and (3) the approval of the proposed change will not be inimical to the common defense and security or to the health and safety of the public.

## **5. REFERENCES**

1. Safety Communication SC02-10, "Drywell-to-Wetwell Differential Pressure Control Technical Specification for some Mark I Containments."

**Attachment**

**General Electric Safety Communication SC02-10,  
"Drywell-to-Wetwell Differential Pressure Control Technical Specification for some  
Mark I Containments."**





GE Nuclear Energy

## 10 CFR Part 21 Notification

SC02-10

July 26, 2002

**To:** BWRs with Mark I Containments

**Subject:** Drywell-to-Wetwell Differential Pressure Control Technical Specification for Some Mark I Containments

☐ Reportable Condition [21.21(d)]

☐ 60 Day Interim Report [21.21(a)(2)]

☐ Transfer of Information [21.21(b)]

☒ Safety Information Communication

### Summary:

The required action given in the Improved Technical Specifications (ITS) for Mark I plants with operating drywell-to-wetwell differential pressure control (LCO 3.6.2.5) may not be consistent with the intended purpose of mitigating the pool swell load in the suppression pool from a postulated design basis accident loss-of-coolant-accident (DBA-LOCA). Some plants with Mark I containment use drywell-wetwell differential pressure ( $\Delta P$ ) control to maintain a positive  $\Delta P$  (drywell pressure above wetwell pressure). This reduces the water leg length in the downcomer lines and reduces the magnitude of the pool swell loads. If the  $\Delta P$  is less than the Technical Specification required minimum value, it is necessary to reduce reactor pressure to effectively mitigate pool swell loads from a postulated DBA-LOCA. ITS LCO 3.6.2.5 allows extended plant operation with reactor power reduced to below 15% of Rated Thermal Power, without reducing reactor pressure. This is acceptable for Mark I plants that have demonstrated acceptable loads with zero  $\Delta P$ , but may be unacceptable for plants that require a positive  $\Delta P$  to maintain pool swell loads within acceptable design limits.

This concern does not produce a significant safety hazard or violate a technical specification safety limit. Therefore, it is not reportable under 10 CFR Part 21. However, Mark I plants should confirm that LCO 3.6.2.5 is consistent with the plant's design basis for pool swell loads.

Issued by:

J. S. Post, Manager  
Engineering Quality and Safety Evaluations  
GE Nuclear Energy, M/C 772  
175 Curtner Avenue, San Jose, CA 95125  
(408) 925-5362

Notice: This 10 CFR Part 21 Notification pertains only to the plants or facilities specifically indicated as being affected. GE Nuclear Energy (GE-NE) has not considered or evaluated the applicability, if any, of this information to any plants or facilities other than those specifically indicated as being affected and for which GE-NE supplied the equipment or services addressed in the Notification. Determination of applicability of this information to a particular plant or facility, and the decision of whether or not to take action based on the Notification, are the responsibilities of the Owner of that plant or facility.

**SC02-10**

---

**Background**

During the Mark I Containment Long-Term Program (LTP), which defined the hydrodynamic loads for Mark I plants, it was determined that pool swell loads were mitigated by maintaining a positive drywell-to-wetwell pressure difference. Based on this determination, a Technical Specification (TS) Limiting Condition for Operation (LCO) was specified to maintain a positive drywell-to-wetwell pressure differential. As required by Reference 1, plants with Mark I containments had the option of either confirming their design was adequate for the higher pool swell loads with a zero drywell-to-wetwell pressure difference (zero  $\Delta P$ ), or of maintaining an operating drywell-to-wetwell pressure difference (operating  $\Delta P$ ) and demonstrating that their containment design was adequate for the lower pool swell loads.

The applicable generic TS LCO included action items to restore the operating  $\Delta P$  within a specified time period. If the operating  $\Delta P$  could not be restored, subsequent actions were described that required the plant to be in the hot shutdown condition and ultimately in the cold shutdown condition within specified times. Since pool swell loads are driven by the reactor pressure, the action to be in cold shutdown (which requires vessel depressurization) is adequate to eliminate pool swell loads during a postulated LOCA.

In the course of reviewing plant-specific TS changes for a proposed plant modification, it was discovered that the existing TS LCO for drywell-to-suppression chamber differential pressure, based on the ITS, did not include an action to depressurize the reactor. The ITS maintains the requirement to restore the pressure differential, when lost. However, if the  $\Delta P$  is not restored, the subsequent action required by LCO 3.6.2.5 is to reduce reactor power to 15% rated thermal power (RTP), and does not include an action to reduce reactor pressure. This action would not significantly mitigate pool swell loads during a postulated DBA-LOCA. This action is also inconsistent with requirements of Reference 1.

**Safety Basis**

The impact of adhering to ITS LCO 3.6.2.5 was evaluated to determine if the pool swell load for a postulated DBA-LOCA during operation with zero  $\Delta P$  could produce a significant safety hazard or lead to violation of a TS safety limit. This affects Mark I plants that have not demonstrated adequate structural capability with zero  $\Delta P$  and have implemented the ITS recommendations for LCO 3.6.2.5.

The safety evaluation focuses on the NRC requirement in Reference 1, which states that Mark I plants with drywell-to-wetwell differential pressure control are required to demonstrate (by structural evaluations) that a DBA-LOCA with the differential pressure control out-of-service would not result in unacceptable consequences. An additional consideration used in the safety evaluation is the significant conservatism in the Mark I pool swell load definition.

*SC02-10*Structural Evaluation Requirements

Mark I plants had a choice to either design for the higher loads associated with a zero drywell-to-wetwell operating  $\Delta P$ , or implement an operating  $\Delta P$  and design for the corresponding lower loads. The NRC, in Reference 1, required that plants that implemented the operating drywell-to-wetwell  $\Delta P$  also must demonstrate that the containment can maintain its functional capability when  $\Delta P$  control is out of service, evaluating against the higher Service Level D limits.

Consequently, pool swell loads with zero drywell-to-wetwell  $\Delta P$  were also defined for plants that use drywell-to-wetwell  $\Delta P$  control. The load definition was used in structural evaluations to confirm the functional capability of the suppression chamber to withstand pool swell loads against Service Level D limits with loss of drywell-to-wetwell  $\Delta P$  control. Compliance with this NRC requirement is sufficient to demonstrate that if a postulated DBA-LOCA were to occur for these plants with a zero  $\Delta P$ , it could not produce a significant safety hazard.

Conservatism in the Mark I Pool Swell Load

The Mark I pool swell loads are based on the Reference 2, Mark I Quarter Scale Test Facility (QSTF) tests. These tests were designed to develop conservative pool swell loads. Two key conservatisms are identified here.

- Pressurization Rate Conservatism: The drywell pressurization transient used for the test was based on the predicted drywell pressure from the approved containment licensing evaluation model M3CPT. Comparisons to the drywell pressurization rate obtained with a more realistic vessel blowdown model (TRACG) have shown that the initial Mark I drywell pressurization rate using the M3CPT model is about 50% higher than realistically expected. Sensitivity tests (Reference 3) shows that the pool swell vertical upforce is approximately proportional to the pressurization rate. They show that the pool swell velocity and vent header impact loads also increase linearly with pressurization rate.
- Air Test Conservatism: A second major conservatism in the tests is the use of air to simulate the break flow to pressurize the test drywell. The use of air instead of steam produces a more severe response. This is because: 1) air tests introduce non-condensable gas into the drywell, which enhances the bubble growth in the suppression pool and 2) the effects of steam condensation, which would occur with steam tests, are not accounted for. Comparison of air versus steam pool swell tests were not available for the Mark I containment. However, a comparison of air and steam tests performed in the Mark III 1/3 area scale Partial Scale Test Facility (PSTF) provides a measure of the conservatism in the use of air tests. Per Reference 4, pool swell air tests produce consistently higher pool surface velocities (by approximately 10 feet per second) than steam tests. According to Reference 4, typical pool swell velocities for the steam tests were 33 ft/sec. Therefore a 10 ft/sec increase represents an increase in the 1/3 scale PSTF pool swell response of 30% due to the use of air as the simulated break flow.

The large (~50%) conservatism in the pressurization rate used for the Mark I QSTF test and the application of other conservatisms in the QSTF tests, such as the use of air to pressurize the

**SC02-10**

---

drywell, introduce a large margin of conservatism in the Mark I pool swell load definition. This provides additional assurance that this concern could not produce a significant safety hazard.

Therefore, it is concluded that a possible failure to comply with appropriate design requirements in the application of ITS LCO does not constitute a Reportable Condition within the context of 10 CFR Part 21 because it does not create a substantial safety hazard or contribute to the exceeding of a Technical Specification Safety Limit (i.e., reactor pressure, reactor water level or minimum critical power ratio).

***Corrective/Preventive Actions***

The BWR Owners' Group Potential Issues Resolution Team (PIRT) and ITS Committee have been informed of this issue, and have been provided a copy of this safety communication. It is recommended that:

1. The ITS Committee modify LCO 3.6.2.5 to require reactor depressurization when  $\Delta P$  control is lost for plants that require a positive drywell-to-wetwell  $\Delta P$  to be consistent with design basis pool swell loads
2. Plants with Mark I containments confirm that if they are using ITS LCO 3.6.2.5, their containment is structurally designed for pool swell loads associated with a zero drywell-to-wetwell  $\Delta P$ . If not, then LCO 3.6.2.5 should be modified to require reactor depressurization if the required drywell-to-wetwell  $\Delta P$  cannot be restored within the allowable time.

***References***

1. US-NRC NUREG-0661, Safety Evaluation Report, Mark I Containment Long-Term Program, July 1980.
2. NEDE-21944-P, "Mark I Containment Program, Quarter Scale Plant Unique Tests, April 1979.
3. NEDE-23545-P, "Mark I Containment Program, 1/4 Scale Pressure Suppression Pool Swell Test Program: LDR Load Tests- Generic Sensitivity, December 1978.
4. 22A7007, Rev. 0, GESSAR II, Appendix 3B, Attachment O, Response to NRC Question 3B.3.

SC02-10

**Attachment 1 - Affected Plants**

<u>Utility</u>	<u>Plant</u>
AmerGen Energy Co.	Clinton
X AmerGen Energy Co.	Oyster Creek
X Constellation Generation Group	Nine Mile Point 1
Constellation Generation Group	Nine Mile Point 2
X Carolina Power & Light Co.	Brunswick 1
X Carolina Power & Light Co.	Brunswick 2
X Detroit Edison Co.	Fermi 2
X Dominion Generation	Millstone 1
Energy Northwest	Columbia
X Entergy Nuclear Northeast	FitzPatrick
X Entergy Nuclear Northeast	Pilgrim
Entergy Operations, Inc.	Grand Gulf
Entergy Operations, Inc.	River Bend
Exelon Generation Co.	CRIT Facility
X Exelon Generation Co.	Dresden 2
X Exelon Generation Co.	Dresden 3
Exelon Generation Co.	LaSalle 1
Exelon Generation Co.	LaSalle 2
Exelon Generation Co.	Limerick 1
Exelon Generation Co.	Limerick 2
X Exelon Generation Co.	Peach Bottom 2
X Exelon Generation Co.	Peach Bottom 3
X Exelon Generation Co.	Quad Cities 1
X Exelon Generation Co.	Quad Cities 2
FirstEnergy Nuclear Operating Co.	Perry 1
X Nebraska Public Power District	Cooper
X Nuclear Management Co.	Duane Arnold
X Nuclear Management Co.	Monticello
Pooled Equipment Inventory Co.	PIM
PPL Inc.	Susquehanna 1
PPL Inc.	Susquehanna 2
X Public Service Electric & Gas Co.	Hope Creek
X Southern Nuclear Operating Co.	Hatch 1
X Southern Nuclear Operating Co.	Hatch 2
X Tennessee Valley Authority	Browns Ferry 1
X Tennessee Valley Authority	Browns Ferry 2
X Tennessee Valley Authority	Browns Ferry 3
X Vermont Yankee Nuclear Power Corp.	Vermont Yankee
<i>Non-US Plants Affected</i>	
X Bernische Kraftwerke AG	Muchleberg
X Japan Atomic Power Corporation	Tsuruga
X Nuclenor SA	Santa Maria de Garona
X Taiwan Power Company	Chinshan 1
X Taiwan Power Company	Chinshan 2
X Tokyo Electric Power Corporation	Fukushima Daiichi 1
X Tokyo Electric Power Corporation	Fukushima Daiichi 2

## **Model Application**

[DATE]

10 CFR 50.90

ATTN: Document Control Desk  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555-0001

DOCKET NO. 50-[xxx]  
PLANT NAME

SUBJECT: Application to Revise Technical Specifications to Adopt  
TSTF-568, "Revise Applicability of BWR TS 3.6.2.5 and  
TS 3.6.3.2"

Pursuant to 10 CFR 50.90, [LICENSEE] is submitting a request for an amendment to the Technical Specifications (TS) for [PLANT NAME, UNIT NOS.].

[LICENSEE] requests adoption of TSTF 568, "Revise Applicability of BWR TS 3.6.2.5 and TS 3.6.3.2." TSTF-568 revises the Applicability and Actions of Technical Specification (TS) [3.6.2.5, "Drywell-to-Suppression Chamber Differential Pressure," and TS] 3.6.3.2, "Primary Containment Oxygen Concentration," and presents the requirements in a manner more consistent with the Standard Technical Specifications (STS) format and content.

The enclosure provides a description and assessment of the proposed change. Attachment 1 provides the existing TS pages marked to show the proposed change. Attachment 2 provides revised (clean) TS pages. Attachment 3 provides the existing TS Bases pages marked to show revised text associated with the proposed TS changes and is provided for information only.

[LICENSEE] requests review of this amendment request under the Consolidated Line Item Improvement Process (CLIIP). Approval of the proposed amendment is requested by [date]. Once approved, the amendment shall be implemented within [ ] days.

There are no regulatory commitments made in this submittal.

In accordance with 10 CFR 50.91, a copy of this application, with attachments, is being provided to the designated [STATE] Official.

[In accordance with 10 CFR 50.30(b), a license amendment request must be executed in a signed original under oath or affirmation. This can be accomplished by attaching a notarized affidavit confirming the signature authority of the signatory, or by including the following statement in the cover letter: "I declare under penalty of perjury that the foregoing is true and correct. Executed on (date)." The alternative statement is pursuant to 28 USC 1746. It does not require notarization.]

If you should have any questions regarding this submittal, please contact [NAME, TELEPHONE NUMBER].

Sincerely,

[Name, Title]

Enclosure:     Description and Assessment

Attachments: 1.    Proposed Technical Specification Changes (Mark-Up)  
                  2.    Revised Technical Specification Pages  
                  3.    Proposed Technical Specification Bases Changes (Mark-Up) – For  
                         Information Only

[The attachments are to be provided by the licensee and are not included in the model application.]

cc:     NRC Project Manager  
         NRC Regional Office  
         NRC Resident Inspector  
         State Contact



## ENCLOSURE

## DESCRIPTION AND ASSESSMENT

## 1.0 DESCRIPTION

[LICENSEE] requests adoption of TSTF-568, "Revise the Applicability of BWR TS 3.6.2.5 and TS 3.6.3.2." TSTF-568 revises the Applicability and Actions of Technical Specification (TS) [3.6.2.5, "Drywell-to-Suppression Chamber Differential Pressure," and TS] 3.6.3.2, "Primary Containment Oxygen Concentration," and presents the requirements in a manner more consistent with the Standard Technical Specifications (STS) format and content.

## 2.0 ASSESSMENT

## 2.1 Applicability of Safety Evaluation

[LICENSEE] has reviewed the safety evaluation for TSTF-568 provided to the Technical Specifications Task Force in a letter dated [DATE]. This review included a review of the NRC staff's evaluation, as well as the information provided in TSTF-568. [As described herein,] [LICENSEE] has concluded that the justifications presented in TSTF-568 and the safety evaluation prepared by the NRC staff are applicable to [PLANT, UNIT NOS.] and justify this amendment for the incorporation of the changes to the [PLANT] TS.

## 2.2 Optional Changes and Variations

[LICENSEE is not proposing any variations from the TS changes described in TSTF-568 or the applicable parts of the NRC staff's safety evaluation dated [DATE].] [LICENSEE is proposing the following variations from the TS changes described in TSTF-568 or the applicable parts of the NRC staff's safety evaluation: describe the variations]

[The [PLANT] TS utilize different [numbering][and][titles] than the Standard Technical Specifications on which TSTF-568 was based. Specifically, [describe differences between the plant-specific TS numbering and/or titles and the TSTF-568 numbering and titles.] These differences are administrative and do not affect the applicability of TSTF-568 to the [PLANT] TS.]

[The [PLANT] TS provide a different limit on primary containment oxygen concentration than the 4.0 volume percent limit shown in NUREG-1433. This difference does not affect the applicability of the proposed change.]

[The [PLANT] TS [3.6.2.5 and 3.6.3.2] include the existing Applicability requirements in the [Actions and Surveillances.] These requirements are [revised/removed] to be consistent with the revised Applicability. This difference does not affect the applicability of the proposed change.]

[The proposed change to TS 3.6.2.5, "Drywell-to-Suppression Chamber Differential Pressure," in TSTF-568 is not applicable to [PLANT] and is not included.]

[The [PLANT] TS contain requirements that differ from the Standard Technical Specifications on which TSTF-568 was based, but are encompassed in the TSTF-568 justification. [Describe differences and why TSTF-568 is still applicable.]]

### 3.0 REGULATORY ANALYSIS

#### 3.1 No Significant Hazards Consideration Analysis

[LICENSEE] requests adoption of TSTF-568, "Revise Applicability of BWR TS 3.6.2.5 and TS 3.6.3.2." TSTF-568 revises the Applicability and Actions of Technical Specification (TS) [3.6.2.5, "Drywell-to-Suppression Chamber Differential Pressure," and TS] 3.6.3.2, "Primary Containment Oxygen Concentration," and presents the requirements in a manner more consistent with the Standard Technical Specifications (STS) format and content.

[LICENSEE] has evaluated if a significant hazards consideration is involved with the proposed amendment(s) by focusing on the three standards set forth in 10 CFR 50.92, "Issuance of amendment," as discussed below:

1. Does the proposed amendment involve a significant increase in the probability or consequences of an accident previously evaluated?

Response: No

The proposed change revises the Applicability and Actions of TS [3.6.2.5, "Drywell-to-Suppression Chamber Differential Pressure," and TS] 3.6.3.2, "Primary Containment Oxygen Concentration," and presents the requirements in a manner more consistent with the STS format and content. [Drywell-to-suppression chamber differential pressure and] primary containment oxygen concentration are not initiators to any accident previously evaluated. As a result, the probability of any accident previously evaluated is not affected by the proposed change.

[Drywell-to-Suppression Chamber Differential Pressure and] Primary Containment Oxygen Concentration are assumptions in the mitigation of some accidents previously evaluated. The Applicability of TS 3.6.3.2 is changed from Mode 1 when thermal power is greater than [15]% to Modes 1 and 2. This expands the Applicability of the TS and will not have an effect on the consequences of an accident. The existing Applicability exceptions are removed and replaced with a longer Completion Time of 72 hours. The consequences of an event that could affect the [drywell-to-suppression chamber differential pressure and] primary containment oxygen concentration are no different during the proposed Completion Time than the consequences of the same event during the existing Completion Times. A note referencing Limiting Condition for Operation (LCO) 3.0.4.c is added to the Actions to permit entering the Applicability with the LCO not met. The note replaces the existing Applicability exceptions. This change is administrative and has no effect on the consequences of an accident.

Therefore, the proposed change does not involve a significant increase in the probability or consequences of an accident previously evaluated.

2. Does the proposed amendment create the possibility of a new or different kind of accident from any accident previously evaluated?

Response: No

The proposed change revises the Applicability and Actions of TS [3.6.2.5, "Drywell-to-Suppression Chamber Differential Pressure," and TS] 3.6.3.2, "Primary Containment Oxygen Concentration," and presents the requirements in a manner more consistent with the STS format and content. The proposed change does not involve a physical alteration of the plant (no new or different type of equipment will be installed). No credible new failure mechanisms, malfunctions, or accident initiators that would have been considered a design basis accident in the UFSAR are created because the Nuclear Regulatory Commission has determined that hydrogen generation is not risk significant for design basis accidents.

Therefore, the proposed change does not create the possibility of a new or different kind of accident from any accident previously evaluated.

3. Does the proposed amendment involve a significant reduction in a margin of safety?

Response: No

The proposed change revises the Applicability and Actions of TS [3.6.2.5, "Drywell-to-Suppression Chamber Differential Pressure," and TS] 3.6.3.2, "Primary Containment Oxygen Concentration," and presents the requirements in a manner more consistent with the STS format and content. No safety limits are affected. No Limiting Conditions for Operation or Surveillance limits are affected. The [Drywell-to-Suppression Chamber Differential Pressure and] Primary Containment Oxygen Concentration Technical Specification requirements assure sufficient safety margins are maintained, and that the design, operation, surveillance methods, and acceptance criteria specified in applicable codes and standards (or alternatives approved for use by the NRC) will continue to be met as described in the plants' licensing basis. The proposed change does not adversely affect existing plant safety margins or the reliability of the equipment assumed to operate in the safety analysis. As such, there are no changes being made to safety analysis assumptions, safety limits, or limiting safety system settings that would adversely affect plant safety.

Therefore, the proposed change does not involve a significant reduction in a margin of safety.

Based on the above, [LICENSEE] concludes that the proposed change presents no significant hazards consideration under the standards set forth in 10 CFR 50.92(c), and, accordingly, a finding of "no significant hazards consideration" is justified.

### 3.2 Conclusion

In conclusion, based on the considerations discussed above, (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner,

(2) such activities will be conducted in compliance with the Commission's regulations, and (3) the issuance of the amendment will not be inimical to the common defense and security or to the health and safety of the public.

#### 4.0 ENVIRONMENTAL EVALUATION

The proposed change does not change a requirement with respect to installation or use of a facility component located within the restricted area, as defined in 10 CFR 20, or does not change an inspection or surveillance requirement. The proposed change does not involve (i) a significant hazards consideration, (ii) a significant change in the types or significant increase in the amounts of any effluents that may be released offsite, or (iii) a significant increase in individual or cumulative occupational radiation exposure. Accordingly, the proposed change meets the eligibility criterion for categorical exclusion set forth in 10 CFR 51.22(c)(9). Therefore, pursuant to 10 CFR 51.22(b), no environmental impact statement or environmental assessment need be prepared in connection with the proposed change.

## **Technical Specifications and Bases Changes**

## 3.6 CONTAINMENT SYSTEMS

## 3.6.2.5 Drywell-to-Suppression Chamber Differential Pressure

LCO 3.6.2.5 The drywell pressure shall be maintained  $\geq$  [1.5] psid above the pressure of the suppression chamber.

APPLICABILITY: MODE 1 *with THERMAL POWER > [15]% RTP. during the time period:*

- ~~a. From [24] hours after THERMAL POWER is > [15]% RTP following startup, to~~
- ~~b. [24] hours prior to reducing THERMAL POWER to < [15]% RTP prior to the next scheduled reactor shutdown.~~

## ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. Drywell-to-suppression chamber differential pressure not within limit.	A.1 <del>----- NOTE -----</del> <del>LCO 3.0.4.c is applicable.</del> Restore differential pressure to within limit.	<del>72</del> 8 hours
B. Required Action and associated Completion Time not met.	B.1 Reduce THERMAL POWER to $\leq$ [15]% RTP.	12 hours

## SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
SR 3.6.2.5.1 Verify drywell-to-suppression chamber differential pressure is within limit.	[ 12 hours  <u>OR</u>  In accordance with the Surveillance Frequency

## 3.6 CONTAINMENT SYSTEMS

## 3.6.3.2 Primary Containment Oxygen Concentration

LCO 3.6.3.2 The primary containment oxygen concentration shall be < 4.0 volume percent.

APPLICABILITY: MODES 1 ~~and 2. during the time period:~~

- ~~a. From [24] hours after THERMAL POWER is > [15]% RTP following startup, to~~
- ~~b. [24] hours prior to reducing THERMAL POWER to < [15]% RTP prior to the next scheduled reactor shutdown.~~

## ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. Primary containment oxygen concentration not within limit.	A.1 <del>----- NOTE -----</del> <del>LCO 3.0.4.c is applicable.</del> <del>-----</del> Restore oxygen concentration to within limit.	<del>72</del> 24 hours
B. Required Action and associated Completion Time not met.	B.1 <del>Be in MODE 3</del> Reduce THERMAL POWER to <del>≤ [15]% RTP.</del>	<del>128</del> hours

## SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
SR 3.6.3.2.1 Verify primary containment oxygen concentration is within limits.	[ 7 days  <u>OR</u>  In accordance with the Surveillance Frequency Control Program ]

## B 3.6 CONTAINMENT SYSTEMS

## B 3.6.2.5 Drywell-to-Suppression Chamber Differential Pressure

## BASES

BACKGROUND	<p>The toroidal shaped suppression chamber, which contains the suppression pool, is connected to the drywell (part of the primary containment) by [eight] main vent pipes. The main vent pipes exhaust into a continuous vent header, from which [96] downcomer pipes extend into the suppression pool. The pipe exit is [4] ft below the minimum suppression pool water level required by LCO 3.6.2.2, "Suppression Pool Water Level." During a loss of coolant accident (LOCA), the increasing drywell pressure will force the waterleg in the downcomer pipes into the suppression pool at substantial velocities as the "blowdown" phase of the event begins. The length of the waterleg has a significant effect on the resultant primary containment pressures and loads.</p>
APPLICABLE SAFETY ANALYSES	<p>The purpose of maintaining the drywell at a slightly higher pressure with respect to the suppression chamber is to minimize the drywell pressure increase necessary to clear the downcomer pipes to commence condensation of steam in the suppression pool and to minimize the mass of the accelerated water leg. This reduces the hydrodynamic loads on the torus during the LOCA blowdown. The required differential pressure results in a downcomer waterleg of [3.06 to 3.58] ft.</p> <p>Initial drywell-to-suppression chamber differential pressure affects both the dynamic pool loads on the suppression chamber and the peak drywell pressure during downcomer pipe clearing during a Design Basis Accident LOCA. Drywell-to-suppression chamber differential pressure must be maintained within the specified limits so that the safety analysis remains valid.</p> <p>Drywell-to-suppression chamber differential pressure satisfies Criterion 2 of 10 CFR 50.36(c)(2)(ii).</p>
LCO	<p>A drywell-to-suppression chamber differential pressure limit of [1.5] psid is required to ensure that the containment conditions assumed in the safety analyses are met. A drywell-to-suppression chamber differential pressure of &lt; [1.5] psid corresponds to a downcomer water leg of &gt; [3.58] ft. Failure to maintain the required differential pressure could result in excessive forces on the suppression chamber due to higher water clearing loads from downcomer vents and higher pressure buildup in the drywell.</p>



## BASES

**APPLICABILITY** Drywell-to-suppression chamber differential pressure must be controlled when the primary containment is inert. The primary containment must be inert in MODE 1 *with THERMAL POWER > [15]% RTP*, since this is the condition with the highest probability for an event that could ~~produce hydrogen. It is also the condition with the highest probability of an event that could~~ impose large loads on the primary containment.

~~Inerting primary containment is an operational problem because it prevents primary containment access without an appropriate breathing apparatus. Therefore, the primary containment is inerted as late as possible in the unit startup and is de-inerted as soon as possible in the unit shutdown. As long as reactor power is < [15]% RTP, the probability of an event that generates hydrogen or excessive loads on primary containment occurring within the first [24] hours following a startup or within the last [24] hours prior to a shutdown is low enough that these "windows," with the primary containment not inerted, are also justified. The [24] hour time period is a reasonable amount time to allow plant personnel to perform inerting or de-inerting.~~

**ACTIONS****A.1**

If drywell-to-suppression chamber differential pressure is not within the limit, the conditions assumed in the safety analyses are not met and the differential pressure must be restored to within the limit within ~~8-72~~ hours. The ~~728~~ hour Completion Time ~~provides sufficient time to restore differential pressure to within limit and~~ takes into account the low probability of an event that would create excessive suppression chamber loads occurring during this time period.

*A Note permits the use of the provisions of LCO 3.0.4.c. This allowance permits entry into the applicable MODE(S) while relying on the ACTIONS. This allowance is acceptable because inerting the primary containment prevents containment access without an appropriate breathing apparatus. Therefore, the primary containment is inerted as late as possible in the plant startup, after entering Mode 1 with THERMAL POWER > [15]% RTP, and de-inerted as soon as possible in the plant shutdown. It is acceptable to intentionally enter Required Action A.1 prior to a shutdown in order to begin de-inerting the primary containment prior to exiting the Applicability.*

**B.1**

If the differential pressure cannot be restored to within limits within the associated Completion Time, the plant must be placed in a MODE in which the LCO does not apply. This is done by reducing power to  $\leq$  [15]% RTP within 12 hours. The 12 hour Completion Time is reasonable, based on operating experience, to reduce reactor power from

## B 3.6 CONTAINMENT SYSTEMS

## B 3.6.3.2 Primary Containment Oxygen Concentration

## BASES

BACKGROUND	<p>All nuclear reactors must be designed to withstand events that generate hydrogen either due to the zirconium metal water reaction in the core or due to radiolysis. The primary method to control hydrogen is to inert the primary containment. With the primary containment inert, that is, oxygen concentration &lt; 4.0 volume percent (v/o), a combustible mixture cannot be present in the primary containment for any hydrogen concentration. An event that rapidly generates hydrogen from zirconium metal water reaction will result in excessive hydrogen in primary containment, but oxygen concentration will remain &lt; 4.0 v/o and no combustion can occur. This LCO ensures that oxygen concentration does not exceed 4.0 v/o during operation in the applicable conditions.</p>
APPLICABLE SAFETY ANALYSES	<p>The Reference 1 calculations assume that the primary containment is inerted when a Design Basis Accident loss of coolant accident occurs. Thus, the hydrogen assumed to be released to the primary containment as a result of metal water reaction in the reactor core will not produce combustible gas mixtures in the primary containment.</p> <p>Primary containment oxygen concentration satisfies Criterion 2 of 10 CFR 50.36(c)(2)(ii).</p>
LCO	<p>The primary containment oxygen concentration is maintained &lt; 4.0 v/o to ensure that an event that produces any amount of hydrogen does not result in a combustible mixture inside primary containment.</p>
APPLICABILITY	<p>The primary containment oxygen concentration must be within the specified limit when primary containment is inerted, <del>except as allowed by the relaxations during startup and shutdown addressed below</del>. The primary containment must be inert in MODE 1 <i>and</i> 2, since this is the condition with the highest probability of an event that could produce hydrogen.</p> <p><del>Inerting the primary containment is an operational problem because it prevents containment access without an appropriate breathing apparatus. Therefore, the primary containment is inerted as late as possible in the plant startup and de-inerted as soon as possible in the plant shutdown. As long as reactor power is &lt; 15% RTP, the potential for an event that generates significant hydrogen is low and the primary containment need not be inert. Furthermore, the probability of an event that generates hydrogen occurring within the first [24] hours of a startup, or within the last [24] hours before a shutdown, is low enough that these "windows," when the primary containment is not inerted, are also justified. The</del></p>

~~[24] hour time period is a reasonable amount of time to allow plant personnel to perform inerting or de-inerting.~~

## BASES

## ACTIONS

A.1

If oxygen concentration is  $\geq 4.0$  v/o ~~at any time~~ while operating in MODE 1 ~~or 2, with the exception of the relaxations allowed during startup and shutdown,~~ oxygen concentration must be restored to  $< 4.0$  v/o within ~~7224~~ hours. The ~~7224~~ hour Completion Time is allowed when oxygen concentration is  $\geq 4.0$  v/o because of the low probability and long duration of an event that would generate significant amounts of hydrogen occurring during this period.

*A Note permits the use of the provisions of LCO 3.0.4.c. This allowance permits entry into the applicable MODE(S) while relying on the ACTIONS. This allowance is acceptable because inerting the primary containment prevents containment access without an appropriate breathing apparatus. Therefore, the primary containment is inerted as late as possible in the plant startup, after entering Modes 1 and 2, and de-inerted as soon as possible in the plant shutdown. It is acceptable to intentionally enter Required Action A.1 prior to a shutdown in order to begin de-inerting the primary containment prior to exiting the Applicability.*

B.1

If oxygen concentration cannot be restored to within limits within the required Completion Time, the plant must be brought to a MODE in which the LCO does not apply. To achieve this status, power must be reduced to ~~MODE 3  $\leq$  [15]% RTP~~ within ~~128~~ hours. The ~~128~~ hour Completion Time is reasonable, based on operating experience, to reduce reactor power from full power conditions in an orderly manner and without challenging plant systems.

SURVEILLANCE  
REQUIREMENTSSR 3.6.3.2.1

The primary containment must be determined to be inert by verifying that oxygen concentration is  $< 4.0$  v/o. [ The 7 day Frequency is based on the slow rate at which oxygen concentration can change and on other indications of abnormal conditions (which would lead to more frequent checking by operators in accordance with plant procedures). Also, this Frequency has been shown to be acceptable through operating experience.

OR

The Surveillance Frequency is controlled under the Surveillance Frequency Control Program.

-----REVIEWER'S NOTE-----