

International Workshop on Age-Related Degradation of Reactor Vessels and Internals
23-24 May 2019, NRC, USA

Current Status of Aging Management on Reactor Vessels in Korea (focusing on surveillance test)

Tae-Kwang Song, Yong-Beum Kim

KINS

Table of Contents

1

Overview of NPPs in Korea

2

Regulatory Requirements on Reactor vessels

3

Surveillance Test Requirements

- Issue 1: Lead Factor
- Issue 2: 60 years Design Life

4

Concluding Remarks

Overview of NPPs in Korea (1)

- ▶ Status of Nuclear Power Plants in Korea
 - ▶ As of May 2019

In Operation (commercial)


24 Units

Decommissioning

1 Unit

Under Construction

5 Units



Overview of NPPs in Korea (2)

▶ Current Status of Operating NPPs

Site	Unit	MW	Reactor Type	Commercial Operation
Kori	2	650	Westinghouse	July 1983
	3	950	Westinghouse	Sep. 1985
	4	950	Westinghouse	April 1986
Shin-Kori	1	1000	OPR-1000	April 2011
	2	1000	OPR-1000	July 2012
	3	1400	APR-1400	Dec. 2016
Wolsong	1	679	PHWR	April 1983
	2	700	PHWR	July 1997
	3	700	PHWR	July 1998
	4	700	PHWR	Oct. 1999
Shin-Wol song	1	1000	OPR-1000	July 2012
	2	1000	OPR-1000	July 2015
Hanbit	1	950	Westinghouse	Aug. 1986
	2	950	Westinghouse	June 1987
	3	1000	OPR-1000	Mar. 1995
	4	1000	OPR-1000	Jan. 1996
	5	1000	OPR-1000	May 2002
	6	1000	OPR-1000	Dec. 2002
Hanul	1	950	Framatome	Sep. 1988
	2	950	Framatome	Sep. 1989
	3	1000	OPR-1000	Aug 1998
	4	1000	OPR-1000	Dec 1999
	5	1000	OPR-1000	July 2004
	6	1000	OPR-1000	April 2005

Overview of NPPs in Korea (3)

▶ Reactor Types

“different reactor type(WH vs KSNP)”

“different design life(40 yrs vs 60 yrs)”

Westinghouse Type

- Kori Units 1~4, Hanbit* Units 1&2

Framatome Type

- Hanul** Units 1&2

KSNP**** Type (OPR-1000)

- Hanbit Units 3~6, Hanul Units 3~6
- Shin***-Kori Units 1&2, Shin-Wolsong Units 1&2

KSNP Type (APR-1400)

- Shin-Kori Units 3~6, Shin-Hanul Units 1&2

PHWR Type

- Wolsong Units 1~4

* Former name is Younggwang

** Former name is Uljin

*** The term of ‘Shin-, 新’ means ‘new’

**** KSNP(Korea Standard Nuclear Plant) has been developed based on CE type reactor

Contents

1

Overview of NPPs in S. Korea

2

Regulatory Requirements on Reactor Vessels


3

Surveillance Program Requirements

- Issue 1 : Lead Factor
- Issue 2 : 60 years design Life

4



Concluding Remarks



Irradiation Embrittlement


▶ Irradiation Embrittlement

- ▶ If fast neutron fluence ($E \geq 1.0 \text{ MeV}$) exceeds 10^{17} n/cm^2 , irradiation embrittlement is introduced in typical low alloy ferritic RPV material




$$\text{Adjusted } RT_{NDT} = \text{Initial } RT_{NDT} + \Delta RT_{NDT} + \text{Margin}$$

Requirements on Surveillance Test




Requirements on Fracture Toughness



Pressure-Temperature Limit Curve

Requirements on Pressurized Thermal Shock



Requirements on Surveillance Test

NSSC : Nuclear Safety and Security Committee

NSSC Notice
2017-20

KINS/RG N6.02

Korea

10 CFR 50 App. H

Reg. Guide 1.99

ASTM E185-82

USA

Requirements on Fracture Toughness

NSSC Notice
2017-20

KINS/RS 6.4.1.5
KINS/RS 6.4.2.1

KEPIC MI,
Appendix E, G, K

Korea

10 CFR 50 App. G

Reg. Guide 1.99
Reg. Guide 1.161

ASME Section XI,
Appendix E, G, K

USA

Requirements on Pressurized Thermal Shock

NSSC Notice
2017-29

KINS/RS 6.4.2.2

Korea

10 CFR 50.61

10 CFR 50.61a

USA

1

Overview of NPPs in S. Korea

2

Regulatory Requirements on Reactor vessels

3

Surveillance Test Requirements

- Issue 1: Lead Factor
- Issue 2: 60 years Design Life

4

Concluding Remarks

Surveillance Test Requirements

- ▶ Surveillance Test
 - ▶ to monitor changes in the fracture toughness properties of ferritic materials in the reactor vessel beltline region which result from exposure of these materials to neutron irradiation and the thermal environment
- ▶ NSSC Notice 2017-20 and 10 CFR 50, App. H
 - ▶ require to perform surveillance program
 - ▶ based on ASTM E185-82
- ▶ ASTM E185-82 provide surveillance program including
 - ▶ surveillance materials
 - ▶ type of specimens
 - ▶ number of specimens
 - ▶ location of capsules
 - ▶ number of capsules
 - ▶ **withdrawal schedule**

Withdrawal Schedule in ASTM E185-82

		Predicted Transition Temperature Shift at Vessel Inside Surface		
		$\leq 56^{\circ}\text{C} (\leq 100^{\circ}\text{F})$	$>56^{\circ}\text{C} (\leq 100^{\circ}\text{F})$ $\leq 111^{\circ}\text{C} (\leq 200^{\circ}\text{F})$	$> 111^{\circ}\text{C} (>200^{\circ}\text{F})$
Minimum Number of Capsules		3	4	5
Withdrawal Sequence	First	6 ^A	3 ^A	1.5 ^A
	Second	15 ^B	6 ^C	3 ^D
	Third	EOL ^E	15 ^B	6 ^C
	Fourth	-	EOL ^E	15 ^B
	Fifth	-	-	EOL ^E

^A Or at the time when the accumulated neutron fluence of the capsule exceeds $5 \times 10^{22} \text{ n/m}^2$ ($5 \times 10^{18} \text{ n/cm}^2$), or at the time when the highest predicted ΔRT_{NDT} of all encapsulated materials is approximately 28°C (50°F), whichever comes first.

^B Or at the time when the accumulated neutron fluence of the capsule corresponds to the approximately EOL fluence at the reactor vessel inner wall location, whichever comes first.

^C Or at the time when the accumulated neutron fluence of the capsule corresponds to the approximately EOL fluence at the reactor vessel $\frac{1}{4}$ T location, whichever comes first.

^D Or at the time when the accumulated neutron fluence of the capsule corresponds to a value midway between that of the first and third capsules.


^E Not less than once or greater than twice the peak EOL vessel fluence. This may be modified on the basis of previous tests. This capsule may be held without testing following withdrawal.



Issue 1: Lead Factor

WH Type

KSNP Type



Lead Factor

- WH Type : 2.9 ~ 3.5
- KSNP Type : ~1.3

$$\text{Lead Factor} = \frac{\text{Fluence of Surveillance Capsule}}{\text{Fluence of Vessel Wall}}$$

Withdrawal Schedule of WH Type Reactor

❑ Assumption

- 40 years design life
- predicted transition shift at vessel inside surface < 56°C

Sequence	Schedule	Remarks
First	< 6 EFPY	- Earlier one of [6EFPY, the time when the accumulated neutron fluence of the capsule exceeds $5 \times 10^{22} \text{ n/m}^2$]
Second	9 EFPY	- 15 EFPY or <u>at the time when the accumulated neutron fluence of the capsule corresponds to the approximately EOL fluence at the reactor vessel inner wall location, whichever comes first</u> - Earlier one of [15EFPY, <u>9.4 EFPY</u>] = 32 EFPY / 3.4 (lead factor)
Third	14 EFPY	- Not less than once or greater than twice the peak EOL vessel fluence - Between [1.0 EOL, 2.0 EOL] - If third surveillance is performed at <u>14 EFPY</u> , 48 EFPY data would be obtained = 48 EFPY / 3.4 (lead factor)

Possible to obtain EOL(40 years) data

Possible to obtain CO(60 years) data

CO : Continued Operation (extended life to 60 yrs)

Withdrawal Schedule of KSNP Type Reactor

❑ Assumption

- 40 years design life
- predicted transition shift at vessel inside surface < 56°C

Sequence	Schedule	Remarks
First	< 6 EFPY	- Earlier one of [6EFPY, the time when the accumulated neutron fluence of the capsule exceeds $5 \times 10^{22} \text{ n/m}^2$]
Second	15 EFPY	- 15 EFPY or <u>at the time when the accumulated neutron fluence of the capsule corresponds to the approximately EOL fluence at the reactor vessel inner wall location, whichever comes first</u> - Earlier one of [15EFPY, <u>24.6 EFPY</u>] = 32 EFPY / 1.3 (lead factor)
Third	32 EFPY	- Not less than once or greater than twice the peak EOL vessel fluence - Between [1.0 EOL, 2.0 EOL] - If third surveillance is performed at <u>32 EFPY</u> , 42 EFPY data would be obtained = 42 EFPY / 1.3 (lead factor)

Impossible to obtain EOL(40 years) data

Impossible to obtain CO(60 years) data

CO : Continued Operation (extended life to 60 yrs)

Obtaining EOL(40 years) Data

- ▶ Adjusted withdrawal schedule was submitted for Operation License Review

Sequence	Withdrawal Schedule (EFPY)											
	Hanbit				Hanul				Shin-Kori		Shin-Wolsong	
	3	4	5	6	3	4	5	6	1	2	1	2
First	6.20	6.02	6.49	6.54	6.61	6.57	6.93	7.16	6 *	6 *	6 *	6 *
Second	14.60	14.88	15*	15*	15.7	15*	15*	15*	15*	15*	15*	15*
Third	26*	26*	26*	26*	23*	23*	23*	23*	26*	26*	26*	26*
4th~6th	Standby	Standby	Standby	Standby	Standby	Standby	Standby	Standby	Standby	Standby	Standby	Standby

Source: FSAR of each plant. As of April 2018


* : planned schedule (not performed)

Obtaining CO(60 years) Data (1)

- ▶ Accelerated Surveillance Test using WH reactors
 - ▶ New surveillance capsules were fabricated using archive materials of KSNP reactors, then inserted into WH reactors during 2014~2016


KSNP Reactors	WH Reactors	Remarks
Hanbit 3	Hanbit 1	two additional surveillance capsules per each KSNP reactor (one for 60 years, another for 80 years)
Hanbit 4		
Hanbit 5	Hanbit 2	
Hanbit 6		
Hanul 3	Kori 3	
Hanul 4		
Hanul 5	Kori 4	
Hanul 6		

Obtaining CO(60 years) Data (2)



Plant	Location		Flux	Relative Lead Factor*
Hanbit 2	Surveillance Capsule	V(107°)	1.32E+11	8.73
		W(110°)	1.08E+11	7.19
	RV Inner wall		3.59E+10	-
Hanbit 5	RV inner wall		1.50E+10	-

Obtaining CO(60 years) Data (3)



Issue 2: 60 years Design Life

- ▶ Current withdrawal schedule
 - ▶ Based on 40 years design life
 - ▶ ASTM E185-82 7.6.2 “The withdrawal schedule is in terms of effective full-power years of the vessel with a design life of 32 EFPY”
 - ▶ Difficult to apply directly to 60 years design life reactors
 - ▶ Design life of APR 1400 reactor is 60 years
- ▶ Design Life, Operating License Period, Continued Operation
 - ▶ Operating license period varies from country to country
 - ▶ (Korea) operating license period is determined by the design life of reactors
 - ▶ (USA) In AEA sec.103, “license shall be issued for a specified period,•••, but not exceeding 40 years
 - ▶ Design Life, LR(License Renewal), SLR(Subsequent License Renewal)...



New criteria for withdrawal schedule is needed

Issue 2: 60 years Design Life

▶ Revision of Withdrawal Schedule in ASTM E185

- ▶ Based on combination of Reactor Year and Fluence (E185-82)
- ▶ Based on **Fluence** (since E185-02)

E185-82

	Predicted Transition Temperature Shift at Vessel Inside Surface		
	≤56°C (≤100°F)	>56°C (>100°F) ≤111°C (≤200°F)	>111°C (>200°F)
Minimum Number of Capsules	3	4	5
Withdrawal Sequence:			
First	6 ^A	3 ^A	1.5 ^A
Second	15 ^B	6 ^B	3 ^B
Third	EOL ^E	15 ^B	6 ^C
Fourth		EOL ^E	15 ^B
Fifth			EOL ^E

^A Or at the time when the accumulated neutron fluence of the capsule exceeds $5 \times 10^{22} \text{ n/cm}^2$ ($5 \times 10^{18} \text{ n/cm}^2$), or at the time when the highest predicted ΔRT_{NDT} of all encapsulated materials is approximately 28°C (50°F), whichever comes first.
^B Or at the time when the accumulated neutron fluence of the capsule corresponds to the approximate EOL fluence at the reactor vessel inner wall location, whichever comes first.
^C Or at the time when the accumulated neutron fluence of the capsule corresponds to the approximate EOL fluence at the reactor vessel 1/4 T location, whichever comes first.
^D Or at the time when the accumulated neutron fluence of the capsule corresponds to a value midway between the EOL fluence at the reactor vessel inner wall location and the EOL fluence at the reactor vessel 1/4 T location, whichever comes first.
^E Not less than once or greater than once. This withdrawal schedule may be modified on the basis of prior testing following withdrawal.

E185-02

Sequence	Target Fluence	Priority
First	$5 \times 10^{18} \text{ n/cm}^2$ ($5 \times 10^{22} \text{ n/cm}^2$) for PWRs; $E > 1 \text{ MeV}$	2 (Required if $\Delta RT_{\text{NDT}} > 56^\circ\text{C}$ [100°F])
Second	EOL 1/4-T	1 (Required for all materials)
Third	EOL ID	1 (Required for all materials)
Fourth	(EOL 1/4-T - 1st Capsule)/2	3 (Required if $\Delta RT_{\text{NDT}} > 111^\circ\text{C}$ [200°F])
Subsequent	Supplemental Evaluations	Not Required

E185-16

Sequence	Target Fluence	Notes
First	1/4 MDF	Testing Required
Second	1/6 MDF	Testing Required
Third		Testing Required
Fourth		Testing Required
Standby		Testing Not Required

- End Of Life & Fluence

- End of License Fluence
- Maximum Design Fluence

Proposed Withdrawal Schedule in Korea

		Predicted Transition Temperature Shift at Vessel Inside Surface		
		$\leq 56^{\circ}\text{C} (\leq 100^{\circ}\text{F})$	$>56^{\circ}\text{C} (\leq 100^{\circ}\text{F})$ $\leq 111^{\circ}\text{C} (\leq 200^{\circ}\text{F})$	$> 111^{\circ}\text{C} (>200^{\circ}\text{F})$
Minimum Number of Capsules		4 3	4	5
Withdrawal Sequence	First	A 6 ^A	A 3 ^A	A 1.5 ^A
	Second	C 15 ^B	C 6 ^C	D 3 ^D
	Third	B EOL ^E	B 15 ^B	C 6 ^C
	Fourth	E -	E EOL ^E	B 15 ^B
	Fifth	-	-	E EOL ^E

A Θ r at the time when the accumulated neutron fluence of the capsule exceeds 5×10^{22} n/m² (5×10^{18} n/cm²), or at the time when the highest predicted ΔRT_{NDT} of all encapsulated materials is approximately 28°C(50°F), whichever comes first.

B Θ r at the time when the accumulated neutron fluence of the capsule corresponds to the approximately EOL fluence at the reactor vessel inner wall location, ~~whichever comes first.~~

C Θ r at the time when the accumulated neutron fluence of the capsule corresponds to the approximately EOL fluence at the reactor vessel 1/4 T location, ~~whichever comes first.~~

D Θ r at the time when the accumulated neutron fluence of the capsule corresponds to a value midway between that of the first and third capsules.

E Not less than once or greater than twice the peak EOL vessel fluence. This may be modified on the basis of previous tests. This capsule may be held without testing following withdrawal.

Proposed Withdrawal Schedules in Korea

▶ Application to APR-1400 model

□ Assume

- Lead Factor : 1.4(APR-1400)

- Calculation of Fluence at ¼ T location: RG-1.99 method $f = f_{surf}(e^{-0.24x})$

Sequence	Schedule	Remarks
First	< 6 EFPY	- At the time when the accumulated neutron fluence of the capsule exceeds $5 \times 10^{22} \text{ n/m}^2$]
Second	17 EFPY	- At the time when the accumulated neutron fluence of the capsule corresponds to the approximately EOL fluence at the reactor vessel ¼ T location $= 48 \times \frac{1}{\cong 2} \times \frac{1}{1.4}$ $f = f_{surf}(e^{-0.24x}) \rightarrow f @ \frac{1}{4}T = \sim 0.5f_{surf}$
Third	34 EFPY	- At the time when the accumulated neutron fluence of the capsule corresponds to the approximately EOL fluence at the reactor vessel inner wall location $= 48 \times \frac{1}{1.4} \text{ (design life/lead factor)}$
4th~6th	Standby	

Concluding Remarks

- ▶ Surveillance test requirement in Korea is presented
 - ▶ current surveillance test is based on ASTM E185-82
- ▶ Low value of Lead Factor issue was resolved by
 - ▶ adjusting withdrawal schedule of KSNP type reactor (40 yrs data)
 - ▶ using WH reactor for acceleration surveillance test (60 yrs data)
- ▶ Revised withdrawal schedule is proposed to cover all the plant regardless of design life (in processing)