CHAPTER 16

TABLE OF CONTENTS

<u>Section</u>	<u>Title</u>	<u>Page</u>
16	TECHNICAL SPECIFICATIONS	16.1-1
16.1	PRELIMINARY TECHNICAL SPECIFICATIONS (PSA	AR)16.1-1
16.2	PROPOSED FINAL TECHNICAL SPECIFICATIONS	(FSAR)16.2-1
APPENDIX	K 16A LICENSING REQUIREMENTS MANUAL	

CHAPTER 16

TECHNICAL SPECIFICATIONS

16.1 PRELIMLINARY TECHNICAL SPECIFICATIONS (PSAR)
Not applicable.

16.2 TECHNICAL SPECIFICATIONS

Technical Specifications (NUREG 1279) are included as Appendix A to Operating License No. NPF-73, issued on August 14, 1987.

APPENDIX 16A

LICENSING REQUIREMENTS MANUAL

Changes to the technical specifications may result in relocating various technical specification items to the Licensing Requirements Manual. This maintains control of the items and allows changing these requirements in accordance with the provisions of 10 CFR 50.59 without the need to process a license amendment request. Items relocated from the Unit 2 Technical Specifications include:

1.	The Core Operating Limits Report (COLR)	[TS	Amendment	31]
2.	Containment penetrations table (containment isolation valves)	[TS	Amendment	66]
3.	Tables of response time limits for the reactor trip system (RTS) and the engineered safety features actuation system (ESFAS)	[TS	Amendment	88]
4.	Meteorological Monitoring Instrumentation	[TS	Amendment	97]
5.	Axial Flux Difference (AFD) and Quadrant Power Tilt Ratio (QPTR) Monitor Surveillance	[TS	Amendment	102]
6.	Seismic Monitoring Instrumentation	[TS	Amendment	107]
7.	Movable Incore Detectors	[TS	Amendment	115]
8.	Turbine Overspeed Protection	[TS	Amendment	115]
9.	Crane Travel - Spent Fuel Storage Pool Building	[TS	Amendment	115]
10.	REACTIVITY CONTROL SYSTEMS (LR 3.1.1 thru 3.1.9 and LR 3.1.11)	[TS	Amendment	124]
11.	Fuel Storage Pool Area Radiation Monitor Instrumentation	[TS	Amendment	124]
12.	PLANT SYSTEMS (LR 3.7.1 thru 3.7.5)	[TS	Amendment	124]
13.	REFUELING Communications ¹ ; Manipulator Crane Operability	[TS	Amendment	124]
14.	REACTOR COOLANT SYSTEM (LR 3.4.1 thru 3.4.5) 2,3	[TS	Amendment	124]

Notes:

- 1. LRM Licensing Document Change Notice 2-055 eliminated LR 7.2, "Communications."
- 2. LRM Licensing Document Change Notice 2-055 eliminated LR 8.2, "Safety Valves Shutdown."
- 3. LRM Licensing Document Change Notice 10-069 eliminated LR 3.4.4, "Structural Integrity ASME Code Class 1, 2 and 3 Components."

15.	Explosive Gas Monitoring Instrumentation	[TS	Amendment	130]
16.	Explosive Gas Mixture	[TS	Amendment	130]
17.	Pressure and Temperature Limits Report (PTLR)	[TS	Amendment	138]
18.	Containment Hydrogen Analyzer	[TS	Amendment	142]
19.	Pressurizer Safety Valve Lift Involving Loop Seal or Water Discharge	[TS	Amendment	161]
20.	RCS Pressure Isolation Valves	[TS	Amendment	161]
21.	Containment Sump	[TS	Amendment	161]
22.	Emergency Diesel Generator (EDG) 2000 Hour Rating Limit	[TS	Amendment	161]
23.	125V D.C. Battery Bank Maintenance	[TS	Amendment	161]
24.	Main Fuel Oil Storage Tank Maintenance	[TS	Amendment	161]
25.	Decay Time	[TS	Amendment	161]
26.	Boron Dilution	[TS	Amendment	161]
27.	Accident Monitoring Instrumentation	[TS	Amendment	161]
28.	Containment Area Radiation Alarm	[TS	Amendment	161]
29.	Control Room Isolation Radiation Monitors	[TS	Amendment	161]
30.	Supplemental Leak Collection and Release System (SLCRS)	[TS	Amendment	161]