# **TURBINE CASING PROPERTIES**

Tensile Strength, psi, Min	70,000
Yield Strength, psi, Min	36,000
Elongation in 2 Inches, %, Min	22
Reduction of Area, %. Min	35

# **STUD MECHANICAL PROPERTIES**

	Size, Inches		
	2-1/2 and Less	Over 2-1/2 to 4	Over 4 to 7
Tensile Strength, psi, Min	125,000	115,000	110,000
Yield Strength, psi, Min (0.2% Offset)	105,000	95,000	85,000
Elongation in 2 Inches, %, Min	16	16	16
Reduction of Area, %, Min	50	50	45

### SIGNAL SYSTEM OPERATING CONDITIONS

- 1. Hydrogen Purity High or Low
- 2. Hydrogen Pressure High or Low
- 3. Hydrogen Supply Pressure Low
- 4. Water Detection High
- 5. Hydrogen Temperature High / Generator Condition Monitor
- 6. Defoaming Tank Level High
- 7. Seal Oil System Trouble
- 8. Loss of Alarm DC Power
- 9. Air Side Seal Oil Backup Pump Running
- 10. +24 VDC Power Off (Alarm Panel)
- 11. Main Seal Oil Pump Off
- 12. Seal Oil Drain Tank Level Error
- 13. Seal Oil Drain Tank Level High
- 14. Seal Oil Drain Tank Level Low
- 15. Seal Oil Drain Tank Level Very Low
- 16. Seal Oil Pressure Low
- 17. Seal Oil Turbine Backup Supply Pressure Low
- 18. TE or EE Seal Oil Pressure Low
- 19. Seal Oil Filter Differential High
- 20. PLC Failure
- 21. Recirc Sol Valve Backup Mode On
- 22. Both Recirc Sol Valves Closed
- 23. 125 VDC Power Supply Failure

### **COOLING TOWER DESIGN SUMMARY**

## (SPX MARLEY TOWER E-30A)

Number of Towers 1

Number of Cells 16/Tower

Type Induced/Cross Flow

Performance at Design Point

Hot Water Flow, gpm 185,000

Approach Temperature, °F 112.77
Range, °F 32
Cold Water Temperature, °F 80.77
Fan Brake Horsepower, bhp 166
Pumping Head Above Sill, ft 90

#### Fans and Fan Motors

Number of Fans 16 Number of Blades 9 Blade Diameter, ft 28

Blade Material Fiberglass Reinforced Vinyl Ester

Tip Speed, ft/s 196 Fan Speed, r/min 134

Rated hp/Voltage 200/460V

# **COOLING TOWER DESIGN SUMMARY**

# (SPX MARLEY TOWER E-30B)

Number of Towers	1
------------------	---

Number of Cells 18/Tower

Type Induced/Cross Flow

### Performance at Design Point

Hot Water Flow, gpm	185,000	
---------------------	---------	--

Approach Temperature, °F	110.9
Range, °F	32
Cold Water Temperature, °F	78.9
Fan Brake Horsepower, bhp	166
Pumping Head Above Sill, ft	90

### Fans and Fan Motors

Number of Fans	18
Number of Blades	9
Blade Diameter, ft	28

Blade Material Fiberglass Reinforced Vinyl Ester

Tip Speed, ft/s 196
Fan Speed, r/min 134
Pated by \( \) \( \

Rated hp/Voltage 200/460V

# **COOLING TOWER PUMPS**

Number of Pumps	2
Number of Fumps	2

Type Vertical, Wet Pit

Design Flow, gpm 164,000

Design Head, ft 87

Design NPSH, ft 29

Pump Speed, r/min 253

Motor Type Induction

Horsepower, hp 7,000

Voltage 4,160