

## Job Performance Measure

**INITIATE A FIREWATCH**

JPM Number: A-N-1-S

Revision Number: 02

Date: 11/18

Developed By:

---

Exam Author

---

Date

Approved By:

---

Facility Representative

---

Date

### JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

**NOTE:** All steps of this checklist should be performed upon initial validation.  
Prior to JPM usage, revalidate JPM using steps 9 and 13 below.

- |       |   |
|-------|---|
| _____ | 1. Task description and number, JPM description and number are identified.  |
| _____ | 2. Knowledge and Abilities (K/A) references are included.   |
| _____ | 3. Performance location specified. (in-plant, control room, simulator, or other)  |
| _____ | 4. Initial setup conditions are identified.   |
| _____ | 5. Initiating cue (and terminating cue if required) are properly identified.  |
| _____ | 6. Task standards identified and verified by SME review.  |
| _____ | 7. Critical steps meet the criteria for critical steps and are identified with an asterisk (*).   |
| N/A   | 8. If an alternate path is used, the task standard contains criteria for successful completion.   |
| _____ | 9. Verify the procedure(s) referenced by this JPM reflects the current revision:<br>Procedure <u>OP-MW-201-007</u> Rev: <u>07</u><br>Procedure <u>TRM 3.7.n</u> Rev: <u>00</u><br>Procedure <u>119 U3RB-22</u> Rev: <u>04</u> |
| _____ | 10. Verify cues both verbal and visual are free of conflict.  |
| _____ | 11. Verify performance time is accurate   |
| _____ | 12. If the JPM cannot be performed as written with proper responses, then revise the JPM.   |
| _____ | 13. When JPM is initially validated, sign and date JPM cover page. Subsequent validations, sign and date below:   |

SME / Instructor	Date
SME / Instructor	Date
SME / Instructor	Date

## **Revision Record (Summary)**

<b>Revision 01</b>	Bank JPM
<b>Revision 02</b>	Updated for 2019 ILT NRC Exam

## **SIMULATOR SETUP INSTRUCTIONS**

This is an admin JPM that is performed in the Simulator

### **DOCUMENT PREPARATION**

1. A copy of OP-MW-201-007 with the initiator section of Attachment 1 filled out.
2. Ensure a copy of the Fire Pre-Plans is available as a resource.
3. Ensure a copy of the TRM is available as a resource.

**INITIAL CONDITIONS**

1. You are the WEC Supervisor on midnights and are acting as the Fire Marshall Designee.
2. As part of a scheduled activity, the Mechanical Maintenance Department must route hoses through the Unit 3 HPCI Room Door and the work will begin promptly at 1600.
3. The activity is being performed under WO 123456-01 and is scheduled for 6 hours.
4. The cognizant Mechanical Maintenance Supervisor is C. Block.
5. TRM 3.3.e was previously entered due to the following XL3 devices currently being inoperable:
  - Zone 13 device 11
  - Zone 23 device 29
  - Zone 33 device 23
  - Zone 34 devices 4, 5, and 29
  - Zone 43 device 30

**INITIATING CUE**

1. Complete Attachments 1 and 2 of the Fire Protection Impairment Permit IAW OP-MW-201-007.

Fill in the JPM Start Time when the student acknowledges the Initiating Cue.

.....

**Information For Evaluator's Use:**

**Task Standard:** Examinee will complete paperwork for a TRM required firewatch utilizing OP-MW-201-007, FIRE PROTECTION SYSTEM IMPAIRMENT CONTROL.

UNSAT requires written comments on respective step.

\* Denotes critical steps.

Number any comments in the "Comment Number" column on the following pages. Then annotate that comment in the "Comments" section. The comment section should be used to document: the reason that a step is marked as unsatisfactory, marginal performance relating to management expectations, or problems the examinee had while performing the JPM. Comments relating to procedural or equipment issues should be entered and tracked using the site's appropriate tracking system.

Some operations that are performed from outside of the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

The timeclock starts when the candidate acknowledges the initiating cue.

.....

JPM Start Time: \_\_\_\_\_

<u>STEP</u>	<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
<b>Note</b>	Give the examinee a copy of OP-MW-201-007 with the initiator section of Attachment 1 filled out.				
<b>Note</b>	Fills out Attachment 1 of OP-MW-201-007 as follows:				
<b>Cue</b>	When the examinee states the need for the Fire Marshall No., inform them "The next available number in the Fire Protection Impairment Barrier Permit Log is 19-31." (May not be performed until later in the JPM)				
1.	Fire Marshall NO:	Examinee uses number provided and enters "19-31"	___	___	___
<b>Cue</b>	Direct the examinee to complete the fire watch authorization if not completed.				
Section II					
2.	Determine Fire Zone.	Determines and enters Fire Zone as 11.1.3 and 11.1.2.	___	___	___
3.	Barrier Functional.	Determines and marks Barrier is Non-Functional.	___	___	___
*4.	Technical Requirement Manual?	Determines TRM is applicable and identifies applicable sections as: "3.7.n". (may also specify A.1.1 and A.2.1)	___	___	___
<b>Cue</b>	If asked: Another SRO is looking at the LCO requirements.				
*5.	Fire Watch Required?	Determines and marks that a Continuous fire watch is required.	___	___	___
*6.	Fire watch performed by:	Designates Department responsible for firewatch.	___	___	___
7.	Additional Compensatory Measures Required?	Marks NO.	___	___	___
8.	Fire Detector Operability Check Required?	Marks NO.	___	___	___
9.	NEIL Notification Required?	Marks NO. (Less than 48 hours from cue sheet)	___	___	___
10.	Fire Marshall Instructions:	Enters NONE or NA.	___	___	___

<u>STEP</u>	<u>ELEMENT</u>	<u>STANDARD</u>	<u>SAT</u>	<u>UNSAT</u>	<u>Comment Number</u>
11.	Restoration/Testing Requirements:	Enters "Door closed and latched" or instructions that convey a similar concept.	___	___	___
12.	Fire Marshall (Designee) Authorization:	Signs name and enters current date.	___	___	___
Section III					
13.	Detection Zones As Indicated In Section II Operable:	Marks <b>NO</b> or <b>NA</b> .	___	___	___
14.	Person Notified of Fire Watch:	Examinee writes their name, Unit Supervisor or C. Block as person notified.	___	___	___
*15.	Shift Management Authorization:	Examinee signs their name as Shift Management Authorization and enter current date and time.	___	___	___
<b>Note</b>	Fills out Attachment 2 of OP-MW-201-007 as follows:				
Section I					
16.	Reason for watch:	Examinee enters "U3 HPCI door blocked" or description conveying that concept.	___	___	___
*17.	TRM Section:	Examinee enters "3.7.n."	___	___	___
18.	Impairment/PBI No.:	Examinee enters "19-31"	___	___	___
19.	AR/WR No.:	Examinee enters "123456-01"	___	___	___
*20.	Type of Fire Watch:	Examinee marks "Continuous"	___	___	___
21.	Location:	Examinee marks: Unit "3" Bldg "RB" (conveys Reactor Bldg) Elev "476" (may indicate 476' 6") Row "N" Col "46"	___	___	___

<u>STEP</u>	<u>ELEMENT</u>	<u>STANDARD</u>	<u>SAT</u>	<u>UNSAT</u>	<u>Comment Number</u>
*22.	Description of area to be inspected:	Examinee indicates "U3 HPCI room" or something that either side of the inoperable barrier.	___	___	___
23.	Required Start Time/Date:	Examinee indicates "1700" and enters today's date. (May enter any time before 1700)	___	___	___
Section II					
24.	Responsible Department:	Examinee indicates "MMD".	___	___	___
25.	Responsible Supervisor:	Examinee indicates "C. Block".	___	___	___
26.	Notification:	Examinee indicates time and date the responsible person is notified (may leave blank until person notified).	___	___	___
<b>Note</b>	Examinee may tell examiner what time fire watch needs to start and enter current time and date.				
Section IV					
27.	Location to be inspected:	Examinee indicates "U3 HPCI room" or something that conveys the Unit 3 HPCI room.	___	___	___
28.	FPI Log Number	Examinee enters "19-31"	___	___	___
<b>Note</b>	Examinee may not fill in Date/time until impairment actually occurs or time and date the paperwork was filled out.				
			___	___	___
<b>Cue</b>	Acknowledge report				
<b>END</b>					

JPM Stop Time: \_\_\_\_\_



# KEY

**OP-MW-201-007**

Revision 7

Page 15 of 19

**ATTACHMENT 1  
Fire Protection Impairment Permit  
Page 1 of 1**

FIRE MARSHAL NO: 19-31

<b>I. INITIATOR:</b>		
Name: <u>C. Block</u>	Station: <u>12</u>	Unit: <u>3</u>
Sch. Start Date: <u>TODAY</u>	Phone: <u>4444</u>	Dept/Co: <u>MMD</u>
Sch. End Date: <u>TOMORROW</u>	Bldg: <u>2B</u>	EPN #: <u>HPCI</u>
AR/WR/OOS#: <u>W10 123456-01</u>	Elev: <u>476</u>	Door #: <u>39</u>
	Row/Col: <u>HPCI</u>	Det. Zone #: <u>34</u>
		Pent #: _____
Impairment Description: <u>DOOR BLOCKED OPEN WHILE ROUTING HOSES INTO HPCI ROOM</u>		Structural fireproofing: <input type="checkbox"/>
		Wall Penetration: <input type="checkbox"/>
<b>II. FIRE MARSHAL REVIEW:</b>		
Fire Zone(s): <u>11.1.3</u> <u>11.1.2</u>		
Barriers: <input type="checkbox"/> Functional <input checked="" type="checkbox"/> Non-Functional		
Technical Requirement Manual? YES <input checked="" type="checkbox"/> NO <input type="checkbox"/> TRM Section: <u>3.7.n A.1.1+A.2.1</u>		
Fire Watch Required? <u>Continuous</u> / Hourly / None / Other: _____		
Fire Watch Performed By (if required): <u>MMD</u>		
Additional Compensatory Measures Required? YES <input type="checkbox"/> NO <input checked="" type="checkbox"/> Description: _____		
Fire Detector Operability Check Required? YES <input type="checkbox"/> NO <input checked="" type="checkbox"/> Panel: _____ Zone: <u>34</u>		
NEIL Notification Required? YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>		
Fire Marshal Instructions: <u>NONE</u>		
Restoration/Testing Requirements: <u>DOOR CLOSED AND LATCHED</u>		
Fire Marshal (Designee) Authorization: <u>EXAMINEE SIGNATURE</u> Date: <u>CURRENT DATE</u>		
<b>III. AUTHORIZATION:</b>		
Detection Zones, Barriers, Suppression As Indicated In Section II Operable: YES <input type="checkbox"/> NO <input type="checkbox"/> NA <input checked="" type="checkbox"/>		
Person Notified of Fire Watch: <u>EXAMINEE/US/C. BLOCK</u>		
Shift Management Authorization: <u>EXAMINEE SIGNATURE</u> Date: <u>CURRENT DATE</u>		
Time: <u>CURRENT TIME</u>		
<b>IV. IMPAIRMENT RESTORATION:</b>		
Restoration/Testing Requirements As Indicated In Section II Met (If Applicable): _____		
Impairment Signs Indicated In Section II Removed: _____		
Shift Management Authorization To Close Impairment and Terminate Fire Watch (If Applicable): _____		
Cognizant Individual _____ Date: _____ Time: _____		

ORIGINAL – Work Package

COP Return of Impairment to the Fire Marshal's Office for retention

# KEY

# KEY

OP-MW-201-007

Revision 7

Page 16 of 19

**ATTACHMENT 2**  
**Fire Watch Inspection Log**  
**Page 1 of 2**

**Section I: Initiation**Reason for watch: U3 HPCI Door Blocked openTRM Section: 3.7.n Impairment / PBI No.: 19-31 AR / WR No: w/o 123456-01Type of fire watch (circle one): Hourly Continuous Other: \_\_\_\_\_Location: Unit 3 Bldg 2B Elev 476 Row N Col 46Description of area to be inspected:  
U3 HPCI ROOM  
\_\_\_\_\_  
\_\_\_\_\_Required Start Time / Date: 1600 / Current date**Section II: Assignment**Responsible Department: MMDResponsible Supervisor: C. BlockNotification: 1600 / Current Date  
Time / Date**Section III: Termination**

Reason: \_\_\_\_\_

On Order of: \_\_\_\_\_

(Print name of individual who ordered termination)

Date: \_\_\_\_\_ Time: \_\_\_\_\_

# KEY

Completed log sheets shall be forwarded to the Fire Marshal.



**JPM SUMMARY****Operator's Name:** \_\_\_\_\_**Emp. ID#:** \_\_\_\_\_**Job Title:**       RO     SRO     SRO Cert**JPM Title:**    Initiate a Firewatch**JPM Number:**    A-N-1-S**Revision Number:** 02**Task Number and Title:** 299L019, Initiate / Terminate a firewatch.**K/A Number and Importance:**    Generic 2.1.8    3.4 / 4.1**Suggested Testing Environment:**      Simulator**Alternate Path:**     Yes     No      **SRO Only:**  Yes     No      **Time Critical:**  Yes     No**Reference(s):**    OP-MW-201-007, Rev. 07  
                     TRM 3.7.n, Rev. 00  
                     119 U3RB-22, Rev. 04**Actual Testing Environment:**     Simulator     Control Room     In-Plant     Other**Testing Method:**     Simulate     PerformEstimated Time to Complete:    23 minutes**Actual Time Used:** \_\_\_\_\_ minutes**EVALUATION SUMMARY:**Were all the Critical Elements performed satisfactorily?       Yes       NoThe operator's performance was evaluated against standards  
contained within this JPM and has been determined to be:       Satisfactory     Unsatisfactory**Comments:** \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_**Evaluator's Name (Print):** \_\_\_\_\_**Evaluator's Signature:** \_\_\_\_\_ **Date:** \_\_\_\_\_

### INITIAL CONDITIONS

1. You are the WEC Supervisor on midnights and are acting as the Fire Marshall Designee.
2. As part of a scheduled activity, the Mechanical Maintenance Department must route hoses through the Unit 3 HPCI Room Door and the work will begin promptly at 1600.
3. The activity is being performed under WO 123456-01 and is scheduled for 6 hours.
4. The cognizant Mechanical Maintenance Supervisor is C. Block.
5. TRM 3.3.e was previously entered due to the following XL3 devices currently being inoperable:
  - Zone 13 device 11
  - Zone 23 device 29
  - Zone 33 device 23
  - Zone 34 devices 4, 5, and 29
  - Zone 43 device 30

### INITIATING CUE

1. Complete Attachments 1 and 2 of the Fire Protection Impairment Permit IAW OP-MW-201-007.

## Job Performance Measure

**DETERMINE ACTIONS REQUIRED FOR A SECURITY THREAT**

JPM Number: A-N-2-S

Revision Number: 02

Date: 11/18

Developed By:

---

Exam Author

---

Date

Approved By:

---

Facility Representative

---

Date

### JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

**NOTE:** All steps of this checklist should be performed upon initial validation.  
Prior to JPM usage, revalidate JPM using steps 9 and 13 below.

- |            |  |   |
|------------|--|---|
| _____      |  | 1. Task description and number, JPM description and number are identified.  |
| _____      |  | 2. Knowledge and Abilities (K/A) references are included.   |
| _____      |  | 3. Performance location specified. (in-plant, control room, simulator, or other)  |
| _____      |  | 4. Initial setup conditions are identified.   |
| _____      |  | 5. Initiating cue (and terminating cue if required) are properly identified.  |
| _____      |  | 6. Task standards identified and verified by SME review.  |
| _____      |  | 7. Critical steps meet the criteria for critical steps and are identified with an asterisk (*).   |
| <u>N/A</u> |  | 8. If an alternate path is used, the task standard contains criteria for successful completion.   |
| _____      |  | 9. Verify the procedure(s) referenced by this JPM reflects the current revision:<br>Procedure <u>SY-AA-101-132</u> Rev: <u>31</u><br>Procedure <u>DOA 0010-13</u> Rev: <u>06</u><br>Procedure <u>DOA 0010-18</u> Rev: <u>42</u> |
| _____      |  | 10. Verify cues both verbal and visual are free of conflict.  |
| _____      |  | 11. Verify performance time is accurate   |
| _____      |  | 12. If the JPM cannot be performed as written with proper responses, then revise the JPM.   |
| _____      |  | 13. When JPM is initially validated, sign and date JPM cover page. Subsequent validations, sign and date below:   |

SME / Instructor	Date
SME / Instructor	Date
SME / Instructor	Date

**Revision Record (Summary)**

<b>Revision 01</b>	Bank JPM
<b>Revision 02</b>	Updated for 2019 ILT NRC Exam



## **SIMULATOR SETUP INSTRUCTIONS**

This is an admin JPM that is performed in the Simulator OR Classroom

### **DOCUMENT PREPARATION**

1. A clean copy of SY-AA-101-132, Threat Assessment.
2. A clean copy of DOA 0010-13, Security Threat.
3. A clean copy of DOA 0010-18, Escalated Security Event / Hostile Force Intrusion.

**INITIAL CONDITIONS**

1. You are the Unit 2 Supervisor.
2. Both Units are operating at rated power.
3. Security was notified earlier in the day that the Department of Homeland Security has elevated the national security risk level to ORANGE.
4. The Security Shift Leader just notified the Shift Manager that Security received a threatening phone call stating that an explosive device has been placed somewhere in the vicinity of the AEER that will detonate 24 hours from now.

**INITIATING CUE**

The Shift Manager has assigned you to Peer Check Security by performing a Threat Disposition per SY-AA-101-132 to determine if the threat is a Non-credible, Credible/Possible, or Credible/Actual threat.

Fill in the JPM Start Time when the student acknowledges the Initiating Cue.

.....

**Information For Evaluator's Use:**

**Task Standard:** Examinee will assess the initial threat utilizing SY-AA-101-132, SECURITY ASSESSMENT AND RESPONSE TO UNUSUAL ACTIVITIES. Then given a second set of conditions, re-assess the threat and determine required plant actions utilizing DOA 0010-18, ESCALATED SECURITY EVENT - HOSTILE FORCE INTRUSION.

UNSAT requires written comments on respective step.

\* Denotes critical steps.

Number any comments in the "Comment Number" column on the following pages. Then annotate that comment in the "Comments" section. The comment section should be used to document: the reason that a step is marked as unsatisfactory, marginal performance relating to management expectations, or problems the examinee had while performing the JPM. Comments relating to procedural or equipment issues should be entered and tracked using the site's appropriate tracking system.

Some operations that are performed from outside of the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

The timeclock starts when the candidate acknowledges the initiating cue.

.....

JPM Start Time: \_\_\_\_\_

<u>STEP</u>	<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
<b>Note</b>	Provide the examinee with copies of: SY-AA-101-132; DOA 0010-13 and DOA 0010-18				
*1.	Assess the threat.	Assess threat as CREDIBLE/POSSIBLE per SY-AA-101-132 section 4.7.1.	___	___	___
<b>Cue</b>	<p>When the threat has been assessed tell the examinee that, "It is 45 minutes later and Security notifies you that an armed hostile force has been sighted inside the Protected Area Boundary.</p> <p>The Shift Manager directs you to continue your peer check of Security and determine what plant actions, if any, need to be performed."</p>				
*2.	Reassess the threat.	Assess threat as CREDIBLE/ACTUAL per SY-AA-101-132 section 4.7.1/4.8.1.	___	___	___
*3.	Determine the required plant actions.	Identifies all actions in DOA 0010-18, step D.4.	___	___	___
4.	Inform Shift Manager of threat status and required actions and the task is complete.	Informs Shift Manager.	___	___	___
<b>Cue</b>	Acknowledge report				
<b>END</b>					

JPM Stop Time: \_\_\_\_\_

**JPM SUMMARY****Operator's Name:** \_\_\_\_\_**Emp. ID#:** \_\_\_\_\_**Job Title:**       RO     SRO     SRO Cert**JPM Title:**    Determine actions required for a security threat**JPM Number:**    A-N-2-S**Revision Number:** 02**Task Number and Title:** 295L012 Respond to a Security Threat**K/A Number and Importance:**    Generic 2.1.20    4.6 / 4.6**Suggested Testing Environment:**      Simulator**Alternate Path:**     Yes     No      **SRO Only:**  Yes     No      **Time Critical:**  Yes     No**Reference(s):**    SY-AA-101-132, Rev. 31  
DOA 0010-13, Rev. 06  
DOA 0010-18, Rev. 42**Actual Testing Environment:**     Simulator     Control Room     In-Plant     Other**Testing Method:**     Simulate     PerformEstimated Time to Complete:    15 minutes**Actual Time Used:** \_\_\_\_\_ minutes**EVALUATION SUMMARY:**Were all the Critical Elements performed satisfactorily?       Yes       NoThe operator's performance was evaluated against standards contained within this JPM and has been determined to be:       Satisfactory     Unsatisfactory**Comments:** \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_**Evaluator's Name (Print):** \_\_\_\_\_**Evaluator's Signature:** \_\_\_\_\_      **Date:** \_\_\_\_\_

### **INITIAL CONDITIONS**

1. You are the Unit 2 Supervisor.
2. Both Units are operating at rated power.
3. Security was notified earlier in the day that the Department of Homeland Security has elevated the national security risk level to ORANGE.
4. The Security Shift Leader just notified the Shift Manager that Security received a threatening phone call stating that an explosive device has been placed somewhere in the vicinity of the AEER that will detonate 24 hours from now.

### **INITIATING CUE**

The Shift Manager has assigned you to Peer Check Security by performing a Threat Disposition per SY-AA-101-132 to determine if the threat is a Non-credible, Credible/Possible, or an Credible/Actual Threat.

**45 MINUTES LATER**

Security notifies you that an armed hostile force has been sighted inside the Protected Area Boundary

**2<sup>ND</sup> INITIATING CUE**

The Shift Manager directs you to continue your peer check of Security and determine what plant actions, if any, need to be performed.

## Job Performance Measure

**REVIEW CALCULATED DRYWELL LEAKRATE AND IDENTIFY TECH SPECS**

JPM Number: A-N-3-S

Revision Number: 04

Date: 03/19

Developed By:

\_\_\_\_\_

Exam Author

\_\_\_\_\_

Date

Approved By:

\_\_\_\_\_

Facility Representative

\_\_\_\_\_

Date

### JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

**NOTE:** All steps of this checklist should be performed upon initial validation.  
Prior to JPM usage, revalidate JPM using steps 9 and 13 below.

- |       |  |   |
|-------|--|---|
| _____ |  | 1. Task description and number, JPM description and number are identified.  |
| _____ |  | 2. Knowledge and Abilities (K/A) references are included.   |
| _____ |  | 3. Performance location specified. (in-plant, control room, simulator, or other)  |
| _____ |  | 4. Initial setup conditions are identified.   |
| _____ |  | 5. Initiating cue (and terminating cue if required) are properly identified.  |
| _____ |  | 6. Task standards identified and verified by SME review.  |
| _____ |  | 7. Critical steps meet the criteria for critical steps and are identified with an asterisk (*).   |
| N/A   |  | 8. If an alternate path is used, the task standard contains criteria for successful completion.   |
| _____ |  | 9. Verify the procedure(s) referenced by this JPM reflects the current revision:<br>Procedure <u>U2 Appendix A</u> Rev: <u>142</u><br>Procedure <u>T.S. 3.4.4</u> Rev: <u>185</u><br>Procedure _____ Rev: _____ |
| _____ |  | 10. Verify cues both verbal and visual are free of conflict.  |
| _____ |  | 11. Verify performance time is accurate   |
| _____ |  | 12. If the JPM cannot be performed as written with proper responses, then revise the JPM.   |
| _____ |  | 13. When JPM is initially validated, sign and date JPM cover page. Subsequent validations, sign and date below:   |

SME / Instructor	Date
SME / Instructor	Date
SME / Instructor	Date



## **Revision Record (Summary)**

<b>Revision 03</b>	Bank JPM
<b>Revision 04</b>	Updated for 2019 ILT NRC Exam

## **SIMULATOR SETUP INSTRUCTIONS**

This is an admin JPM that is performed in the Simulator

### **DOCUMENT PREPARATION**

1. Markup a copy of U2 Appendix A pages 18-22.

**INITIAL CONDITIONS**

1. You are the Unit 2 Unit Supervisor.
2. Due to increased leakage in the drywell, the Drywell Floor Drain and Drywell Equipment Drain sumps are being pumped every 4 hours.
3. The NSO has just completed the Monday 1200 pumping of the sumps.

**INITIATING CUE**

1. Review the Monday 1200 Drywell sump data.
2. Verify all requirements are within specifications, paperwork is correct, and what actions (if any) are required.

Fill in the JPM Start Time when the student acknowledges the Initiating Cue.

.....

**Information For Evaluator's Use:**

**Task Standard:** Examinee will review completed Drywell sump logs and identify that an error was made in calculations that require a Tech Spec LCO entry.

UNSAT requires written comments on respective step.

\* Denotes critical steps.

Number any comments in the "Comment Number" column on the following pages. Then annotate that comment in the "Comments" section. The comment section should be used to document: the reason that a step is marked as unsatisfactory, marginal performance relating to management expectations, or problems the examinee had while performing the JPM. Comments relating to procedural or equipment issues should be entered and tracked using the site's appropriate tracking system.

Some operations that are performed from outside of the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

The timeclock starts when the candidate acknowledges the initiating cue.

.....

JPM Start Time: \_\_\_\_\_

<u>STEP</u>	<u>ELEMENT</u>	<u>STANDARD</u>	<u>SAT</u>	<u>UNSAT</u>	<u>Comment Number</u>
<b>Note</b>	Provide the Examinee with the attached copy of U2 Appendix A pages 18-22. The flowing steps may be performed in any order.				
*1.	Verifies Calculated Floor Drain Leakage (FDL) is correct.	Identifies Floor Drain leakage for MON 1200 hours should be 5.20 gpm (TS).	___	___	___
2.	Verifies Calculated Equipment Drain Leakage (EDL) is correct.	Identifies Equipment Drain Leakage for MON 1200 hours is correct.	___	___	___
3.	Verifies Total FDL and EDL is correct.	Identifies Total FDL and EDL should be 13.46 gpm. (within TS)	___	___	___
*4.	References Tech Specs.	References Tech Spec 3.4.4 and recognizes <ul style="list-style-type: none"> <li>&gt;5 gpm unidentified leakage for MON 1200 hours.</li> </ul> Recognizes TS 3.4.4 Cond A1 applies. <ul style="list-style-type: none"> <li>Reduce LEAKAGE to within limits within 4 hours.</li> </ul>	___	___	___
5.	Reports discrepancies and TS applicability.	Reports that the Drywell FDL is not within TS limits and TS 3.4.4 condition A1 applies with a 4 hour time limit.	___	___	___
<b>Cue</b>	Acknowledge report				
<b>END</b>					

JPM Stop Time: \_\_\_\_\_

# KEY

**CATEGORY 1**

 UNIT DAILY SURVEILLANCE LOG  
 ATTACHMENT A  
 EIGHT HOUR SHIFTS

 UNIT 2(3)  
 APPENDIX A  
 REVISION 142

UNIT 2 NSO MODE 1, 2 AND 3 REACTOR COOLANT LEAKAGE LOG Tech Spec SR 3.4.4.1 associated Tech Spec 3.4.5														
Floor Drain Leakage (FDL) Note 4						Equipment Drain Leakage (EDL) Note 4								
Day	Note 1 Note 8 Note 9	Time Note 2	Integrator Reading Gallons Pumped Note 9	GPM Note 5, 8, 9 (AC: ≤ 5 gpm)	NOTE 8, 9 (AC: ≤ 2 gpm increase within 24 hr) (✓)	Flow rate Calculated (✓) Note 7		Integrator Reading Gallons Pumped Note 9	GPM Note 5 8, 9	Total FDL & EDL NOTE 5, 8, 9 (AC: ≤ 25 gpm)	Flow rate Calculated (✓) Note 7		US Initials	
						A	B				A	B		
TUE		2000												
		1600												
		1200												
		0800												
		0400												
MON		2000												
		1600												
		1200	1200	1248	4.78	✓	↑	↑	1982	8.20	13.04	↑	↑	
		0800	0800	1048	4.37	✓	↑	N/A	1745	7.27	11.64	↑	N/A	~
		0400	0400	1020	4.25	✓	N/A	✓	1925	8.02	12.27	N/A	✓	~
SUN*		0000	1032	4.30	✓	✓	N/A	2028	8.45	12.75	✓	N/A	~	
		2000	2000	1056	4.40	✓	X	X	2215	9.23	X	X	X	X
		1600	1600	X	4.55	X	X	X	X	7.31	X	X	X	X
		1200	1200	X	4.40	X	X	X	X	8.35	X	X	X	X
		0800	0800	X	4.25	X	X	X	X	9.22	X	X	X	X
	0400	0400	X	4.30	X	X	X	X	8.05	X	X	X	X	
	0000	0000	X	4.25	X	X	X	X	8.56	X	X	X	X	

START \*(Review all Notes on page 20)

# KEY

**JPM SUMMARY****Operator's Name:** \_\_\_\_\_**Emp. ID#:** \_\_\_\_\_**Job Title:**       RO     SRO     SRO Cert**JPM Title:**    Review Calculated Drywell Leakrate and Identify Tech Specs**JPM Number:**    A-N-3-S**Revision Number:** 04**Task Number and Title:** 299L080 Perform the administrative duties for conduct of surveillance, special, or complex procedures**K/A Number and Importance:**    Generic 2.2.12    -- / 4.1

Generic 2.2.40    -- / 4.7

**Suggested Testing Environment:**      Simulator**Alternate Path:**     Yes     No      **SRO Only:**  Yes     No      **Time Critical:**  Yes     No**Reference(s):**    Unit 2 Appendix A, Rev. 142

TS 3.4.4 Amendment No. 185/180

**Actual Testing Environment:**       Simulator     Control Room     In-Plant     Other**Testing Method:**       Simulate     PerformEstimated Time to Complete:    10 minutes**Actual Time Used:** \_\_\_\_\_ minutes**EVALUATION SUMMARY:**Were all the Critical Elements performed satisfactorily?       Yes       NoThe operator's performance was evaluated against standards contained within this JPM and has been determined to be:       Satisfactory     Unsatisfactory**Comments:** \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_**Evaluator's Name (Print):** \_\_\_\_\_**Evaluator's Signature:** \_\_\_\_\_ **Date:** \_\_\_\_\_

**INITIAL CONDITIONS**

1. You are the Unit 2 Unit Supervisor.
2. Due to increased leakage in the drywell, the Drywell Floor Drain and Drywell Equipment Drain sumps are being pumped every 4 hours.
3. The NSO has just completed the Monday 1200 pumping of the sumps.

**INITIATING CUE**

1. Review the Monday 1200 Drywell sump data.
2. Verify all requirements are within specifications, paperwork is correct, and what actions (if any) are required.

## Job Performance Measure

**SELECT PERSONNEL FOR RADIATION WORK**

JPM Number: A-N-4-S

Revision Number: 03

Date: 11/18

Developed By:

---

Exam Author

---

Date

Approved By:

---

Facility Representative

---

Date



### JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

**NOTE:** All steps of this checklist should be performed upon initial validation.  
Prior to JPM usage, revalidate JPM using steps 9 and 13 below.

- |       |  |   |
|-------|--|---|
| _____ |  | 1. Task description and number, JPM description and number are identified.  |
| _____ |  | 2. Knowledge and Abilities (K/A) references are included.   |
| _____ |  | 3. Performance location specified. (in-plant, control room, simulator, or other)  |
| _____ |  | 4. Initial setup conditions are identified.   |
| _____ |  | 5. Initiating cue (and terminating cue if required) are properly identified.  |
| _____ |  | 6. Task standards identified and verified by SME review.  |
| _____ |  | 7. Critical steps meet the criteria for critical steps and are identified with an asterisk (*).   |
| N/A   |  | 8. If an alternate path is used, the task standard contains criteria for successful completion.   |
| _____ |  | 9. Verify the procedure(s) referenced by this JPM reflects the current revision:<br>Procedure <u>RP-AA-203</u> Rev: <u>05</u><br>Procedure _____ Rev: _____<br>Procedure _____ Rev: _____ |
| _____ |  | 10. Verify cues both verbal and visual are free of conflict.  |
| _____ |  | 11. Verify performance time is accurate   |
| _____ |  | 12. If the JPM cannot be performed as written with proper responses, then revise the JPM.   |
| _____ |  | 13. When JPM is initially validated, sign and date JPM cover page. Subsequent validations, sign and date below:   |

SME / Instructor	Date
SME / Instructor	Date
SME / Instructor	Date

## **Revision Record (Summary)**

<b>Revision 02</b>	Bank JPM
<b>Revision 03</b>	Updated for 2019 ILT NRC Exam

## **SIMULATOR SETUP INSTRUCTIONS**

This is an admin JPM that is performed in the Simulator

### **DOCUMENT PREPARATION**

1. Markup a copy of an RWP for the Unit 3 RWCU Pump Room.
2. Markup a survey map for the Unit 3 RWCU Pump Room.
3. Clean copy of RP-AA-203.



Fill in the JPM Start Time when the student acknowledges the Initiating Cue.



**Information For Evaluator’s Use:**

**Task Standard:** Examinee will identify workers capable of performing work in an RCA without exceeding radiological control limits utilizing the supplied RWP, survey map and RP-AA-203, EXPOSURE CONTROL AND AUTHORIZATION.

UNSAT requires written comments on respective step.

\* Denotes critical steps.

Number any comments in the “Comment Number” column on the following pages. Then annotate that comment in the “Comments” section. The comment section should be used to document: the reason that a step is marked as unsatisfactory, marginal performance relating to management expectations, or problems the examinee had while performing the JPM. Comments relating to procedural or equipment issues should be entered and tracked using the site’s appropriate tracking system.

Some operations that are performed from outside of the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

The timeclock starts when the candidate acknowledges the initiating cue.



JPM Start Time: \_\_\_\_\_

<u>STEP</u>	<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
<b>Note</b>	Provide the examinee with the supplied copy of the RWP and survey map of the RWCU pump room and, if requested, the supplied copy of RP-AA-203.				
1.	Reviews Survey Maps to determine area dose rates.	Reviews the survey maps and determines area dose rates to be 40 mr/hr for the first group of 2 valves and 140 mr/hr for the remaining valve.	___	___	___
<b>Note</b>	The following calculations should be made: 2 valve clearance projected dose = 0.50 hr x 40 mr/hr = <b>20 mrem</b> 1 valve clearance projected dose = 0.25 hr x 140 mr/hr = <b>35 mrem</b> Total projected dose for the job = 20 mrem + 35 mrem = <b>55 mrem</b>				
2.	Calculates that the projected dose that will be received for the task is 55 mrem.	Determines the EOs will receive 20 mrem on the first 2 valves and 35 on the next valve.	___	___	___
*3.	Determines that <b>ALEX CAN NOT</b> perform the job.	Alex would exceed the 80 mrem dose alarm on RWP DR-0-19-00333. Total daily dose on RWP DR-0-19-00333 would be <b>105 mrem</b> .	___	___	___
*4.	Determines that <b>Dan CAN NOT</b> perform the job.	Dan would exceed the 2000 mrem Exelon Annual limit. Total Annual dose would be <b>2010 mrem</b> .	___	___	___
*5.	Determines that Mike CAN perform the job because no limits will be exceeded.	Mike's total RWP daily dose and Annual dose will remain below the limits.	___	___	___
*6.	Determines that <b>Sue CAN NOT</b> perform the job.	Sue would exceed the 80 mrem dose alarm on RWP DR-0-19-00333. Total daily dose on RWP DR-0-19-00333 would be <b>102 mrem</b> .	___	___	___
*7.	Determines that Tom CAN perform the job because no limits will be exceeded.	Tom's total RWP daily dose and Annual dose will remain below the limits.	___	___	___

<u>STEP</u>	<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
<b>Cue</b>	Acknowledge completion of JPM				
<b>END</b>					

JPM Stop Time: \_\_\_\_\_

# KEY

**EVALUATOR: The candidate must determine that dose for the task will be 55 mrem and determine that only two EOs can receive the dose, necessary to complete the task. They are Mike and Tom. See the table below for projected job dose, 24 hour total dose on RWP DR-0-19-00333, and total Annual TEDE dose for each Operator.**

Calculation:

2 valves clearance (at RWCU Aux Pump) projected dose = 0.50 hr x 40 mr/hr = 20mrem

1 valve clearance (at 'A' RWCU Pump) projected dose = 0.25hr x 140 mr/hr = 35mrem

20 mrem + 35 mrem = 55 mrem projected job dose for clearance order hanging

Name	DDE dose received on RWP DR-0-19-00333 today	Annual TEDE dose as of Midnight To Date	Projected dose on RWP DR-0-19-00333 for the 24 hour period	Projected Annual TEDE (including all dose from last 24 hours)
Alex	50 mrem	1550 mrem	(50 + 55 =) <b><u>105 mrem</u></b>	(1550 + 105 =) <u>1655 mrem</u>
Dan	5 mrem	1950 mrem	(5 + 55 =) <u>60 mrem</u>	(1950 + 60 =) <b><u>2010 mrem</u></b>
Mike	0 mrem	1920 mrem	(0 + 55 =) <u>55 mrem</u>	(1920 + 55 =) <u>1975 mrem</u>
Sue	47 mrem	1850 mrem	(47 + 55 =) <b><u>102 mrem</u></b>	(1850 + 102 =) <u>1952 mrem</u>
Tom	8 mrem	1750 mrem	(8 + 55 =) <u>63 mrem</u>	(1750 + 63 =) <u>1813 mrem</u>

The **bolded** values in the table exceed the applicable Company, RWP, or 10CFR limit.

# KEY



**JPM SUMMARY****Operator's Name:** \_\_\_\_\_**Emp. ID#:** \_\_\_\_\_**Job Title:**       RO     SRO     SRO Cert**JPM Title:**    Select Personnel for Radiation Work**JPM Number:**    A-N-4-S**Revision Number:** 03**Task Number and Title:** 29900LK119 Discuss the items to be considered prior to work authorization**K/A Number and Importance:**    Generic 2.3.13    3.4 / 3.8**Suggested Testing Environment:**      Simulator**Alternate Path:**     Yes     No      **SRO Only:**  Yes     No      **Time Critical:**  Yes     No**Reference(s):**    RP-AA-203, Rev. 05**Actual Testing Environment:**     Simulator     Control Room     In-Plant     Other**Testing Method:**     Simulate     PerformEstimated Time to Complete:    20 minutes**Actual Time Used:** \_\_\_\_\_ minutes**EVALUATION SUMMARY:**Were all the Critical Elements performed satisfactorily?       Yes       NoThe operator's performance was evaluated against standards contained within this JPM and has been determined to be:       Satisfactory     Unsatisfactory**Comments:** \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_**Evaluator's Name (Print):** \_\_\_\_\_**Evaluator's Signature:** \_\_\_\_\_      **Date:** \_\_\_\_\_

### INITIAL CONDITIONS

1. You are a Unit Supervisor and will be briefing EOs to perform a Clearance Order First Hang in the Unit 3 RWCU Pump Room under RWP DR-0-19-00333.
2. Five EOs are available this shift.
  - None of the five have received dose at any location other than Dresden Station.
  - None of the five have received dose since midnight on any RWPs other than DR-0-19-00333.
3. The Radiation Protection Department has provided the attached Survey map, and the following dose history for the five EOs to assist you in your planning:

Name	DDE dose received On RWP DR-0-19-00333 <u>Today</u>	Annual TEDE dose <u>Prior to Shift</u>
Alex	50 mrem	1550 mrem
Dan	5 mrem	1950 mrem
Mike	0 mrem	1920 mrem
Sue	47 mrem	1850 mrem
Tom	8 mrem	1750 mrem

4. The total expected stay time for each EO will be 45 minutes. Based on past job history, it will breakdown as follows:
  - 30 minutes total in the area near the following **two** valves:
    - 3-1201-138 RWCU Aux Pump Suction (at RWCU Aux Pump)
    - 3-1201-139 RWCU Aux Pump Discharge (at RWCU Aux Pump)
  - 15 minutes total in the area near the following **one** valve:
    - 3-1201-128A 'A' RWCU Pump Suction (at 'A' RWCU Pump)

### INITIATING CUE

CALCULATE the expected dose for the work in RWCU Pump Room. DETERMINE which EO(s) CAN and which EO(s) CAN NOT be assigned to perform the task. Demonstrate dose calculation to determine all violations (if any). EXPLAIN the basis for your determination.

## Job Performance Measure

**DETERMINE EMERGENCY CLASSIFICATION**

JPM Number: A-N-5-S

Revision Number: 00

Date: 11/18

Developed By:

\_\_\_\_\_

Exam Author

\_\_\_\_\_

Date

Approved By:

\_\_\_\_\_

Facility Representative

\_\_\_\_\_

Date

### JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

**NOTE:** All steps of this checklist should be performed upon initial validation.  
 Prior to JPM usage, revalidate JPM using steps 9 and 13 below.

- \_\_\_\_\_ 1. Task description and number, JPM description and number are identified.
- \_\_\_\_\_ 2. Knowledge and Abilities (K/A) references are included.
- \_\_\_\_\_ 3. Performance location specified. (in-plant, control room, simulator, or other)
- \_\_\_\_\_ 4. Initial setup conditions are identified.
- \_\_\_\_\_ 5. Initiating cue (and terminating cue if required) are properly identified.
- \_\_\_\_\_ 6. Task standards identified and verified by SME review.
- \_\_\_\_\_ 7. Critical steps meet the criteria for critical steps and are identified with an asterisk (\*).
- N/A 8. If an alternate path is used, the task standard contains criteria for successful completion.
- \_\_\_\_\_ 9. Verify the procedure(s) referenced by this JPM reflects the current revision:  
 Procedure EP-AA-1004 Addendum 3 Rev: 8  
 Procedure EP-MW-114-100-F-01 Rev: J  
 Procedure \_\_\_\_\_ Rev: \_\_\_\_\_
- \_\_\_\_\_ 10. Verify cues both verbal and visual are free of conflict.
- \_\_\_\_\_ 11. Verify performance time is accurate
- \_\_\_\_\_ 12. If the JPM cannot be performed as written with proper responses, then revise the JPM.
- \_\_\_\_\_ 13. When JPM is initially validated, sign and date JPM cover page. Subsequent validations, sign and date below:

SME / Instructor	Date
SME / Instructor	Date
SME / Instructor	Date

## **Revision Record (Summary)**

**Revision 00**

New JPM for 2019 ILT NRC Exam

**SIMULATOR SETUP INSTRUCTIONS**

**N/A:** This is an admin JPM that is performed in the Simulator

**Note:** Examinee will need to find and reference proper procedures in Simulator

### INITIAL CONDITIONS

1. This is a time critical JPM.
2. You are required to locate the appropriate procedures for this JPM.
3. You are the Shift Emergency Director.
4. A Report of steam coming from Unit 2 HPCI Room resulting in the following plant conditions:
  - U2 HPCI PP Area temp Hi Alarm.
  - HPCI Auto Isolation Initiated.
  - 2-2301-4 and 2-2301-5, HPCI inboard and outboard steam isolation valves failed to close on the isolation signal. All attempts to close 2-2301-4 and 2-2301-5 valves have been unsuccessful.
  - Crew manually scrammed Unit 2 and reports all control rods in.
  - Reactor Building Ventilation failed to trip and Standby Gas Treatment failed to start. Manual attempts to secure RB Vent have been unsuccessful.
  - 2/3 Reactor Building Ventilation Radiation levels are trending up.
  - HPCI Room temperature is 250 °F. HPCI Room and West LPCI radiation levels are greater than 2500 mr/hr

### INITIATING CUE

1. Determine the emergency classification. Ignore discretionary EALs.
2. Complete a NARS form.

Fill in the JPM Start Time when the student acknowledges the Initiating Cue.

---

#### Information For Evaluator's Use:

**Task Standard:** Examinee will determine the emergency classification within 15 minutes and fill out a NARS form utilizing EP-AA-1004 ADDENDUM 3, EXELON NUCLEAR EMERGENCY ACTION LEVELS FOR DRESDEN STATION

UNSAT requires written comments on respective step.

\* Denotes critical steps.

Number any comments in the "Comment Number" column on the following pages. Then annotate that comment in the "Comments" section. The comment section should be used to document: the reason that a step is marked as unsatisfactory, marginal performance relating to management expectations, or problems the examinee had while performing the JPM. Comments relating to procedural or equipment issues should be entered and tracked using the site's appropriate tracking system.

Some operations that are performed from outside of the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

The timeclock starts when the candidate acknowledges the initiating cue.

---

JPM Start Time: \_\_\_\_\_

<u>STEP</u>	<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
*1.	Determines final classification of a SITE AREA EMERGENCY.	Determines highest classification is a SITE AREA EMERGENCY per EAL FS1 within 15 minutes. Time Classified: _____	___	___	___
<b>Note</b>	Determines that a loss of 2 FP barriers has occurred: <ul style="list-style-type: none"> <li>• UNISOLABLE Main Steam Line (MSL), Isolation Condenser, HPCI, Feedwater, or RWCU line break. – loss of RCS.</li> <li>• UNISOLABLE direct downstream pathway to the environment exists after primary containment isolation signal. - loss of CT. -OR-</li> <li>• UNISOLABLE primary system leakage that results in Secondary Containment area temperature &gt; DEOP 300-1, Maximum Safe operating levels. - loss of CT.</li> </ul> Determines that there is a ground level release in progress: <ul style="list-style-type: none"> <li>• Failure of RB ventilation to isolate and SGBT to initiate.</li> </ul>				
*2.	Completes NARS Form.	Correctly completes NARS Form per Attachment 1.	___	___	___
<b>Cue</b>	If requested to verify the NARS form, inform the examinee that a verifier is not available.				
<b>Note</b>	Acknowledge report				
<b>END</b>					

JPM Stop Time: \_\_\_\_\_



## Nuclear Accident Reporting System (NARS) Form

Or Electronic Facsimile

No Revision bars were used for this revision

UTILITY MESSAGE NO. 1

STATE MESSAGE NO. N/A

1. **STATUS**  
[A] ACTUAL  
[B] DRILL/EXERCISE
2. **STATION**  
[A] BRAIDWOOD [C] CLINTON [E] LASALLE [G] ZION  
[B] BYRON [D] DRESDEN [F] QUAD CITIES
3. **ONSITE CONDITION**  
[A] UNUSUAL EVENT  
[B] ALERT  
[C] SITE AREA EMERGENCY  
[D] GENERAL EMERGENCY  
[E] RECOVERY  
[F] TERMINATED
4. **ACCIDENT CLASSIFIED**  
TIME (3[A-E]): \_\_\_\_\_  
DATE (3[A-E]): \_\_\_\_\_  
EAL#: FS1
- ACCIDENT TERMINATED**  
TIME (3[F]): N/A  
DATE (3[F]): N/A

5. **RELEASE STATUS**  
[A] NONE  
[B] OCCURRING  
[C] TERMINATED
6. **TYPE OF RELEASE**  
[A] NOT APPLICABLE  
[B] GASEOUS  
[C] LIQUID
7. **WIND DIR**  
2  
(DEGREES FROM)
8. **WIND SPEED**  
[A] METERS/SEC.: 6.8  
[B] MILES/HR.: 15.2
9. **RECOMMENDED ACTIONS**  
**UTILITY RECOMMENDATION**  
[A] NONE (UE, Alert and SAE Only)

----- (General Emergency Only) -----

[B] SHELTER ILLINOIS SUB-AREAS: \_\_\_\_\_  
[C] SHELTER IOWA SUB-AREAS: \_\_\_\_\_  
[D] EVACUATE ILLINOIS SUB-AREAS: \_\_\_\_\_  
[E] EVACUATE IOWA SUB-AREAS: \_\_\_\_\_

**AND**  
ADVISE THE REMAINDER OF THE 10 MILE EPZ TO MONITOR AND PREPARE  
**AND**  
FOR ILLINOIS ONLY, CONSIDER JIC ADVISORY WITH POTASSIUM IODIDE (KI) STATEMENT IN ACCORDANCE WITH STATE PROCEDURES

**STATE RECOMMENDATION**

- [F] NONE  
[G] SHELTER SUB-AREAS: \_\_\_\_\_  
[H] EVACUATE SUB-AREAS: \_\_\_\_\_  
[I] RECOMMEND POTASSIUM IODIDE (KI) PER PROCEDURES  
[J] COMMENCE RETURN OF PUBLIC  
[K] OTHER \_\_\_\_\_

10. **ADDITIONAL INFORMATION** N/A
- Verified With: N/A Approved By: \_\_\_\_\_
11. **TRANSMITTED BY:** N/A **PHONE NUMBER** \_\_\_\_\_ **TIME/DATE** \_\_\_\_\_  
[A] EXELON: \_\_\_\_\_  
[B] STATE: \_\_\_\_\_  
[C] COUNTY: \_\_\_\_\_
12. **RECEIVED BY:** \_\_\_\_\_ **ORGANIZATION** \_\_\_\_\_ **TIME/DATE** \_\_\_\_\_

## Nuclear Accident Reporting System (NARS) Form

Or Electronic Facsimile

No Revision bars were used for this revision

<b>Braidwood BW 38</b>	
<u>Initial</u> _____	<u>Final</u> <input type="checkbox"/>
# Illinois EMA	
(Time) (217)782-7860	
<input type="checkbox"/> * Grundy County	<input type="checkbox"/>
<input type="checkbox"/> * Kankakee County	<input type="checkbox"/>
<input type="checkbox"/> * Will County	<input type="checkbox"/>
<input type="checkbox"/> Illinois REAC	<input type="checkbox"/>
Time initial roll complete: _____	

<b>Clinton CL 36</b>	
<u>Initial</u> _____	<u>Final</u> <input type="checkbox"/>
# Illinois EMA	
(Time) (217)782-7860	
<input type="checkbox"/> * DeWitt County	<input type="checkbox"/>
<input type="checkbox"/> Illinois REAC	<input type="checkbox"/>
Time initial roll complete: _____	

<b>LaSalle LS 25</b>	
<u>Initial</u> _____	<u>Final</u> <input type="checkbox"/>
# Illinois EMA	
(Time) (217)782-7860	
<input type="checkbox"/> * Grundy County	<input type="checkbox"/>
<input type="checkbox"/> * LaSalle County	<input type="checkbox"/>
<input type="checkbox"/> Illinois REAC	<input type="checkbox"/>
Time initial roll complete: _____	

<b>Byron BY 37</b>	
<u>Initial</u> _____	<u>Final</u> <input type="checkbox"/>
# Illinois EMA	
(Time) (217)782-7860	
<input type="checkbox"/> ^ Ogle County	<input type="checkbox"/>
<input type="checkbox"/> ^ Rochelle Police	<input type="checkbox"/>
<input type="checkbox"/> Illinois REAC	<input type="checkbox"/>
Time initial roll complete: _____	

<b>Dresden DR 22</b>	
<u>Initial</u> _____	<u>Final</u> <input type="checkbox"/>
# Illinois EMA	
(Time) (217)782-7860	
<input type="checkbox"/> * Grundy County	<input type="checkbox"/>
<input type="checkbox"/> * Kendall County	<input type="checkbox"/>
<input type="checkbox"/> * Will County	<input type="checkbox"/>
<input type="checkbox"/> Illinois REAC	<input type="checkbox"/>
Time initial roll complete: _____	

<b>Quad Cities QC 23</b>	
<u>Initial</u> _____	<u>Final</u> <input type="checkbox"/>
# Illinois EMA	
(Time) (217) 782-7860	
<input type="checkbox"/> # Iowa HSEMD	<input type="checkbox"/>
(515) 725-3231	
<input type="checkbox"/> # Clinton County	<input type="checkbox"/>
(563) 242-9211	
<input type="checkbox"/> # Scott County	<input type="checkbox"/>
(563) 388-3904	
<input type="checkbox"/> * Rock Island County	<input type="checkbox"/>
<input type="checkbox"/> * Whiteside County	<input type="checkbox"/>
<input type="checkbox"/> Illinois REAC	<input type="checkbox"/>
Time initial roll complete: _____	

- NOTES:
- # Indicates that this agency is required to be notified within 15 minutes for all NARS messages
  - \* Indicates that this agency is required to be notified within 15 minutes if the initiating event is a General Emergency
  - ^ Indicates that only one of Ogle County or Rochelle Police is required to be notified within 15 minutes if the initiating event is a General Emergency (Byron Only)

**JPM SUMMARY****Operator's Name:** \_\_\_\_\_**Emp. ID#:** \_\_\_\_\_**Job Title:**       SRO     SRO Cert**JPM Title:**    Determine Emergency Classification**JPM Number:**    A-N-5-S**Revision Number:** 00**Task Number and Title:** 295L160 / Perform the duties of the Emergency Shift Director**K/A Number and Importance:**      Generic 2.4.40      -- / 4.5

Generic 2.4.41      -- / 4.6

**Suggested Testing Environment:**      Simulator**Alternate Path:**     Yes     No      **SRO Only:**  Yes     No      **Time Critical:**  Yes     No**Reference(s):**    EP-AA-1004 Addendum 3, Rev. 08

EP-MW-114-100-F-01, Rev. J

**Actual Testing Environment:**       Simulator       Control Room       In-Plant       Other**Testing Method:**       Simulate       PerformEstimated Time to Complete:      27 minutes**Actual Time Used:** \_\_\_\_\_ minutes**EVALUATION SUMMARY:**Were all the Critical Elements performed satisfactorily?       Yes       NoThe operator's performance was evaluated against standards contained within this JPM and has been determined to be:       Satisfactory       Unsatisfactory**Comments:** \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_**Evaluator's Name (Print):** \_\_\_\_\_**Evaluator's Signature:** \_\_\_\_\_      **Date:** \_\_\_\_\_

### **INITIAL CONDITIONS**

1. This is a time critical JPM.
2. You are required to locate the appropriate procedures for this JPM.
3. You are the Shift Emergency Director.
4. A Report of steam coming from Unit 2 HPCI Room resulting in the following plant conditions:
  - U2 HPCI PP Area temp Hi Alarm.
  - HPCI Auto Isolation Initiated.
  - 2-2301-4 and 2-2301-5, HPCI inboard and outboard steam isolation valves failed to close on the isolation signal. All attempts to close 2-2301-4 and 2-2301-5 valves have been unsuccessful.
  - Crew manually scrammed Unit 2 and reports all control rods in.
  - Reactor Building Ventilation failed to trip and Standby Gas Treatment failed to start. Manual attempts to secure RB Vent have been unsuccessful.
  - 2/3 Reactor Building Ventilation Radiation levels are trending up.
  - HPCI Room temperature is 250 °F. HPCI Room and West LPCI radiation levels are greater than 2500 mr/hr

### **INITIATING CUE**

1. Determine the emergency classification. Ignore discretionary EALs.
2. Complete a NARS form.