

PUBLIC SUBMISSION

SUNSI Review Complete
 Template = ADM-013
 E-RIDS=ADM-03
 ADD: Jazel Parks, Edward
 O'Donnell

COMMENT (1)
 PUBLICATION DATE:
 6/17/2019
 CITATION 84 FR 27809

As of: 7/12/19 10:57 AM Received: July 09, 2019 Status: Pending_Post Tracking No. 1k3-9axu-37us Comments Due: August 13, 2019 Submission Type: Web

Docket: NRC-2019-0111

Pre-Earthquake Planning, Shutdown, and Restart of a Nuclear Power Plant Following an Earthquake

Comment On: NRC-2019-0111-0001

Pre-Earthquake Planning, Shutdown, and Restart of a Nuclear Power Plant Following an Earthquake

Document: NRC-2019-0111-DRAFT-0001

Comment on FR Doc # 2019-12556

Submitter Information

Name: Raymond Pace

Address:

Imperia Engineering Partners

113 Cedar St

Milford, MA, 01757

Email: raymond.pace@imperiaep.com

General Comment

The ASME Task Group on Beyond Design Basis Events has one comment with respect to the Regulatory Guide

There is no discussion in Staff Regulatory Guidance Section C. on use of strain based allowable values for the directed analytical evaluations of selected components. The DG limits the results of the analytical evaluation to Service Level D.