NRC FORM 366
(7-77)

U.S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: [ ] (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

[0 1] [P A T M I 2] (2) [0 1 0 - 0 0 0 0 0 - 0 0] (3) [4 1 1 1 1] (4) [ ] (5)
7 8 9 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 57 CAT 58

CON'T
[0 1] REPORT SOURCE [L] (6) [0 5 0 0 0 3 2 0] (7) [0 6 1 3 7 8] (8) [0 7 1 4 7 8] (9)
7 8 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

[0 2] While in Mode 6, while performing surveillance 2303-05, the pressure in the accumu-
[0 3] lator for damper 4092e could not be maintained within 10 psi of the initial pressure.
[0 4] Because no condition existed which required operation of the Control Room emergency
[0 5] ventillation system, this event posed no threat to the health and safety of the
[0 6] public.
[0 7]
[0 8]
7 8 9 80

[0 9] SYSTEM CODE [A A] (11) CAUSE CODE [B] (12) CAUSE SUBCODE [C] (13) COMPONENT CODE [Z Z Z Z Z Z] (14) COMP. SUBCODE [Z] (15) VALVE SUBCODE [Z] (16)
7 8 9 10 11 12 13 18 19 20

(17) LER/RO REPORT NUMBER: EVENT YEAR [7 8] 21 22 | 23 | SEQUENTIAL REPORT NO. [0 4 2] 24 26 | 27 | OCCURRENCE CODE [0 3] 28 29 | REPORT TYPE [L] 30 | 31 | REVISION NO. [0] 32

ACTION TAKEN [P] (18) FUTURE ACTION [X] (19) EFFECT ON PLANT [Z] (20) SHUTDOWN METHOD [Z] (21) HOURS [0 0 0 0] (22) ATTACHMENT SUBMITTED [N] (23) NPRC 4 FORM SUB. [N] (24) PRIME COMP. SUPPLIER [Z] (25) COMPONENT MANUFACTURER [Z 9 9 0] (26)
33 34 35 36 37 40 41 42 43 44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

[1 0] This event was caused by the improper location of the 3-way valve for damper 4092e.
[1 1] This construction problem will be corrected. Flow paths to the other accumulators
[1 2] in this system will be checked to verify that no additional discrepancies exist.
[1 3] This item will be resolved prior to entering Mode 4.
[1 4]
7 8 9 80

[1 5] FACILITY STATUS [B] (28) % POWER [0 0 0] (29) OTHER STATUS (30) NA 44 METHOD OF DISCOVERY [B] (31) DISCOVERY DESCRIPTION (32) Periodic Surveillance
7 8 9 10 12 13 44 45 46 80

[1 6] ACTIVITY RELEASED [Z] (33) CONTENT OF RELEASE [Z] (34) AMOUNT OF ACTIVITY (35) NA 44 LOCATION OF RELEASE (36) NA 45 80

[1 7] PERSONNEL EXPOSURES NUMBER [0 0 0] (37) TYPE [Z] (38) DESCRIPTION (39) NA 13 80

[1 8] PERSONNEL INJURIES NUMBER [0 0 0] (40) DESCRIPTION (41) NA 80

[1 9] LOSS OF OR DAMAGE TO FACILITY (42) TYPE [Z] (42) DESCRIPTION NA

13 016

80

[2 0] PUBLICITY ISSUED [Y] (44) DESCRIPTION (45) Weekly News Release 7904100186 NRC USE ONLY
7 8 9 10 68 69 80

NAME OF PREPARER R. A. Tenzel PHONE (215) 929-3601 Ext. 149