NRC FORM 366
(7-77)

U.S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: | | | | | | | (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

Line	Field	Value
0 1	Licensee Code (2)	P A T M I 2
	License Number (3)	0 0 - 0 0 0 0 0 - 0 0
	License Type (4)	4 1 1 1 1
	CAT (5)	
CON'T 0 1	Report Source (6)	L
	Docket Number (7)	0 5 0 0 0 3 2 0
	Event Date (8)	0 4 1 5 7 8
	Report Date (9)	0 5 0 3 7 8

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 While in Mode 3, during performance of RB Isolation and Cooling SFAS surveillance
0 3 testing, the Decay Heat Closed Cooling System DC-V103 failed to close, thus entering
0 4 the action statement associated with T.S. 3.6.3.1. Because the valve was locked in
0 5 place within the time constraints associated with T.S. 3.6.3.1, this event posed no
0 6 threat to the health and safety of the public.
0 7
0 8

System Code (11)	Cause Code (12)	Cause Subcode (13)	Component Code (14)	Comp. Subcode (15)	Valve Subcode (16)
C F	E	B	V A L V O P	A	Z

LER/RO REPORT NUMBER (17)

Event Year		Sequential Report No.		Occurrence Code	Report Type		Revision No.
7 8	—	0 2 8	/	0 3	L	—	0

Action Taken (18)	Future Action (19)	Effect on Plant (20)	Shutdown Method (21)	Hours (22)	Attachment Submitted (23)	NPRD-4 Form Sub. (24)	Prime Comp. Supplier (25)	Component Manufacturer (26)
A	Z	Z	Z	0 0 0 0	N	X	Z	B 1 6 5

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 This event was caused by a failed motor on the valve operator. DC-V103 was locked
1 1 closed within the time frame of the action statement of T.S. 3.6.3.1. The motor was
1 2 replaced and the valve was returned to service.
1 3
1 4

Line	Facility Status (28)	% Power (29)	Other Status (30)	Method of Discovery (31)	Discovery Description (32)
1 5	B	0 0 0	NA	B	Routine Surveillance

Line	Activity Released (33)	Content of Release (34)	Amount of Activity (35)	Location of Release (36)
1 6	Z	Z	NA	NA

PERSONNEL EXPOSURES

Line	Number (37)	Type (38)	Description (39)
1 7	0 0 0	Z	NA

PERSONNEL INJURIES

Line	Number (40)	Description (41)
1 8	0 0 0	NA

13 018

LOSS OF OR DAMAGE TO FACILITY (43)

Line	Type (42)	Description
1 9	Z	NA

PUBLICITY

Line	Issued (44)	Description (45)
2 0	Y	Weekly News Release

7904100188

NRC USE ONLY

NAME OF PREPARER R. A. Lencel PHONE: 215-929-3601 Ext. 148