

Docket No. 50-320

FEB 21 1972

Metropolitan Edison Company
ATTN: Mr. John C. Miller
Vice President
P.O. Box 242
Reading, Pennsylvania 19603

Gentlemen:

We have reviewed the additional information for the anchorage system design for the prestressed containment building of the Three Mile Island Nuclear Station Unit 2 as described in Amendment No. 12 to the application.

On the basis of this information we have concluded that this anchorage system is acceptable provided that due attention is given to Quality Assurance and Quality Control during shop fabrication and during construction.

Sincerely,

Original signed by
D. R. Muller

R. C. DeYoung, Assistant Director
for Pressurized Water Reactors
Division of Reactor Licensing

Distribution:
Docket ✓
PWR-2
DRL Reading
FWKaras (2)
HSchierling
AEC PDR
Local PDR
R.C. DeYoung
C.G. Long
A. Gluckmann

7905020027 A

OFFICE ▶	DRL:PWR-2	DRL:PWR-2	DRL:AD/PWRs		
SURNAME ▶	HSchierling:bnCGLong	RCDeYoung		15	292
DATE ▶	1/2/72	2/2/72	2/1/72		