

U.S. NUCLEAR REGULATORY COMMISSION
OFFICE OF INSPECTION AND ENFORCEMENT

Region I

Report No. 77-36

Docket No. 50-320

License No. CPPR-66 Priority -- Category B

Licensee: Metropolitan Edison Company

P. O. Box 542

Reading, Pennsylvania 19603

Facility Name: Three Mile Island Nuclear Station, Unit 2

Inspection at: Middletown, Pennsylvania

Inspection conducted: September 12-14, 1977

Inspectors: A. E. Zickel for R. J. Paolino
R. J. Paolino, Reactor Inspector

Oct 5, 1977
date signed

date signed

date signed

Approved by: A. S. Zickel for S. D. Ebnetter
S. D. Ebnetter, Chief, Engineering Support
Section No. 2, RC&ES Branch

Oct 5, 1977
date signed

Inspection Summary:

Inspection on September 12-14, 1977 (Report No. 50-320/77-36)

Areas Inspected: Routine, unannounced inspection of pertinent work and quality records relative to safety related instrument cables, terminations and associated hardware to ascertain whether the records meet established procedures and whether records reflect work accomplishment consistent with NRC requirements. The inspection involved 18 inspector-hours for one NRC inspector.

Results: Of the one area inspected, one apparent item of noncompliance was identified. (Deficiency - failure to follow instrumentation installation procedures - Para. 4)

17 115