

Docket File

MAR 6 1978

Docket No. 50-320

MEMORANDUM FOR: D. B. Vassallo, Assistant Director for Light Water Reactors, DPM

FROM: R. L. Tedesco, Assistant Director for Plant Systems, DSS

SUBJECT: CSB COMMENTS ON SUPPLEMENT 2 TO THE SAFETY EVALUATION REPORT FOR THREE MILE ISLAND, UNIT 2

We have noted that certain Containment Systems Branch comments related to Supplement 2 to the Safety Evaluation Report for Three Mile Island, Unit 2 were not incorporated. Specifically:

1. the fourth paragraph of Section 5.2.2 should not infer that our preliminary review indicates satisfactory resolution of our concerns regarding the containment spray pump net positive suction head; and
2. the supplement should include a statement to the effect that our acceptance of the applicant's proposed use of the containment purge system during normal plant operation is contingent upon the finding that the purge system isolation valves are capable of closing during the design basis loss of coolant accident.

These comments were omitted and we feel that they should have been incorporated in Supplement 2 to the SER.

Original signed by
Robert L. Tedesco

Robert L. Tedesco, Assistant Director
for Plant Systems
Division of Systems Safety

cc: R. Hartfield
S. Varga
G. Lainas
R. Bosnak
R. Kiessel
H. Silver
J. Kudrick
J. Shapaker
J. Glynn
F. Eltawila

17 166

773550375

Contact:
F. Eltawila, CSB

OFFICE	492-7711 PS:CSB	PS:CSB	PS:CSB	DSS:PS	
SURNAME	F. Eltawila/mc	J. Shapaker	G. Lainas	R. Tedesco	
DATE	3/2/78	3/2/78	3/2/78	3/2/78	

7905030032