

JAN 28 1977

MEMORANDUM FOR: William H. Segan, Jr., Chief, Environmental Projects
Branch No. 2, USE

FROM: Donald P. Cleary, Section Leader, Regional Impact
Analysis Section, Cost-Benefit Analysis Branch, ST, USE

SUBJECT: DRAFT TESTIMONY FOR THREE MILE ISLAND, UNIT 2

PLANT NAME: Three Mile Island, Unit 2
 LICENSING STAGE: OL
 DOCKET NUMBER: 50-320
 RESPONSIBLE BRANCH: Environmental Projects No. 2
 PROJECT MANAGER: Jan Morris
 DESCRIPTION OF RESPONSE: Draft Testimony

Attached is the draft testimony in relation to Contention 3 dealing
with cooling towers design adequacy related to earthquakes and
tornadoes.

The attachment was prepared by Louis Bykoski, Cost Benefit Analysis
Branch, 492-7906. Please forward a copy of the attachment to CELE.

Donald P. Cleary, Section Leader
Regional Impact Analysis Section
Cost-Benefit Analysis Branch
Division of Site Safety and
Environmental Analysis

Attachment: As stated

cc: J. Morris
B. J. Youngblood
L. Bykoski

DISTRIBUTION
Central Files
~~Docket File 50-320~~
NRR r/f
DSE r/f
CBAB r/f

19 112

7905040215 A

OFFICE:	DSE/ST/CBAB	DSE/ST/CBAB			
SURNAME:	DCleary	BJYoungblood			
DATE:	1-26-77	1-26-77			

This testimony addresses Contention 3 which states:

"The design for the cooling towers is inadequate to withstand the earthquake or tornado that the rest of the plant is built to withstand. As a result, if this earthquake or tornado does occur and the main plant does withstand it, it is highly probable that the cooling towers will not. Then, either the plant will shut down for two or three years while the towers are rebuilt or repaired, or the plant will continue to operate without cooling towers using once-through cooling. In this latter event, it is highly likely that state water quality criteria would be violated and severe environmental impacts would ensue. Therefore, no operating license should be granted until the entire plant is rendered capable of withstanding the maximum anticipated earthquake or tornado or until an adequate cost-benefit analysis pursuant to NEPA is conducted taking into account the impact of possible loss of the cooling towers."

The plant, as it is designed, is physically incapable of operating a once-through cooling system. Therefore, the plant will not operate in violation of state water quality criteria as a result of once-through cooling.

The contention assumes that all plant systems and structures other than the cooling towers are designed to withstand earthquakes and tornadoes. In fact, only those plant systems and structures which are necessary to shut the plant down safely and maintain it in a safe shutdown condition are designed to withstand tornadoes and a level of seismic shaking called the Safe Shutdown Earthquake.

These stringent design requirements against the effects of natural phenomena are required by NRC to protect the health and safety of the public. The remaining systems and structures, including the cooling towers, are not specified by NRC regulations with regard to effects of natural phenomena. Plant features not included in the health and

safety category are designed by the applicant to be cost effective and to meet any building codes as may be required by state and local regulations. The same conditions would exist for any alternative energy source plant at the same site.

If one were to consider the loss of cooling towers at the site sometime during the lifetime of the plant, this would only change the lifetime capacity factor of the plant from an assumed 70% to about 65%. However, it is important to realize that this same reduction in capacity factor would occur if a fossil plant were located at that site. It should be further realized that the probability of occurrence of natural phenomena sufficient to cause such damage is lower than the assumed 100 percent probability, thus, the actual probabilistic reduction in capacity factor due to the effects of natural phenomena on the cooling towers would be even lower than the five percentage points calculated. In addition to the above points, it must be remembered that there are portions of the plant other than cooling towers that also are not designed to NRC seismic and wind loading safety criteria, such as the turbine, main condenser, turbine building, switchyard, and transmission lines. Thus, the design of cooling towers to more stringent requirements would not substantially improve the ability of the entire plant and transmission system to withstand severe natural phenomena. Also, since statistical information on capacity factors inherently includes the impacts of such natural phenomena, it is clear that to reduce the value of the anticipated capacity factor further because of this postulated impact would be improper.