

X

DISTRIBUTION:  
Central Files  
PSS rdg. file

April 24, 1979

NOTE TO: Victor Stello, Jr., Director, TMI Operations  
FROM: Frank J. Miraglia, Coordinator, Team B

Attached for your information is the updated primary coolant  
sample analyses.

15/  
Frank J. Miraglia  
Coordinator  
Team B

Attachment:  
As Stated

cc: see attached distribution list

790507 0029

20 134

OFFICE	Team B				
SURNAME	Frank J. Miraglia:dfr				
DATE	04/24/79				

20 155

2nd Primary Coolant Sample

Analyses corrected to 4/11/79

1st Primary Coolant Sample

Analyses corrected to 3/30/79

Nuclide	Y 1/2	Bettis		SRI		ORNL		Bettis		ORNL	
		Coolant concentration (μCi/cc)	Fraction of Core in Primary Coolant	Coolant concentration (μCi/cc)	Fraction of Core in Primary Coolant	Coolant concentration (μCi/cc)	Fraction of Core in Primary Coolant	Coolant concentration (μCi/cc)	Fraction of Core in Primary Coolant	Coolant concentration (μCi/cc)	Fraction of Core in Primary Coolant
I-131	8d	$1.4 \times 10^4$	0.095	$7.25 \times 10^3$	0.14	$0.2 \times 10^3$	0.155	$0.5 \times 10^3$	0.16	$6.7 \times 10^3$	0.13
I-133	20.8h	$6.8 \times 10^3$	0.003								
Sr-90	29Y	$6.3 \times 10^1$	0.068	$7.7 \times 10^1$	0.006	$0.2 \times 10^1$	0.091	$7.4 \times 10^1$	0.003	$7.3 \times 10^1$	0.002
Sr-89	13d	$1.8 \times 10^2$	0.10	$1.2 \times 10^2$	0.12	$1.1 \times 10^2$	0.12	$1.1 \times 10^2$	0.12	$9.5 \times 10^1$	0.10
Sr-90	30Y	$2.7 \times 10^2$	0.11	$3.2 \times 10^2$	0.13	$3.3 \times 10^2$	0.13	$3.4 \times 10^2$	0.13	$2.8 \times 10^2$	0.11
Ru-106	368d	5.4	0.000031	$1.0 \times 10^3$	0.0060	$6.0 \times 10^2$	0.0042	$7.3 \times 10^2$	0.004		
Ru-106	368d	$3.6 \times 10^{-1}$	0.000019			$5.0 \times 10^1$	0.022				
Ba-140	12.8d	$2.1 \times 10^1$	0.000066	$2.6 \times 10^2$	0.0015	$2.9 \times 10^2$	0.0018	$2.2 \times 10^2$	0.0014	$1.5 \times 10^2$	0.00094
Ba-140	40h			$1.4 \times 10^2$	0.00075	$1.6 \times 10^2$	0.00086	$1.4 \times 10^2$	0.00075		
Mo-99	66h			$1.3 \times 10^2$	0.012	$1.8 \times 10^2$	0.017			$1.3 \times 10^2$	0.012
Fe-132	78h										
Ce-141	32d			$1.05 \times 10^2$	0.00051						
Ba-136m	0.35s daughter of Cs-136			$9.0 \times 10^1$	0.61						
Gross α		$3.6 \times 10^4$	$1 \times 10^{-10}$	$1 \times 10^3$	$1 \times 10^0$	$4.5 \times 10^{-4}$	$4.6 \times 10^{-4}$	$1.3 \times 10^{-3}$	$1.3 \times 10^{-3}$		
U				<1 ppb		<20 ppb					
H						1.2	0.1				
pH				7.0		0.0		7.7		0.4	

\*Based on a primary coolant volume of  $3.8 \times 10^8$  ml. If the make-up water ( $9 \times 10^8$  ml) from the RWST is included and considered to be at the same concentration, the fraction of the core in the coolant would be about a factor of 3 higher.

20 136

2nd Primary Coolant Sample  
Analyses corrected to 4/11/79

1st Primary Coolant  
Sample  
Analyses corrected to  
3/30/79

Nuclide	T 1/2	Bettis		SRL		ORNL		Bettis		B&W	
		Coolant con- centration ( $\mu\text{Ci/cc}$ )	Fraction* of Core in Primary Coolant	Coolant con- centration ( $\mu\text{Ci/cc}$ )	Fraction* of Core in Primary Coolant	Coolant con- centration ( $\mu\text{Ci/cc}$ )	Fraction* of Core in Primary Coolant	Coolant con- centration ( $\mu\text{Ci/cc}$ )	Fraction* of Core in Primary Coolant	Coolant con- centration ( $\mu\text{Ci/cc}$ )	Fraction* of Core in Primary Coolant
I-131	8d	$1.4 \times 10^4$	0.095	$7.25 \times 10^3$	0.14	$8.2 \times 10^3$	0.155	$8.5 \times 10^3$	0.16	$6.7 \times 10^3$	0.13
I-133	20.8h	$6.8 \times 10^3$	0.083								
Cs-134	2Y	$6.3 \times 10^1$	0.068	$7.7 \times 10^1$	0.086	$8.2 \times 10^1$	0.091	$7.4 \times 10^1$	0.083	$7.3 \times 10^1$	0.082
Cs-136	13d	$1.8 \times 10^2$	0.10	$1.2 \times 10^2$	0.12	$1.1 \times 10^2$	0.12	$1.1 \times 10^2$	0.12	$9.5 \times 10^1$	0.10
Cs-137	30Y	$2.7 \times 10^2$	0.11	$3.2 \times 10^2$	0.13	$3.3 \times 10^2$	0.13	$3.4 \times 10^2$	0.13	$2.8 \times 10^2$	0.11
Sr-89	50d	5.4	0.000031	$1.0 \times 10^3$	0.0060	$6.0 \times 10^2$	0.0042	$7.3 \times 10^2$	0.004		
Sr-90	29Y					$5.0 \times 10^1$	0.022				
Ru-106	368d	$3.6 \times 10^1$	0.000039								
Ba-140	12.8d	$2.1 \times 10^1$	0.000066	$2.6 \times 10^2$	0.0015	$2.9 \times 10^2$	0.0018	$2.2 \times 10^2$	0.0014	$1.5 \times 10^2$	0.00094
La-140	40h			$1.4 \times 10^2$	0.00075	$1.6 \times 10^2$	0.00086	$1.4 \times 10^2$	0.00075		
Mo-99	66h			$1.3 \times 10^2$	0.012	$1.8 \times 10^2$	0.017			$1.3 \times 10^2$	0.012
Te-132	78h	$2.0 \times 10^2$	0.0012								
Ce-141	32d			$1.05 \times 10^2$	0.00051						
Ba-136m	0.35s daughter of Cs-136			$9.0 \times 10^1$	0.61						
Gross $\alpha$		$3.6 \times 10^4$	$1 \times 10^{-10}$	$<1 \times 10^3$	$<1 \times 10^{-8}$	$<4.5 \times 10^{-4}$	$<4.6 \times 10^{-9}$	$1.3 \times 10^{-3}$	$1.3 \times 10^{-8}$		
U				$<1$ ppb		$<20$ ppb					
H <sup>3</sup>	12Y			7.0		8.0	0.1	7.7		8.4	
pH											

\*Based on a primary coolant volume of  $3.8 \times 10^8$  ml. If the make-up water ( $9 \times 10^8$  ml) from the BWST is included and considered to be at the same concentration, the fraction of the core in the coolant would be about a factor of 3 higher.

## REVISIONS TO PRIMARY COOLANT ANALYSES

This table, dated 4/24/79, presents corrections to three of the radio-nuclide analyses reported by Savannah River Laboratory for the second primary coolant sample. I-131 coolant concentration has been changed from  $4.5 \times 10^3 \mu\text{Ci/cc}$  to  $7.25 \times 10^3 \mu\text{Ci/cc}$ ; a counting efficiency error for I-131 was corrected. Sr coolant concentration has been changed from  $1.5 \times 10^3 \mu\text{Ci/cc}$  to  $1.0 \times 10^3 \mu\text{Ci/cc}$ . Ba-140 coolant concentration has been changed from  $1.7 \times 10^2 \mu\text{Ci/cc}$  to  $2.6 \times 10^2 \mu\text{Ci/cc}$ ; a dilution factor error was corrected. B. Grimes received these corrections from R. Overman, SRL, by telephone on April 23, 1979. The fractions of core in the primary coolant for those nuclides were also changed to reflect corrections in coolant concentration.