FORM 366 U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

1 | PATM12 (2) | 00-00000-00 (3) | 4111 (4) | (5)
LICENSEE CODE (9–14) LICENSE NUMBER (15–25) LICENSE TYPE (26–30) CAT (57–58)

1 REPORT SOURCE | L (6) | 05000320 (7) | 031578 (8) | 041278 (9)
(8–60) DOCKET NUMBER (61–68) EVENT DATE (69–74) REPORT DATE (75–80)

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

2 While the Unit was in mode 3 and the surveillance requirements of T.S. 4.6.1.3 were
3 being performed, the inner door seals on both airlocks failed. At least one door on
4 each airlock was maintained closed per the action statement of T.S. 3.6.1.3. Since
5 the unit had not yet gone critical, there was no effect on the health and safety of
6 the public.
7
8 (9–80)

9 SYSTEM CODE: SD (11) | CAUSE CODE: E (12) | CAUSE SUBCODE: B (13) | COMPONENT CODE: PENETR (14) | COMP. SUBCODE: A (15) | VALVE SUBCODE: Z (16)
(9–10) (11–12) (12–13) (13–18) (19–20)

(17) LER/RO REPORT NUMBER: EVENT YEAR 78 (21–22) | — (23) | SEQUENTIAL REPORT NO. 014 (24–26) | / (27) | OCCURRENCE CODE 03 (28–29) | REPORT TYPE L (30) | — (31) | REVISION NO. 0 (32)

ACTION TAKEN: E (18) (33) | FUTURE ACTION: Z (19) (34) | EFFECT ON PLANT: Z (20) (35) | SHUTDOWN METHOD: Z (21) (36) | HOURS (22): 0000 (37–40) | ATTACHMENT SUBMITTED: N (23) (41) | NPRD-4 FORM SUB.: N (24) (42) | PRIME COMP. SUPPLIER: A (25) (43) | COMPONENT MANUFACTURER: P270 (26) (44–47)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

0 The cause has been determined to be that the inner doors did not seat with a close
1 enough tolerance. The Unit was placed in cold shutdown within 30 hours for other re-
2 quired maintenance. While in cold shutdown, both inner doors were adjusted to provide
3 a closer fit and retested as satisfactory.
4
5 (9–80)

5 FACILITY STATUS: B (28) (9–10) | % POWER: 000 (29) (10–12) | OTHER STATUS (30): NA (13–44) | METHOD OF DISCOVERY: B (31) (45–46) | DISCOVERY DESCRIPTION (32): Discovered during Surveillance Test (46–80)

6 ACTIVITY RELEASED: Z (33) (9–10) | CONTENT OF RELEASE: Z (34) (10–11) | AMOUNT OF ACTIVITY (35): NA (11–44) | LOCATION OF RELEASE (36): NA (45–80)

7 PERSONNEL EXPOSURES: NUMBER 000 (37) (9–11) | TYPE Z (38) (11–12) | DESCRIPTION (39): NA (12–80)

8 PERSONNEL INJURIES: NUMBER 000 (40) (9–11) | DESCRIPTION (41): NA (11–80)

9 LOSS OF OR DAMAGE TO FACILITY (43): TYPE Z (42) (9–10) | DESCRIPTION: NA (10–80)

0 PUBLICITY: ISSUED Y (44) (9–10) | DESCRIPTION (45): Weekly News Release (10–80)

54-359

NRC USE ONLY

7904190390